

United States Department of Commerce Technology Administration National Institute of Standards and Technology



NIST PUBLICATIONS

NIST BUILDING SCIENCE SERIES 171

Field Monitoring of a Variable-Speed Integrated Heat Pump/Water Heating Appliance

A. Hunter Fanney

TA 435

.U58

#171

1993

he National Institute of Standards and Technology was established in 1988 by Congress to "assist industry in the development of technology . . . needed to improve product quality, to modernize manufacturing processes, to ensure product reliability . . . and to facilitate rapid commercialization . . . of products based on new scientific discoveries."

NIST, originally founded as the National Bureau of Standards in 1901, works to strengthen U.S. industry's competitiveness; advance science and engineering; and improve public health, safety, and the environment. One of the agency's basic functions is to develop, maintain, and retain custody of the national standards of measurement, and provide the means and methods for comparing standards used in science, engineering, manufacturing, commerce, industry, and education with the standards adopted or recognized by the Federal Government.

As an agency of the U.S. Commerce Department's Technology Administration, NIST conducts basic and applied research in the physical sciences and engineering and performs related services. The Institute does generic and precompetitive work on new and advanced technologies. NIST's research facilities are located at Gaithersburg, MD 20899, and at Boulder, CO 80303. Major technical operating units and their principal activities are listed below. For more information contact the Public Inquiries Desk, 301-975-3058.

Technology Services

- · Manufacturing Technology Centers Program
- · Standards Services
- Technology Commercialization
- Measurement Services
- Technology Evaluation and Assessment
- Information Services

Electronics and Electrical Engineering Laboratory

- Microelectronics
- · Law Enforcement Standards
- · Electricity
- Semiconductor Electronics
- Electromagnetic Fields¹
- Electromagnetic Technology¹

Chemical Science and Technology Laboratory

- · Biotechnology
- Chemical Engineering¹
- · Chemical Kinetics and Thermodynamics
- Inorganic Analytical Research
- · Organic Analytical Research
- · Process Measurements
- · Surface and Microanalysis Science
- Thermophysics²

Physics Laboratory

- · Electron and Optical Physics
- · Atomic Physics
- Molecular Physics
- · Radiometric Physics
- · Quantum Metrology
- · Ionizing Radiation
- Time and Frequency¹
- · Quantum Physics1

Manufacturing Engineering Laboratory

- · Precision Engineering
- Automated Production Technology
- Robot Systems
- · Factory Automation
- · Fabrication Technology

Materials Science and Engineering Laboratory

- · Intelligent Processing of Materials
- · Ceramics
- Materials Reliability¹
- · Polymers
- Metallurgy
- · Reactor Radiation

Building and Fire Research Laboratory

- Structures
- Building Materials
- Building Environment
- · Fire Science and Engineering
- · Fire Measurement and Research

Computer Systems Laboratory

- Information Systems Engineering
- Systems and Software Technology
- · Computer Security
- Systems and Network Architecture
- · Advanced Systems

Computing and Applied Mathematics Laboratory

- Applied and Computational Mathematics²
- Statistical Engineering²
- Scientific Computing Environments²
- Computer Services²
- Computer Systems and Communications²
- · Information Systems

¹At Boulder, CO 80303.

²Some elements at Boulder, CO 80303.

NIST BUILDING SCIENCE SERIES 171

Field Monitoring of a Variable-Speed Integrated Heat Pump/Water Heating Appliance

A. Hunter Fanney

Building and Fire Research Laboratory National Institute of Standards and Technology Gaithersburg, MD 20899

June 1993

Sponsored by: Allegheny Power System R&D Project RP 89-60 Cabin Hill Greensburg, PA 15601



U.S. Department of Commerce Ronald H. Brown, Secretary National Institute of Standards and Technology Arati Prabhakar, Director National Institute of Standards and Technology Building Science Series 171
Natl. Inst. Stand. Technol. Bldg. Sci. Ser. 171, 60 pages (June 1993)
CODEN: NBSSES

U.S. GOVERNMENT PRINTING OFFICE WASHINGTON: 1993

TABLE OF CONTENTS

Pag	ge
BSTRACT	1
EYWORDS	2
TRODUCTION	3
ESIDENCE	4
EAT PUMP DESCRIPTION	6
ISTRUMENTATION	10
GNAL PROCESSING	15
XPERIMENTAL RESULTS1Electrical Energy Consumption1Hourly Electrical Demands2Indoor and Outdoor Temperatures3Advanced Integrated Heat Pump System Performance3	16 24 34
J MMARY 4	19
CKNOWLEDGMENTS	52
EFERENCES	53

LIST OF FIGURES

			1	agc
Figure	1	-	Monitored Residence	. 5
Figure :	2	-	Instrumentation Schematic	. 7
Figure :	3	-	Typical Thermocouple Calibration Curve	12
Figure	4	-	Air Flow Measurement Station	13
Figure	5	-	Monthly Energy Consumption for Base Load, Heat Pump, Supplemental Space Heater, and Water Heater	21
Figure	6	-	Energy Contributions of Heat Pump and Electrical Resistance Elements to Water Heater	22
Figure '	7	-	Distribution of Energy Consumption	23
Figure	8	-	Monthly Peak Electrical Demands	26
Figure !	9	-	Monthly Electrical Demands Coincident with Allegheny Power System's Peak Demand	27
Figure	10	-	Monthly Electrical Demands Coincident with Potomac Edison Company's Peak Demand	29
Figure	11	-	Average Energy Consumption of Heat Pump, Supplemental Space Heater, and Water Heater Versus Outdoor Temperature During 1990-1991 Heating Season (SI Units)	30
Figure	11a	-	Average Energy Consumption of Heat Pump, Supplemental Space Heater, and Water Heater Versus Outdoor Temperature During 1990-1991 Heating Season (IP Units)	31
Figure	12	-	Average Energy Consumption of Heat Pump and Water Heater Versus Outdoor Temperature During 1991 Cooling Season (SI Units)	32
Figure	12a	***	Average Energy Consumption of Heat Pump and Water Heater Versus Outdoor Temperature During 1991 Cooling Season (IP Units)	33
Figure	13	-	Monthly Average Indoor Temperature	35

LIST OF FIGURES (continued)

			Page
Figure 14	-	Variation in Living Room Temperature During January 1991	36
Figure 15	-	Variation in Master Bedroom Temperature During January 1991	37
Figure 16	-	Variation in Family Room Temperature During January 1991	38
Figure 17	-	Monthly Average Outdoor Temperature	40
Figure 18	-	Monthly Heating Load Versus Heating Degree Days	41
Figure 19	-	Monthly Energy Consumption of Heat Pump in Various Operational Modes	42
Figure 20	-	Monthly Water Heating Coefficient of Performance Versus Average Monthly Outdoor Temperature	46
Figure 21	-	Monthly Combined Performance Factor	48

LIST OF TABLES

Table 1 -	Space Heating Load, Energy Transferred from Heat Pump to	Page
	Water Heater, and Energy Consumptions During Space Heating Months	17
Table 2 -	Monthly, Seasonal, and Annual Performance Summary, SI Units	19
Table 2A -	Monthly, Seasonal, and Annual Performance Summary, IP Units	20
Table 3 -	Comparison of Measured Energy Consumption Using Electronic Digital Power Analyzer and Electric Utility Watthour Meter	25

ABSTRACT

This report summarizes a study in which a variable-speed integrated heat pump/water heating appliance was monitored for 2 years while meeting the space conditioning and water heating needs of an occupied residence. Experimental results are presented which show that the total energy consumed by the residence was significantly reduced compared to previous years in which electric baseboard heat, a wood stove, and window air-conditioners were used. During the two space heating seasons, the variable-speed integrated heat pump/water heating appliance used 60% less energy than would have been consumed by an electric furnace with the same air distribution system and a storage-type electric water heater.

The monthly space cooling only coefficients of performance ranged from 2.50 to 4.03, whereas, the monthly space heating only coefficients of performance ranged from a low of 0.91 to a high of 3.33. A proposed index to quantify the overall system performance of integrated water heating/space conditioning appliances, referred to as the combined performance factor, ranged from 1.55 to 3.50. The majority of larger values occurred during months in which space cooling dominated. The combined performance factor for the entire 2-year study was 2.45.

A conventional watthour meter supplied by the local electrical utility and an electronic digital power analyzer were used to measure the energy consumption of the variable speed heat pump in order to discern if variable-speed equipment introduces errors in conventional utility metering equipment. Measurements made using the two instruments were in excellent agreement.

The monthly energy consumption and peak electrical demands of the residence, integrated heat pump/water heating appliance, supplemental space heater, and water heater are discussed. The influence of outdoor temperature on electrical power demand is presented.

KEYWORDS

building technology; coefficient of performance; combined performance factor; field study; heat pump; HSPF; integrated water heating; peak demand; SEER; thermal performance; variable speed

INTRODUCTION

Nearly one out of three new single-family houses built in the United States uses an electric heat pump for space conditioning. Since the early 1950's, when heat pumps were introduced into the residential market, manufacturers have continuously strived to improve reliability, increase efficiency, improve thermal comfort, and meet increasingly stringent environmental concerns while remaining competitive with oil and gas-fired residential space conditioning equipment.

During the past decade, heat pumps have evolved from units utilizing a single-speed reciprocating compressor to units which incorporate variable-speed components, rotary and scroll compressors, microprocessor controls, demand limiting features, and integrated water heating. These technological advances have resulted in heat pumps which are significantly more efficient than traditionally designed units, although they have yet to gain a significant share of the heat pump market. Additional technological advances, including thermal storage, multiple condensers, and adaptive controls, are currently being introduced into the market.

This report summarizes a research project in which a commercially available, technologically advanced, integrated heat pump/water heating appliance (hereafter referred to as heat pump) was extensively instrumented and monitored under field conditions. The heat pump selected for this study incorporates a variable-speed compressor and indoor fan, microprocessor controls, and a refrigerant-to-water heat exchanger. The unit attempts to improve thermal comfort by controlling the ratio of indoor fan speed to compressor speed in a manner which improves humidity control during the cooling season and avoids the occasional blowing of cool air during the heating season. Rather than extracting heat from the conditioned space to defrost the outdoor coil, the heat pump uses energy stored within the water heater.

The research was undertaken to determine the thermal performance of an integrated heat pump system and the electrical load characteristics of an occupied residence equipped with such a unit. Secondary objectives were to investigate if the variable-speed components within the heat pump system introduce errors in conventional residential watthour meters and to provide data for future computer simulation validation studies.

This report describes the residence, heat pump system, and monitoring equipment. Results are presented which include comparison of the total electrical energy consumption of the residence prior to and after installation of the heat pump system, the portion of energy used by each end use within the residence, a comparison of the heat pump's energy consumption using a conventional watthour meter and an electronic digital power analyzer, and the hourly electrical demands imposed on the utility. The thermal performance of the heat pump system is reported on a monthly, seasonal, and annual basis using conventional performance indicators in addition to using an index, proposed by NIST, which quantifies the overall system performance of integrated appliances.

RESIDENCE


The residence in which the integrated heat pump was tested, Figure 1, is located approximately 19 km (12 mi) south of Hagerstown, MD. Space heating and cooling is provided to 153.6 m² (1653 ft²) of living area within the residence. The integrated heat pump system and accompanying water heater are located in the 53.5 m² (576 ft²) unconditioned below-grade basement. The first level of the conditioned space includes a family room, bathroom, and laundry room. A living room, dining room, and kitchen are located on the second level. Three bedrooms and two full baths are contained within the third level.

The first level's exterior walls consist of nominal 50.8 mm by 101.6 mm (2 in by 4 in) studs on 0.406 m (16 in) centers, with R-11 fiberglass batts between the studs, positioned against an 0.203 m (8 in) concrete block wall. The exterior walls of the second and third levels consist of nominal 50.8 mm by 101.6 mm (2 in by 4 in) studs spaced 0.406 m (16 in) apart. The walls are insulated with nominal R-11 fiberglass batts between the studs and 25.4 mm (1 in) of extruded polystyrene sheathing fastened to the exterior beneath vinyl siding. The uninsulated exterior walls of the basement are constructed of 0.305 m (12 in) concrete blocks.


The windows throughout the residence are vinyl clad double-glazed, double-hung wood units. Exterior insulated steel doors are located in the kitchen and living rooms. The remaining exterior doors, one in the walkout family room and one leading onto the deck from the dining room, are double-glazed sliding units. Attic insulation consists of R-30 fiberglass batts placed between the 0.610 m (24 in) on center roof trusses.

Prior to the installation of the variable-speed integrated heat pump, the residence was heated by electric baseboard heaters in each room and a wood stove located in the family room. Approximately five cords of wood were burned each heating season prior to the installation of the heat pump. Space cooling was provided to approximately one-third of the residence through the use of two 1.46 kW (5,000 Btu/hr) window air conditioners, one located in the living room and the second one in the master bedroom. The domestic water heating needs of the residence were met through the use of a nominal 0.197 m³ (52 gallon) electric storage-type water heater.

MONITORED RESIDENCE



FRONT ELEVATION



REAR ELEVATION

Figure 1

Scale 1/4" = 1'-0"

HEAT PUMP DESCRIPTION

The variable-speed integrated heat pump system was installed in the residence during the month of March 1990. The system consists of three distinct components: (1) an indoor fan coil; (2) an outdoor fan coil; and (3) a compressor section which accommodates the compressor, a refrigerant-to-water heat exchanger, a water pump, a bi-directional electronic expansion device, and the majority of the heat pump controls.

The heat pump is connected to a 0.197 m³ (52 gallon), dual 4500 watt element, electric storage-type water heater. The water heater's thermostats were maintained at 51.7 °C (125 °F) throughout the study. Water is removed from the water heater by a tee connection on the cold water supply pipe, circulated through the refrigerant-to-water heat exchanger, and subsequently returned to the storage tank through the port normally used to drain the water heater, Figure 2.

The heat pump system incorporates several unique technological innovations. The compressor and indoor fan both have electronically commutated, permanent-magnet motor drives. These variable-speed components are used to enhance both comfort and efficiency. The control logic maximizes the efficiency of the heat pump by operating the blower and compressor at the lowest possible speeds at which the conditioned space temperature can be maintained within 0.6 °C (1° F) of the thermostat's setpoint. If the relative humidity is too high, the control logic decreases the indoor fan speed, relative to the compressor speed. The evaporator coil temperature decreases; thus, increasing the rate of dehumidification. In order to improve comfort levels during the heating season, the unit cycles on and quickly ramps the compressor to maximum speed while operating the indoor fan at minimum speed until the indoor coil warms up. This procedure avoids the "cold blow" associated with conventional heat pumps. During defrost cycles, energy is removed from the water heater as opposed to extracting energy from the conditioned space.

The heat pump can operate in five distinct operating modes: space cooling only, combined space cooling and water heating, space heating only, combined space and water heating, and water heating only. A microprocessor controls the operating mode of the system and the heating elements within the storage-type water heater. A brief description of the logic employed by the heat pump system for each mode follows.

<u>Space Cooling Only</u> - The heat pump system provides space cooling in proportion to the space load by varying the compressor and indoor fan speeds. For systems equipped with a humidistat, the humidity level within the residence is controlled by varying the indoor fan speed relative to the compressor speed. When the humidity is above the setpoint, the compressor and fan speeds are varied to satisfy the sensible cooling load with the lowest practical indoor coil temperature.

INSTRUMENTATION SCHEMATIC




Figure 2

Temperature difference across water side of heat pump

ΔTw -

 $\Delta T_A\,$ - Temperature difference across heat pump

1 IN - Relative humidity of air entering heat pump

◆ OUT - Relative humidity of air leaving heat pump

Space Cooling Plus Water Heating - In this mode heat removed from the house is transferred to the water heater and outside air. If the outdoor fan is off, the heat pump operates in a full condensing mode, in which the majority of the heat is delivered to the water heater. Whenever the outdoor fan is operational, the heat pump operates in a desuperheater mode, in which the majority of the heat is dissipated by the outdoor coil and a smaller portion to the water heater. Outdoor fan operation is based upon the cooling and water heating loads. If a substantial cooling load exists, the unit will operate in the desuperheater mode since the space cooling capacity is not diminished. The heat pump will operate in a fully condensing mode if the space cooling load is small and a large water heating load exists. Although the space cooling capacity is decreased in this mode, the maximum contribution to the water heating load is obtained. If both the space cooling and water heating loads are small, the heat pump will operate in the desuperheating mode.

<u>Space Heating Only</u> - The control logic varies the compressor speed to meet the space heating load while the indoor speed is varied to maintain comfortable supply air temperatures. The maximum compressor speed is 5300 rpm; however, at temperatures between -8.3 °C (17 °F) and -17.8 °C (0 °F) the compressor speed is limited to 3600 rpm. If the space heating load exceeds the heat pump's capacity, supplemental resistive heat is added. At temperatures below -17.8 °C (0 °F) the compressor is turned off and the total space heating load is met using auxiliary resistive heating.

Space Plus Water Heating - The condenser heat is shared by the space and water heating loads. The compressor is typically ramped to and maintained at maximum speed until operation in the space plus water heating mode is discontinued. The distribution of heat between these two loads depends upon the indoor fan speed which is controlled to meet the space heating load. At a high fan speed, the majority of heat is supplied to the conditioned space. As the fan speed is lowered, heat delivered to the water heater increases. If the space heating requirement exceeds that of the compressor, water heating by the heat pump ceases, and the electric resistance heaters provide all needed water heating.

Water Heating Only - The integrated heat pump used in this study can heat water even if a space conditioning load does not exist. The system monitors the water temperature in the bottom of the tank by means of a sensor located in the water heater drain port. If the controller senses that the water temperature is low, it will energize the pump, which circulates water from the water heater through the refrigerant-to-water heat exchanger for 3 minutes, so that a representative water temperature can be obtained. At the end of this sampling period, the compressor and outdoor fan will start if the water temperature is low. The unit will operate in the water heating mode when the outdoor temperature is between 8.3 °C (17 °F) and 35 °C (95 °F). The heating elements within the storage tank will be enabled by control logic within the heat pump system, if the water heating capacity of the heat pump is insufficient to meet the water heating load. The heat pump will heat water to 54.4 °C (130 °F) under most conditions, and then the electric elements are energized if the water heater thermostats are set higher.

The Air-Conditioning and Refrigeration Institute (ARI), an independent rating organization, lists the cooling capacity of this heat pump as 10.78 kW (36,800 Btu/h), and the seasonal energy efficiency ratio (SEER) as 14.05. This SEER corresponds to a cooling season coefficient of performance of 4.12. The heating capacity and heating seasonal performance factor (HSPF) are listed as 10.37 kW (35,400 Btu/h) and 9.05 respectively. This HSPF corresponds to a heating season COP of 2.65. These values are obtained from tests where the heat pump operated in the space heating only and space cooling only modes. Existing test methods do not capture the additional benefit of integrated water heating. NIST is currently developing a test method, under the sponsorship of the U.S. Department of Energy and the Electric Power Research Institute [1,2], which will quantify the benefits of water heating for all integrated space conditioning/water heating appliances.

INSTRUMENTATION

The integrated variable-speed heat pump in the Hagerstown house was extensively instrumented by NIST, as shown in Figure 2. This section describes the instrumentation and the procedures used to calibrate the individual instruments. All instrumentation was calibrated prior to the beginning of the monitoring period and upon completion of the 2-year data collection period.

Watt/Watthour transducers were used to measure the energy consumption of the house, water heater, and resistance strip heaters. These transducers provide an analog voltage proportional to the instantaneous power and a digital signal that is proportional to the electrical energy consumption. Current transformers were utilized to scale the measured current supplied to the house and resistance strip heater to a level compatible with the maximum current capability of the watt transducers, 20 amperes. Each watt/watthour transducer was individually calibrated using a watthour standard. An electronic digital power analyzer was used to measure the electrical power consumed by the heat pump. The electronic digital power analyzer was used in lieu of a watt/watthour transducer due to concerns regarding the accuracy of the watt/watthour transducers when subjected to harmonics produced by the variable-speed components [3-4]. The Potomac Edison Company, the electric utility to which the residence is connected and sponsor of this research, installed a watthour meter upstream of the electronic digital power analyzer which permitted an assessment of the error which would be encountered if conventional residential metering equipment was used.

The indoor temperature of the residence was monitored in three locations—the family room, the living room, and the master bedroom—using radiation-shielded thermocouples. The outdoor temperature sensor consisted of a shielded thermocouple located on the north side of the residence. All thermocouple and thermopiles used in this study were constructed of premium type-T thermocouple wire. An eight junction thermopile was used to determine the air temperature difference across the heat pump. The thermopile junctions were positioned such that each junction represented an equal cross sectional area within the duct. Thermocouples were installed in the supply and return ducts in the vicinity of the thermopiles to provide redundant measurements. Sheathed thermocouples were used to measure the cold water inlet temperature, the hot water supply temperature, and temperatures within the storage tank at the center of six equal vertical volumes.

The inlet and outlet water temperatures associated with the refrigerant-to-water heat exchanger were measured using sheathed-platinum resistance temperature detectors immersed in the water at the entrance and exit of the heat exchanger. A constant 100 microampere current, supplied by the data acquisition system, passed through each of these sensors resulting in voltage drop proportional to the temperature.

The thermocouples, thermopile, and platinum resistance temperature detectors were calibrated at the field site by immersing each sensor in a constant temperature bath containing


a NIST calibrated thermometer. The temperature sensors were calibrated over the temperature range to which they were subjected during the monitoring period. The indicated temperatures were compared to the NIST calibrated thermometers, and correction algorithms developed for the data reduction software. The calibrations were performed "end-to-end," that is the sensor, connecting wire, and data acquisition system were calibrated as a unit. A typical thermocouple calibration curve is shown in Figure 3.

A turbine flowmeter was used to measure the flow rate through the water side of the refrigerant to water heat exchanger. The pulsed output of this turbine flowmeter is fed to an electronic signal conditioner which converts the turbine flowmeter's output frequency to an analog voltage signal proportional to flow rate and a digital pulse output corresponding to the integrated volume of water through the flowmeter. An integrating-type flow meter measured the quantity of water circulated through the water heater. This flowmeter provides a pulse output with a resolution of 3.8 x 10⁻⁵ m³ (0.01 gallons). Both flowmeters and associated electronic packages were calibrated at NIST. An airflow measurement station was used to measure the velocity of the air in the 0.457 m (18 in) by 0.609 m (24 in) return duct. This device, Figure 4, contains parallel cell honeycomb panels which straighten the air flow prior to it arriving at the averaging pitot tube station. The pitot tube station contains total and static pressure manifolds which average 26 individual measurements of total and static pressure. Equivalent cross sectional areas are monitored by each individual sensor. The averaged total and static pressures are supplied to an electronic differential pressure manometer which incorporates an integral square root extractor to convert the differential pressure into an analog output voltage proportional to flow rate. This unit was factory calibrated and checked periodically during the 2-year period by comparing it to a second reference unit.


The relative humidity entering and leaving the indoor coil of the heat pump was measured using thin-film capacitive humidity sensors. Electronic signal processing converted the measured capacitance into an analog voltage. The relative humidity transmitters were calibrated three times during the 2-year study: at the beginning, after 1 year, and at the conclusion of the study. During calibration, the sensors were placed in a small environmental chamber with temperature and humidity control. A calibrated thermocouple and dew point hygrometer were placed in close proximity to the relative humidity transmitters within the chamber. Using the measured dew point and chamber temperatures, the relative humidity within the chamber was determined and compared to that indicated by the relative humidity transducers.

The status of the indoor fan, water circulation pump, defrost valve, and reversing valve were determined by measuring their respective control signals. Logic within the data reduction software was able to discern the operational mode of the heat pump system based upon these control signals.





AIR FLOW MEASUREMENT STATION



All of the instrumentation used in the study was connected to a microprocessor based data acquisition system. The data acquisition system combines a 5 1/2 digit voltmeter, a clock, a precision current source, and an IEEE-488 interface to transmit the scanned data to a personal computer. The voltmeter has a 1 microvolt sensitivity, is fully guarded, and uses an integrating analog to digital conversion technique. Data is captured at a rate of 50 readings per second. Installed within the data acquisition system are two multiplexing analog relay cards and two digital counter cards. One multiplexing card is dedicated to analog voltage signals; for example, the relative humidity transmitter signals are supplied to this card assembly. The second multiplexing card, which incorporates type-T thermocouple compensation, is used to sample the signals from the thermocouples. The digital counter cards are used to count the pulses which are generated by the flow meters and the watt/watthour transducers.

SIGNAL PROCESSING

The acquired data were processed in real time using a personal computer interfaced to the data acquisition system. The computer controls the data acquisition system, converts the sensor signals into engineering quantities, corrects the measurements using calibration data, integrates or averages the data over appropriate time intervals, displays the current measurements on a video monitor, and records the data. All sensors are scanned every 10 seconds.

The energy delivered from the heat pump to the residence is computed using the measured air velocity, the cross sectional area of the return duct, the density of the air at the flow measurement station, and the change in enthalpy. The change in enthalpy is calculated from the temperature and humidity measurements at the heat pump's entrance and exit. The energy supplied to the water heater is computed using the temperature difference across the water side of the refrigerant-to-water heat exchanger, the flow rate of the water, and the density and specific heat of the water. These values are integrated over 1-hour time intervals yielding the hourly thermal load of the residence and the amount of energy delivered to the water heater during each hour. The energy delivered to the water heater takes into account the energy removed from the water heater during the defrost cycle. The hot water load is determined by integrating the product of the temperature difference between the water temperature entering and exiting the water heater, the hot water load flow rate, and the density and specific heat of water whenever a hot water draw occurs.

The average temperatures for the outdoor ambient, family room, living room, and master bedroom are recorded each hour. Temperature, relative humidity measurements, and air flow rates associated with the heat pump operation are only averaged during operation of the heat pump. Thus, any convective heating or cooling which takes place, due to a temperature difference between the indoor coil and surrounding air when the indoor fan is not operating, is ignored. It should be noted that these averaged values are not used to calculate the energy delivered by the heat pump, which is computed every 10 seconds based on instantaneous measurements whenever the heat pump is providing space conditioning. Measurements of the electrical energy supplied to the house, heat pump, water heater, and supplemental air heater were integrated to give the total energy consumption on a hourly basis.

At the end of each hour, values are recorded on a floppy disk. The values are recorded on a single disk for 10 consecutive days. At the end of the tenth day, the computer begins storing data on the second disk and displays a message on the monitor instructing the homeowner to remove the disk and replace it with a blank formatted disk. This scheme provides a maximum of 20 days of data collection without operator intervention. The homeowner of this residence, a Potomac Edison Company employee, monitored the system to ensure proper operation and mailed the data disks to NIST for final data reduction. Upon arrival at NIST, the individual 10-day files were combined into monthly data files. The monthly files were imported into a spreadsheet program for final analysis. During this study over 205 million measurements were taken and processed (32 measurements every 10 seconds). Over the 2-year monitoring period 99.8% of the available data was captured and processed due to the quality of the instrumentation, the use of an uninterruptible power supply, and the integrity of the data collection software.

EXPERIMENTAL RESULTS

Electrical Energy Consumption

Prior to the installation of the advanced integrated heat pump system, the residence was not monitored. Thus, a direct comparison between the energy required for space conditioning, water heating, and other uses before and after installation of the integrated heat pump system is not possible. It is possible, however, to compare the bimonthly billing data for the entire residence. For the 2-year period from October 1986 through September 1988, the total electrical energy consumed by the residence was 116,143 MJ (32,262 kWh). In addition, approximately 10 cords of oak wood were burned during the two heating seasons. Assuming a fuel value of 28,784 MJ (27.3 million Btu) per cord [5] and a 40% wood stove efficiency [6], an additional 115,116 MJ (31,977 kWh) of electricity would have been consumed if electric resistance heat had been used in lieu of the wood stove, resulting in a total estimated energy consumption of 231,259 MJ (64,239 kWh) for the residence. Space cooling was provided to approximately 30% of the home through the use of two 1.46 kW (5,000 Btu/hr) window air conditioners during the cooling seasons.

The energy consumed by the residence from October 1989 through September 1991 was 110,405 MJ (30,668 kWh), representing a 4.9% reduction in electrical energy consumption and an estimated 52% reduction in total energy consumption. The total electrical energy consumed by the residence was reduced by 6.1% for the period of time in which space heating was required and 1.0% for the months in which space cooling occurred. During this 2-year period, the integrated heat pump system was operational, the wood stove was not used, and the entire residence was space conditioned during both the heating and cooling seasons. It should be noted that differences in weather conditions, temperatures within the conditioned spaces, and hot water consumption before and after installation of the integrated heat pump system are not taken into account in this comparison.

A comparison can be made between the total energy consumption of the advanced integrated heat pump and associated water heater during the monitoring period to the energy which would have been consumed if an electric furnace and an identical water heater had been used during the months in which space heating occurred. Months during which both space heating and cooling occurred, September 1990 and May 1991, were not included in this comparison. The measured space heating load, energy supplied to the water heater, and energy supplied from the heat pump to the water heater were combined to represent the equivalent amount of electrical energy required to space condition the residence with an electric resistance furnace and provide hot water, Table 1. The use of an electric furnace with the same air distribution system and an identical electric water heater would have resulted in 112,094 MJ (31,137 kWh) of energy being consumed to meet the space and water heating loads over the two seasons, assuming that the heating elements within the water heater have an efficiency of 98%. This compares to an actual energy consumption of 45,092 MJ (12,526 kWh) to perform these two functions, or a savings of 67,002 MJ (18,612 kWh), a 60% reduction.

		SPACE I	TABLE 1 SPACE HEATING LOAD, ENERGY TRANSFERRED FROM HEAT PUMP TO WATER HEATER, AND ENERGY CONSUMPTIONS DURING SPACE HEATING MONTHS	TABLE 1 TING LOAD, ENERGY TRANSFERRED FROM HEA WATER HEATER, AND ENERGY CONSUMPTIONS DURING SPACE HEATING MONTHS	TABLE RGY TRAN AND ENEI	1 SFERRED RGY CONSI	FROM HE/ UMPTIONS THS	AT PUMP T	0,		
		G		Energy Transferred	rgy ferred			Energy Consumption	sumption		
Year	Month	Space Heating Load	ce Load	rrom Hear Pump to Water Heater	Heat p to Heater	Heat	Heat Pump	Suppl He	Supplemental Heater	Water	Water Heater
		MJ	kWh	MJ	kWh	MJ	kWh	MLJ	kWh	MJ	kWh
199	October	2109.0	585.8	864.0	240.0	1172.5	325.7	10.8	0.0	0.0	0.0
1990	November	5618.9	1560.8	1100.2	305.6	2405.2	668.1	10.8	2.8	4.7	1.3
1990	December	9244.4	2567.9	1128.6	313.5	3573.4	992.6	492.1	136.7	56.2	15.6
1991	January	12254.4	3404.0	1263.6	351.0	4672.1	1297.8	1312.2	364.5	112.0	31.1
1991	February	8767.8	2435.5	1028.2	285.6	3404.	945.7	403.9	112.2	24.8	0.0
1991	March	6692.0	1858.9	1289.9	358.3	2927.5	812.7	85.3	23.7	7.2	2.0
1991	April	2678.4	744.0	1102.0	306.1	1396.1	387.8	4.0	1.1	0.6	2.5
1991	October	2143.1	595.3	923.4	256.5	1261.8	350.5	0.5	0.0	5.0	1.3
1991	November	5958.0	1655.0	963.4	267.6	2541.2	705.9	74.9	20.8	20.9	5.8
1991	December	8948.2	2485.6	1229.0	341.4	3740.4	1039.0	298.8	83.0	79.2	22.0
1991	January	10747.4	2985.4	1109.5	308.2	4063.7	1128.8	931.7	258.8	146.9	40.8
1991	February	8852.8	2459.1	1099.4	305.4	3548.5	325.7	397.8	110.5	115.2	32.0
1991	March	7456.3	2071.2	1274.0	353.9	3297.6	916.0	79.2	22.0	54.7	115.2
1991	April	2638.1	732.8	1110.6	308.5	1553.4	431.5	3.6	1.0	9.0	2.5
1992	May	515.9	143.3	996.5	276.8	779.4	216.5	0.0	0.0	5.0	1.5
TOTAL		94624.7	26284.6	16482.3	4578.4	40337.3	11204.8	4104.4	1140.1	650.2	9.081

A comparison can also be made to the total energy which would have been consumed if an identical water heater and electric baseboard heat had been used. The air distribution system for this study was installed under direct supervision of Potomac Edison personnel. The entire duct system is located within interior wall partitions and between floor joists. Approximately 70% of the air distribution system is located in the conditioned space with the remaining portion within the unheated basement. During installation every effort was made to minimize air leakage by sealing each individual seam. The portion of the air distribution system within the basement was insulated to an R-5 level. Thus, for this particular duct system, a thermal efficiency value of 85% is assumed. With this assumption, the space heating loads using electric baseboard heat would be 15% less than the values given in Table 1. Thus, the use of an identical water heater and electric baseboard heat during months in which space heating was required would have resulted in 97,900 MJ (27,194 kWh) of energy being consumed to meet the space and water heating requirements compared to the measured energy consumption of 45,092 MJ (12,526 kWh), a 54% reduction.

The energy consumed by the residence, water heater, supplemental heaters, and heat pump is given in columns D, E, F, and G of Tables 2 and 2A on a monthly, seasonal, and annual basis. Table 2 uses the SI system of units whereas Table 2A uses the conventional IP system of units. The tables are discussed in greater detail in the section entitled "Advanced Integrated Heat Pump System Performance." The base load, which includes all miscellaneous uses of electricity within the residence such as lights, stove, clothes washer, dryer, refrigerator, and small appliances, may be determined by subtracting the electrical energy consumption of the heat pump, water heater, and supplemental heater from the total energy consumption of the residence. Figure 5 shows the monthly energy consumption for each end use. The heat pump system is the primary end user for the months of November through March. The primary end user of electricity during the remaining months is the base load.

The energy supplied to the resistive heating elements within the water heater represents a small fraction of the total energy consumption, ranging from 0 MJ (0 kWh) in October 1990 to 306 MJ (85 kWh) during the month of May 1991. The May 1991 value is unrepresentative due to a 1-week test during this month in which the heat pump was prevented from heating water. During this 1-week interval, an energy balance was performed on the water heater to ensure that the hot water load was accurately being measured. The energy supplied by the heat pump to the water heater and energy consumed by resistive elements within the water heater are shown for each month in Figure 6. Over the monitoring period, the water heater represented only 1.2% of the total energy consumed, followed by the supplemental duct heaters (3.6%), heat pump (44.7%) and base load (50.5%), Figure 7.

							HE/	HEAT PUMP ENERGY CONSUMPTION	P ENER	GY CO	NSUMP	LION						
*	В	U		Ω	ជា	ír.	Ö	Н	_	î	м	7	X	Z	0	ο.	O	α
MONTH	YEAR	HOUSE THERMAL LOAD (MJ)	(MJ)	TOTAL	WATER	SUPPLEMENTAL HEATER	TOTAL	WATER	SPACE	SPACE	SPACE	SPACE	AVERAGE DAILY	STATUS	COOLING	MONTHLY	WATER HEATING COEFFICIENT	PERFORMANC
	LUI T	HEATING	COOLING	ENERGY CONSUMPTION	ELECTRICAL	ELECTRICAL		ONLY	ONLY	WATER	ONLY	AND WATER HEATING	HOT WATER CONSUMPTION	OF HEAT PUMP	COEFFICIENT OF PERFORMANCE	COEFFICIENT OF PERFORMANCE	OF PERFORMANCE	FACTOR
				(M)	(M3)	(MI)	(MI)	(MI)	(MI)	(MJ)	(MJ)	(MJ)	(m^3*10^3)		Ī	(=)	<u>-</u>	(<u>-</u>)
JUNE	0661	0000	2432.88	2815.6	34,9	0.0	1071.0	n/a	n/a	n/a	n/a	n/a	167.7	COOT	3,60	n/a	n/a	2.88
JULY	1990	00.00	3926.88	2770.9	38.9	0.0	1242.0	n/a	n/a	e/u	n/a	n/a	1408	COOL	3.62	n/a	n/a	3.50
AUGUST	1990	00.00	3599.28	3482.3	25.2	0.0	1228.3	247.0	n/s	0.0	360.7	510.8	1503	T000	4.03	n/a	16,1	3.36
SEPTEMBER	0661	28138	1362.96	3215,9	20.2	0.0	891.0	3830	40.7	28.1	149.4	1891	1461	COOL/HEAT	3.85	1.81	1.84	2.42
OCTOBER	1990	2108.95	00'0	3381.8	0.0	10.8	1172.5	4424	3359	254,5	0.0	0.0	127.2	HEAT	n/a	2.75	1.70	2.28
NOVEMBER	1990	88'8199	00.00	4617.0	4.7	10.1	2405.2	5627	9724	7801	0.0	0.0	1563	HEAT	n/a	3,30	1,39	2,62
DECEMBER	1990	9244.44	0.00	6489.0	56.2	4921	3573,4	626.8	1711.8	1153.1	0.0	0.0	1431	HEAT	n/a	2.69	1.24	2,43
JANUARY	1661	12254.40	0.00	8574.1	1120	1312.2	4672.1	586.1	2423.9	1555.6	0.0	0.0	157.9	HEAT	n/a	2.19	1111	2.13
FEBRUARY	1661	8767.8	00'0	5814.0	24.8	403.9	3404.5	4986	1820.9	1013.4	0.0	0.0	1420	HEAT	n/a	2.69	1,23	2,45
MARCH	1991	6692.04	0.00	5747.0	7.2	85.3	2927.5	679.3	1316.2	837.7	0.0	0.0	1711	HEAT	n/a	3.01	1.36	2,50
APRIL	1661	2678.4	0.00	3494.2	0.6	4.0	1396.1	559.1	4554	2952	0.0	0.0	1866	HEAT	n/a	3,33	1.71	2.50
MAY	1661	18576	76284	3141.7	3060	0.0	7063	2556	27.0	38.5	87.1	114.1	1624	COOL/HEAT	4.03	0.91	1.85	1.65
JUNE	1661	00'0	3851.64	4529.5	95.4	0.0	1392.1	219.6	0.0	0.0	4651	919	1688	TOOO	3.58	s/u	2.01	3,07
JULY	1661	0000	4849,56	4816.1	54.7	0.0	1590.8	1454	0.0	0.0	633.2	720.4	138.5	T000	39.6	E/3	2.05	3.31
AUGUST	1991	0.00	4326,84	4508.6	47.9	0.0	1498.0	1789	0.0	0.0	557.3	673.2	154.4	COOL	3.61	n/s	2.02	3,22
SEPTEMBER	1991	0.00	916.56	3312.0	39.2	0.0	707.4	350.3	0.0	0.0	139.3	1120	135.9	T000	2,50	η(3	1.86	1,99
OCTOBER	1661	2143.08	00.0	3760.2	5.0	0.0	1261.8	499.7	42.52	231.8	0.0	0.0	138.9	HEAT	n/a	2,92	1.62	2.21
NOVEMBER	1661	8665	00'0	48.58.9	20.9	74.9	2541.2	474.5	1168.6	810.4	0.0	0.0	129.8	HEAT	n/s	2.94	1.11	2.49
DECEMBER	1661	8948.16	0.00	7135.9	79.2	298.8	3740.4	587.5	1827.0	1233.7	0,0	0,0	166.2	HEAT	n/s	2.65	1.26	2.37
JANUARY	1992	10747.44	0.00	7542.7	146.9	931.7	4063.7	472.3	2147.0	1359.0	0*0	0.0	1526	HEAT	n/a	2,33	1.15	2,24
FEBRUARY	1992	8852.76	0.00	6489.4	1152	397.8	3548.5	550.4	1719.0	1208.2	0,0	0,0	163.5	HEAT	n/a	2.63	121	4.24
MARCH	1992	7456.32	0.00	6037.9	54.7	79.2	3297.6	630.7	1552.3	1028.9	0.0	0.0	1654	HEAT	n/a	2.57	1.31	2,42
APRIL	1992	2638.08	00.00	3719.9	0.6	3.6	1553.4	6163	460.1	3863	0.0	0.0	146.5	HEAT	n/a	3.58	1.55	2,16
MAY	1992	51588	00.0	2972.5	5.4	0.0	779.4	5252	65.5	92.5	0.0	0.0	1563	HEAT	n/n	1.61	1.50	1,55
1990 COOLING SEASON	CING	n/a	11322	10897.6	119.2	0.0	4098.2	424.8	0.0	0.0	5101	679.0	147.6		3,7,	п.	1.02	\$18
19X0-91 HEATING SEASON	ATING	47832.05	n/a	41936.8	510.8	2318.4	20244.6	4398.5	9103.7	5955.5	0,0	0.0	153.7		n/a	2.03	29.1	3.34
1991 COOLING	LING	n/a	14707.44	17875.4	2462	0.0	5414.4	9104	0.0	0.0	1881.7	2235,6	147,6		3.52	n/a	1.96	3,06
1991 – 92 HEATING SFASON	ATING	47259.72	11/8	42517.4	4363	1786.0	20785.7	43.56.7	9364.7	6350.8	0.0	0.0	151.4		nva	2.63	1.40	2.31
ANNUAL 6/90 - 5/91	16/5 - 0	47832.05	12084.84	53542.8	639.0	2318.4	24568.6	4822.9	9103.7	5935.5	510.1	7927	151.8		103	2.63	1.47	2.45
ANNUAL 6/91 - 5/92	1 - 5/93	47259.72	13944,6	59084,4	6736	1786.0	25974.4	5267,2	9365.0	63.30.8	1794.6	2121.5	1503		3.50	F.0.5	9.	2.45
(I) Oncral	lion	Ileating	Model	1000 0/18/00	0 - 00-00	1) Oberation in Heating Mode began 0/18/00 of 00:00 - Oberation in Collins Mode began 5/27/01 of 13:00	Soling A	fode bee	12015	01 01 13.	1	1						

⁽¹⁾ Operation in Heating Mode began 9/18/90 at 00:00; Operation in Cooling Mode began 5/27/91 at 13:00

(3) Heating Coefficient of Performance is computed for space heating only operation. Supplemental and parasitic energy is included. (2) Cooling Coefficient of Performance is computed for space cooling only operation. Parasitic energy consumption is included.

⁽⁴⁾ Water Heating Coefficient of Performance is the ratio of the energy delivered to the water heater divided by the energy consumed while operating in the water heating only mode.


(5) The Combined Performance Factor is the sum of the space conditioning and hot water loads divided by the energy consumed by the heat pump, supplemental heaters, and water heater.


MONTHLY, SEASONAL, AND ANNUAL PERFORMANCE SUMMARY (IP UNITS) **TABLE 2A**

HEAT PITMP ENERGY CONSTIMPTION


WATER SUPPLEMENTAL WATER WATER HEATTER TOTAL HEATTNO	TRAM TOTAL WATER SUPPLIARETAL TOTAL WATER MATER MATER 1.0.05 (KMH) RESIDENCE HEATING CONSUMPTION CONSUMPTION TOTAL HEATING 1.900 0.000 67380 7821 9.7 0.0 297.3 n/a 1.900 0.000 67380 7821 9.7 0.0 297.3 n/a 1.900 0.000 67380 7627 1.08 0.0 297.3 n/a 1.900 0.000 67380 7627 1.08 0.0 297.3 n/a 1.900 0.000 67380 7667 1.08 0.0 297.3 n/a 1.900 78.16 37.60 893.3 5.6 0.0 247.5 1.04 1.900 78.16 37.60 893.3 5.6 0.0 247.5 1.04 1.900 78.16 78.2 1.3 1.3 1.3 1.1 1.2 1.901 38.16	YEAR HOUSE THERNALL FOTAL WATER SUPPENDING HEATER AATER 1900 LOAD (KMH) RENEDNOR HEATER CONSUNTTION CONSUNTTION CONSUNTTION 1990 0.000 67380 7821 9.7 0.00 207.3 n/a 1990 0.000 67380 7821 9.7 0.00 207.3 n/a 1990 0.000 109280 768.7 1038 0.00 207.3 n/a 1990 78.16 78.00 788.1 7.0 0.00 207.3 n/a 1990 78.16 78.00 198.2 7.0 0.0 207.3 1.0 1990 78.16 7.8 1.0 0.0 2.0 2.0 0.0 1991 78.16 7.8 7.1 2.0 2.0 0.0 2.0 0.0 1990 78.16 7.8 7.1 2.0 2.0 0.0 2.0 0.0 0.0 0.0 0.0<	HOUSE THERMAL FOTAL WATER SUPPLEMENTAL TOTAL WATER SUPPLEMENTAL TOTAL MATER 1900 LOAD (KM1) FENDENCE EHEATER TOTAL HEATTRO PERATOR CONSUMPTION CONSUM	TEAM LOADE (NRH) TOTAL WATER SUPPLEADYNAL TOTAL WATER TOTAL HEATING TOTAL HEATING COLING CONSINATION	TEAM LOADE FHERMAL TOTAL WATER SUPPLEATER TOTAL WATER SUPPLEATER TOTAL MATER TEAM LOADE (KWH) RENDEOY CONSUMPTION CONSUMPTION <td< th=""><th>В</th><th>O</th><th>Ω</th><th>B</th><th>ш</th><th>Ď</th><th>н</th><th></th><th></th><th>-</th><th>J. K</th><th>J</th><th></th><th>W</th><th>J K L L</th><th>O Z</th></td<>	В	O	Ω	B	ш	Ď	н			-	J. K	J		W	J K L L	O Z
YEAR LOAD (KWH) RESIDENCE HEATER HEATER TOAL HEATER 1500 COOLINO CONSIDNATIOAL	YEAR LOAD (KWH) RESIDENCE HEATER HEATER TOAL HEATER 1900 COOLING COOLING CONSIDERTICAL CELECTRICAL CONSIDERTICAL	TACAR LOAD (KWH) RESIDENCE HEATING TOTAL HEATING 1900 COLLING CONSUMETION CONSUMETION CONSUMETION CONSUMETION 1900 0.000 67380 7821 9.7 0.0 3450 0.0 1900 0.000 67380 7687 1.08 0.0 3450 0.0 1900 0.000 99880 967.3 7.0 0.0 34.1 68.6 1900 1.000 99880 967.3 7.0 0.0 34.1 68.6 1900 1.000 1.988.0 967.3 7.0 0.0 34.1 68.6 1900 1.000 1.887.1 1.3 2.0 0.0 1.2 1.2 190 1.200 1.882.2 0.0 1.3 1.3 1.2 68.6 190 1.200 1.882.2 1.2 1.2 1.2 1.2 1.2 190 1.200 1.882.2 1.2 1.2<	TFAME LOAD (KWH) RESIDENCE HEATTER HEATTER THEATTER THEATTER TOTAL HEATTER 1900 0.000 67.860 782.11 9.77 0.00 34.50 ONIX 1900 0.000 67.860 782.11 9.77 0.00 34.50 NA 1900 0.000 67.860 782.11 9.77 0.00 34.50 NA 1900 0.000 1098.80 967.3 7.0 0.00 34.50 NA 1900 0.000 1188.20 0.00 3.00 3.0 3.0 3.0 1.20 1900 1.200.80 98.33 5.6 0.00 3.45 1.20	PEAR LOAD (KWH) RENDENCE HEATER HEATER TOTAL HEATER TOTAL HEATER 1950 COOLING CONSUMPTION CONSUMPTION CONSUMPTION CWH) CWH) 1950 0.000 67.350 782.1 97.0 10.3 34.2 n/4 1950 0.000 67.350 77.2 10.3 0.00 34.2 n/4 1950 0.000 67.35 77.2 10.3 0.00 34.2 n/4 1950 0.000 10.03.50 76.7 10.3 0.00 34.2 n/4 1950 78.16 39.8 7.0 0.00 34.2 10.4 10.4 1950 78.16 39.8 7.0 0.00 34.2 10.4 10.4 1950 78.16 39.8 3.6 1.3 1.3 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 <t< td=""><td>VEAR LOAD (KWH) RESIDENCE HEATIRA HEATIRA TOTAL HEATIRA 190 COOD CONSUMPTOY CONSUMPTOY CONSUMPTOY CONSUMPTOY CONSUMPTOY 1900 COOD CONSUMPTOY CONSUMPT</td><td>НОС</td><td>E THERMAL</td><td>TOTAL</td><td>WATER</td><td>SUPPLEMENTAL</td><td></td><td>WATER</td><td></td><td>SPACE</td><td></td><td>SPACE</td><td>SPACE SPACE</td><td>SPACE SPACE A</td><td>SPACE SPACE SPACE AVERAGE OF</td><td>SPACE SPACE SPACE AVERAGE OPERATIONAL</td><td>SPACE SPACE AVERAGE OPERATIONAL MONTHLY</td></t<>	VEAR LOAD (KWH) RESIDENCE HEATIRA HEATIRA TOTAL HEATIRA 190 COOD CONSUMPTOY CONSUMPTOY CONSUMPTOY CONSUMPTOY CONSUMPTOY 1900 COOD CONSUMPTOY CONSUMPT	НОС	E THERMAL	TOTAL	WATER	SUPPLEMENTAL		WATER		SPACE		SPACE	SPACE SPACE	SPACE SPACE A	SPACE SPACE SPACE AVERAGE OF	SPACE SPACE SPACE AVERAGE OPERATIONAL	SPACE SPACE AVERAGE OPERATIONAL MONTHLY
HEATING COOLING CONSUMPTION CONSUMPT	Health H	HEATING COOLING CONSTANTION CICAGO CI	HeATING COOLING CONSUMPTION CONSUMPT	HEATING COOLING CONSUNPTION CONSUNPT	HeATING COULNG CONSUMPTION CONSUMPTI		D (KWH)	RESIDENCE	HEATER	HEATER	TOTAL	HEATING	HEATING	(h)		AND	AND COOLING	AND COOLING COOLING	AND COOLING COOLING DAILY	AND COOLING COOLING DAILY	AND COOLING COOLING DAILY STATUS
1990 0.00 67.80 782.1 9.7 0.00 297.5 n/a 1990 0.00 67.80 782.1 9.7 0.00 34.0 n/a 1990 0.00 1090.80 768.7 10.8 0.0 34.2 n/a 1990 0.00 998.60 967.3 7.0 0.0 34.2 n/a 1990 788.6 378.60 894.3 5.6 0.0 247.5 1124. 1990 788.6 0.00 1282.5 1.3 2.8 1.5 1.2 1990 156.80 0.00 1802.5 1.5 1.3 1.2 1.2 1991 245.70 0.00 1802.5 1.5 1.3 1.4 1.2 1.4 1991 245.80 0.00 1.856.4 2.0 2.4 1.2 1.4 1.2 1.4 1.2 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 <td>1990 0.000 67380 7821 9.7 0.00 297.5 n/a 1990 0.000 67380 7821 9.7 0.00 297.5 n/a 1990 0.000 1090.80 765.7 10.8 0.0 34.2 68.6 1990 0.00 999.80 967.3 7.0 0.0 34.2 68.6 1990 781.6 378.0 993.4 0.0 3.0 247.5 102.7 1990 782.6 0.00 1282.3 1.3 2.8 1.2 68.6 1991 1440.0 0.00 1282.3 1.3 2.8 1.4 1.6 1.2 1991 7440.0 0.00 165.0 2.5 1.2 1.4 1.4 1.4 1.4 3.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4</td> <td>1900 0.000 67380 7KWH) 7KWH) 7KWH 7KWH</td> <td>1990 0.000 67380 7821 97 0.00 297.5 n/a 1990 0.000 67380 7821 97 0.00 297.5 n/a 1990 0.000 1090.80 7687 10.8 0.00 34.50 n/a 1990 0.00 998.80 967.3 7.0 0.00 34.2 68.6 1990 0.00 998.80 967.3 7.0 0.0 34.2 68.6 1990 78.16 378.0 893.3 5.6 0.0 247.2 122.7 1990 180.0 998.4 0.0 3.0 34.2 68.6 1991 1992 188.0 0.0 118.7 118.7 118.7 118.8 1991 244.0 0.0 165.9 125.2 11.1 364.5 118.7 1991 244.0 0.0 165.9 125.2 12.9 11.4 11.2 1991 244.0 0.0 168.9<td> 1950 0.000 0.7580 782.1 9.7 0.00 207.5 10.4 1950 0.000 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 0.9584 0.00 0.247.5 1.04.7 1.259 1.250</td><td>1990 0.000 67380 78211 97 0.00 2975 n/a 1990 0.000 67380 7821 9.7 0.00 2975 n/a 1990 0.000 109080 7667 10.8 0.00 3412 68.6 1990 0.000 99800 9673 7.0 0.00 3412 68.6 1990 7846 8943 5.6 0.0 2475 1127 1990 7856 0.00 1582.3 1.3 2.8 4.4 156.3 1990 1860.0 0.00 1880.2 1.3 2.8 4.4 156.3 1.2 1991 1878.0 0.00 1860.2 1.3 3.4 1.8 1.4 1.8 1.8 1.4 1.8 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4</td><td></td><td>G COOLING</td><td>ENERGY</td><td>ELECTRICAL</td><td>ELECTRICAL</td><td></td><td>ONLY</td><td>ONLY</td><td></td><td>WATER</td><td>WATER ONLY HEATING</td><td></td><td>ONLY</td><td>ONLY AND WATER HEATING</td><td>ONLY ANDWATER HOT WATER HEATING CONSUMPTION</td><td>ONLY AND WATER HOT WATER OFHEAT HEATING CONSUMPTION PUMP</td></td>	1990 0.000 67380 7821 9.7 0.00 297.5 n/a 1990 0.000 67380 7821 9.7 0.00 297.5 n/a 1990 0.000 1090.80 765.7 10.8 0.0 34.2 68.6 1990 0.00 999.80 967.3 7.0 0.0 34.2 68.6 1990 781.6 378.0 993.4 0.0 3.0 247.5 102.7 1990 782.6 0.00 1282.3 1.3 2.8 1.2 68.6 1991 1440.0 0.00 1282.3 1.3 2.8 1.4 1.6 1.2 1991 7440.0 0.00 165.0 2.5 1.2 1.4 1.4 1.4 1.4 3.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4	1900 0.000 67380 7KWH) 7KWH) 7KWH	1990 0.000 67380 7821 97 0.00 297.5 n/a 1990 0.000 67380 7821 97 0.00 297.5 n/a 1990 0.000 1090.80 7687 10.8 0.00 34.50 n/a 1990 0.00 998.80 967.3 7.0 0.00 34.2 68.6 1990 0.00 998.80 967.3 7.0 0.0 34.2 68.6 1990 78.16 378.0 893.3 5.6 0.0 247.2 122.7 1990 180.0 998.4 0.0 3.0 34.2 68.6 1991 1992 188.0 0.0 118.7 118.7 118.7 118.8 1991 244.0 0.0 165.9 125.2 11.1 364.5 118.7 1991 244.0 0.0 165.9 125.2 12.9 11.4 11.2 1991 244.0 0.0 168.9 <td> 1950 0.000 0.7580 782.1 9.7 0.00 207.5 10.4 1950 0.000 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 0.9584 0.00 0.247.5 1.04.7 1.259 1.250</td> <td>1990 0.000 67380 78211 97 0.00 2975 n/a 1990 0.000 67380 7821 9.7 0.00 2975 n/a 1990 0.000 109080 7667 10.8 0.00 3412 68.6 1990 0.000 99800 9673 7.0 0.00 3412 68.6 1990 7846 8943 5.6 0.0 2475 1127 1990 7856 0.00 1582.3 1.3 2.8 4.4 156.3 1990 1860.0 0.00 1880.2 1.3 2.8 4.4 156.3 1.2 1991 1878.0 0.00 1860.2 1.3 3.4 1.8 1.4 1.8 1.8 1.4 1.8 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4</td> <td></td> <td>G COOLING</td> <td>ENERGY</td> <td>ELECTRICAL</td> <td>ELECTRICAL</td> <td></td> <td>ONLY</td> <td>ONLY</td> <td></td> <td>WATER</td> <td>WATER ONLY HEATING</td> <td></td> <td>ONLY</td> <td>ONLY AND WATER HEATING</td> <td>ONLY ANDWATER HOT WATER HEATING CONSUMPTION</td> <td>ONLY AND WATER HOT WATER OFHEAT HEATING CONSUMPTION PUMP</td>	1950 0.000 0.7580 782.1 9.7 0.00 207.5 10.4 1950 0.000 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 987.3 7.00 0.9580 0.9584 0.00 0.247.5 1.04.7 1.259 1.250	1990 0.000 67380 78211 97 0.00 2975 n/a 1990 0.000 67380 7821 9.7 0.00 2975 n/a 1990 0.000 109080 7667 10.8 0.00 3412 68.6 1990 0.000 99800 9673 7.0 0.00 3412 68.6 1990 7846 8943 5.6 0.0 2475 1127 1990 7856 0.00 1582.3 1.3 2.8 4.4 156.3 1990 1860.0 0.00 1880.2 1.3 2.8 4.4 156.3 1.2 1991 1878.0 0.00 1860.2 1.3 3.4 1.8 1.4 1.8 1.8 1.4 1.8 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4 1.4		G COOLING	ENERGY	ELECTRICAL	ELECTRICAL		ONLY	ONLY		WATER	WATER ONLY HEATING		ONLY	ONLY AND WATER HEATING	ONLY ANDWATER HOT WATER HEATING CONSUMPTION	ONLY AND WATER HOT WATER OFHEAT HEATING CONSUMPTION PUMP
1900 0.000 67380 7821 9.7 0.00 297.3 n/4 1900 0.000 1090.80 7687 10.8 0.00 34.0 10.4 1900 0.000 998.80 967.3 7.0 0.00 34.1 68.6 1900 7821 967.3 7.0 0.0 247.5 10.47 1900 5858.2 0.00 9384.3 5.6 0.0 247.5 1134.7 1900 1560.80 0.00 1282.5 1.3 2.8 4.5 1125.9 1901 1560.80 0.00 1802.5 1.3 2.8 1.2 1.2 1901 1560.80 0.00 1802.5 1.1 364.5 1.2 1.2 1901 1560.80 0.00 1802.0 2.3 1.4 1.6 1.8 1901 1560 11.20 8.5 1.1 364.5 1.4 1.6 1902 1560 0.00 1802.0 </td <td>1990 0.00 67380 7821 9.7 0.00 297.3 n/a 1990 0.00 1090.80 7687 10.8 0.0 34.0 n/a 1990 0.00 1090.80 967.3 7.0 0.0 34.2 68.6 1990 781.6 318.60 893.3 5.6 0.0 247.5 1134.7 1990 585.82 0.00 1282.8 1.3 2.8 4.6 152.9 1990 585.82 0.00 1282.3 1.3 2.8 4.5 1.2 1990 156.80 0.00 1882.3 1.5 1.3 1.4 1.5 1991 156.00 1.6 1.8 1.5 1.3 1.8 1.4</td> <td>1990 0.000 67580 78211 9,7 0.00 297.5 n/a 1990 0.000 67080 7821.1 108.8 0.00 340.0 104.8 1990 0.000 99880 967.3 7.0 0.00 341.2 68.6 1990 281.6 37860 893.3 5.6 0.00 241.5 1127.9 1990 281.6 37860 893.3 5.6 0.00 241.5 1127.9 1990 281.6 0.00 1180.2 11.3 3.4 1127.9 1991 1560.30 0.00 180.2 1.1 364.5 112.1 1992 1560.30 0.00 165.0 1.1 364.5 1.1 1991 1560.30 0.00 158.7 1.2 1.1 387.8 1.6 1991 1560.30 0.00 158.7 1.2 2.2 1.1 1.6 1.0 1991 1560.3 1.1 1.3</td> <td>1900 0.000 67.80 79.21 9.7 0.00 29.7.5 n/a 1900 0.000 67.80 79.21 10.8 0.00 34.20 n/a 1900 0.000 99.80 967.3 7.0 0.00 34.20 10.41 1900 78.16 37.860 89.33 5.6 0.00 34.12 68.6 1900 78.16 37.860 89.33 5.6 0.00 34.15 112.0 1900 58.28.2 0.00 99.44 0.0 3.0 37.5 112.0 1901 158.00 0.00 180.25 1.3 2.8 1.1 364.5 192.0 104.1 1901 144.00 0.00 180.20 1.1 364.5 1.1 364.5 1.1 364.5 1.1 1901 144.00 0.00 1.2 2.2 1.1 364.5 1.1 1.1 1901 1.180 8.7 1.2 2.0 2</td> <td>1906 0.00 67.80 782.1 9.7 0.0 297.3 n/a 1906 0.00 1.00.80 769.7 10.8 0.0 34.50 n/a 1906 0.00 1.00.80 769.7 10.8 0.0 34.5 n/a 1906 0.00 998.0 967.3 7.0 0.0 34.5 10.2 11.2 68.6 1907 38.45 378.0 998.4 0.0 20.3 1.3 6.0 27.7 11.2 68.6 11.2 11.2 68.6 11.2 11.2 11.2 6.0 17.4 11.2<td>1990 0.00 67.80 778.1 9.7 0.00 297.5 n/a 1990 0.00 100.80 768.7 10.8 0.00 345.0 n/a 1990 0.00 998.80 967.3 7.0 0.0 341.2 68.6 1990 7.84 378.60 893.3 5.6 0.0 247.5 1129 1990 7.84 0.00 128.23 1.3 0.0 247.5 1129 1990 3.858.7 0.00 128.23 1.3 2.8 4.4 1.2 1991 1.868.80 0.00 1.882.3 1.3 3.8 1.3 1.8 1991 1.858.90 0.00 1.857.4 3.1 3.64.5 1.2 1.2 1991 1.440.0 0.00 1.857.4 3.1 3.64.5 1.1 38.7 1.1 3.8 1.1 3.8 1.1 3.6 1.1 1.1 3.6 1.1 1.1 1.1 1.1</td><td></td><td></td><td>(KWH)</td><td>(KWH)</td><td>(KWH)</td><td>(KWH)</td><td>(KWH)</td><td>(KWH)</td><td>~</td><td>(KWH)</td><td>KWH) (KWH)</td><td>(KWH)</td><td>(KWH)</td><td>(KWH) (KWH)</td><td>(KWH) (KWH) (GALLONS)</td><td>(KWH) (KWH) (GALLONS)</td></td>	1990 0.00 67380 7821 9.7 0.00 297.3 n/a 1990 0.00 1090.80 7687 10.8 0.0 34.0 n/a 1990 0.00 1090.80 967.3 7.0 0.0 34.2 68.6 1990 781.6 318.60 893.3 5.6 0.0 247.5 1134.7 1990 585.82 0.00 1282.8 1.3 2.8 4.6 152.9 1990 585.82 0.00 1282.3 1.3 2.8 4.5 1.2 1990 156.80 0.00 1882.3 1.5 1.3 1.4 1.5 1991 156.00 1.6 1.8 1.5 1.3 1.8 1.4	1990 0.000 67580 78211 9,7 0.00 297.5 n/a 1990 0.000 67080 7821.1 108.8 0.00 340.0 104.8 1990 0.000 99880 967.3 7.0 0.00 341.2 68.6 1990 281.6 37860 893.3 5.6 0.00 241.5 1127.9 1990 281.6 37860 893.3 5.6 0.00 241.5 1127.9 1990 281.6 0.00 1180.2 11.3 3.4 1127.9 1991 1560.30 0.00 180.2 1.1 364.5 112.1 1992 1560.30 0.00 165.0 1.1 364.5 1.1 1991 1560.30 0.00 158.7 1.2 1.1 387.8 1.6 1991 1560.30 0.00 158.7 1.2 2.2 1.1 1.6 1.0 1991 1560.3 1.1 1.3	1900 0.000 67.80 79.21 9.7 0.00 29.7.5 n/a 1900 0.000 67.80 79.21 10.8 0.00 34.20 n/a 1900 0.000 99.80 967.3 7.0 0.00 34.20 10.41 1900 78.16 37.860 89.33 5.6 0.00 34.12 68.6 1900 78.16 37.860 89.33 5.6 0.00 34.15 112.0 1900 58.28.2 0.00 99.44 0.0 3.0 37.5 112.0 1901 158.00 0.00 180.25 1.3 2.8 1.1 364.5 192.0 104.1 1901 144.00 0.00 180.20 1.1 364.5 1.1 364.5 1.1 364.5 1.1 1901 144.00 0.00 1.2 2.2 1.1 364.5 1.1 1.1 1901 1.180 8.7 1.2 2.0 2	1906 0.00 67.80 782.1 9.7 0.0 297.3 n/a 1906 0.00 1.00.80 769.7 10.8 0.0 34.50 n/a 1906 0.00 1.00.80 769.7 10.8 0.0 34.5 n/a 1906 0.00 998.0 967.3 7.0 0.0 34.5 10.2 11.2 68.6 1907 38.45 378.0 998.4 0.0 20.3 1.3 6.0 27.7 11.2 68.6 11.2 11.2 68.6 11.2 11.2 11.2 6.0 17.4 11.2 <td>1990 0.00 67.80 778.1 9.7 0.00 297.5 n/a 1990 0.00 100.80 768.7 10.8 0.00 345.0 n/a 1990 0.00 998.80 967.3 7.0 0.0 341.2 68.6 1990 7.84 378.60 893.3 5.6 0.0 247.5 1129 1990 7.84 0.00 128.23 1.3 0.0 247.5 1129 1990 3.858.7 0.00 128.23 1.3 2.8 4.4 1.2 1991 1.868.80 0.00 1.882.3 1.3 3.8 1.3 1.8 1991 1.858.90 0.00 1.857.4 3.1 3.64.5 1.2 1.2 1991 1.440.0 0.00 1.857.4 3.1 3.64.5 1.1 38.7 1.1 3.8 1.1 3.8 1.1 3.6 1.1 1.1 3.6 1.1 1.1 1.1 1.1</td> <td></td> <td></td> <td>(KWH)</td> <td>(KWH)</td> <td>(KWH)</td> <td>(KWH)</td> <td>(KWH)</td> <td>(KWH)</td> <td>~</td> <td>(KWH)</td> <td>KWH) (KWH)</td> <td>(KWH)</td> <td>(KWH)</td> <td>(KWH) (KWH)</td> <td>(KWH) (KWH) (GALLONS)</td> <td>(KWH) (KWH) (GALLONS)</td>	1990 0.00 67.80 778.1 9.7 0.00 297.5 n/a 1990 0.00 100.80 768.7 10.8 0.00 345.0 n/a 1990 0.00 998.80 967.3 7.0 0.0 341.2 68.6 1990 7.84 378.60 893.3 5.6 0.0 247.5 1129 1990 7.84 0.00 128.23 1.3 0.0 247.5 1129 1990 3.858.7 0.00 128.23 1.3 2.8 4.4 1.2 1991 1.868.80 0.00 1.882.3 1.3 3.8 1.3 1.8 1991 1.858.90 0.00 1.857.4 3.1 3.64.5 1.2 1.2 1991 1.440.0 0.00 1.857.4 3.1 3.64.5 1.1 38.7 1.1 3.8 1.1 3.8 1.1 3.6 1.1 1.1 3.6 1.1 1.1 1.1 1.1			(KWH)	(KWH)	(KWH)	(KWH)	(KWH)	(KWH)	~	(KWH)	KWH) (KWH)	(KWH)	(KWH)	(KWH) (KWH)	(KWH) (KWH) (GALLONS)	(KWH) (KWH) (GALLONS)
1900 0.00 100,080 769.7 10.8 0.00 34.2 6.8 n/a n/a 1900 0.00 998.80 967.3 7.0 0.00 34.2 68.6 n/a 1900 78.16 378.60 893.43 5.6 0.00 247.5 1127.9 61.6 1900 186.82 0.00 1282.5 1.3 2.8 41.61 152.9 93.3 1990 156.08 0.00 1802.5 1.3 2.8 41.61 475.2 570.1 1990 156.08 0.00 1802.5 1.3 2.8 41.61 475.2 570.1 1991 244.00 0.00 1615.0 6.9 112.2 94.5 112.9 85.6 1991 244.00 0.00 1615.0 6.9 112.2 94.5 11.6 6.9 1991 246.00 1.00 1.55.2 2.5 1.1 86.6 7.1 1901 1.00	1900 0.00 100.808 769.73 10.88 0.00 34.20 68.6 n/a n/a 1900 0.00 993.80 967.3 7.0 0.0 34.12 68.6 n/a 1900 78.16 378.60 89.33 5.6 0.0 247.5 102.7 6.1 1900 58.58.7 0.00 1282.5 1.3 2.8 41.61 152.9 93.3 1900 156.05.0 0.00 1282.5 1.5 1.3 2.8 41.61 157.5 93.3 1901 156.05.0 0.00 1802.5 1.5 1.3 2.8 7.1 475.5 1901 1490 1.00.00 1.615.0 6.9 112.7 94.5 1.741 475.5 1901 1.440 0.00 1.615.0 6.9 112.2 1.88.7 36.4 1.14.1 475.5 1901 1.840 0.00 1.586.4 2.0 2.3 1.14.1 475.5 1	1990 0.00 109.80 769.7 10.88 0.00 34.5 68.6 n/a 1990 0.00 998.80 967.3 7.0 0.00 341.2 68.6 n/a 1990 78.16 378.60 893.3 5.6 0.00 247.3 10.27 61.6 1990 38.58.2 0.00 998.4 0.0 3.0 32.7 122.9 93.3 1991 158.62 0.00 128.2.5 1.3 2.8 1.4 47.5 1991 158.60 0.00 1615.0 3.1 364.5 157.8 157.8 67.8 1991 248.50 0.00 1615.0 2.5 1.1 387.8 158.6 67.3 170.1 47.5 1991 248.50 0.00 1586.4 2.0 2.3 1.1 47.5 36.8 1991 188.80 0.00 1586.4 2.0 2.3 1.1 4.1 4.1 4.1 4.1 <td< td=""><td>190 0.00 1908 7697 108 0.00 1412 6846 n/a 190 0.00 998.0 9673 7.0 0.00 3412 6846 n/a 190 0.00 988.0 9673 7.0 0.00 2473 1.2 684 n/a 190 588.2 0.00 998.4 0.0 3.0</td><td>190 0.00 100.00 1769.7 10.8 0.0 34.5 nåa nåa nåa 190 0.00 998.0 967.3 7.0 0.0 34.1 68.6 nåa 190 78.6 378.0 893.3 5.6 0.0 247.5 112.9 68.6 nåa 190 58.62 0.00 998.4 0.0 3.0 3.0 3.0 3.2 112.9 68.6 nåa 190 156.8 0.00 1180.2 1.3 2.8 4.6 112.9 9.3 190 156.0 0.00 1180.2 1.3 3.0 112.9 12.0 190 156.0 0.00 1180.2 1.3 1.4<</td><td>199 0.00 100.00 100.00 100.00 100.00 100.00 100.00 993.00 967.3 7.00 0.00 34.12 68.6 n/a 199 78.16 378.60 983.3 3.5 7.00 34.12 68.6 n/a 190 78.16 378.60 983.3 3.5 1.20 34.2 61.0 n/a 190 285.83 0.00 1282.3 1.3 2.4 1.42 1.6 <</td><td></td><td>67580</td><td>7821</td><td>7.6</td><td>0.0</td><td>297.5</td><td>n/a</td><td>n/a</td><td></td><td>n/a</td><td>n/a n/a</td><td></td><td>n/a</td><td>n/a n/a</td><td>n/a n/a 44.3</td><td>n/a n/a 44.3 COOL</td></td<>	190 0.00 1908 7697 108 0.00 1412 6846 n/a 190 0.00 998.0 9673 7.0 0.00 3412 6846 n/a 190 0.00 988.0 9673 7.0 0.00 2473 1.2 684 n/a 190 588.2 0.00 998.4 0.0 3.0	190 0.00 100.00 1769.7 10.8 0.0 34.5 nåa nåa nåa 190 0.00 998.0 967.3 7.0 0.0 34.1 68.6 nåa 190 78.6 378.0 893.3 5.6 0.0 247.5 112.9 68.6 nåa 190 58.62 0.00 998.4 0.0 3.0 3.0 3.0 3.2 112.9 68.6 nåa 190 156.8 0.00 1180.2 1.3 2.8 4.6 112.9 9.3 190 156.0 0.00 1180.2 1.3 3.0 112.9 12.0 190 156.0 0.00 1180.2 1.3 1.4<	199 0.00 100.00 100.00 100.00 100.00 100.00 100.00 993.00 967.3 7.00 0.00 34.12 68.6 n/a 199 78.16 378.60 983.3 3.5 7.00 34.12 68.6 n/a 190 78.16 378.60 983.3 3.5 1.20 34.2 61.0 n/a 190 285.83 0.00 1282.3 1.3 2.4 1.42 1.6 <		67580	7821	7.6	0.0	297.5	n/a	n/a		n/a	n/a n/a		n/a	n/a n/a	n/a n/a 44.3	n/a n/a 44.3 COOL
1980 0.00 99280 9673 7.0 0.0 3412 68.6 n/a 1990 78.16 378.00 893.3 5.6 0.0 2475 1027 61.0 1990 58.88.2 0.00 938.4 0.0 3.0 128.5 11.3 2.8 4.61 15.20 93.3 1990 1580.8 0.00 1280.2 1.3 2.8 4.61 15.20 93.3 1991 1560.0 0.00 1380.2 1.5 136.7 92.6 17.1 475.5 1991 2485.0 0.00 1680.0 2381.7 36.4 12.2 36.8 5.0 1991 2485.0 0.00 112.2 36.4 11.2 36.8 11.2 36.8 11.2 36.8 11.2 36.8 11.2 5.0 11.2 5.0 11.2 11.2 11.2 11.2 5.0 11.2 11.2 11.2 11.2 11.2 11.2 11.2 1	1900 0.00 998,80 967.3 7.0 0.0 341.2 68.6 n/a 1900 78.16 378.60 893.3 5.6 0.00 247.3 1127 61.8 1900 58.58.5 0.00 999.4 0.00 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0 1.2 3.0 1.3 2.8 41.61 1.5 9.3 1.0 9.3 1.0 1.0 9.3 1.0 1.0 9.3 1.0 1.2 1.3 2.8 41.61 1.5 9.3 1.1 1.0 9.3 1.0 1.2 1.3 1.3 1.3 1.2 1.4 41.5 1.4 41.5 1.4 41.5 9.2 1.1 41.5 9.4 41.6 41.5 9.4 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3 9.3	1990 0.00 998.80 967.3 7.0 0.0 341.2 68.6 n/a 1990 78.16 378.60 699.33 5.6 0.0 247.3 102.7 102.7 61.8 1990 78.16 378.60 693.4 0.0 3.0 3.0 13.2 11.2 12.2 <	1990 0.00 99,830 9673 7.0 0.00 341.2 68.6 n/a 1990 78.16 378.60 893.3 5.6 0.00 247.5 10\$\$7 61.9 1990 58.82 0.00 958.4 0.00 132.5 1.22 12.0 61.9 1990 158.08 0.00 1182.5 1.3 2.8 4.44 155.3 1741 47.5 1991 258.70 0.00 1180.2 1.13 36.4 152.9 1741 47.5 1991 248.50 0.00 1615.0 6.9 112.2 2.3 1741 47.5 1991 248.50 0.00 158.6 2.5 1.1 38.4 158.7 36.6 1991 244.00 0.00 158.2 2.5 1.1 44.1 47.5 1.2 1991 244.00 0.00 158.2 1.2 1.2 1.2 0.0 1.2 1.2 1.2 1.2 </td <td>1990 0.00 99280 9673 7.0 0.0 3412 68.6 n/4 1990 78.16 378.60 893.3 3.6 0.0 247.5 10.7 61.4 1990 38.85 0.00 1382.3 1.3 1.2 1.2 1.4 61.4 1.4 61.4 1.4<</td> <td>1990 0,000 998,80 967.3 7.0 0.0 341,2 68.6 n/a 1990 78.46 378.60 893.3 3.6 0.0 247.5 10.27 61.4 1990 38.85 0.00 1328.2 1.3 1.22 93.3 1990 186.26 0.00 1138.2 1.3 2.4 1.22 93.3 1990 186.26 0.00 1188.2 1.3 2.8 1.3 1.4 4.5 1.0 1991 2485.9 0.00 1.65.0 6.9 111.2 9.45 1.2 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 <</td> <td></td> <td>1090.80</td> <td>7.69.7</td> <td>10.8</td> <td>0.0</td> <td>3450</td> <td>s/u</td> <td>n/a</td> <td></td> <td>n/a</td> <td>n/a n/a</td> <td></td> <td>n/a</td> <td>n/a n/a</td> <td>π/a π/a 37.2</td> <td>n/a n/a 37.2 COOL</td>	1990 0.00 99280 9673 7.0 0.0 3412 68.6 n/4 1990 78.16 378.60 893.3 3.6 0.0 247.5 10.7 61.4 1990 38.85 0.00 1382.3 1.3 1.2 1.2 1.4 61.4 1.4 61.4 1.4<	1990 0,000 998,80 967.3 7.0 0.0 341,2 68.6 n/a 1990 78.46 378.60 893.3 3.6 0.0 247.5 10.27 61.4 1990 38.85 0.00 1328.2 1.3 1.22 93.3 1990 186.26 0.00 1138.2 1.3 2.4 1.22 93.3 1990 186.26 0.00 1188.2 1.3 2.8 1.3 1.4 4.5 1.0 1991 2485.9 0.00 1.65.0 6.9 111.2 9.45 1.2 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 1.4 4.5 <		1090.80	7.69.7	10.8	0.0	3450	s/u	n/a		n/a	n/a n/a		n/a	n/a n/a	π/a π/a 37.2	n/a n/a 37.2 COOL
1990 78.16 318.60 993.3 5.6 0.0 24.15 10.20 93.4 0.0 3.0 3.0 12.20 93.3 1990 158.62 0.00 1282.5 1.3 2.8 4.54 122.9 93.3 1990 1560.20 0.00 1282.5 1.3 2.8 4.54 15.29 93.3 1991 2456.30 0.00 1802.5 1.5 136.7 92.6 1741 47.55 1991 138.50 0.00 158.6 2.8 1.12 94.5 1741 47.55 1991 138.50 0.00 158.6 2.0 1.12 94.5 1741 47.5 1991 138.60 0.00 158.6 2.5 1.1 387.8 15.5 9.5 1991 139.0 1158.2 2.5 1.1 387.8 15.5 9.0 1991 0.00 1258.2 2.5 0.0 1.6 1.0 0.0 1.0<	1900 78.16 318.60 893.3 5.6 0.0 24.15 10.20 93.4 6.1 4.1 6.1 6.1 1900 385.82 0.00 939.4 0.0 3.0 122.3 1220 93.3 1900 1560.30 0.00 1282.5 1.3 2.8 4.5 15.2 93.3 1901 2456.30 0.00 1802.5 1.5 136.7 92.6 17.4 47.5 1901 3464.00 0.00 1802.5 1.5 136.7 92.6 17.4 47.5 1901 2435.80 0.00 1615.0 6.9 112.2 92.8 17.1 47.5 17.1 47.5 1991 2435.80 0.00 1586.4 2.0 112.2 94.5 11.0 48.6 11.0 47.5 11.6 47.5 11.6 47.5 11.6 47.5 11.6 47.5 11.6 47.5 11.6 47.5 11.6 47.5 11.6	1990 78.16 318.60 893.3 3.6 0.0 241.5 108.7 61.9 1990 58.82 0.00 939.4 0.0 3.0 12.2 12.2 12.2 93.3 1990 150.88 0.00 12.82.5 1.3 2.8 41.61 156.3 2701 1991 256.79 0.00 1802.5 15.6 134.7 92.5 174.1 475.5 1991 2435.9 0.00 165.0 6.9 112.2 85.2 174.1 475.5 1991 2435.9 0.00 165.0 2.0 112.2 85.3 174.1 475.5 1991 2435.9 0.00 1556.4 2.0 2.2 17.0 87.8 6.9 17.1 475.5 1991 2435.9 0.00 1556.4 2.0 2.2 17.0 86.5 17.0 87.8 6.9 1991 744.0 1.0 1.25.4 1.3 85.0 17.1	1990 78.16 378.60 89.3.3 5.6 0.0 24.75 1027 61.9 1990 58.83.2 0.00 998.4 0.0 3.0 120.7 93.3 120.7 120.9 93.3 1990 1560.80 0.00 1282.5 1.3 2.8 4.6 1.56 9.3 3.0 1991 2567.90 0.00 1802.5 1.56 1.3 9.26 17.41 475.5 1991 2485.0 0.00 1802.4 2.0 1.2 1.2 3.64.5 17.41 475.5 1991 2485.0 0.00 15.66.4 2.0 2.3 1.88.7 3.64.8 3.04.8 3.04.8 1991 2485.0 0.00 15.66.4 2.0 2.3 1.88.7 3.64.8 3.04.8 3.04.8 1991 2485.0 0.00 15.66.4 2.0 2.3 1.14.9 3.64.8 3.04.8 3.04.8 3.04.8 3.04.8 3.04.8 3.04.8 3.0	1990 78.16 378.60 893.3 3.6 0.0 247.5 10247 61.9 1990 58.82 0.00 939.4 0.0 3.0 132.7 122.9 93.3 1990 1560.80 0.00 1282.3 1.3 1.2 122.9 93.3 1991 1560.80 0.00 1802.3 1.5 1.2 1.2 1.2 1.2 1991 2485.0 0.00 1802.3 1.1 364.3 1.2 1.	1990 78.16 99.34 5.6 0.0 21.75 11.20 91.3 1990 58.882 0.00 93.94 0.0 3.0 3.0 3.1 1.25 1.22 9.3 1990 1858.2 0.00 1.82.5 1.3 2.8 1.3 1.5 1.2 9.3 1991 256.90 0.00 1.88.7 3.1 3.6 1.7 4.5 2.0 1991 248.50 0.00 1.65.0 6.9 11.2 9.45 1.7 4.5 1992 248.00 0.00 1.65.0 6.9 11.2 9.45 1.8 3.0 1991 248.00 0.00 1.65.0 6.9 1.1 3.6 1.6 1.6 9.6 1992 244.00 0.00 1.65.0 2.5 1.1 3.6 1.6 9.6 1.1 1.6 1.6 9.6 1.1 1.6 1.6 9.6 1.1 1.6 1.6 1.1		08'666	967.3	7.0	0.0	341.2	9.89	n/a	3	0:0	0,0 100.2	-	1002	1002 141.9	1002 141.9 39.7	1002 141.9 39.7 COOL 4.03
1990 38882 0.00 99944 0.0 3.0 41.20 93.3 1990 1580.80 0.00 1180.5 1.3 2.8 4.46 15.0 93.4 1990 2567.90 0.00 1880.5 1.5 136.7 174.1 475.5 1991 3404.00 0.00 1861.5 6.9 112.2 945.7 118.5 57.8 1991 2435.30 0.00 1615.0 6.9 112.2 945.7 118.5 505.8 1991 1882.0 0.00 1586.4 2.5 1.1 387.8 165.8 673.3 1991 1882.0 0.00 1586.4 2.5 1.1 387.8 165.8 1.2 185.8 165.8 1.1 185.8 165.8 1.1 185.7 185.8 165.8 1.1 185.8 165.8 1.1 1.1 175.9 1.1 1.1 1.1 1.1 1.1 1.1 1.1 1.1 1.1 1.1	1990 38882 0.00 9994 0.0 3.0 4.54 1120 93.3 1990 158030 0.00 1180.3 1.3 2.8 4.54 15.6 9.3 1990 2567.90 0.00 1800.3 1.56 136.7 92.6 1741 47.5 1991 3404.00 0.00 1800.3 3.11 364.5 1122 92.6 1741 47.5 1991 2435.30 0.00 1615.0 6.9 112.2 94.57 138.5 505.8 1991 2435.3 0.00 1586.4 2.0 112.2 94.57 138.5 126.5 1991 2436.0 0.00 1586.4 2.0 0.0 10.6 0.0 125.4 125.5 10.0 1991 2460 120.4 13.3 0.0 136.7 12.4 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0	1990 38882 0.00 9994 0.0 3.0 3.0 1.20 93.3 1990 15803 0.00 1282.3 1.3 2.8 4.46 152.9 93.3 1990 156030 0.00 1882.3 1.5 136.7 174.1 475.2 1991 3404.00 0.00 1882.3 3.1 364.5 112.2 945.7 174.1 475.5 1991 2435.30 0.00 1586.4 2.0 112.2 945.7 138.5 358.8 1991 1882.0 0.00 1586.4 2.0 123.7 138.5 365.8 1991 1882.0 0.00 1586.4 15.2 0.0 136.5 11.1 387.8 136.5 156.0 1991 2440.0 150.0 158.2 26.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 0.0 156.5 0.0	1990 535.82 0.00 939.4 0.0 3.0 93.4 0.0 3.0 93.4 0.0 3.0 93.4 1.3 2.8 41.61 15.0 19.0 19.0 15.0 1.3 2.8 41.61 15.6 17.1 47.5 17.1 47.5 19.1 47.5 17.1 47.5 19.1 47.6 17.6 17.6 17.1 47.5 17.1	1990 58582 0.00 98944 0.00 3.0 122.0 932.4 1.3 2.8 4.61 125.0 93.3 1990 1560.80 0.00 1126.2 1.3 2.8 4.61 156.3 270.1 1990 2567.90 0.00 1802.5 1.5 1.5 1.5 273.1 1991 3464.00 0.00 1.556.4 2.0 1.12.2 94.7 1.85.3 273.1 1991 2485.0 0.00 1.556.4 2.0 2.3 1.11.2 94.7 1.85.3 2.04.8 1991 744.00 0.00 1.556.4 2.0 2.3 1.11. 387.8 1.55.3 1.25.3 1991 744.00 0.00 9.06 2.5 0.0 1.96.2 1.14.9 0.0 1991 7.14.00 0.00 1.14.3 1.14.9 0.0 1.14.9 0.0 1.14.9 0.0 1.14.9 0.0 1.14.9 0.0 1.14.9 0.0	1990 5858.2 0.00 9994.4 0.00 35.0 175.0 172.0 93.3 1990 1560.80 0.00 1126.3 1.3 2.8 4.461 156.3 270.1 1990 1560.80 0.00 1180.3 1.5 1.27 1.74.1 4.75.5 1991 3494.00 0.00 1.381.7 3.1.1 364.3 1.27.8 1.62.8 6.73.1 1991 1.445.0 0.00 1.155.4 2.0 1.11.2 94.7 1.88.7 3.65.6 1991 1.445.0 0.00 1.556.4 2.0 2.3 1.11 387.8 1.12.2 3.65.6 1991 1.440.0 0.00 9.06 2.5 0.0 1.96.2 0.0 1.96.2 0.0 1991 0.00 1.347.1 1.37.8 1.5 0.0 1.96.2 0.0 1.96.2 1.10.9 9.0 1991 0.00 1.347.1 1.34.2 0.0 1.34.2 1.10.9	1990	\dashv	893.3	5.6	0.0	247.5	102.7	61.0	9.6	0	9 41.5	-	41.5	41.5 46.7	41.5 46.7 38.6	41.5 46.7 38.6 COOL/HEAT
1990 1560.80 0.00 128C.3 1.3 2.8 4161 156.3 2701 1990 2567.90 0.00 188C.3 15.6 1367 92.6 1741 475.5 1991 3404.00 0.00 238L.7 31.1 364.5 1122 92.6 1741 475.5 1991 2435.30 0.00 1556.4 2.0 223.7 812.5 188.7 365.8 1991 1885.0 0.00 1556.4 2.5 1.1 387.8 185.7 365.8 1991 744.00 0.00 970.6 2.5 1.1 387.8 185.7 365.8 1991 0.00 120.90 125.2 0.0 1.6 0.0 1.0 0.0 1991 0.00 120.10 125.4 13.3 0.0 1.6 0.0 1.6 0.0 1.0 0.0 0.0 1.0 0.0 1.0 0.0 0.0 1.0 0.0 1.0 0	1990 1560.80 0.00 1282.5 1.3 2.8 4161 156.3 2701 1990 2567.90 0.00 1880.5 15.6 136.7 92.6 1741 475.5 1991 3404.00 0.00 2381.7 31.1 364.5 1122 92.6 1741 475.5 1991 2435.30 0.00 1615.0 6.9 112.2 945.7 188.7 365.8 1991 1882.0 0.00 1586.4 2.0 112.2 188.7 365.8 1991 1882.0 0.00 970.6 2.5 1.1 387.8 156.0 0.0 1991 0.00 1280.2 26.3 0.0 16.0 0.0 15.6 1.0 0.0 1991 0.00 127.0 13.3 0.0 16.2 0.0 16.2 0.0 16.0 0.0 1991 0.00 127.0 13.3 1.4 1.0 0.0 1.0 0.0 <t< td=""><td>1990 1560.80 0.00 1282.5 1.3 2.8 4.44 156.3 2701 1990 2567.90 0.00 1802.5 1.56 1367 992.6 1741 475.5 1991 3400.00 0.00 1581.7 31.1 364.5 1127.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 1112.2 945.7 138.5 505.8 1991 1835.0 0.00 1650.0 2.5 1.1 387.8 156.3 156.5 1991 1840.0 0.00 1586.4 2.5 1.1 387.8 156.5 156.5 1991 0.00 1367.1 158.2 0.0 441.0 10.7 0.0 1991 0.00 1367.1 137.8 15.2 0.0 166.7 0.0 1991 0.00 1367.0 13.3 0.0 136.8 37.6 118.7 118.7 1991 0.00 1367.2 <td< td=""><td>1900 1560.80 0.00 128C.3 1.3 2.8 4.461 156.3 2701 1900 2567.90 0.00 188C.3 15.6 136.7 94.5 174.1 475.3 1901 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1901 3435.0 0.00 1615.0 6.9 112.2 94.7 138.5 505.8 1991 1888.90 0.00 1556.4 2.0 23.7 81.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 0.0 1991 744.00 0.00 158.2 26.5 0.0 156.5 0.0 156.5 0.0 1991 0.00 158.2 15.2 0.0 156.2 0.0 156.5 0.0 160.0 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0</td><td>1990 1560.80 0.00 1282.5 1.3 2.8 416.1 156.3 270.1 1990 2567.90 0.00 1802.5 15.6 136.7 992.6 174.1 475.5 1991 3445.00 0.00 2381.7 31.1 364.5 129.8 174.1 475.5 1991 2455.0 0.00 1655.0 6.9 112.2 945.7 118.8 50.88 1991 1858.90 0.00 1506.4 2.0 23.7 118.8 50.88 1991 7440 0.00 970.6 2.5 1.1 387.8 15.6 0.0 1991 31.60 970.6 2.5 0.0 1.3 36.6 0.0 1.3 36.6 1.1 36.8 1.2 1.2 1.2 1.2 1.2 1.2 1.2 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.2</td></td<></td></t<> <td>1990 1560,50 0.00 1126.5 1.3 2.8 4.46 156.3 2701 1990 2567,90 0.00 1802.5 15.6 134.7 992.6 1741 473.5 1991 2485.50 0.00 1615.0 6.9 112.2 945.7 188.5 50.88 1991 2485.6 0.00 1556.4 2.0 112.2 945.7 188.5 50.88 1991 2485.0 0.00 1556.4 2.0 2.3 112.2 945.7 188.5 50.88 1991 346.0 0.00 1556.4 2.0 1.1 86.7 6.0 0.0 1991 346.0 1.1 87.2 85.0 0.0 1.1 8.6 1.1 8.6 1.1 8.6 1.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0</td> <td></td> <td></td> <td>939.4</td> <td>0.0</td> <td>3.0</td> <td>32.5.7</td> <td>1229</td> <td>93.3</td> <td>70.7</td> <td>7</td> <td>7 0.0</td> <td></td> <td>0.0</td> <td>0.0 0.0</td> <td>0.0 0.0 33.6</td> <td>0.0 0.0 33.6 HEAT</td>	1990 1560.80 0.00 1282.5 1.3 2.8 4.44 156.3 2701 1990 2567.90 0.00 1802.5 1.56 1367 992.6 1741 475.5 1991 3400.00 0.00 1581.7 31.1 364.5 1127.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 1112.2 945.7 138.5 505.8 1991 1835.0 0.00 1650.0 2.5 1.1 387.8 156.3 156.5 1991 1840.0 0.00 1586.4 2.5 1.1 387.8 156.5 156.5 1991 0.00 1367.1 158.2 0.0 441.0 10.7 0.0 1991 0.00 1367.1 137.8 15.2 0.0 166.7 0.0 1991 0.00 1367.0 13.3 0.0 136.8 37.6 118.7 118.7 1991 0.00 1367.2 <td< td=""><td>1900 1560.80 0.00 128C.3 1.3 2.8 4.461 156.3 2701 1900 2567.90 0.00 188C.3 15.6 136.7 94.5 174.1 475.3 1901 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1901 3435.0 0.00 1615.0 6.9 112.2 94.7 138.5 505.8 1991 1888.90 0.00 1556.4 2.0 23.7 81.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 0.0 1991 744.00 0.00 158.2 26.5 0.0 156.5 0.0 156.5 0.0 1991 0.00 158.2 15.2 0.0 156.2 0.0 156.5 0.0 160.0 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0</td><td>1990 1560.80 0.00 1282.5 1.3 2.8 416.1 156.3 270.1 1990 2567.90 0.00 1802.5 15.6 136.7 992.6 174.1 475.5 1991 3445.00 0.00 2381.7 31.1 364.5 129.8 174.1 475.5 1991 2455.0 0.00 1655.0 6.9 112.2 945.7 118.8 50.88 1991 1858.90 0.00 1506.4 2.0 23.7 118.8 50.88 1991 7440 0.00 970.6 2.5 1.1 387.8 15.6 0.0 1991 31.60 970.6 2.5 0.0 1.3 36.6 0.0 1.3 36.6 1.1 36.8 1.2 1.2 1.2 1.2 1.2 1.2 1.2 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.2</td></td<>	1900 1560.80 0.00 128C.3 1.3 2.8 4.461 156.3 2701 1900 2567.90 0.00 188C.3 15.6 136.7 94.5 174.1 475.3 1901 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1901 3435.0 0.00 1615.0 6.9 112.2 94.7 138.5 505.8 1991 1888.90 0.00 1556.4 2.0 23.7 81.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 0.0 1991 744.00 0.00 158.2 26.5 0.0 156.5 0.0 156.5 0.0 1991 0.00 158.2 15.2 0.0 156.2 0.0 156.5 0.0 160.0 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0 156.5 0.0	1990 1560.80 0.00 1282.5 1.3 2.8 416.1 156.3 270.1 1990 2567.90 0.00 1802.5 15.6 136.7 992.6 174.1 475.5 1991 3445.00 0.00 2381.7 31.1 364.5 129.8 174.1 475.5 1991 2455.0 0.00 1655.0 6.9 112.2 945.7 118.8 50.88 1991 1858.90 0.00 1506.4 2.0 23.7 118.8 50.88 1991 7440 0.00 970.6 2.5 1.1 387.8 15.6 0.0 1991 31.60 970.6 2.5 0.0 1.3 36.6 0.0 1.3 36.6 1.1 36.8 1.2 1.2 1.2 1.2 1.2 1.2 1.2 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.3 1.2 1.3 1.2 1.3 1.2 1.3 1.2	1990 1560,50 0.00 1126.5 1.3 2.8 4.46 156.3 2701 1990 2567,90 0.00 1802.5 15.6 134.7 992.6 1741 473.5 1991 2485.50 0.00 1615.0 6.9 112.2 945.7 188.5 50.88 1991 2485.6 0.00 1556.4 2.0 112.2 945.7 188.5 50.88 1991 2485.0 0.00 1556.4 2.0 2.3 112.2 945.7 188.5 50.88 1991 346.0 0.00 1556.4 2.0 1.1 86.7 6.0 0.0 1991 346.0 1.1 87.2 85.0 0.0 1.1 8.6 1.1 8.6 1.1 8.6 1.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0 9.0			939.4	0.0	3.0	32.5.7	1229	93.3	70.7	7	7 0.0		0.0	0.0 0.0	0.0 0.0 33.6	0.0 0.0 33.6 HEAT
1990 2567-90 0.00 1880.3 1156 136.7 992.6 174.1 475.2 1991 3450.0 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.5 0.00 1615.0 6.9 112.2 945.7 138.5 503.8 1991 1883.90 0.00 1598.4 2.0 2.3 1.1 387.8 156.9 355.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.9 126.5 1991 744.00 10.00 970.6 2.5 0.0 156.0 0.0 1991 744.00 1387.8 15.2 0.0 16.0 0.0 1991 0.00 120.90 125.4 0.0 13.4 0.0 16.0 0.0 1991 0.00 124.0 1.2 0.0 13.4 18.7 118.1 118.1 1992 2.456.0 0.00 124.9 </td <td>1990 2567-90 0.00 1880.3 15.6 136.7 992.6 17.11 475.5 1991 3440.0 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2455.5 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 1858.90 0.00 1596.4 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 126.5 1991 744.00 0.00 970.6 2.5 0.0 188.7 126.5 126.5 1991 744.00 10.09.90 15.2 26.5 0.0 10.0 0.0 126.5 0.0 126.5 0.0 1991 0.00 120.00 125.2 13.3 0.0 136.5 13.4 13.4 118.1 118.1 1991 246.50 0.00 125.4 14.4 10.0</td> <td>1990 2567-90 0.00 1880.3 15.6 13.67 992.6 17.11 475.5 1991 3445.0 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.5 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 1885.90 0.00 1598.4 2.0 2.3 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 0.0 1991 744.0 1.0 872.7 853.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0<td>1990 2567.90 0.00 1880.3 15.6 136.7 992.6 174.1 475.2 1991 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 18820 0.00 1586.4 2.0 2.2 1.1 387.8 156.8 673.3 1991 18820 0.00 970.6 2.5 1.1 387.8 156.0 6.0 1991 744.0 0.00 970.6 2.5 1.1 388.7 6.1 6.0 1991 744.0 137.1 13.3 0.0 1.6 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0</td><td>1990 2567-90 0.00 1880.3 15.6 13.67 992.6 17.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.3 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 111.2 945.7 138.5 505.8 1991 1888.90 0.00 165.0 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 0.0 188.7 36.0 0.0 1991 744.00 1.0 1.282.2 2.5 0.0 441.5 1.0 8.6 1992 0.00 1.347.1 1.33 0.0 441.5 1.0 8.6 1991 0.00 1.347.1 1.33 0.0 441.5 1.0 9.6 1992 0.00 1.347.2 1.34<!--</td--><td>1992 2567.90 0.00 1802.3 1.56 156.7 99.26 174.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.5 129.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 112.2 94.7 188.5 503.8 1991 1838.0 0.00 1556.4 2.0 23.7 188.7 365.6 1991 744.00 0.00 976.6 2.5 1.1 387.8 156.5 156.5 1991 744.00 0.00 976.6 2.5 0.0 188.7 156.5 0.0 156.6 0.0 1991 344.00 10.09.9 1.28.2 2.6.5 0.0 156.7 1.0 0.0 1991 344.00 1.00.9 1.28.2 2.6.5 0.0 1.0 0.0 0.0 1.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td><td>1990</td><td></td><td>1282.5</td><td>1.3</td><td>2.8</td><td>4161</td><td>1563</td><td>270.1</td><td>2167</td><td>-</td><td>.7 0.0</td><td>_</td><td>0.0</td><td>0.0 0.0</td><td>0.0 0.0 41.3</td><td>0.0 0.0 41.3 HEAT</td></td></td>	1990 2567-90 0.00 1880.3 15.6 136.7 992.6 17.11 475.5 1991 3440.0 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2455.5 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 1858.90 0.00 1596.4 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 126.5 1991 744.00 0.00 970.6 2.5 0.0 188.7 126.5 126.5 1991 744.00 10.09.90 15.2 26.5 0.0 10.0 0.0 126.5 0.0 126.5 0.0 1991 0.00 120.00 125.2 13.3 0.0 136.5 13.4 13.4 118.1 118.1 1991 246.50 0.00 125.4 14.4 10.0	1990 2567-90 0.00 1880.3 15.6 13.67 992.6 17.11 475.5 1991 3445.0 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.5 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 1885.90 0.00 1598.4 2.0 2.3 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 0.0 1991 744.0 1.0 872.7 853.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 <td>1990 2567.90 0.00 1880.3 15.6 136.7 992.6 174.1 475.2 1991 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 18820 0.00 1586.4 2.0 2.2 1.1 387.8 156.8 673.3 1991 18820 0.00 970.6 2.5 1.1 387.8 156.0 6.0 1991 744.0 0.00 970.6 2.5 1.1 388.7 6.1 6.0 1991 744.0 137.1 13.3 0.0 1.6 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0</td> <td>1990 2567-90 0.00 1880.3 15.6 13.67 992.6 17.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.3 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 111.2 945.7 138.5 505.8 1991 1888.90 0.00 165.0 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 0.0 188.7 36.0 0.0 1991 744.00 1.0 1.282.2 2.5 0.0 441.5 1.0 8.6 1992 0.00 1.347.1 1.33 0.0 441.5 1.0 8.6 1991 0.00 1.347.1 1.33 0.0 441.5 1.0 9.6 1992 0.00 1.347.2 1.34<!--</td--><td>1992 2567.90 0.00 1802.3 1.56 156.7 99.26 174.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.5 129.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 112.2 94.7 188.5 503.8 1991 1838.0 0.00 1556.4 2.0 23.7 188.7 365.6 1991 744.00 0.00 976.6 2.5 1.1 387.8 156.5 156.5 1991 744.00 0.00 976.6 2.5 0.0 188.7 156.5 0.0 156.6 0.0 1991 344.00 10.09.9 1.28.2 2.6.5 0.0 156.7 1.0 0.0 1991 344.00 1.00.9 1.28.2 2.6.5 0.0 1.0 0.0 0.0 1.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td><td>1990</td><td></td><td>1282.5</td><td>1.3</td><td>2.8</td><td>4161</td><td>1563</td><td>270.1</td><td>2167</td><td>-</td><td>.7 0.0</td><td>_</td><td>0.0</td><td>0.0 0.0</td><td>0.0 0.0 41.3</td><td>0.0 0.0 41.3 HEAT</td></td>	1990 2567.90 0.00 1880.3 15.6 136.7 992.6 174.1 475.2 1991 3404.00 0.00 2381.7 31.1 364.5 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 112.2 945.7 138.5 505.8 1991 18820 0.00 1586.4 2.0 2.2 1.1 387.8 156.8 673.3 1991 18820 0.00 970.6 2.5 1.1 387.8 156.0 6.0 1991 744.0 0.00 970.6 2.5 1.1 388.7 6.1 6.0 1991 744.0 137.1 13.3 0.0 1.6 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0	1990 2567-90 0.00 1880.3 15.6 13.67 992.6 17.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.3 157.8 162.8 673.3 1991 2435.30 0.00 1615.0 6.9 111.2 945.7 138.5 505.8 1991 1888.90 0.00 165.0 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 0.0 188.7 36.0 0.0 1991 744.00 1.0 1.282.2 2.5 0.0 441.5 1.0 8.6 1992 0.00 1.347.1 1.33 0.0 441.5 1.0 8.6 1991 0.00 1.347.1 1.33 0.0 441.5 1.0 9.6 1992 0.00 1.347.2 1.34 </td <td>1992 2567.90 0.00 1802.3 1.56 156.7 99.26 174.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.5 129.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 112.2 94.7 188.5 503.8 1991 1838.0 0.00 1556.4 2.0 23.7 188.7 365.6 1991 744.00 0.00 976.6 2.5 1.1 387.8 156.5 156.5 1991 744.00 0.00 976.6 2.5 0.0 188.7 156.5 0.0 156.6 0.0 1991 344.00 10.09.9 1.28.2 2.6.5 0.0 156.7 1.0 0.0 1991 344.00 1.00.9 1.28.2 2.6.5 0.0 1.0 0.0 0.0 1.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0</td> <td>1990</td> <td></td> <td>1282.5</td> <td>1.3</td> <td>2.8</td> <td>4161</td> <td>1563</td> <td>270.1</td> <td>2167</td> <td>-</td> <td>.7 0.0</td> <td>_</td> <td>0.0</td> <td>0.0 0.0</td> <td>0.0 0.0 41.3</td> <td>0.0 0.0 41.3 HEAT</td>	1992 2567.90 0.00 1802.3 1.56 156.7 99.26 174.1 475.2 1991 3440.00 0.00 2381.7 31.1 364.5 129.8 162.8 673.3 1991 2435.0 0.00 1615.0 6.9 112.2 94.7 188.5 503.8 1991 1838.0 0.00 1556.4 2.0 23.7 188.7 365.6 1991 744.00 0.00 976.6 2.5 1.1 387.8 156.5 156.5 1991 744.00 0.00 976.6 2.5 0.0 188.7 156.5 0.0 156.6 0.0 1991 344.00 10.09.9 1.28.2 2.6.5 0.0 156.7 1.0 0.0 1991 344.00 1.00.9 1.28.2 2.6.5 0.0 1.0 0.0 0.0 1.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	1990		1282.5	1.3	2.8	4161	1563	270.1	2167	-	.7 0.0	_	0.0	0.0 0.0	0.0 0.0 41.3	0.0 0.0 41.3 HEAT
1991 34404.00 0.000 2381.7 31.1 364.5 1122 9457 158.5 673.3 1991 2435.5 0.000 1615.0 6.9 1122 9457 138.5 505.8 1991 1888.90 0.00 1596.4 2.0 2.3 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.5 126.5 1991 744.00 10.00 970.6 2.5 1.1 387.8 156.5 126.5 1991 0.00 118.7 15.2 0.0 386.7 61.0 0.0 1991 0.00 127.0 13.3 0.0 141.6 16.7 0.0 1991 0.00 125.0 12.2 0.0 141.6 16.7 0.0 1991 0.00 125.0 12.9 2.5 0.0 350.5 131.8 324.6 1992 24.55.1 0.00	1991 3440.00 0.000 238.7 3.1. 364.5 1122 9457 158.5 673.3 1991 2435.5 0.00 1615.0 6.9 1122 9457 138.5 505.8 1991 1885.90 0.00 1598.4 2.0 2.3 1.1 387.8 156.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 126.5 126.5 1991 744.00 10.00 970.6 2.5 1.1 387.8 126.5 126.5 1991 70.00 115.00 15.2 0.0 196.0 126.0 0.0 126.0 0.0 126.0 0.0 1991 0.00 120.00 125.4 13.3 0.0 141.1 16.7 0.0 196.2 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1 118.1	1991 3446.00 0.00 238.7 31.1 364.5 1127 9457 15.8 673.3 1991 2435.5 0.00 1615.0 6.9 1112 9457 138.5 505.8 1991 1858.9 0.00 1556.4 2.0 23.7 813.2 188.7 365.6 1991 744.0 0.00 970.6 2.5 1.1 387.8 126.5 126.5 1991 51.60 211.90 872.7 85.0 0.0 156.5 126.5	1991 3446.00 0.00 2381.7 31.1 364.3 1529.8 162.8 673.3 1991 2435.20 0.00 1615.0 6.9 112.2 9457 138.5 505.8 1991 1858.9 0.00 1596.4 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.8.3 126.5 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.8.3 126.5 1991 744.00 1.00 970.6 2.5 0.0 1962.0 7.1.0 0.0 1991 0.00 1.347.8 15.2 0.0 441.5 10.7 0.0 1991 0.00 1.287.8 15.2 0.0 441.5 10.7 0.0 1991 1.347.0 1.347.4 1.33 0.0 441.5 10.7 0.0 1992 1.447.0 1.348.7 1.441.0	1991 34404.00 0.000 2381.7 31.1 364.5 1122 9457 138.5 673.3 1991 2435.5 0.00 1615.0 6.9 1112.2 9457 138.5 503.8 1991 1885.90 0.00 1615.0 2.0 2.3 1.1 387.8 136.5 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.5 126.5 1991 744.00 10.00 970.6 15.3 0.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 1.0 0.0 1.0 0.0 1.0 1.0 1.0 0.0 1.0 1.0 1.0 0.0 1.0 0.0 1.0 1.0 1.0 1.0 1.0 </td <td>1991 34404.00 0.00 2381.7 31.1 364.5 1227 6.28 6.73 1991 2435.50 0.00 1615.0 6.9 112.2 94.57 118.5 5038 1991 1888.90 0.00 1586.4 2.0 23.7 113.5 5038 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.5 126.5 1992 51.60 211.90 872.7 85.0 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 0.0 126.5 0.0 0.0 126.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.</td> <td>1990</td> <td></td> <td>1802.5</td> <td>15.6</td> <td>1367</td> <td>9766</td> <td>174.1</td> <td>475.5</td> <td>3203</td> <td></td> <td>0.0</td> <td></td> <td>0.0</td> <td>0.0 0.0</td> <td>0.0 0.0 37.8</td> <td>0.0 0.0 37.8 HEAT</td>	1991 34404.00 0.00 2381.7 31.1 364.5 1227 6.28 6.73 1991 2435.50 0.00 1615.0 6.9 112.2 94.57 118.5 5038 1991 1888.90 0.00 1586.4 2.0 23.7 113.5 5038 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.5 126.5 1992 51.60 211.90 872.7 85.0 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 126.5 0.0 0.0 126.5 0.0 0.0 126.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.	1990		1802.5	15.6	1367	9766	174.1	475.5	3203		0.0		0.0	0.0 0.0	0.0 0.0 37.8	0.0 0.0 37.8 HEAT
1991 2435.50 0.00 1615.0 6.9 112.2 9457 1385 5088 1991 1888.90 0.00 1586.4 2.0 23.7 813.2 1887 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.63 126.5 1991 51.60 211.90 872.7 85.0 0.0 196.2 7.10 0.0 1994 0.00 1128.2 2.5 0.0 196.2 7.10 0.0 1994 0.00 1367.10 13.3 0.0 441.5 10.7 0.0 1994 0.00 125.24 13.3 0.0 441.5 10.7 0.0 1994 0.00 125.04 10.9 0.0 196.2 97.3 0.0 1994 165.00 10.4 1.4 0.0 196.2 97.3 0.0 1995 245.01 0.0 10.4 1.4 1.6 1.6 0.0 <td>1991 2485.9 0.00 1615.0 6.9 112.2 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 813.2 1887 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.63 126.5 1991 51.60 211.90 872.7 85.0 0.0 156.2 1.1 387.8 126.5 1991 51.60 121.90 872.7 85.0 0.0 196.2 7.10 0.0 1991 0.00 1367.0 13.3 0.0 141.0 10.0 0.0 1991 0.00 125.0 10.9 0.0 141.0 10.0 0.0 1991 2485.0 0.00 134.0 1.4 0.0 188.7 118.1 1992 2485.0 0.00 1982.2 22.0 10.9 188.7 118.1 1992 2485.0 0.00 1982.2 25.0</td> <td>1991 2435.50 0.00 1615.0 6.9 1112 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 813.2 1887 3656 1991 744.00 0.00 970.6 2.5 1.11 387.8 156.3 126.5 1991 31.60 211.90 872.7 855.0 0.00 196.2 71.0 0.0 1991 0.00 1347.10 1387.8 15.2 0.0 441.9 10.0 0.0 1991 0.00 1257.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 1257.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 125.0 13.3 0.0 13.6 13.4 0.0 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0<</td> <td>1991 2435.50 0.00 1615.0 6.9 1112 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 811.2 1887 356.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 8.6 1992 0.00 1347.10 1138.2 26.5 0.0 196.2 71.0 8.6 1994 0.00 1347.10 1138.2 15.2 0.0 441.5 10.7 0.0 1994 0.00 1347.10 1138.2 13.3 0.0 196.2 0.0 196.2 118.0 0.0 0.0 0.0 196.0 0.0 196.0 0.0 196.0 196.0 0.0 196.2 0.0 196.0 0.0 196.0 0.0 196.0 196.0 196.0 196.0 196.0 196.0</td> <td>1991 2485.9 0.00 1615.0 6.9 1112 9457 1385 5088 1991 1888.9 0.00 1596.4 2.0 23.7 8112 1887 3656 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 51.60 211.90 872.7 853.0 0.0 196.2 71.0 6.0 1991 6.00 112.92 2.5 0.0 196.2 71.0 6.0 1991 0.00 112.2.4 13.3 0.0 141.0 10.7 0.0 1991 0.00 122.4 13.3 0.0 141.0 10.7 0.0 1991 0.00 122.4 13.3 0.0 196.2 97.3 0.0 1991 1485.0 0.00 13.40.7 1.4 0.0 13.4 1.4 10.7 11.8 11.8 11.8 11.8 11.8 11.8 11.8 11.8<</td> <td>1991 1435.50 0.00 1615.0 6.9 1112 9457 1385 5088 1991 1888.90 0.00 1586.4 2.0 23.7 8112 1887 3656 1991 744.00 0.00 9706.6 2.5 1.1 387.8 156.3 17.0 8.6 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 8.6 1991 0.00 1307.0 1387.2 15.2 0.0 196.2 71.0 0.0 1991 0.00 1307.0 1387.2 15.2 0.0 196.2 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 <t< td=""><td></td><td></td><td>2381.7</td><td>31.1</td><td>364.5</td><td>1297.8</td><td>1628</td><td>673.3</td><td>4321</td><td></td><td>0.0</td><td>0.0 0.0</td><td></td><td>0.0</td><td>0.0 41.7</td><td>0.0 41.7 HEAT</td></t<></td>	1991 2485.9 0.00 1615.0 6.9 112.2 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 813.2 1887 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.63 126.5 1991 51.60 211.90 872.7 85.0 0.0 156.2 1.1 387.8 126.5 1991 51.60 121.90 872.7 85.0 0.0 196.2 7.10 0.0 1991 0.00 1367.0 13.3 0.0 141.0 10.0 0.0 1991 0.00 125.0 10.9 0.0 141.0 10.0 0.0 1991 2485.0 0.00 134.0 1.4 0.0 188.7 118.1 1992 2485.0 0.00 1982.2 22.0 10.9 188.7 118.1 1992 2485.0 0.00 1982.2 25.0	1991 2435.50 0.00 1615.0 6.9 1112 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 813.2 1887 3656 1991 744.00 0.00 970.6 2.5 1.11 387.8 156.3 126.5 1991 31.60 211.90 872.7 855.0 0.00 196.2 71.0 0.0 1991 0.00 1347.10 1387.8 15.2 0.0 441.9 10.0 0.0 1991 0.00 1257.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 1257.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 125.0 13.3 0.0 13.6 13.4 0.0 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0 13.6 0.0<	1991 2435.50 0.00 1615.0 6.9 1112 9457 1385 9088 1991 1888.90 0.00 1586.4 2.0 23.7 811.2 1887 356.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 8.6 1992 0.00 1347.10 1138.2 26.5 0.0 196.2 71.0 8.6 1994 0.00 1347.10 1138.2 15.2 0.0 441.5 10.7 0.0 1994 0.00 1347.10 1138.2 13.3 0.0 196.2 0.0 196.2 118.0 0.0 0.0 0.0 196.0 0.0 196.0 0.0 196.0 196.0 0.0 196.2 0.0 196.0 0.0 196.0 0.0 196.0 196.0 196.0 196.0 196.0 196.0	1991 2485.9 0.00 1615.0 6.9 1112 9457 1385 5088 1991 1888.9 0.00 1596.4 2.0 23.7 8112 1887 3656 1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 51.60 211.90 872.7 853.0 0.0 196.2 71.0 6.0 1991 6.00 112.92 2.5 0.0 196.2 71.0 6.0 1991 0.00 112.2.4 13.3 0.0 141.0 10.7 0.0 1991 0.00 122.4 13.3 0.0 141.0 10.7 0.0 1991 0.00 122.4 13.3 0.0 196.2 97.3 0.0 1991 1485.0 0.00 13.40.7 1.4 0.0 13.4 1.4 10.7 11.8 11.8 11.8 11.8 11.8 11.8 11.8 11.8<	1991 1435.50 0.00 1615.0 6.9 1112 9457 1385 5088 1991 1888.90 0.00 1586.4 2.0 23.7 8112 1887 3656 1991 744.00 0.00 9706.6 2.5 1.1 387.8 156.3 17.0 8.6 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 8.6 1991 0.00 1307.0 1387.2 15.2 0.0 196.2 71.0 0.0 1991 0.00 1307.0 1387.2 15.2 0.0 196.2 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 196.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 <t< td=""><td></td><td></td><td>2381.7</td><td>31.1</td><td>364.5</td><td>1297.8</td><td>1628</td><td>673.3</td><td>4321</td><td></td><td>0.0</td><td>0.0 0.0</td><td></td><td>0.0</td><td>0.0 41.7</td><td>0.0 41.7 HEAT</td></t<>			2381.7	31.1	364.5	1297.8	1628	673.3	4321		0.0	0.0 0.0		0.0	0.0 41.7	0.0 41.7 HEAT
1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 365.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 154.3 155.5 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 9.9 1991 0.00 1128.2 25.5 0.0 441.0 10.0 0.0 1991 0.00 127.0 13.3 0.0 441.0 10.7 0.0 1991 0.00 127.0 13.3 0.0 196.2 9.73 0.0 1991 0.00 124.0 1.0 0.0 196.2 1.4 1.0 0.0 1991 165.0 0.0 104.5 1.4 0.0 186.7 1.8 </td <td>1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 744.00 0.00 970.6 2.5 1.11 387.8 156.3 156.5 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 9.9 1991 0.00 1128.2 26.5 0.0 441.5 10.7 0.0 1991 0.00 127.0 13.3 0.0 441.5 10.7 0.0 1991 0.00 125.0 10.9 0.0 196.2 9.0 10.0 1991 6.00 125.0 10.9 0.0 10.4 0.0 196.2 9.0 196.2 9.0<td>1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.43 125.5 1991 31.60 211.90 872.7 85.0 0.0 166.2 71.0 9.0 1991 0.00 10.85.0 12.82.2 26.5 0.0 441.5 1.0 0.0 1991 0.00 13.71.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 12.82.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.1 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.2 13.3 0.0 1.0 1.0 0.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 <</td><td>1991 1888.90 0.00 1586.4 2.0 23.7 8122 1887 36.6 1991 744.00 0.00 9706 2.5 1.1 3878 154.3 156.5 1991 31.60 211.90 872.7 85.0 0.00 166.9 171.0 8.0 1991 0.00 10.89.0 12.82.2 26.5 0.0 441.5 11.0 8.0 1991 0.00 13.47.0 13.7 13.3 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0<</td><td>1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 74400 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 31.60 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 51.60 211.90 872.7 85.0 0.00 190.6 0.00 15.65 71.0 0.0 1991 0.00 1347.10 1387.8 15.2 0.0 4415.1 10.7 0.0 1991 0.00 127.00 10.9 0.0 15.6 97.3 0.0 1991 555.0 0.00 114.4 1.4 0.0 186.7 1.8</td><td>1991 1888.90 0.00 1596.4 2.0 23.7 8122 1887 3656 1991 744.00 0.00 9706 2.5 1.1 387.8 154.9 156.5</td><td>1961</td><td></td><td>1615.0</td><td>6.9</td><td>1122</td><td>9457</td><td>138.5</td><td>5058</td><td>281.5</td><td>-</td><td>0.0</td><td>0.0 0.0</td><td></td><td>0.0</td><td>0.0 37.5</td><td>0.0 37.5 HEAT</td></td>	1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 744.00 0.00 970.6 2.5 1.11 387.8 156.3 156.5 1991 31.60 211.90 872.7 85.0 0.0 196.2 71.0 9.9 1991 0.00 1128.2 26.5 0.0 441.5 10.7 0.0 1991 0.00 127.0 13.3 0.0 441.5 10.7 0.0 1991 0.00 125.0 10.9 0.0 196.2 9.0 10.0 1991 6.00 125.0 10.9 0.0 10.4 0.0 196.2 9.0 196.2 9.0 <td>1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.43 125.5 1991 31.60 211.90 872.7 85.0 0.0 166.2 71.0 9.0 1991 0.00 10.85.0 12.82.2 26.5 0.0 441.5 1.0 0.0 1991 0.00 13.71.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 12.82.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.1 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.2 13.3 0.0 1.0 1.0 0.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 <</td> <td>1991 1888.90 0.00 1586.4 2.0 23.7 8122 1887 36.6 1991 744.00 0.00 9706 2.5 1.1 3878 154.3 156.5 1991 31.60 211.90 872.7 85.0 0.00 166.9 171.0 8.0 1991 0.00 10.89.0 12.82.2 26.5 0.0 441.5 11.0 8.0 1991 0.00 13.47.0 13.7 13.3 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0<</td> <td>1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 74400 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 31.60 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 51.60 211.90 872.7 85.0 0.00 190.6 0.00 15.65 71.0 0.0 1991 0.00 1347.10 1387.8 15.2 0.0 4415.1 10.7 0.0 1991 0.00 127.00 10.9 0.0 15.6 97.3 0.0 1991 555.0 0.00 114.4 1.4 0.0 186.7 1.8</td> <td>1991 1888.90 0.00 1596.4 2.0 23.7 8122 1887 3656 1991 744.00 0.00 9706 2.5 1.1 387.8 154.9 156.5</td> <td>1961</td> <td></td> <td>1615.0</td> <td>6.9</td> <td>1122</td> <td>9457</td> <td>138.5</td> <td>5058</td> <td>281.5</td> <td>-</td> <td>0.0</td> <td>0.0 0.0</td> <td></td> <td>0.0</td> <td>0.0 37.5</td> <td>0.0 37.5 HEAT</td>	1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 744.00 0.00 970.6 2.5 1.1 387.8 15.43 125.5 1991 31.60 211.90 872.7 85.0 0.0 166.2 71.0 9.0 1991 0.00 10.85.0 12.82.2 26.5 0.0 441.5 1.0 0.0 1991 0.00 13.71.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 12.82.0 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.1 13.3 0.0 441.5 1.0 0.0 1991 0.00 13.47.2 13.3 0.0 1.0 1.0 0.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 0.0 1.0 <	1991 1888.90 0.00 1586.4 2.0 23.7 8122 1887 36.6 1991 744.00 0.00 9706 2.5 1.1 3878 154.3 156.5 1991 31.60 211.90 872.7 85.0 0.00 166.9 171.0 8.0 1991 0.00 10.89.0 12.82.2 26.5 0.0 441.5 11.0 8.0 1991 0.00 13.47.0 13.7 13.3 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0<	1991 1888.90 0.00 1586.4 2.0 23.7 813.2 188.7 36.6 1991 74400 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 31.60 0.00 970.6 2.5 1.11 387.8 15.63 15.65 1991 51.60 211.90 872.7 85.0 0.00 190.6 0.00 15.65 71.0 0.0 1991 0.00 1347.10 1387.8 15.2 0.0 4415.1 10.7 0.0 1991 0.00 127.00 10.9 0.0 15.6 97.3 0.0 1991 555.0 0.00 114.4 1.4 0.0 186.7 1.8	1991 1888.90 0.00 1596.4 2.0 23.7 8122 1887 3656 1991 744.00 0.00 9706 2.5 1.1 387.8 154.9 156.5	1961		1615.0	6.9	1122	9457	138.5	5058	281.5	-	0.0	0.0 0.0		0.0	0.0 37.5	0.0 37.5 HEAT
1991 744.00 0.00 970.6 2.5 1.1 387.8 15.63 12.65 1991 51.60 211.00 872.7 85.0 0.0 1062. 71.0 6.0 1991 0.00 1069.90 12.82.2 26.5 0.0 441.5 10.7 0.0 1991 0.00 13.71.0 13.75.4 13.3 0.0 441.5 10.7 0.0 1991 0.00 125.460 920.0 10.9 0.0 441.5 10.7 0.0 1991 0.00 125.460 920.0 10.9 0.0 11.85.7 0.0 0.0 1991 4.855.0 0.00 10.44.5 1.4 0.0 11.85.7 11.81 1992 24.856.0 0.00 10.44.5 1.4 0.0 13.6 11.81 1992 24.856.0 0.00 13.80.7 2.5 10.8 13.1 32.6 1992 24.951.0 11.0 98.7	1991 744.00 0.00 970.6 2.5 1.1 387.8 15.63 12.65 1994 51.60 21.100 872.7 85.0 0.0 106.2 71.0 6.0 1991 0.00 1069.90 12.82.2 26.5 0.0 441.5 10.7 0.0 1991 0.00 1347.0 133.8 0.0 441.5 10.7 0.0 1991 0.00 125.60 920.0 10.9 0.0 441.5 10.7 0.0 1991 0.00 125.40 920.0 10.9 0.0 11.65.7 0.0 1991 595.30 0.00 1044.3 1.4 0.0 136.7 11.8 33.6 1992 2485.60 0.00 1349.7 5.8 20.8 705.9 131.2 33.6 1992 2485.60 0.00 1362.2 22.0 83.0 10.8 37.5 118.1 34.6 1992 2455.10 1.0	1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 51.60 211.90 872.7 85.0 0.0 196.2 71.0 6.0 1991 0.00 1347.10 1387.8 15.5 0.0 441.9 10.7 0.0 1991 0.00 1347.10 1337.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 124.00 125.4 13.3 0.0 10.4 10.0 0.0 0.0 10.4 0.0 0.0 10.0 0.0 10.0 0.0 10.0 0.0 10.0 0.0 0.0 10.0 0.0 10.0 0.0 0.0 10.0 0.0 0.0 10.0 0.0 0.0 10.0 10.0 0.0 10.0 10.0 0.0 10.0 10.0 10.0 10.0 10.0 10.0 0.0 10.0 10.0 10.0 10.0 10.0 10.0 10.0	1991 744.00 0.00 970.6 2.5 1.1 387.8 156.3 126.5 1991 51.60 211.90 872.7 85.0 0.0 196.2 71.0 6.0 1991 0.00 1367.10 1282.2 26.5 0.0 441.9 16.7 0.0 1991 0.00 1367.10 1282.4 135.2 0.0 441.9 16.7 0.0 1991 0.00 1367.10 128.2 13.3 0.0 16.0 0.0 0.0 16.0 0.0 0.0 16.0 0.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0 16.0 0.0	1991 744.00 0.00 970.66 2.5 1.1 387.8 156.3 126.5 1994 51.60 21.100 872.7 85.0 0.0 1062 71.0 6.0 1991 0.00 1069.90 12.82.2 26.5 0.0 441.5 10.7 0.0 1991 0.00 1347.0 137.8 15.2 0.0 441.5 10.7 0.0 1991 0.00 1347.0 13.2 0.0 441.5 10.7 0.0 1991 0.00 134.0 13.3 0.0 10.4 0.0 10.6 0.0 0.0 11.6 0.0 0.0 0.0 0.0 10.4 0.0 11.6 0.0 0.0 0.0 0.0 11.8 0.0 11.8 0.0 0.0 11.8 0.0 11.8 0.0 0.0 0.0 0.0 11.8 0.0 0.0 0.0 0.0 0.0 0.0 11.8 0.0 0.0 0.0 </td <td>1991 74400 0.00 9706 2.5 1.1 3878 156.3 126.5 1994 51.60 21.100 8727 85.0 0.0 1962 71.0 6.0 1991 0.00 1069.90 1285.2 26.5 0.0 441.9 10.7 0.0 1991 0.00 1347.0 1357.8 152.2 0.0 441.9 10.7 0.0 1991 0.00 1201.90 125.460 920.0 10.4 0.0 441.9 10.7 0.0 1991 0.00 1347.0 13.3 0.0 10.4 0.0 10.4 0.0 0.0 11.0 0.0 1991 0.00 1347.0 1.4 0.0 350.3 118.0 0.0 118.0 0.0 118.0 0.0 118.0 118.0 118.0 118.0 118.0 0.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0</td> <td></td> <td></td> <td>1596.4</td> <td>2.0</td> <td>23.7</td> <td>8132</td> <td>1887</td> <td>3656</td> <td>232.7</td> <td>- 1</td> <td>0.0</td> <td>0.0 0.0</td> <td></td> <td>0.0</td> <td>0.0 45.2</td> <td>0.0 45.2 HEAT</td>	1991 74400 0.00 9706 2.5 1.1 3878 156.3 126.5 1994 51.60 21.100 8727 85.0 0.0 1962 71.0 6.0 1991 0.00 1069.90 1285.2 26.5 0.0 441.9 10.7 0.0 1991 0.00 1347.0 1357.8 152.2 0.0 441.9 10.7 0.0 1991 0.00 1201.90 125.460 920.0 10.4 0.0 441.9 10.7 0.0 1991 0.00 1347.0 13.3 0.0 10.4 0.0 10.4 0.0 0.0 11.0 0.0 1991 0.00 1347.0 1.4 0.0 350.3 118.0 0.0 118.0 0.0 118.0 0.0 118.0 118.0 118.0 118.0 118.0 0.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0 118.0			1596.4	2.0	23.7	8132	1887	3656	232.7	- 1	0.0	0.0 0.0		0.0	0.0 45.2	0.0 45.2 HEAT
1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 8.0 1991 0.00 1069.90 12.82.2 26.5 0.0 386.7 61.0 0.0 1991 0.00 1347.10 137.8 15.2 0.0 441.9 16.7 0.0 1991 0.00 1347.2 13.3 0.0 16.7 0.0 10.0 0.0 16.7 0.0 1991 595.30 0.00 1044.5 1.4 0.0 350.5 97.3 0.0 1991 4585.0 0.00 1949.7 2.8 20.8 70.5 1181 32.46 1992 2495.0 0.0 1962.2 2.2 83.0 10.3 13.2 50.5 1992 2495.1 0.0 1982.2 2.2 10.8 13.2 50.5 1992 2495.1 180.6 32.0 110.8 13.2 477.5 1992 24.9 1.0 11.2	1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 8.0 1991 0.00 1069.90 12.82.2 26.5 0.0 38.67 61.0 0.0 1991 0.00 1347.10 137.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 12.01.90 12.54.4 13.3 0.0 11.67 0.0 1991 0.00 25.460 92.0 10.9 1.0 1.0 0.0 1991 595.30 0.00 10.44.5 1.4 0.0 1.0 0.0 1991 585.00 0.00 13.40.7 5.8 20.8 70.59 1.18.1 32.46 1992 24.95.10 n/a 1802.2 22.0 83.0 10.30 163.2 505.5 1992 24.95.10 n/a 1802.6 22.0 11.0 98.5 13.1 50.54 1992 24.95.10 n/a 16.0 22.0 <td>1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 8.0 1991 0.00 1009.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.2 135.2 0.0 441.9 16.7 0.0 1991 0.00 254.60 920.0 10.4 13.3 0.0 16.6 0.0 10.6 0.0 10.6 0.0 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 11.6 0.0 10.6 11.8 0.0 10.6 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.2</td> <td>1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 10.09.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 10.7 0.0 1992 0.00 1201.90 1252.4 133.3 0.0 166.1 0.0 0.0 10.0 0.0 167.2 0.0 0.0 167.2 0.0 0.0 198.2 0.0 198.2 0.0 0.0 198.2 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 1182 1181 1182 1181 1182 1181 1182 1181 1182</td> <td>1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 10.09.90 11.88.2 26.5 0.0 386.7 61.0 0.0 1991 0.00 13.01.90 12.22.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 12.01.90 12.22.4 13.3 0.0 196.7 6.0 0.0 1991 0.00 254.60 920.0 10.4 1.4 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 197.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 1</td> <td>1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 1069.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 16.7 0.0 1991 0.00 1201.90 125.4 13.3 0.0 16.7 0.0 6.0 0.0 10.4 11.3 0.0 16.0 0.0 11.0<!--</td--><td></td><td></td><td>9706</td><td>2.5</td><td>1.1</td><td>387.8</td><td>1563</td><td>126.5</td><td>82.0</td><td></td><td>0.0</td><td>0.0 0.0</td><td></td><td>0.0</td><td>0.0 49.3</td><td>0.0 49.3 HEAT</td></td>	1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 8.0 1991 0.00 1009.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.2 135.2 0.0 441.9 16.7 0.0 1991 0.00 254.60 920.0 10.4 13.3 0.0 16.6 0.0 10.6 0.0 10.6 0.0 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 0.0 10.6 11.6 0.0 10.6 11.8 0.0 10.6 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.8 0.0 11.2	1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 10.09.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 10.7 0.0 1992 0.00 1201.90 1252.4 133.3 0.0 166.1 0.0 0.0 10.0 0.0 167.2 0.0 0.0 167.2 0.0 0.0 198.2 0.0 198.2 0.0 0.0 198.2 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 0.0 198.2 1181 1182 1181 1182 1181 1182 1181 1182 1181 1182	1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 10.09.90 11.88.2 26.5 0.0 386.7 61.0 0.0 1991 0.00 13.01.90 12.22.4 13.3 0.0 441.9 10.7 0.0 1991 0.00 12.01.90 12.22.4 13.3 0.0 196.7 6.0 0.0 1991 0.00 254.60 920.0 10.4 1.4 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 197.7 0.0 196.7 0.0 196.7 0.0 196.7 0.0 196.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 197.7 1	1991 51.60 211.90 872.7 85.0 0.0 1962 71.0 6.0 1991 0.00 1069.90 12.82 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 16.7 0.0 1991 0.00 1201.90 125.4 13.3 0.0 16.7 0.0 6.0 0.0 10.4 11.3 0.0 16.0 0.0 11.0 </td <td></td> <td></td> <td>9706</td> <td>2.5</td> <td>1.1</td> <td>387.8</td> <td>1563</td> <td>126.5</td> <td>82.0</td> <td></td> <td>0.0</td> <td>0.0 0.0</td> <td></td> <td>0.0</td> <td>0.0 49.3</td> <td>0.0 49.3 HEAT</td>			9706	2.5	1.1	387.8	1563	126.5	82.0		0.0	0.0 0.0		0.0	0.0 49.3	0.0 49.3 HEAT
1991 0.00 1069-90 1128.2 26.5 0.0 3867 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1201.90 1252.4 13.3 0.0 441.6 16.7 0.0 1991 0.00 254.60 920.0 10.9 0.0 1965. 97.3 0.0 1991 1.655.00 0.00 113.67 5.8 20.8 97.3 1181. 1992 2485.0 0.00 113.67 5.8 20.8 75.9 131.8 324.6 1992 2485.0 0.0 1982.2 22.0 83.0 1035.0 163.2 507.5 1992 2485.0 0.0 1982.2 22.0 83.0 1035.0 477.5 1992 24.9 1.0 10.5 110.5 98.7 132.9 477.5 1992 24.9 1.0 11.0 21.1	1991 0.00 1.009-90 1.28.2 26.5 0.0 36.7 61.0 0.0 1991 0.00 1.37.10 1.37.8 15.2 0.0 441.9 1.07 0.0 1991 0.00 1.201.90 1.22.4 1.33 0.0 441.6 1.07 0.0 1991 0.00 2.24.60 920.0 1.09 0.0 1.96.5 97.3 0.0 1991 1.655.00 0.00 1.34.7 1.4 0.0 3.24.6 1.18.1 1.18.2 1.18.1 1.18.1 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2 1.18.2	1991 0.00 1.009-90 1.28.2 26.5 0.0 36.7 61.0 0.0 1991 0.00 1.37.10 1.37.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1.22.4 1.33 0.0 1.96.5 97.3 0.0 1991 595.30 0.00 1.044.5 1.14 0.0 3.56.5 97.3 0.0 1991 585.0 0.00 1.349.7 5.8 2.0.8 1.34.5 0.0 1991 1.555.0 0.00 1.349.7 5.8 2.0.8 1.34.5 0.0 1992 2.485.0 0.00 1.982.2 2.20.0 83.0 1.08.0 1.63.2 5.0.8 1992 2.485.0 0.00 1.982.2 2.20.0 83.0 1.05.0 1.63.2 5.0.8 1992 2.485.0 0.0 1.982.2 2.20.0 83.0 1.10.5 1.12.2 4.77.5 1992 2.485.0 <	1991 0.00 1.009.90 1.28.2 26.5 0.00 441.5 61.0 0.00 1991 0.00 1.37.10 1.37.8 15.2 0.00 441.5 10.7 0.00 1991 0.00 1.201.90 1.22.4 1.33 0.00 1.96.7 97.3 0.00 1991 950.30 0.00 1.044.5 1.44 0.00 1.96.7 97.3 0.00 1991 550.30 0.00 1.044.5 1.44 0.00 3.50.5 1.88.7 1.181 1992 1.485.60 0.00 1.98.7 2.20 83.0 1.03.0 1.82.4 9.0.6 1992 2.485.60 0.00 1.98.2 2.20 83.0 1.03.0 1.82.8 9.0.5 1992 2.485.60 0.00 1.98.2 2.20 83.0 1.03.0 1.32.9 477.5 1992 2.485.60 0.0 1.677.2 1.52 2.20 9.60 1.72.9 477.5	1991 0.00 1.009.90 1.28.2 26.5 0.0 3867 61.0 0.0 1991 0.00 1.347.10 1.37.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1.227.4 13.3 0.0 166.7 0.0 1991 0.00 25460 9200 10.9 0.0 156.5 97.3 0.0 1991 595.30 0.00 1044.5 1.4 0.0 350.5 182.7 1181 1992 1485.60 0.00 1947.7 5.8 20.8 135.0 131.8 334.6 1992 2485.60 0.0 1982.2 22.0 83.0 10.9 135.8 334.6 1992 2485.60 0.0 1982.2 22.0 83.0 118.2 344.5 1992 2450.10 0.0 1882.2 110.2 132.0 147.5 147.5 1992 2450.10 0.0 1882.0 <t< td=""><td>1991 0.00 1069-90 1282.2 26.5 0.00 441.9 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1201.90 1252.4 13.3 0.0 1967 0.0 1991 0.00 254.60 920.0 10.9 0.0 1967 0.0 1967 0.0 1967 0.0 1967 0.0 0.0 1967 0.0 1967 0.0 1967 0.0 1967 10.0 0.0 1967 10.0 0.0 1968 10.0<!--</td--><td></td><td></td><td>872.7</td><td>85.0</td><td>0.0</td><td>1962</td><td>71.0</td><td>9.</td><td>10.7</td><td></td><td>24.2</td><td>24.2 31.7</td><td></td><td>31.7</td><td>31,7 42.9</td><td>31,7 COOL/HEAT</td></td></t<>	1991 0.00 1069-90 1282.2 26.5 0.00 441.9 61.0 0.0 1991 0.00 137.10 137.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1201.90 1252.4 13.3 0.0 1967 0.0 1991 0.00 254.60 920.0 10.9 0.0 1967 0.0 1967 0.0 1967 0.0 1967 0.0 0.0 1967 0.0 1967 0.0 1967 0.0 1967 10.0 0.0 1967 10.0 0.0 1968 10.0 </td <td></td> <td></td> <td>872.7</td> <td>85.0</td> <td>0.0</td> <td>1962</td> <td>71.0</td> <td>9.</td> <td>10.7</td> <td></td> <td>24.2</td> <td>24.2 31.7</td> <td></td> <td>31.7</td> <td>31,7 42.9</td> <td>31,7 COOL/HEAT</td>			872.7	85.0	0.0	1962	71.0	9.	10.7		24.2	24.2 31.7		31.7	31,7 42.9	31,7 COOL/HEAT
1991 0.00 1.347.10 1.357.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1.225.4 13.3 0.0 4461 10.7 0.0 1991 0.00 254.60 9200 10.9 0.0 196.5 97.3 0.0 1991 58.20 0.00 1144.5 1.4 0.0 350.5 188.7 1181 1991 1.655.00 0.00 1198.2 2.2 2.0 13.4 32.46 1992 2485.0 0.00 1982.2 2.2 83.0 1059.0 163.2 507.5 1992 2485.0 0.0 1982.2 2.2 83.0 1059.0 163.2 507.5 1992 24.9 1.0 10.0 110.3 163.2 50.5 110.3 477.5 1992 24.9 1.0 10.0 10.5 17.2 431.2 127.8 1992 1.0 1.0 1.0	1991 0.00 1347.10 1357.8 152 0.00 441.9 10.7 0.0 1991 0.00 1201.90 122.4 13.3 0.0 166.1 10.7 0.0 1991 595.30 0.00 1044.5 1.4 0.0 186.7 97.3 0.0 1991 1655.00 0.00 1349.7 5.8 20.8 350.8 11811 3246 1992 2485.0 0.00 1349.7 5.8 20.8 138.9 1181 3246 1992 2485.0 0.00 1982.2 22.0 83.0 1039.0 138.7 1181 1992 2485.0 1.0 <t< td=""><td>1991 0.00 1.347.10 1.357.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1252.4 13.3 0.0 4161 19.7 0.0 1991 0.00 254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 595.30 0.00 1144.5 1.4 0.0 350.5 188.7 1181 1991 4585.0 0.00 1349.7 5.8 20.8 10.8 13.4 33.46 1992 2485.6 0.00 1982.2 22.0 83.0 10.8 13.4 33.46 1992 2485.6 0.0 1982.2 22.0 83.0 10.8 30.5 118.1 34.6 1992 2485.4 0.0 1677.2 40.8 25.8 110.3 477.5 477.5 1992 73.8 0.0 16.7 15.2 22.0 416.5 172.2 431.2 1992</td><td>1991 0.00 1.347.10 1.357.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1.22.4 13.3 0.0 4161 16.7 0.0 1991 0.00 2.5460 9200 10.9 0.0 196.5 97.3 0.0 1991 35530 0.00 1044.5 1.4 0.0 350.5 1181 1181 1992 1485.60 0.00 1349.7 5.8 20.8 13.2 324.6 1992 2485.60 0.00 1349.7 5.8 20.8 13.1 324.6 1992 2485.60 0.00 1382.2 22.0 83.0 103.0 13.1 324.6 1992 2485.60 0.00 1382.2 22.0 83.0 113.2 39.5 1992 143.0 16.6 25.0 110.5 91.6 17.2 417.5 1992 143.0 16.3 2.5 1.0 415.2</td><td>1991 0.00 1.347.10 1.357.8 15.2 0.00 441.9 16.7 0.0 1991 0.00 2.5460 9.00 1.03.4 0.0 1.65.7 97.3 0.0 1991 595.30 0.00 1.044.5 1.4 0.0 1.65.7 97.3 0.0 1991 4.655.0 0.00 1.044.5 1.4 0.0 350.5 188.7 11811 1991 4.655.0 0.00 1.949.7 5.8 2.08 70.5 131.8 324.6 1992 2.485.0 0.0 1.892.2 2.20 83.0 1.82.7 11811 1992 2.485.10 0.0 1.882.6 32.0 1103.0 1.52.9 477.3 1992 2.485.10 0.0 1.882.6 32.0 1103.0 175.2 431.2 1992 2.485.10 0.0 1.882.6 1.5 2.5 1.1 1.1 1.1 1992 1.483.0 0.0 1.2</td><td>1991 0.00 1.347.10 1.357.8 15.2 0.00 441.9 16.7 0.00 1991 0.00 25460 9200 10.9 0.00 156.5 97.3 0.00 1991 595.30 0.00 1044.3 1.4 0.00 156.5 97.3 0.00 1991 595.30 0.00 1044.3 1.4 0.00 350.5 188.7 1181 1992 1485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.0 1.4 1.6 32.0 110.5 94.5 17.2 17.2 1992 2475.0 1.4 1.6 32.0 110.5 94.5 17.2 17.2 1992 <</td><td></td><td></td><td>1258.2</td><td>26.5</td><td>0.0</td><td>386.7</td><td>0.19</td><td>0.0</td><td>0.0</td><td></td><td>129.2</td><td>129.2 171.1</td><td></td><td>1711</td><td>17L1 44.6</td><td>17L1 44.6 COOL</td></t<>	1991 0.00 1.347.10 1.357.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1252.4 13.3 0.0 4161 19.7 0.0 1991 0.00 254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 595.30 0.00 1144.5 1.4 0.0 350.5 188.7 1181 1991 4585.0 0.00 1349.7 5.8 20.8 10.8 13.4 33.46 1992 2485.6 0.00 1982.2 22.0 83.0 10.8 13.4 33.46 1992 2485.6 0.0 1982.2 22.0 83.0 10.8 30.5 118.1 34.6 1992 2485.4 0.0 1677.2 40.8 25.8 110.3 477.5 477.5 1992 73.8 0.0 16.7 15.2 22.0 416.5 172.2 431.2 1992	1991 0.00 1.347.10 1.357.8 15.2 0.0 441.9 10.7 0.0 1991 0.00 1.201.90 1.22.4 13.3 0.0 4161 16.7 0.0 1991 0.00 2.5460 9200 10.9 0.0 196.5 97.3 0.0 1991 35530 0.00 1044.5 1.4 0.0 350.5 1181 1181 1992 1485.60 0.00 1349.7 5.8 20.8 13.2 324.6 1992 2485.60 0.00 1349.7 5.8 20.8 13.1 324.6 1992 2485.60 0.00 1382.2 22.0 83.0 103.0 13.1 324.6 1992 2485.60 0.00 1382.2 22.0 83.0 113.2 39.5 1992 143.0 16.6 25.0 110.5 91.6 17.2 417.5 1992 143.0 16.3 2.5 1.0 415.2	1991 0.00 1.347.10 1.357.8 15.2 0.00 441.9 16.7 0.0 1991 0.00 2.5460 9.00 1.03.4 0.0 1.65.7 97.3 0.0 1991 595.30 0.00 1.044.5 1.4 0.0 1.65.7 97.3 0.0 1991 4.655.0 0.00 1.044.5 1.4 0.0 350.5 188.7 11811 1991 4.655.0 0.00 1.949.7 5.8 2.08 70.5 131.8 324.6 1992 2.485.0 0.0 1.892.2 2.20 83.0 1.82.7 11811 1992 2.485.10 0.0 1.882.6 32.0 1103.0 1.52.9 477.3 1992 2.485.10 0.0 1.882.6 32.0 1103.0 175.2 431.2 1992 2.485.10 0.0 1.882.6 1.5 2.5 1.1 1.1 1.1 1992 1.483.0 0.0 1.2	1991 0.00 1.347.10 1.357.8 15.2 0.00 441.9 16.7 0.00 1991 0.00 25460 9200 10.9 0.00 156.5 97.3 0.00 1991 595.30 0.00 1044.3 1.4 0.00 156.5 97.3 0.00 1991 595.30 0.00 1044.3 1.4 0.00 350.5 188.7 1181 1992 1485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.60 0.00 1982.2 22.0 83.0 1059.0 1652.2 507.5 1992 2485.0 1.4 1.6 32.0 110.5 94.5 17.2 17.2 1992 2475.0 1.4 1.6 32.0 110.5 94.5 17.2 17.2 1992 <			1258.2	26.5	0.0	386.7	0.19	0.0	0.0		129.2	129.2 171.1		1711	17L1 44.6	17L1 44.6 COOL
1991 0.00 1201.90 1252.4 13.3 0.0 4161 16.7 0.0 1991 0.00 254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 585.30 0.00 1144.5 1.4 0.0 350.5 11817 1181 1991 2485.60 0.00 1349.7 5.8 20.8 705.9 131.8 324.6 1992 2485.6 0.00 1982.2 22.0 83.0 1030.0 163.2 507.5 1992 2445.1 n/a 1802.6 32.0 112.8 131.2 548.8 1992 245.1 1.0 160.5 152.9 477.5 477.5 1992 245.1 1.0 167.2 152.9 477.5 431.2 1992 245.0 1.0 167.2 172.9 477.5 431.2 1992 245.0 1.0 172.5 171.2 127.8	1991 0.00 1201.90 1252.4 13.3 0.00 4161 16.7 0.0 1991 0.00 254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 585.30 0.00 11349.7 5.8 20.8 705.9 1181 1181 1991 1485.00 0.00 11349.7 5.8 20.8 705.9 1181 324.6 1992 2485.0 0.0 1982.2 22.0 83.0 108.0 132.6 80.5 1992 2485.0 0.0 1982.2 22.0 83.0 108.0 132.6 80.5 1992 2485.0 1.0 1.0 1.0 1.0 1.0 80.5 80.5 1992 2495.1 1.0	1991 0.00 1201.90 125.4 13.3 0.0 4161 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1862 97.3 0.0 1991 59530 0.00 10445 1.4 0.0 350.5 188.7 1181 1991 48550 0.00 1349.7 5.8 20.8 705.9 131.8 33.46 1992 2485.60 0.00 1982.2 22.0 83.0 1039.0 168.2 507.5 1992 2485.60 0.0 1982.2 22.0 83.0 1039.0 163.2 507.5 1992 2485.60 0.0 1982.2 22.0 110.5 91.0 173.2 477.5 1992 2491.0 0.0 1677.2 15.2 22.0 91.60 173.2 431.2 1992 73.80 0.0 16.3 2.5 1.0 431.2 171.2 177.8 1992 73.80 <td>1991 0.00 1201.90 125.4 13.3 0.0 4161 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1862 97.3 0.0 1991 59530 0.00 1144.5 1.4 0.0 350.5 188.7 11811 1991 1485.0 0.00 1349.7 5.8 20.8 7059 131.8 324.6 1992 2485.6 0.00 1982.2 22.0 83.0 1050 163.2 50.5 1992 2485.4 n/a 1802.6 32.0 110.3 98.7 132.0 477.5 1992 2450.1 n/a 1807.6 32.0 110.3 98.7 15.2 477.5 1992 2450.1 n/a 1877.2 15.2 22.0 916.0 175.2 431.2 1992 143.9 n/a 1873.2 1.0 431.2 171.2 127.8 1992 143.0 n/a</td> <td>1991 0.00 1201.90 1252.4 13.3 0.00 4161 16.7 0.00 1991 50.53 0.00 1254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 58.53 0.00 114.5 1.4 0.0 350.5 1181 1181 1991 1655.00 0.00 1349.7 5.8 20.8 10.5 131.8 324.6 1992 2485.0 0.00 1982.2 22.0 83.0 10.5 131.8 324.6 1992 2485.0 0.0 1982.2 22.0 83.0 10.5 131.8 324.6 1992 2485.1 0.0 1802.6 32.0 110.5 143.2 477.5 1992 2485.1 0.0 115.2 22.0 916.0 175.2 477.5 1992 2485.1 11.3 0.0 11.8 11.1 11.1 1992 143.5 14.3 11.2 14.9<td>1991 0.00 1201.90 1252.4 13.3 0.00 1461 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1965 97.3 0.0 1991 95830 0.00 1044.5 1.4 0.0 350.5 1181 1181 1991 1655.00 0.00 1349.7 5.8 20.8 1059 1348.7 1181 1991 2485.60 0.00 1982.2 22.0 83.0 1059 1348.7 1181 1992 2485.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.5 98.5 147.5 417.5 1992 143.20 n/a 1677.2 15.2 22.0 916.0 172.9 477.5 1992 143.20 n/a 11</td><td></td><td>1347.10</td><td>1337.8</td><td>15.2</td><td>0.0</td><td>44F9</td><td>10.7</td><td>0.0</td><td>0.0</td><td></td><td>1759</td><td>1759 2001</td><td></td><td>200.1</td><td>2001 36.6</td><td>2001 36.6 COOL</td></td>	1991 0.00 1201.90 125.4 13.3 0.0 4161 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1862 97.3 0.0 1991 59530 0.00 1144.5 1.4 0.0 350.5 188.7 11811 1991 1485.0 0.00 1349.7 5.8 20.8 7059 131.8 324.6 1992 2485.6 0.00 1982.2 22.0 83.0 1050 163.2 50.5 1992 2485.4 n/a 1802.6 32.0 110.3 98.7 132.0 477.5 1992 2450.1 n/a 1807.6 32.0 110.3 98.7 15.2 477.5 1992 2450.1 n/a 1877.2 15.2 22.0 916.0 175.2 431.2 1992 143.9 n/a 1873.2 1.0 431.2 171.2 127.8 1992 143.0 n/a	1991 0.00 1201.90 1252.4 13.3 0.00 4161 16.7 0.00 1991 50.53 0.00 1254.60 920.0 10.9 0.0 196.5 97.3 0.0 1991 58.53 0.00 114.5 1.4 0.0 350.5 1181 1181 1991 1655.00 0.00 1349.7 5.8 20.8 10.5 131.8 324.6 1992 2485.0 0.00 1982.2 22.0 83.0 10.5 131.8 324.6 1992 2485.0 0.0 1982.2 22.0 83.0 10.5 131.8 324.6 1992 2485.1 0.0 1802.6 32.0 110.5 143.2 477.5 1992 2485.1 0.0 115.2 22.0 916.0 175.2 477.5 1992 2485.1 11.3 0.0 11.8 11.1 11.1 1992 143.5 14.3 11.2 14.9 <td>1991 0.00 1201.90 1252.4 13.3 0.00 1461 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1965 97.3 0.0 1991 95830 0.00 1044.5 1.4 0.0 350.5 1181 1181 1991 1655.00 0.00 1349.7 5.8 20.8 1059 1348.7 1181 1991 2485.60 0.00 1982.2 22.0 83.0 1059 1348.7 1181 1992 2485.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.5 98.5 147.5 417.5 1992 143.20 n/a 1677.2 15.2 22.0 916.0 172.9 477.5 1992 143.20 n/a 11</td> <td></td> <td>1347.10</td> <td>1337.8</td> <td>15.2</td> <td>0.0</td> <td>44F9</td> <td>10.7</td> <td>0.0</td> <td>0.0</td> <td></td> <td>1759</td> <td>1759 2001</td> <td></td> <td>200.1</td> <td>2001 36.6</td> <td>2001 36.6 COOL</td>	1991 0.00 1201.90 1252.4 13.3 0.00 1461 16.7 0.0 1991 0.00 25460 9200 10.9 0.0 1965 97.3 0.0 1991 95830 0.00 1044.5 1.4 0.0 350.5 1181 1181 1991 1655.00 0.00 1349.7 5.8 20.8 1059 1348.7 1181 1991 2485.60 0.00 1982.2 22.0 83.0 1059 1348.7 1181 1992 2485.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.8 131.2 504.5 1992 24.9.10 n/a 1802.6 32.0 110.5 98.5 147.5 417.5 1992 143.20 n/a 1677.2 15.2 22.0 916.0 172.9 477.5 1992 143.20 n/a 11		1347.10	1337.8	15.2	0.0	44F9	10.7	0.0	0.0		1759	1759 2001		200.1	2001 36.6	2001 36.6 COOL
1991 0.00 23.460 920.0 10.9 0.0 196.5 97.3 0.0 1991 958.30 0.00 1044.5 1.4 0.0 35.61 188.7 1181 1991 1655.00 0.00 1349.7 5.8 20.8 70.59 134.8 324.6 1992 2485.60 0.00 1982.2 22.0 83.0 1039.0 163.2 507.5 1992 2455.10 n/a 1802.6 32.0 110.8 98.57 15.2 94.8 1992 24.59.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 23.50 10.0 10.35.3 2.5 1.0 431.2 171.2 127.8	1991 0.00 23.460 920.0 10.9 0.0 196.5 97.3 0.0 1991 585.30 0.00 1044.5 1.4 0.0 35.61 188.7 1181 1991 1.655.00 0.00 1349.7 5.8 20.8 70.59 134.8 324.6 1992 2485.6 0.00 1982.2 22.0 83.0 1030 163.2 507.5 1992 2459.1 n/a 1882.6 32.0 112.8 131.2 548.8 1992 2459.1 n/a 1872.6 32.0 110.50 175.2 477.5 1992 2459.1 n/a 1677.2 15.2 112.3 172.2 431.2 1992 275.0 16.0 16.5 17.2 431.2 173.2 431.2 1992 132.80 n/a 16.3 2.5 1.0 431.5 17.1 12.8 1992 143.9 n/a 143.5 143.5 143	1991 0.00 25460 9200 10.9 0.0 1965 973 0.0 1991 59530 0.00 1044.5 1.4 0.0 350.5 188.7 11811 1991 1485.0 0.00 13.90.7 5.8 20.8 70.5 131.8 32.46 1992 2485.6 0.00 1982.2 22.0 83.0 10350 131.8 32.46 1992 2485.4 n/a 2005.2 40.8 25.88 1128.8 131.2 59.63 1992 2450.10 n/a 1802.6 32.0 110.5 91.50 173.2 477.5 1992 2450.10 n/a 1677.2 15.2 22.0 91.60 173.2 431.2 1992 732.80 n/a 1033.3 2.5 1.0 431.2 171.2 177.8 1992 732.80 n/a 8257.7 1.5 0.0 2165.9 172.5 182.2 1892 1	1991 0.00 25460 9200 109 0.00 1965 973 0.0 1991 58530 0.00 1044.5 1.4 0.0 350.5 1887 1181 1991 1655.00 0.00 1380.7 5.8 20.8 70.59 131.8 324.6 1992 1485.0 0.00 1882.2 22.0 83.0 109.0 163.2 507.5 1992 2485.0 1.0 2005.2 40.8 258.8 112.8 131.2 594.7 1992 2450.1 1.0 1802.6 32.0 1103.0 96.7 15.2 477.5 1992 143.0 1.0 1.0 115.2 22.0 916.0 175.2 431.2 1992 143.0 1.0 1.0 431.5 171.2 127.8 1992 143.0 1.0 1.0 1.0 1180.4 1180.4 60.0 1892 143.0 1.1 3.4 1.1	1991 0.00 23460 9200 109 0.00 1965 97.3 0.0 1991 98530 0.00 1044.5 1.4 0.0 350.5 1887 1181 1991 1655.00 0.00 1349.7 5.8 20.8 705.9 131.8 324.6 1991 2485.00 0.00 1982.2 22.0 83.0 108.0 163.2 807.5 1992 2485.0 0.0 1982.2 22.0 83.0 112.8 131.2 584.8 1992 2458.1 0.0 1802.6 32.0 110.5 477.5 477.5 1992 2458.1 0.0 15.2 22.0 916.0 175.2 477.5 1992 143.2 0.0 15.2 15.2 17.2 171.2 173.8 1992 143.5 0.0 11.8 0.0 11.8 11.8 0.0 1892 143.5 0.0 11.8 0.0 11.8	1991 0.00 23460 9200 109 0.00 1965 97.3 0.0 1991 95830 0.00 1044.5 1.4 0.0 3561 1887 1181 1991 1658.00 0.00 1346.7 5.8 20.8 7059 1348 3146 1991 2485.60 0.00 1962.2 22.0 83.0 1039 1632 807.3 1992 2456.10 n/a 1802.6 32.0 110.8 131.2 394.4 1992 2456.10 n/a 1807.2 15.2 22.0 916.0 175.2 477.5 1992 2456.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 143.0 n/a 1635.3 1.5 0.0 116.2 447.5 117.8 1992 143.0 n/a 116.9 1.5 0.0 116.2 147.5 147.5 1804 n/a 116.9		1201.90	1252.4	13.3	0.0	4161	10.7	0.0	0.0		154.8	154.8 187.0		187.0	187.0 40.8	187.0 40.8 COOL
1991 595.30 0.00 1044.3 1.4 0.0 350.5 182.7 1181 1991 1655.00 0.00 13-67.7 5.8 20.8 705.9 131.8 324.6 1992 2485.60 0.00 1992.2 22.0 83.0 10.39.0 163.2 507.5 1992 24.95.10 n/a 1802.6 32.0 1128.8 131.2 595.4 1992 24.95.10 n/a 1807.6 32.0 110.5 98.7 152.9 477.5 1992 27.95.10 n/a 1637.2 15.2 22.0 916.0 175.2 431.2 1992 27.35.0 1.0 431.5 171.2 127.8 127.8	1991 595.30 0.00 1044.3 1.4 0.0 350.5 188.7 1181 1991 1658.00 0.00 1349.7 5.8 20.8 705.9 134.8 324.6 1992 2485.60 0.00 1982.2 22.0 83.0 1039.0 1632 507.5 1992 2458.10 n/a 1802.6 32.0 1128.8 131.2 595.4 1992 2459.10 n/a 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2459.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 1/a 27.0 916.0 175.2 431.2 1992 732.80 1/a 175.2 171.2 171.8 1992 143.9 1/a 172.0 173.8 182.	1991 595.30 0.00 1044.3 1.4 0.0 350.5 182.7 1181 1991 1655.00 0.00 13-67 5.8 20.8 705.9 13.18 324.6 1992 2485.40 0.00 1992.2 22.0 83.0 10.30 163.2 507.5 1992 24.90.10 n/a 1802.6 32.0 110.5 98.7 132.9 477.5 1992 24.90.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 73.280 n/a 83.57.7 1.5 1.0 431.5 171.2 177.8 1992 143.30 n/a 82.57 1.5 0.0 216.5 145.9 182.2 1NO n/a 8155.0 1.5 0.0 216.5 145.9 182.2 1NO n/a 815.0 0.0 216.5 145.9 182.2 0.0 1NO 11.8 0.0 11.8 <td>1991 95530 0.00 1044.5 1.4 0.0 350.5 18E7 1181 1992 1655.00 0.00 1346.7 5.8 20.8 705.9 131.8 324.6 1992 2485.60 0.00 1982.2 22.0 83.0 1030.0 163.2 807.5 1992 2485.40 n/a 1802.6 32.0 1103.6 98.7 15.2 98.7 1992 249.10 n/a 1677.2 15.2 22.0 916.0 17.2 47.5 1992 143.0 n/a 1677.2 15.2 22.0 916.0 17.2 43.2 1992 143.0 n/a 1673.2 2.5 1.0 43.1.5 17.1.2 127.8 1992 143.0 n/a 1638.3 2.5 1.0 43.1.5 17.1.2 127.8 1992 143.0 11.8 3145.0 30.0 216.5 145.9 182.2 1892 143.0</td> <td>1991 595.30 0.00 1044.5 1.4 0.0 350.5 188.7 1181 1991 1658.00 0.00 1349.7 5.8 20.8 705.9 134.5 1181 334.6 1992 2485.60 0.00 1982.2 22.0 83.0 1039.0 163.2 507.3 1992 2485.40 n/a 1882.6 32.0 110.6 98.7 15.2 477.5 1992 2459.10 n/a 1677.2 15.2 22.0 916.0 175.2 471.2 1992 2459.10 n/a 1677.2 15.2 22.0 916.0 175.2 471.2 1992 143.9 n/a 1633.3 2.5 1.0 431.5 171.2 173.6 1992 143.9 n/a 82.57 1.5 0.0 216.5 145.9 182.2 1NO 1326.6 n/a 1169.1 141.9 644.0 5623.5 121.8 2528.8</td> <td>1991 58530 0.00 1044.3 1.4 0.0 35G.5 18g.7 1181 1991 1655.00 0.00 1349.7 5.8 20.8 705.9 131.8 3246 1992 2485.60 0.00 1992.2 22.0 83.0 10.90 163.2 595.3 1992 24.90.10 n/a 1802.6 32.0 110.8 131.2 595.3 1992 24.90.10 n/a 1802.6 32.0 110.3 98.7 15.2 477.5 1992 24.90.10 n/a 1677.2 15.2 22.0 98.7 15.2 477.5 1992 143.30 n/a 163.3 2.5 1.0 431.2 127.8 127.8 1892 143.30 n/a 82.57 1.5 0.0 216.5 14.5 18.2 1804 138.66 n/a 116.91 141.9 644.0 563.5 121.8 252.8 1805 n/a <td< td=""><td>1661</td><td></td><td>9200</td><td>10.9</td><td>0.0</td><td>196.5</td><td>97.3</td><td>0.0</td><td>0.0</td><td>- 1</td><td>38.7</td><td>38.7 31.1</td><td></td><td>31.1</td><td>31.1 35.9</td><td>31.1 35.9 COOL</td></td<></td>	1991 95530 0.00 1044.5 1.4 0.0 350.5 18E7 1181 1992 1655.00 0.00 1346.7 5.8 20.8 705.9 131.8 324.6 1992 2485.60 0.00 1982.2 22.0 83.0 1030.0 163.2 807.5 1992 2485.40 n/a 1802.6 32.0 1103.6 98.7 15.2 98.7 1992 249.10 n/a 1677.2 15.2 22.0 916.0 17.2 47.5 1992 143.0 n/a 1677.2 15.2 22.0 916.0 17.2 43.2 1992 143.0 n/a 1673.2 2.5 1.0 43.1.5 17.1.2 127.8 1992 143.0 n/a 1638.3 2.5 1.0 43.1.5 17.1.2 127.8 1992 143.0 11.8 3145.0 30.0 216.5 145.9 182.2 1892 143.0	1991 595.30 0.00 1044.5 1.4 0.0 350.5 188.7 1181 1991 1658.00 0.00 1349.7 5.8 20.8 705.9 134.5 1181 334.6 1992 2485.60 0.00 1982.2 22.0 83.0 1039.0 163.2 507.3 1992 2485.40 n/a 1882.6 32.0 110.6 98.7 15.2 477.5 1992 2459.10 n/a 1677.2 15.2 22.0 916.0 175.2 471.2 1992 2459.10 n/a 1677.2 15.2 22.0 916.0 175.2 471.2 1992 143.9 n/a 1633.3 2.5 1.0 431.5 171.2 173.6 1992 143.9 n/a 82.57 1.5 0.0 216.5 145.9 182.2 1NO 1326.6 n/a 1169.1 141.9 644.0 5623.5 121.8 2528.8	1991 58530 0.00 1044.3 1.4 0.0 35G.5 18g.7 1181 1991 1655.00 0.00 1349.7 5.8 20.8 705.9 131.8 3246 1992 2485.60 0.00 1992.2 22.0 83.0 10.90 163.2 595.3 1992 24.90.10 n/a 1802.6 32.0 110.8 131.2 595.3 1992 24.90.10 n/a 1802.6 32.0 110.3 98.7 15.2 477.5 1992 24.90.10 n/a 1677.2 15.2 22.0 98.7 15.2 477.5 1992 143.30 n/a 163.3 2.5 1.0 431.2 127.8 127.8 1892 143.30 n/a 82.57 1.5 0.0 216.5 14.5 18.2 1804 138.66 n/a 116.91 141.9 644.0 563.5 121.8 252.8 1805 n/a <td< td=""><td>1661</td><td></td><td>9200</td><td>10.9</td><td>0.0</td><td>196.5</td><td>97.3</td><td>0.0</td><td>0.0</td><td>- 1</td><td>38.7</td><td>38.7 31.1</td><td></td><td>31.1</td><td>31.1 35.9</td><td>31.1 35.9 COOL</td></td<>	1661		9200	10.9	0.0	196.5	97.3	0.0	0.0	- 1	38.7	38.7 31.1		31.1	31.1 35.9	31.1 35.9 COOL
1991 1655.00 0.00 1349.7 5.8 20.8 705.9 131.8 324.6 1991 2485.60 0.00 1982.2 22.0 83.0 1035.0 163.2 507.5 1992 2495.10 n/a 1802.6 32.0 110.5 98.7 131.2 59.6 1992 24.9.10 n/a 1677.2 15.2 22.0 98.7 15.2 477.5 1992 232.0 10.0 175.2 431.2 431.2 431.2 1992 732.80 n/a 1033.3 2.5 1.0 431.2 172.8	1991 1655.00 0.00 1349.7 5.8 20.8 7059 1318 3246 1991 2485.60 0.00 1982.2 22.0 83.0 1039.0 1632 507.5 1992 2495.10 n/a 2095.2 40.8 2288 1128.8 131.2 5044 1992 24.9.10 n/a 1802.6 32.0 110.5 98.7 152.9 477.5 1992 24.9.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 73.280 n/a 1033.3 2.5 1.0 431.5 171.2 127.8 1992 143.0 n/a 8257 1.5 0.0 216.5 145.9 182.	1991 1655.00 0.00 13.9.7 5.8 20.8 7059 13.18 3246 1991 2485.60 0.00 1982.2 22.0 83.0 1095.0 1632 507.5 1992 2985.40 n/a 2095.2 40.8 258.8 1128.8 131.2 548.8 1992 24.95.10 n/a 1802.6 32.0 1103.5 985.7 152.9 477.5 1992 24.95.10 n/a 1677.2 15.2 22.0 916.0 173.2 431.2 1992 73.280 n/a 823.7 1.0 431.5 171.2 171.2 1992 143.30 n/a 823.7 1.5 0.0 216.5 145.9 182.2 1NO n/a 815.0 0.0 216.5 145.9 182.2	1991 1655.00 0.00 1349.7 5.8 20.8 705.9 131.8 324.6 1991 2485.60 0.00 1982.2 22.0 83.0 1095.0 163.2 507.5 1992 2585.40 n/a 2095.2 40.8 25.88 112.8 131.2 584. 1992 249.10 n/a 1607.2 32.0 110.5 98.7 152.9 477.5 1992 143.0 n/a 1677.2 15.2 1.0 431.2 171.2 171.2 1992 143.9 n/a 1033.3 2.5 1.0 431.5 171.2 171.8 1870 n/a 3165.0 307.1 33.1 0.0 118.4 118.0 6.0 N N 307.1 33.1 644.0 5623.5 121.8 225.88	1991 1655.00 0.00 1349.7 5.8 20.8 7050 1318 3246 1991 2485.60 0.00 1982.2 22.0 83.0 1039.0 1632 507.5 1992 2285.40 n/a 2095.2 40.8 258.8 1128.8 131.2 598.4 1992 24.90.10 n/a 1807.6 32.0 110.3 98.7 152.0 477.5 1992 24.90.10 n/a 1677.2 15.2 2.5 1.0 431.5 127.8 132.8 1992 132.80 n/a 1633.3 2.5 1.0 431.5 172.2 127.8 1992 143.30 n/a 825.7 1.5 0.0 216.5 145.9 182.2 1NO 1326.68 n/a 1169.1 141.9 644.0 5623.5 121.8 2528.8 N 1NO 4065.4 686.4 0.0 1690.0 252.9 0.0	1991 1655.00 0.00 13.9.7 5.8 20.8 705.0 131.8 324.6 1992 2485.60 0.00 1982.2 22.0 83.0 1095.0 163.2 507.5 1992 2985.40 n/a 1802.6 32.0 110.3 98.7 152.9 477.5 1992 2495.10 n/a 1677.2 15.2 22.0 91.6 173.2 471.5 1992 72.80 n/a 1677.2 15.2 22.0 91.6 173.2 471.5 1992 73.80 n/a 1677.2 1.5 0.0 21.65 145.9 172.8 1NO n/a 1677.2 1.5 0.0 21.65 145.9 182.2 1NO n/a 3145.00 307.1 33.1 0.0 11.84 118.0 0.0 N N 1169.1 141.9 644.0 562.5 121.8 252.8 N 180.7 496.1 150.4 <td>_ </td> <td></td> <td>1044.5</td> <td>1.4</td> <td>0.0</td> <td>350.5</td> <td>188.7</td> <td>1181</td> <td>10.7</td> <td>- 1</td> <td>0.0</td> <td>0.0 0.0</td> <td></td> <td>0.0</td> <td>0.0 36.7</td> <td>0.0 36.7 HEAT</td>	_		1044.5	1.4	0.0	350.5	188.7	1181	10.7	- 1	0.0	0.0 0.0		0.0	0.0 36.7	0.0 36.7 HEAT
1991 2485.60 0.00 1982.2 22.0 83.0 1030.0 163.2 507.5 1992 2965.40 n/a 21065.2 40.8 258.8 1128.8 131.2 548.8 1992 24.95.10 n/a 1802.6 32.0 110.5 985.7 152.9 477.5 1992 2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/a 1038.3 2.5 1.0 431.5 171.2 127.8	1991 2485.60 0.00 1982.2 22.0 83.0 1090.0 163.2 5075. 1992 2965.40 n/a 2095.2 40.8 258.8 1128.8 131.2 548.8 1992 24.91.0 n/a 1802.6 32.0 110.5 985.7 152.9 477.5 1992 2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/a 1035.3 2.5 1.0 431.5 172.8 1992 143.0 n/a 825.7 1.5 0.0 216.5 145.9 182.	1991 2485.60 0.00 1982.2 22.0 83.0 1039.0 163.2 507.5 1992 2885.40 n/a 2095.2 40.8 258.8 112.8 131.2 58.8 1992 24.90.10 n/a 1802.6 32.0 110.5 98.7 152.9 477.5 1992 24.90.10 n/a 1677.2 152.0 916.0 175.2 431.2 1992 732.80 n/a 1035.3 2.5 1.0 431.2 127.8 1992 143.30 n/a 8227.7 1.5 0.0 216.5 145.9 182.2 1AN n/a 8227.7 1.5 0.0 216.5 145.9 182. N n/a 33.1 0.0 11.84 1180 0.0	1991 2485.60 0.00 1982.2 22.0 83.0 1030.0 163.2 507.5 1992 2985.40 n/a 2085.2 40.8 258.8 112.8 131.2 548.4 1992 24.9.10 n/a 1802.6 32.0 110.5 98.7 152.9 477.5 1992 2071.20 n/a 1677.2 15.2 22.0 916.0 173.2 431.2 1992 143.90 n/a 1673.3 2.5 1.0 431.5 171.2 127.8 11NG n/a 825.7 1.5 0.0 118.4 118.0 6.0 N N 825.7 1.5 0.0 118.4 118.0 6.0 N N 1169.1 141.9 6444.0 562.5 121.8 252.88	1991 2485.60 0.00 1982.2 22.0 83.0 1030.0 163.2 507.5 1992 2968.40 n/a 2096.2 40.8 258.8 112.8 131.2 586.7 1992 24.9.10 n/a 1802.6 32.0 110.8 985.7 152.9 477.5 1992 24.9.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 143.9 n/a 1033.3 2.5 1.0 431.5 112.8 182.6 1100 143.0 n/a 82.57.7 1.5 0.0 216.5 145.9 182.2 1100 1326.68 n/a 1169.1 141.9 644.0 5623.5 121.8 2528.8 NA 11AG 4965.4 684.4 0.0 1594.0 2529.9 0.0	1991 2485.60 0.00 1982.2 22.0 83.0 1030.0 1632 507.5 1992 2985.40 n/a 2085.2 40.8 258.8 112.8 131.2 5848 1992 24.9.10 n/a 1802.6 32.0 110.5 98.7 152.9 477.5 1992 24.9.10 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/a 1035.3 2.5 1.0 431.5 171.2 171.8 1NO n/a 82.57 1.5 0.0 216.5 145.9 182.2 ATINO n/a 1169.1 141.9 644.0 562.5 121.8 252.8 N n/a 4085.4 496.5 684.4 0.0 1504.0 252.0 0.0 N n/a 4085.4 685.4 0.0 1504.0 252.0 0.0 N n/a 4085.4 496.1 496.1 <td>1661</td> <td>_</td> <td>1349.7</td> <td>5.8</td> <td>20.8</td> <td>7059</td> <td>131.8</td> <td>324.6</td> <td>2251</td> <td></td> <td>0.0</td> <td>0.0 0.0</td> <td></td> <td>0.0</td> <td>0.0 34.3</td> <td>0.0 34.3 HEAT</td>	1661	_	1349.7	5.8	20.8	7059	131.8	324.6	2251		0.0	0.0 0.0		0.0	0.0 34.3	0.0 34.3 HEAT
1992 2045.40 n/h 2005.2 40.8 258.8 1128.8 131.2 598.8 1992 24.95.10 n/h 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/h 1035.3 2.5 1.0 431.5 171.2 1278	1992 298X-40 n/h 2005.2 40.8 258.8 1128.8 131.2 598.8 1992 2459.10 n/h 1802.6 32.0 110.5 98X7 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 173.2 431.2 1992 732.80 n/h 1033.3 2.5 1.0 431.5 171.2 127.8 1992 143.30 n/h 82X7 1.5 0.0 216.5 145.9 182.	1992 298X-40 n/h 2085.2 40.8 258.8 1128.8 131.2 598.7 1992 24.9A.10 n/h 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 173.2 431.2 1992 143.90 n/h 1035.3 2.5 1.0 431.5 171.2 127.8 1992 143.90 n/h 82.57 1.5 0.0 216.5 145.9 182.2 1AN n/h 335.1 0.0 118.4 1180 0.0	192 298X-40 n/a 208X-2 40.8 258.8 112.8 131.2 598.4 192 24.9,10 n/a 180.26 32.0 110.5 98.57 15.29 477.5 192 2071,20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 192 732.80 n/a 1633.3 2.5 1,0 431.5 171.2 127.8 11NO n/a 82.57 1.5 0.0 216.5 145.9 18.2 N N 3307.1 33.1 0.0 118.4 118.0 6.0 N N 1169.1 141.9 644.0 562.5 121.8 225.8	1992 298X-40 n/h 2085.2 40.8 258.8 1128.8 131.2 59£4 1992 24.9.10 n/h 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.2 431.2 1992 143.90 n/h 82.57 1.5 0.0 216.5 143.9 182.2 1NG n/h 307.1 33.1 0.0 216.5 143.9 182. N N/h 1169.1 141.9 644.0 5623.5 1231.8 2528.8 N 11NG 4965.4 688.4 0.0 1594.0 252.9 0.0	1922 298X-40 m/a 208X-3 40.8 258.8 112.8 131.2 598.4 1922 24.9,10 m/a 180Z-6 32.0 110.5 98.7 15.2 477.5 1922 2071,20 m/a 1677.2 15.2 22.0 91.60 173.2 431.2 1922 73280 m/a 1673.3 2.5 1.0 431.5 171.2 127.8 1920 143.30 m/a 82.57 1.5 0.0 216.5 145.9 18.2 1NN 1326.68 m/a 1169.1 141.9 644.0 562.5 121.8 252.8 NING 1326.68 m/a 1169.4 141.9 644.0 562.5 121.8 252.8 NN N 496.4 573.8 121.2 2601.3 2601.3	1661		1982.2	22.0	83.0	1039.0	1632	507.5	3427		0.0	0.0 0.0		0.0	0.0 43.9	0.0 43.9 HEAT
1992 24.93.10 n/h 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 9160 175.2 431.2 1992 732.80 n/h 1033.3 2.5 1.0 431.5 171.2 127.8	1992 24.93.10 n/h 1802.6 32.0 110.5 98.57 152.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/h 1035.3 2.5 1.0 431.5 171.2 127.8 1992 143.30 n/h 825.7 1.5 0.0 216.5 145.9 182.	1992 24.93.10 n/a 1802.6 32.0 110.5 98.77 15.29 477.5 1992 2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/a 1033.3 2.5 1.0 431.5 171.2 177.8 1992 143.90 n/a 8257.7 1.5 0.0 216.5 145.9 182.7 LING n/a 3145.00 3927.1 33.1 0.0 1184.4 1180 0.0	1992 24.90.10 n/h 1802.6 32.0 110.5 98.57 15.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.9 431.2 1992 143.80 n/h 1035.3 2.5 1.0 431.5 171.2 127.8 1992 143.30 n/h 825.7 1.5 0.0 216.5 145.9 18.2 LING n/h 335.7 1.5 0.0 118.4 118.0 0.0 N N 1169.1 141.9 644.0 5623.5 121.8 225.8.8	1992 24.9L0 n/h 1802.6 32.0 1104.5 98.57 15.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/h 1033.3 2.5 1.0 431.5 171.2 127.8 1992 143.30 n/h 825.7 1.5 0.0 216.5 145.9 18.2 1NO n/h 3145.00 3027.1 33.1 0.0 11.84 1180 0.0 N N 4085.4 4965.4 684.4 0.0 159.0 252.9 0.0 N N 4085.4 68.4 0.0 159.0 252.9 0.0	1992 24.9.10 n/h 1802.6 32.0 110.5 98.57 15.9 477.5 1992 2071.20 n/h 1677.2 15.2 22.0 916.0 175.2 431.2 1992 732.80 n/h 1633.3 2.5 1.0 431.5 171.2 127.8 11NG n/h 82.57 1.5 0.0 216.5 145.9 18.2 11NG n/h 397.1 33.1 0.0 118.4 118.0 6.0 ATINO 1326.68 n/h 1169.1 141.9 644.0 562.5 121.8 2528.8 N 11NG 496.4 562.5 121.8 2528.8 6.0 N N 496.4 406.1 150.0 252.9 0.0	_		2095.2	40.8	258.8	1128.8	131.2	5953	377.5	- 1	0.0	0.0 0.0		0.0	0.0 40.3	0.0 40.3 HEAT
2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 732.80 n/a 1038.3 2.5 1.0 431.5 171.2 127.8	2 2071.20 n/a 1677.2 15.2 22.0 9160 1752 431.2 1732 1732 1732 1732 1732 1732 1733 1733	2 2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 2 732.80 n/a 1033.3 2.5 1.0 431.5 171.2 127.8 2 143.30 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3027.1 33.1 0.0 1186.4 1180 0.0	2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 732.80 n/a 1033.3 2.5 1.0 431.5 171.2 127.8 143.90 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3027.1 33.1 0.0 1136.4 1180 0.0 13356.68 n/a 1169.1 141.9 644.0 3623.5 1221.8 2528.8	2071,20 n/a 1677,2 15.2 22.0 916.0 175.2 431.2 732,80 n/a 1033,3 2.5 1.0 431.5 171.2 177.8 143,9 n/a 82.57 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3077.1 33.1 0.0 1186.4 1180 0.0 13286.68 n/a 1169.1 141.9 644.0 5623.5 1221.8 2528.8 n/a 4085.4 68.4 0.0 1594.0 2529 0.0	2071.20 n/a 1677.2 15.2 22.0 916.0 175.2 431.2 732.80 n/a 1033.3 2.5 1.0 431.5 171.2 127.8 143.90 n/a 307.1 1.5 0.0 216.5 145.9 18.2 1326.68 n/a 1169.1 141.9 644.0 3623.5 121.8 2528.8 n/a 4085.40 4965.4 68.4 0.0 1504.0 252.9 0.0 13127.70 n/a 11810.4 121.2 496.1 2773.8 1210.2 2601.3	1992		1802.6	32.0	110.5	7286	1529	477.5	3326		0.0	0.0 0.0		0.0	0.0 43.2	0.0 43.2 HEAT
732.80 n/a 1035.3 2.5 1.0 431.5 171.2 127.8	2 73280 n/a 10353 2.5 1.0 431.5 171.2 127.8 143.9 n/a 83.57 1.5 0.0 216.5 145.9 18.2	2 73280 n/a 1033-3 2.5 1.0 431.5 171.2 127.8 2 143.30 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3027.1 33.1 0.0 1136.4 1180 0.0	732.80 n/a 1035.3 2.5 1.0 431.5 171.2 127.8 143.90 n/a 82X7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3027.1 33.1 0.0 11.84.4 1180 0.0 1336.68 n/a 11649.1 141.9 644.0 5621.5 1221.8 2328.8	73280 n/a 1033.3 2.5 1.0 431.5 171.2 172.8 143.9 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 307.1 33.1 0.0 118.4 1180 6.4 13286.8 n/a 11649.1 141.9 644.0 5623.5 1221.8 2352.8 n/a 4065.4 68.4 0.0 1504.0 252.9 0.0	732.80 n/a 1035.3 2.5 1.0 431.5 171.2 127.8 143.90 n/a 825.7 1.5 0.0 216.5 14.59 18.2 n/a 3145.00 307.1 33.1 0.0 11.84.4 118.0 0.0 13356.68 n/a 11649.1 141.9 644.0 5624.5 1221.8 2528.8 n/a 4085.40 4965.4 68.4 0.0 1504.0 252.0 0.0 13127.70 n/a 11810.4 121.2 496.1 5773.8 1210.2 2601.3			1677.2	15.2	22.0	9160	1752	431.2	2858		0.0	0.0 0.0		0.0	0.0 43.7	0.0 43.7 HEAT
	2 14330 n/a 8257 1.5 0.0 216.5 1459 18.2	2 143.30 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 3027.1 33.1 0.0 1138.4 1180 0.0	143.9 n/a 825.7 1.5 0.0 216.5 145.9 182 n/a 3145.00 3027.1 33.1 0.0 11.86.4 1180 0.0 1336.68 n/a 11649.1 141.9 644.0 5621.5 1221.8 2528.8	143.90 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 307.1 33.1 0.0 1138.4 118.0 0.0 1326.68 n/a 11649.1 141.9 644.0 3623.5 1221.8 2328.8 n/a 4085.40 4965.4 68.4 0.0 1504.0 252.9 0.0	143.9 n/a 825.7 1.5 0.0 216.5 145.9 18.2 n/a 3145.00 307.1 33.1 0.0 118.4 118.0 0.0 1336.68 n/a 116.9.1 141.9 644.0 5623.5 1221.8 2528.8 n/a 4965.4 68.4 0.0 1594.0 252.9 0.0 13127.70 n/a 11810.4 121.2 4961. 2701.8 2001.3			1033.3	2.5	1.0	431.5	171.2	127.8	107.3		0.0	0.0 0.0		0.0	0.0	0.0 38.7 HEAT
n/a 314500 307.1 33.1 0.0 118.4 118.0 0.0 13286.68 n/a 11649.1 141.9 644.0 5623.5 1221.8 2528.8 n/a 4085.40 68.4 0.0 1504.0 252.9 0.0 13127.70 n/a 11810.4 121.2 496.1 5773.8 1210.2 2601.3 1338.68 3355.90 1487.3 177.5 644.0 6824.6 1339.7 2528.8	1326.68 n/a 11649.1 141.9 644.0 5623.5 1221.8 2528.8 n/a 4085.40 4965.4 68.4 0.0 1504.0 252.9 0.0 13127.70 n/a 11810.4 121.2 496.1 5773.8 1210.2 2601.3 1326.68 338.50 1487.3 177.5 644.0 6824.6 1399.7 2528.8	n/a 4065.40 4965.4 68.4 0.0 1594.0 232.9 0.0 13127.70 n/a 11810.4 121.2 496.1 5773.8 1210.2 2601.3 1326.66 3356.50 1487.3 177.5 644.0 6824.6 1339.7 2528.8	13127.70 n/a 11810.4 121.2 496.1 577.8 1210.2 2601.3 1326.68 3356.90 1487.3 177.5 644.0 6824.6 1339.7 2528.8	13386.68 3355.90 14873 177.5 644.0 6824.6 1339.7 2538.8		02 TS181 6/01 - 5/07	1873 50	053													

Operation in Heating Mode began 9/18/90 at 00:00; Operation in Cooling Mode began 5/27/91 at 13:00
 Cooling Coefficient of Performance is computed for space cooling only operation. Parasitic energy consumption is included.
 Heating Coefficient of Performance is computed for space heating only operation. Supplemental and parasitic energy is included.
 Water Heating Coefficient of Performance is the ratio of the energy delivered to the water heater divided by the energy consumed while operating in the water heating only mode.
 Water Heating Coefficient of Performance is the ratio of the energy delivered to the water loads divided by the energy consumed by the heat pump, supplemental heaters and water heater.





DISTRIBUTION OF ENERGY CONSUMPTION



An objective of this project was to compare the measured energy consumption of the heat pump system using an electronic digital power analyzer to measurements made using a conventional residential watt hour meter. The utility industry is concerned whether the harmonics produced by variable-speed equipment will introduce errors in conventional watt hour meters. For the current and voltage ranges used in this experimental investigation, the accuracy of the electronic digital power analyzer is specified as 0.8% of the actual power over a band width of 20 to 100 H_z . The Potomac Edison Company calibrated a conventional watthour meter in accordance with ANSI Standard C12-1975 and found the meter accurate to within 0.2%.

Table 3 gives the energy consumed by the integrated variable-speed heat pump as measured by the electronic digital power analyzer, the conventional watt hour meter and the percent difference. With the exception of 4 months, there is less than a 0.63% difference, which is within the error bands of the two instruments. The cause of the greater disagreements observed for the months of June 1990, October 1990, May 1991, and May 1992 is not known. Over the entire 2-year monitoring period, the energy consumption measured by both instruments was essentially identical, 50,662 MJ (14,073 kWh) versus 50,669 (14,075 kWh). This finding is consistent with studies performed by Baldwin et al [3] who found that the average meter error due to distorted current waveforms caused by a single-phase variable-speed AC motor drive was less than 0.8%. Grady [4], however, has voiced concern over possible metering errors which may result if a significant number of variable-speed motors are connected on the same utility feeder.

Hourly Electrical Demands


The maximum hourly electrical energy demand for the total residence, heat pump, water heater, and supplemental heaters is shown on a monthly basis in Figure 8. Excluding the peak for the residence (which is the sum of the base load, water heater, heat pump, and supplemental), the greatest peak demand was due to the supplemental space heaters, 5.30 kJ/s (5.30 kW) which occurred during the month of January 1991. The peak demand imposed by the heat pump ranged from 1.89 kJ/s (1.89 kW), measured in August 1991, to 3.70 kJ/s (3.70 kW) measured during the month of February 1991. The highest electrical demand recorded for the water heater was 2.97 kJ/s (2.97 kW) occurring during the month of February 1992. The peak demand imposed by the total residence ranged from 5.80 kJ/s (5.80 kW) in June 1990 to a high of 17.00 kJ/s (17.00 kW) recorded during the month of November 1990.


The Allegheny Power System consists of three utilities, Monongahela Power Company, West Penn Power Company, and The Potomac Edison Company which is the electrical utility to which the residence is connected. An objective of the project was to document the relationship between the electrical loads of the residence and the peak loads encountered by The Potomac Edison Company and overall the Allegheny Power System. The hourly electrical demands present when peak load conditions were being experienced by the Allegheny Power System (APS) are shown in Figure 9. A comparison of the monthly peak

TABLE 3 COMPARISON OF MEASURED ENERGY CONSUMPTION USING ELECTRONIC DIGITAL POWER ANALYZER AND ELECTRIC UTILITY WATTHOUR METER

N.	No. al		ic Power Analyzer	Electric Watt Ho	Utility ur Meter	Percent ¹
Year	Month	MJ	kWh	MJ	kWh	Difference (%)
1990	June	1071.0	297.5	1057.3	293.7	+1.3
1990	July	1242.0	345.0	1235.5	343.2	+0.5
1990	August	1228.3	341.2	1226.9	340.8	+0.0
1990	September	891.0	247.5	894.2	248.4	-0.4
1990	October	1172.5	325.7	1199.9	333.3	-2.4
1990	November	2405.2	668.1	2397.6	666.0	+0.3
1990	December	3573.4	992.6	3556.8	988.0	+0.5
1991	January	4672.1	1297.8	4673.9	1298.3	-0.0
1991	February	3404.5	945.7	3399.1	944.2	-0.0
1991	March	2925.7	812.7	2927.5	813.2	-0.●
1991	April	1396.1	387.8	1390.7	386.3	-0.0
1991	May	706.3	196.2	712.8	198.0	-0.0
1991	June	1392.1	386.7	1394.6	387.4	-0.2
1991	July	1590.8	441.9	1539.7	442.7	-0.0
1991	August	1498.0	416.1	1497.2	415.9	0.0
1991	September	707.4	196.5	703.1	195.3	+0.6
1991	October	1261.8	350.5	1266.8	351.9	-0.0
1991	November	2541.2	705.9	2542.7	706.3	-0.●
1991	December	3740.4	1039.0	3739.0	1038.6	+0.0
1992	January	4063.7	1128.8	4063.3	1128.7	0.0
1992	February	3548.5	985.7	3545.3	984.8	0.1
1992	March	3297.6	916.0	3297.2	415.9	0.0
1992	April	1553.4	431.5	1563.1	434.2	+0.5
1992	May	779.4	216.5	790.6	219.6	-1.4
Total		50662.4	14072.9	50668.9	14074.7	0.0

¹Percent Difference = <u>Electronic Digital Analyzer - Watthour Meter Measurements</u> Electronic Digital Analyzer Measurement






27

hourly demands, Figure 8, and the hourly electrical demands present when APS was experiencing peak load conditions, Figure 9, shows that the only peak load at the monitored residence which coincided with any APS peak was the supplemental heater during the month of April 1992. The hourly electrical demands present when peak load conditions were being experienced by The Potomac Edison Company are shown in Figure 10. Peak loads coincident with the Potomac Edison peaks occurred during February 1992 for the total residence and during the months of November 1991, February 1992, and March 1992 for the water heater.

The average hourly energy consumed by the heat pump, supplemental heaters, and water heater are plotted versus outdoor temperature for the 1990-1991 heating season, Figures 11 (SI) and 11a (IP), and the 1991 cooling season, Figures 12 (SI) and 12a (IP). The graphs were produced by averaging the hourly energy consumption measurements within each 2-degree outdoor temperature increment. The heating season includes all hours of data between September 1, 1990 and May 27, 1991, the period during which the homeowner operated the heat pump in the space heating mode. The homeowner operated the system in the space cooling mode between May 28, 1991 and September 31, 1991. Each temperature entry includes all hours during which the temperature was greater than or equal to the value and less than the temperature entry to its right. For example, the temperature increment labelled 0 °C (32 °F) on Figure 11 includes all hours of data during which the outdoor temperature was greater than or equal to 0 °C (32 °F) but less than 2 °C (35.6 °F).

During the heating season (see fig. 11), above temperatures of 4.0 °C (39.2 °F) supplemental energy was not required to meet the space heating load. As the outdoor temperature decreased below 4.0 °C (39.2 °F), the use of supplemental heat increased, reaching an average hourly value of 15.94 MJ (4.43 kWh) when the outdoor temperature was equal to or above -12.0 °C (10.4 °F) and less than -10.0 °C and (14 °F). It is interesting to note, Figure 11a, that as the outdoor temperature decreased below -6.7 °C (20 °F), the average hourly energy consumed by the heat pump decreased and became essentially constant. This is attributed to the heat pump's control logic which limits the compressor speed to approximately two-thirds its maximum value for outdoor temperatures below -8.3 °C (17 °F). The accompanying reduction in space heating capacity resulted in the heat pump operating continuously during each hour in an attempt to meet the space heating load, with the supplemental heat providing the difference between the space heating load and the heating capacity of the heat pump.

The difference between the actual temperature at which the hourly energy consumed by the heat pump decreased, -6.7 °C (20 °F), and the control logic value of -8.3 °C (17 °F), is attributed to a temperature difference between the outdoor temperature sensor and the sensor utilized by the heat pump's control logic. The outdoor sensor is located on the north side of the residence at an elevation of 8 feet. The heat pump's sensor is located on the exterior of the heat pump at an elevation of 6 inches. A short-term experiment was conducted in which two calibrated thermocouples, one positioned at the outdoor temperature sensor location and a second one adjacent to the heat pump's outdoor temperature sensor, were used to measure



29

AVERAGE ENERGY CONSUMPTION OF HEAT PUMP, SUPPLEMENTAL SPACE HEATER, AND WATER HEATER VERSUS OUTDOOR TEMPERATURE




Figure 11

AVERAGE ENERGY CONSUMPTION OF HEAT PUMP, SUPPLEMENTAL SPACE HEATER, AND WATER HEATER VERSUS OUTDOOR TEMPERATURE




Figure 11a




Figure 12

AVERAGE ENERGY CONSUMPTION OF HEAT PUMP AND WATER HEATER




Figure 12a

the temperature at these two locations for ten days. During the experiment the outdoor temperature ranged from -7.8 °C (18 °F) to 0.6 °C (33 °F). The average temperature measured adjacent to the heat pump's sensor was found to be 1.3 °C (2.4 °F) less than that measured by the ambient sensor, which explains the discrepancy in outdoor temperature at which the compressor's speed reduction occurred.

The energy consumed by the resistance elements within the water heater tends to be negligible for outdoor temperatures between 0 °C (32 °F) and 18 °C (64.4 °F) during the heating season. At temperatures below this range, the energy consumed by the water heater increased with decreasing outdoor temperature. As the space heating load increases, the indoor fan speed increases, supplying more heat to the space heating load and less to the water heating load. Additionally, whenever supplemental heat is required, the control logic prevents water heating by the heat pump and only the resistance heaters within the water heater are used to meet the water heating load. Finally, when the outdoor temperature is less than -8.3 °C (17 °F) the control logic does not permit water heating by the heat pump.

As expected, the average hourly energy consumption of the heat pump increased with outdoor temperature during the cooling season, Figures 12 and 12a. The average energy consumed by the water heater is less than 0.36 MJ (0.1 kWh) for any 2-degree temperature increment and in general decreased as the outdoor temperature increased. The greater usage of energy for heating water at the lower ambient temperatures during the cooling season may be attributed to the fact that the lower outdoor temperatures tend to occur during the early morning hours which coincide with the greatest demand for hot water within this residence.

Indoor and Outdoor Temperatures

The thermostat, located within the living room, was set to 25.6 °C (78 °F) during the cooling seasons and 22.2 °C (72 °F) and 21.1 °C (70 °F) during the first and second heating seasons, respectively. The measured average indoor temperature for each month is shown in Figure 13. During the cooling seasons, the average monthly indoor temperature ranged from 23.4 °C (74.2 °F) to 25.2 °C (77.3 °F), with an overall average of 24.3 °C (75.7 °F). Average indoor temperatures of 21.4 °C (70.6 °F) and 21.1 °C (70.0 °F) were maintained during the 1990 and 1991 heating seasons, respectively.

The variation in living room temperature for a representative month, January 1991, is shown in Figure 14. The radiation-shielded thermocouple which measures the living room temperature is in close proximity to the thermostat. As expected, the master bedroom and family room temperatures, Figures 15 and 16, show greater variations than those measured within the living room. During the month, with a 22.2 °C (72 °F) thermostat set point, the average temperature within the living room was 22.3 °C (72.1 °F) with hourly minimum and maximum values of 21.3 °C (70.4 °F) and 22.9 °C (73.2 °F). The master bedroom's temperature ranged from 19.4 °C (67.0 °F) to 24.4 °C (75.9 °F) with an average value of 22.4 °C (72.3 °F). The average family room temperature was 20.7 °C (69.3 °F) with temperatures varying from 17.7 °C (63.9 °F) to 22.6 °C (72.7 °F).






Figure 14










A similar temperature variation between the three rooms exists during the cooling season months. As an example, during the month of August 1991, the average living room temperature was 25.4 °C (77.7 °F), the average master bedroom temperature was 25.0 °C (77.0 °F), and 23.7 °C (74.7 °F) was recorded for the family room. The consistently lower family room temperature, observed during both the heating and cooling seasons, is attributed to the presence of an on-grade concrete slab floor.


The average monthly outdoor temperatures are shown in Figure 17, ranging from a value of 25.0 °C (77.0 °F) recorded for the month of July 1991 to a monthly average of 1.1 °C (33.9 °F) recorded for January 1991. The highest hourly temperature recorded during the 2-year study was 37.1 °C (98.8 °F) recorded at 5 p.m. on July 21, 1991. The lowest temperature recorded was -12.2 °C (10.1 °F) on January 19, 1992 at 9 a.m. The number of 18.3 °C (65 °F) heating degree days was 4,156 during the 1990-91 heating season and 4,711 during the 1991-92 heating season. Figure 18 shows the relationship between the space heating load and the number of heating degree days for each month.

Advanced Integrated Heat Pump System Performance


The advanced integrated heat pump system became operational in February 1990, 3 months before the monitoring effort commenced. After 3 years of operation, there have been two problems associated with the heat pump system. A noisy electrical contactor was replaced during the monitoring period with no loss of data. The water pump used to circulate water from the water heater through the refrigerant-to-water heat exchanger failed after the monitoring was complete.

The performance of the heat pump is summarized in Tables 2 and 2A on a monthly, seasonal, and annual basis. The thermal load of the residence is separated into heating and cooling loads, column C. The space conditioning loads for the two heating seasons were essentially equal, whereas the 1991 space cooling load was substantially greater than the space cooling load measured in 1990, 14,707 MJ (4085.4 kWh) versus 11,322 MJ (3145.0 kWh). During the months of September 1990 and May 1991 the heat pump operated in both the space heating and cooling modes. The total energy consumed by the heat pump system (neglecting the supplemental heater), column G, is divided into energy consumed in the various operational modes in columns H through L. Figure 19 shows the energy consumed by the heat pump, ignoring the supplemental heater, in its various modes for each month from June 1991 to May 1992. The data collection software did not initially permit the breakdown of total heat pump energy consumption into the energy consumed during various modes of operation, and was altered at the end of July 1990 to obtain this additional information. During the 1991 cooling season (May 1, through September 31), 2,235.6 MJ (621.0 kWh) of energy was consumed in the combined space cooling and water heating mode compared to an energy consumption of 1,881.7 MJ (522.7 kWh) while operating in the space cooling only mode. When a substantial space heating load exists, for example, November 1991 through March 1992, the majority of energy is consumed during the times in which the









heat pump is operated in the space heating only mode 8,414 MJ (2337.2 kWh), followed by space and water heating 5,640 MJ (1566.7 kWh), and finally water heating only, 2,715.5 MJ (754.3 kWh). The heat pump consumes the largest amount of energy while operating in the water heating only mode during temperate months, such as September, October, March, and April. Column N lists the space conditioning mode in which the heat pump operated during each month.

The monthly cooling coefficients of performance, Column O, and monthly heating coefficients of performance, Column P, are computed using data collected when the heat pump was operating in the space conditioning only mode. Thus, the energy consumed by the heat pump and space conditioning loads during time intervals in which the heat pump was operating in the combined or water heating only modes are not included in these columns. The total parasitic energy, the energy consumed when the unit is not space conditioning and/or water heating, is included in the calculation of the monthly cooling and heating coefficients of performance. Parasitic energy is computed by taking the total heat pump energy, column G, and subtracting the energy consumed for each of the operational modes, columns H through L. During months in which both space heating and cooling took place, the parasitic energy is allocated in proportion to the length of time the heat pump operated in each mode.

The monthly cooling coefficient of performance is defined as

$$MCCOP = \frac{Q_{LSCO}}{E_{SCO} + E_{PAR}} \tag{1}$$

where

 Q_{LSCO} is the monthly space cooling load when the heat pump provides space cooling only, MJ (MBtu),

 E_{SCO} is the monthly energy consumed by the heat pump when the unit operates in the space cooling only mode, MJ (kWh),

and

E_{PAR} represents the monthly energy consumed by the heat pump when the unit is not providing any space conditioning and/or water heating, MJ (kWh).

The monthly cooling coefficient of performance ranged from a low value of 2.50, September 1991, to 4.03 recorded for the month of June 1990. The inclusion of parasitic or "standby" energy has a significant impact on both heating and cooling coefficients of performance. This impact is greatest for months in which a low space conditioning and/or water heating load exists. For example, during the month of September 1991 the coefficient of performance was 2.5, but would have been 4.40 if no parasitic energy was consumed during standby intervals.

The cooling seasonal coefficient of performance is defined as,

$$CSCOP = \frac{\sum_{i=1}^{n} Q_{LSCO}}{\sum_{i=1}^{n} E_{SCO} + \sum_{i=1}^{n} E_{PAR}}$$
 (2)

where the monthly quantities Q_{LSCO} , and E_{SCO} , and E_{PAR} are summed over the number of months, n, is which space cooling only took place. The cooling seasonal coefficient of performance for the 1990 season was 3.72 (corresponding to a SEER of 12.68 Btu/Wh), whereas for the second cooling season, the heat pump achieved a cooling seasonal coefficient of 3.52 (corresponding to a SEER of 12.02 Btu/Wh). Without parasitic energy consumption, the SEER values would have risen to 14.83 Btu/Wh and 14.49 Btu/Wh, respectively. The annual cooling coefficients of performance, 3.73 for the first year of the study and 3.50 for the second year, are calculated using eq (2) and summing the variables over each year.

In a similar manner, the monthly heating coefficient of performance is defined as

$$MHCOP = \frac{Q_{LSHO}}{E_{SHO} + E_{SUPP} + E_{PAR}}$$
 (3)

where

 Q_{LSHO} is the monthly space heating load when the heat pump provides space heating only, MJ (MBtu),

 E_{SUPP} is the monthly energy consumed by the supplemental electric resistance heaters, MJ (kWh),

and

E_{SHO} is the monthly energy consumed by the heat pump when the unit operates in the space heating only mode, MJ (kWh).

The monthly heating coefficient of performance ranged from a low of 0.91, May 1991, to 3.33 for the month of April 1991. The lower values tended to occur primarily during months in which the energy consumed by the heat pump in the "standby" mode is significant in comparison to the energy consumed by the heat pump while operating in the space heating only mode. The higher heating coefficients of performance occurred for months in which a significant space heating load existed, which was met without the assistance of the supplemental resistance heaters.

The heating seasonal coefficient of performance is computed in an identical manner to that used to compute the monthly heating coefficient of performance, eq (3), except the space heating load, energy consumed by the heat pump while operating in the space heating only mode, supplemental energy consumption, and parasitic energy are the seasonal totals, rather than monthly values. The heating seasonal coefficients of performance and annual heating

coefficients of performance were all identical with a value of 2.63 corresponding to a heating seasonal performance factor of 8.98. Without parasitic energy consumption, the heating seasonal coefficient of performance would have risen to a value of 2.82 for the 1990-91 heating season and 2.80 for the 1991-92 heating season.

Column Q, the water heater coefficient of performance, is a performance index based on data collected during times in which the heat pump operates in the water heating only mode, i.e.,

$$COP_{WH} = \frac{Q_{HPWH}}{E_{WHO}} \tag{4}$$

where

Q_{HPWH} is the energy delivered by the heat pump to the water heater when the unit operates in the water heating only mode, MJ (Btu),

and

 E_{WHO} represents the energy consumed by the heat pump when the unit operates in the water heating only mode, MJ(kWh).

The monthly water heating coefficients of performance are plotted versus average monthly outdoor temperature in Figure 20. As expected, the higher the average outdoor temperature the greater the water heating coefficient of performance, ranging from a value of 1.11, January 1991, to an upper value of 2.05 for July 1991. The seasonal and annual values were calculated by summing the variables in eq (4) over the appropriate time intervals. The seasonal water heating coefficients of performance for the 1991 and 1992 cooling seasons are 1.92 and 1.96, compared to 1.42 and 1.40 for the heating seasons. The annual water heating coefficients of performance were 1.47 for June 1990 through May 1991 and 1.50 for June 1991 through May 1992.

The combined performance factor, Column R, is an index proposed by Dougherty [1-2] to quantify the performance of combined appliances. This factor represents the ratio of the energy delivered by the heat pump and water heater in the form of space heating, space cooling and/or water heating loads to the energy consumed by the heat pump, supplemental heaters, and water heater, i.e.


$$CPF = \frac{Q_{CL} + Q_{HL} + Q_{HWL}}{E_{HP} + E_{SUPP} + E_{WH}}$$
 (5)

where

 Q_{CL} is the total monthly space cooling load, MJ (MBtu)

 Q_{HL} is the total monthly space heating load, MJ (MBtu)

 Q_{HWL} is the total monthly domestic water heating load, MJ (MBtu)




 E_{HP} is the total monthly energy consumed by the heat pump excluding supplemental energy consumption, MJ (MBtu)

 E_{SUPP} is the total monthly energy consumed by the supplemental heaters, MJ (MBtu)

and E_{WH} is the total monthly energy consumed by the water heater, MJ (MBtu).

Figure 21 shows the combined performance factor for each month which ranged from a low of 1.55 to a high of 3.5. The combined performance factors are substantially greater during the cooling months as opposed to months when space heating is required, Tables 2 and 2A. This can be partially attributed to the fact that during the space cooling season, energy removed from the house is transferred to the water heater, the supplemental resistive heaters are not needed, and energy is not removed from the water heater to defrost the outdoor coil.

The cooling season, heating season, and annual combined performance factors, Tables 2 and 2A, are computed in an identical manner to that used to compute the monthly combined performance factors except the values in eq (5) are summed over appropriate time intervals. The combined performance factor for the entire 24 month monitoring period is 2.47. Thus, for every unit of energy consumed by the heat pump and water heater, 2.47 units were supplied in the form of domestic water heating, space heating, and/or space cooling. The effect of parasitic energy consumption has a relatively small effect on the combined performance factor. For example, if the heat pump had not consumed any parasitic energy during the second year, the combined performance factor would have increased from 2.45 to 2.51, a 2.4% increase.



SUMMARY

An integrated heat pump/water heating appliance was extensively monitored for 2 years. The heat pump system incorporated variable-speed components, microprocessor-based control logic, and a refrigerant-to-water heat exchanger. The heat pump used in this study operates in five-distinct modes: space cooling only, space cooling and water heating, space heating only, space and water heating, and water heating only.

The heat pump was instrumented with temperature, relative humidity, watt/watthour, air flow rate, and water flow rate transducers. An electronic digital power analyzer was used to monitor the energy consumption of the heat pump in addition to a conventional residential watthour meter, in order to address concerns regarding the accuracy of conventional utility metering equipment when variable-speed equipment is present within a residence.

The total energy consumed by the residence after installation of the heat pump system was an estimated 52% less than the amount consumed prior to the study, by electric baseboard heaters, a wood stove, and window air-conditioners. The latter were used to cool approximately one-third of the residence. A comparison between the electrical energy consumed by the heat pump and water heater during the monitoring period to the energy which would have been consumed if an electric furnace with the same air distribution systems and an identical water heater had been used during the space heating months suggests a 60% reduction in total electrical energy consumption.

The electric resistance heaters within the water heater accounted for 1.2% of the total energy consumed by the residence, after the integrated heat pump/water heating appliance was installed, followed by the supplemental resistance heaters (3.6%), heat pump (44.7%), and base load (50.5%). Agreement between the measured energy consumption of the heat pump system using two different instruments, a residential watthour meter and an electronic digital power analyzer, over the entire 2-year monitoring period was excellent. Month-to-month variations ranged from -1.4% to 2.4% with variations for the vast majority of months being within the error bands of the two instruments, 0.6%.

The maximum hourly demand for the residence, heat pump, water heater, and supplemental heaters was recorded for each month. The peak demand of the residence ranged from 5.80 kJ/s (5.80 kW) in June 1990 to a high of 17.00 kJ/s (17.00 kW) during the month of November 1990. The highest peak demands recorded during the study were 3.70 kJ/s (3.70 kW) for the heat pump, 5.30 kJ/s (5.30 kW) for the supplemental resistance heaters, and 2.97 kJ/s (2.97 kW) for the water heater.

The average energy consumed by the heat pump, supplemental heaters, and water heater was computed for 2 °C and 2 °F increments over the range of outdoor temperatures encountered during the study. During the heating seasons, the use of supplemental heaters was not required to meet the space heating load when outdoor temperatures exceeded 4.4 °C (40 °F). As expected, the average hourly energy consumption of the supplemental heaters increased

with decreasing outdoor temperature, reaching a value of 15.94 MJ (4.43 kWh) as the outdoor temperature approached -11.1 °C (12 °F). As the outdoor temperature decreased below -6.7 °C (20 °F), the hourly energy consumed by the heat pump became constant due to control logic which limits the compressor speed to two-thirds of its maximum value for outdoor temperatures below -8.3 °C (17 °F), while supplemental energy consumption increased to meet the space heating load. During the cooling season, the average hourly energy consumption of the heat pump increased with increasing outdoor temperature reaching a value of 6.59 MJ (1.83 kWh) for ambient temperatures exceeding 36.7 °C (98 °F). The average hourly energy consumption values for the water heater during the cooling season were always less than 0.05 MJ (0.05 kWh), independent of the outdoor temperature.

The majority of energy used by the heat pump during the heating season is consumed while providing space heating only, closely followed by energy consumed when operating in the combined space and water heating mode. During the cooling seasons, the energy consumed by the heat pump while operating in the space cooling mode is roughly equivalent to that consumed by the heat pump while operating in the combined space cooling and water heating mode. The quantity of energy consumed while operating in the water heating only mode tends to be substantially less than that used during operating in the space conditioning only or combined modes. The exception is for temperate months such as September, October, April, and May. The monthly parasitic energy was relatively constant having an average value of 100.8 MJ (28 kWh).

The monthly cooling coefficient of performance ranged from a low value of 2.50 to a value of 4.03. The inclusion of parasitic or "standby" energy had a significant impact on the monthly cooling efficiency ratio for months in which the space cooling load and/or water heating load is small. For example, the lowest value of the monthly cooling coefficient of performance was 2.5, but would have been 4.40 if parasitic energy was not consumed during standby intervals. The seasonal cooling coefficients of performance were 3.72 (SEER of 12.70 Btu/W) and 3.52 (SEER of 12.02 Btu/W) for the 1990 and 91 cooling seasons, respectively.

The monthly heating coefficients of performance ranged from 0.91 to 3.33. The higher values were recorded during months in which a significant space heating load existed which was met without the assistance of supplemental resistance heaters. The lower monthly values occurred during periods in which parasitic energy was a significant portion of the total energy consumed by the heat pump. The heating seasonal coefficients of performance were identical for the two heating seasons, 2.63 equivalent to an HSPF of 8.99 Btu/Wh.

The monthly water heating coefficients of performance ranged from a value of 1.11 to an upper value of 2.05. The values for the cooling seasons were 1.92 for 1990 and 1.96 for 1991, as compared to the 1.42 and 1.40 values recorded during the 1990-91 and 1991-92 heating seasons. The water heating coefficient of performance was found to be proportional to the outdoor temperature.

A performance indicator proposed by Dougherty [1-2] to quantify the overall performance of combined appliances was utilized in this study. This indicator, named a combined performance factor, is the ratio of the space conditioning and water heating loads divided by the energy consumed by the heat pump for space heating and cooling, supplemental heaters, and water heater. A combined performance factor of 2.0 would indicate that for every unit of energy consumed by the heat pump, supplemental heaters, and water heater two units of energy were delivered by the heat pump and water heater to meet the space cooling, space heating, and/or water heating loads. The monthly combined performance factor ranged from a low of 1.5 to 3.5. The seasonal combined performance factors for the cooling seasons were substantially higher than those obtained during the heating seasons. For example, the 1990 cooling season combined performance factor was 3.18 compared to a value of 2.34 for the 1990-91 heating season. The combined performance factor for the entire 24 month monitoring period was 2.45. Thus, 2.45 units of energy were delivered for space conditioning (heating and cooling) and water heating for every unit of electricity purchased.

ACKNOWLEDGMENTS

This research has been supported by the Allegheny Power System through The Potomac Edison Company. The author would like to thank the following employees of the Allegheny Power System: Timothy Croushore, Jerry Davis, Bill Guyker, and John Hose for project guidance; Merle Guyton, Chuck Barger, and Dave Raymer for installing the advanced integrated heat pump system and associated duct work; and Chuck and Mary Barger who volunteered their home for the study and assisted NIST in all phases of the project.

Kevin Dunshee and John Ferguson of the Carrier Corporation have been extremely helpful in answering questions related to the operation of the heat pump system used in this study. Their eagerness to help is greatly appreciated.

The following NIST personnel were instrumental in conducting the project: Donn Ebberts for calibrating and installing the instrumentation; Teresa Wright for writing the data reduction software; Ken Kramp, Daniel Shapiro, and Chris Saunders who assisted in the preparation of this report; Brian Dougherty, George Kelly and Steve Petersen for providing insight and valuable suggestions throughout this project; Ray Mele for producing the graphics within this report; and Flora Parsons for preparing the manuscript.

REFERENCES

- [1] Department of Energy Proposed Rule on a Uniform Method for Measuring the Energy Consumption of A Combined Heat Pump Water Heating Appliances. To be published in the Federal Register.
- [2] Dougherty, Brian P. Laboratory Performance of A Combined Heat Pump Water Heating Appliance. Electric Power Research report in preparation.
- [3] Baldwin, A. J. and Planer. Evaluation of Electrical Interference to the Induction Watthour Meter. Electric Power Research Institute. Report No. EL-2315; 1982 April.
- [4] Grady, W.M. Power System Harmonics and the Potential Impact of Residential ASD Heat Pumps. Presentation to the EPRI Advanced Heat Pump Interest Group; 1991 April.
- [5] Gray, L. <u>The Complete Book of Heating with Wood</u>. Charlotte, Vermont, Garden Way Publishing; 1977.
- [6] ASHRAE. <u>1992 ASHRAE Handbook--HVAC Systems and Equipment</u>. American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.; 1992. p 30.5.



U.S. DEPARTMENT OF COMMERCE (ERB USE ONLY) **NIST-114** ERB CONTROL NUMBER DIVISION (REV. 9-92) NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY **ADMAN 4.09** W931073 863 **PUBLICATION REPORT NUMBER** CATEGORY CODE MANUSCRIPT REVIEW AND APPROVAL NIST/BSS-171 140 INSTRUCTIONS: ATTACH ORIGINAL OF THIS FORM TO ONE (1) COPY OF MANUSCRIPT AND SEND TO: **PUBLICATION DATE** NUMBER PRINTED PAGES THE SECRETARY, APPROPRIATE EDITORIAL REVIEW BOARD 60 June 1993 TITLE AND SUBTITLE (CITE IN FULL) Field Monitoring of a Variable-Speed Integrated Heat Pump/Water Heating Appliance CONTRACT OR GRANT NUMBER TYPE OF REPORT AND/OR PERIOD COVERED R&D Project Number RP 89-60 Final AUTHOR(S) (LAST NAME, FIRST INITIAL, SECOND INITIAL) PERFORMING ORGANIZATION (CHECK (X) ONE BOX) NIST/GAITHERSBURG Fanney, A. Hunter NIST/BOULDER JILA/BOULDER LABORATORY AND DIVISION NAMES (FIRST NIST AUTHOR ONLY) Building and Fire Research Laboratory, Building Environment Division SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (STREET, CITY, STATE, ZIP) Allegheny Power System, Cabin Hill, Greensburg, PA 15601 RECOMMENDED FOR NIST PUBLICATION JOURNAL OF RESEARCH (NIST JRES) MONOGRAPH (NIST MN) LETTER CIRCULAR J. PHYS. & CHEM. REF. DATA (JPCRD) NATL. STD. REF. DATA SERIES (NIST NSRDS) **BUILDING SCIENCE SERIES** HANDBOOK (NIST HE) FEDERAL INF. PROCESS. STDS. (NIST FIPS) PRODUCT STANDARDS SPECIAL PUBLICATION (NIST SP) LIST OF PUBLICATIONS (NIST LP) OTHER **TECHNICAL NOTE (NIST TN)** NIST INTERAGENCY/INTERNAL REPORT (NISTIR) RECOMMENDED FOR NON-NIST PUBLICATION (CITE FULLY) **FOREIGN PUBLISHING MEDIUM** U.S. CD-ROM ASHRAE Transactions PAPER DISKETTE (SPECIFY) OTHER (SPECIFY) SUPPLEMENTARY NOTES In addition to being published as a BSS, an abbreviated version will be submitted to ASHRAE for inclusion in ASHRAE Transactions. ABSTRACT (A 1500-CHARACTER OR LESS FACTUAL SUMMARY OF MOST SIGNIFICANT INFORMATION. IF DOCUMENT INCLUDES A SIGNIFICANT BIBLIOGRAPHY OR LITERATURE SURVEY, CITE IT HERE, SPELL OUT ACRONYMS ON FIRST REFERENCE,) (CONTINUE ON SEPARATE PAGE, IF NECESSARY,) This report summarizes a study in which a variable-speed integrated heat pump/water heating appliance was monitored for two years while meeting the space conditioning and water heating needs of an occupied residence. Experimental results are presented which show that the total energy consumed by the residence was significantly reduced compared to previous years in which electric baseboard heat, a wood stove, and window air-conditioners were used. During the two space heating seasons, the variable-speed integrated heat pump/water heating appliance used 60% less energy than would have been consumed by an electric furnace with the same air distribution system and a storage-type electric water heater. The monthly space cooling only coefficients of performance ranged from 2.50 to 4.03, whereas, the monthly space heating only coefficients of performance ranged from a low of 0.91 to a high of 3.33. A proposed index to quantify the overall system performance of integrated water heating/space conditioning appliances, referred to as the combined performance factor, ranged from 1.55 to 3.50. The majority of larger values occurred during months in which space cooling dominated. The combined performance factor for the entire two-year study was 2.45. A conventional watthour meter supplied by the local electrical utility and an electronic digital power analyzer were used to measure the energy consumption of the variable speed heat pump in order to discern if variable-speed equipment introduces errors in conventional utility metering equipment. Measurements made using the two instruments were in excellent agreement, The monthly energy consumption and peak electrical demands of the residence, integrated heat pump/water heating appliance, supplemental space heater, and water heater are discussed. The influence of outdoor temperature on electrical power demand is presented. KEY WORDS (MAXIMUM 9 KEY WORDS; 28 CHARACTERS AND SPACES EACH; ALPHABETICAL ORDER; CAPITALIZE ONLY PROPER NAMES) building technology; coefficient of performance; combined performance factor; field study; heat pump; HSPF; integrated water heating; peak demand; SEER, thermal performance; variable speed AVAILABILITY NOTE TO AUTHOR(S): IF YOU DO NOT WISH THIS FOR OFFICIAL DISTRIBUTION. DO NOT RELEASE TO NTIS. UNLIMITED MANUSCRIPT ANNOUNCED BEFORE PUBLICATION, х ORDER FROM SUPERINTENDENT OF DOCUMENTS, U.S. GPO, WASHINGTON, DC 20402 PLEASE CHECK HERE. ORDER FROM NTIS, SPRINGFIELD, VA 22161

ELECTRONIC FORM







NIST Technical Publications

Periodical

Journal of Research of the National Institute of Standards and Technology—Reports NIST research and development in those disciplines of the physical and engineering sciences in which the Institute is active. These include physics, chemistry, engineering, mathematics, and computer sciences. Papers cover a broad range of subjects, with major emphasis on measurement methodology and the basic technology underlying standardization. Also included from time to time are survey articles on topics closely related to the Institute's technical and scientific programs. Issued six times a year.

Nonperiodicals

Monographs – Major contributions to the technical literature on various subjects related to the Institute's scientific and technical activities.

Handbooks – Recommended codes of engineering and industrial practice (including safety codes) developed in cooperation with interested industries, professional organizations, and regulatory bodies.

Special Publications—Include proceedings of conferences sponsored by NIST, NIST annual reports, and other special publications appropriate to this grouping such as wall charts, pocket cards, and bibliographies.

Applied Mathematics Series—Mathematical tables, manuals, and studies of special interest to physicists, engineers, chemists, biologists, mathematicians, computer programmers, and others engaged in scientific and technical work.

National Standard Reference Data Series—Provides quantitative data on the physical and chemical properties of materials, compiled from the world's literature and critically evaluated. Developed under a worldwide program coordinated by NIST under the authority of the National Standard Data Act (Public Law 90-396). NOTE: The Journal of Physical and Chemical Reference Data (JPCRD) is published bimonthly for NIST by the American Chemical Society (ACS) and the American Institute of Physics (AIP). Subscriptions, reprints, and supplements are available from ACS, 1155 Sixteenth St., NW, Washington, DC 20056.

Building Science Series – Disseminates technical information developed at the Institute on building materials, components, systems, and whole structures. The series presents research results, test methods, and performance criteria related to the structural and environmental functions and the durability and safety characteristics of building elements and systems.

Technical Notes—Studies or reports which are complete in themselves but restrictive in their treatment of a subject. Analogous to monographs but not so comprehensive in scope or definitive in treatment of the subject area. Often serve as a vehicle for final reports of work performed at NIST under the sponsorship of other government agencies.

Voluntary Product Standards — Developed under procedures published by the Department of Commerce in Part 10, Title 15, of the Code of Federal Regulations. The standards establish nationally recognized requirements for products, and provide all concerned interests with a basis for common understanding of the characteristics of the products. NIST administers this program in support of the efforts of private-sector standardizing organizations.

Consumer Information Series – Practical information, based on NIST research and experience, covering areas of interest to the consumer. Easily understandable language and illustrations provide useful background knowledge for shopping in today's technological marketplace.

Order the above NIST publications from: Superintendent of Documents, Government Printing Office, Washington, DC 20402.

Order the following NIST publications—FIPS and NISTIRs—from the National Technical Information Service, Springfield, VA 22161.

Federal Information Processing Standards Publications (FIPS PUB) — Publications in this series collectively constitute the Federal Information Processing Standards Register. The Register serves as the official source of information in the Federal Government regarding standards issued by NIST pursuant to the Federal Property and Administrative Services Act of 1949 as amended, Public Law 89-306 (79 Stat. 1127), and as implemented by Executive Order 11717 (38 FR 12315, dated May 11, 1973) and Part 6 of Title 15 CFR (Code of Federal Regulations).

NIST Interagency Reports (NISTIR)—A special series of interim or final reports on work performed by NIST for outside sponsors (both government and non-government). In general, initial distribution is handled by the sponsor; public distribution is by the National Technical Information Service, Springfield, VA 22161, in paper copy or microfiche form.

U.S. Department of Commerce National Institute of Standards and Technology Gaithersburg, MD 20899

Official Business Penalty for Private Use \$300