

Reference

NBS
Publi-
cations

NATL INST OF STAND & TECH



A11106 978772

~~A11101 726683~~

NBSIR 78-1485

Low Velocity Performance of a Ball Bearing Vane Anemometer

L. P. Purtell

National Bureau of Standards
Fluid Engineering Division
Washington, D.C. 20234

June 1978

Task Report
on
Contract No. H0166198
Evaluation of the Behavior of Mine Anemometers in the NBS Low
Velocity Calibration Facility

Prepared for
**United States Department of the Interior
Bureau of Mines**

QC
100
.U56
78-1485

APR 17 1979

not acc-1978
26100
1036
73-117-402

NBSIR 78-1485

**LOW VELOCITY PERFORMANCE OF A
BALL BEARING VANE
ANEMOMETER**

L. P. Purtell

Fluid Engineering Division
Center for Mechanical Engineering
and Process Technology
National Engineering Laboratory
National Bureau of Standards
Washington, D.C. 20234

June 1978

Task Report

Prepared for
United States Department of the Interior
Bureau of Mines



NBS Interagency Report, NBSIR 78-1485

U.S. DEPARTMENT OF COMMERCE, Juanita M. Kreps, Secretary

Dr. Sidney Herman, Under Secretary

Jordan J. Baruch, Assistant Secretary for Science and Technology

NATIONAL BUREAU OF STANDARDS, Ernest Ambler, Director



- FOREWORD -

This report was prepared by the National Bureau of Standards, Fluid Engineering Division, Washington, D. C. 20234, under USBM Contract Number H0166198. The contract was initiated under the Coal Mine Health and Safety Program. It was administered under the technical direction of PM&SRC, with Dr. George H. Schnakenberg, Jr., acting as the Technical Project Officer. Mr. H. R. Eveland was the contract administrator for the Bureau of Mines.

This report is a summary of the work recently completed as part of this contract during the period February 1, 1977 to March 31, 1977. This report was submitted by the author June 1978.

LIST OF SYMBOLS

U	velocity measured by laser velocimeter
U_i	velocity indicated by anemometer under test
U_{if}	line segments fitted to U , U_i data
\bar{U}	group mean true velocity
\bar{U}_i	group mean indicated velocity
σ_i	standard deviation of U_i data from U_{if}
σ	standard deviation of U_i data expressed as true velocity
σ_c	σ adjusted for known variance in laser velocimeter measurements

LOW VELOCITY PERFORMANCE OF A BALL BEARING VANE ANEMOMETER

L. P. Purtell

1. INTRODUCTION

The National Bureau of Standards in order to meet the need for a calibration capability with adequate accuracy at low air velocities, i.e., below 500 feet per minute (fpm) undertook the development of a low-velocity calibration facility for wind speed measuring instruments which would provide a capability down to 3 meters per minute (approximately 10 fpm) with an accuracy of plus or minus one percent. It was a natural consequence therefore that when said facility became operational to undertake an evaluation of the state-of-the-art and to provide the information needed as to the reliability and performance of instrumentation for such measurement. Accordingly, a number of prototypes of various types of instruments for low velocity air measurements are undergoing test at NBS, and this report is concerned specifically with the results of one such test.

2. THE INSTRUMENT

The rotary vane anemometer tested for this report is a commercially available instrument (Davis Instrument Manufacturing Co., Inc., 4-Inch Low Speed Anemometer, S/N 24323 B)¹ used in the mining industry and elsewhere as a portable anemometer. It was supplied for test by the U. S. Mining Enforcement and Safety Administration (MESA) at the request of the U. S. Bureau of Mines. The housing is 4 inches in diameter and 1-3/4 inches deep (Figure 1). Thin metal vanes without camber or twist mounted on arms drive a rotor linked to a dial indicator by a gear train. The bearings in this particular instrument are ball bearings (as opposed to standard bronze sleeve bearings). One revolution on the dial represents an indicated passage of 100 feet of air through the instrument. Thus an external timer (not a part of the anemometer) is required to complete a measurement of velocity (an average velocity for the duration of the measurement).

¹

This particular instrument was selected as being representative of this type of anemometer and its selection does not represent an endorsement.

3. THE TESTS

The NBS Low Velocity Airflow Facility [1] used to test this instrument generates a low velocity air stream having a low turbulence intensity (less than 0.05%) and a large region of uniform flow (at least 75 x 75 cm). A laser velocimeter is employed as a primary velocity standard. It is nonintrusive, has a linear response with velocity, and has good spatial resolution. Adequate sensitivity is obtained without the artificial seeding of scattering particles. Thus the difficulties and inconvenience associated with seeding and the possible effect of such seeding on the performance of the device under test are avoided.

The vane anemometer was mounted on the centerline of the tunnel test section one meter downstream of the entrance to the test section in a manner to minimize the effect of the support on the air stream around the anemometer (Figure 1). Since the anemometer itself modifies the airflow in the tunnel, the velocity should be measured at a location in the flow which has the same velocity in the presence of the anemometer as it does in the absence of the anemometer. Since this anemometer is identical in shape to a bronze bearing anemometer tested previously, the results are used from the tests on that instrument wherein the velocity upstream of the anemometer on the centerline was measured to find the position where deceleration of the flow due to the presence of the anemometer was no longer detectable within the scatter of the measurements. These measurements were performed at two free-stream speeds, 700 and 72 fpm, and as predicted by ideal flow theory the variation of the ratio of the local velocity to the free-stream velocity with distance upstream of the anemometer is independent of free-stream velocity (Figure 2). A distance of 30 cm upstream of the anemometer was chosen as the position for velocity measurement by the laser velocimeter. With no anemometer in the tunnel, variation in velocity along the centerline is imperceptible over the distance traversed (30 cm).

The air speed indicated by the vane anemometer was computed from initial and final readings of the dial and of the associated time interval (around two minutes). The anemometer runs continuously in the tunnel since it cannot be accessed while the tunnel is in operation without disturbing the flow. Thus the readings of the anemometer were performed with the anemometer in operation. The laser velocimeter measurement of the air velocity was performed during the time interval for reading the vane anemometer. Five separate test runs were made, each consisting of about ten such measurements over the range 23 to 724 fpm. The lower velocity was limited by the starting and stopping speeds of the instrument. The data are presented in chronological order in Tables 1A to 1E.

To determine the starting speeds of the instrument, the velocity in the tunnel was increased from below the starting speed at a smooth acceleration of approximately 30 fpm/min until movement of the vanes could be detected by eye. At that moment the air velocity would be fixed and the laser velocimeter measurements initiated. If the anemometer continued rotating for at least thirty seconds and did not decelerate, the measurement of velocity by the laser velocimeter was recorded as the starting speed. Ten such measurements are presented in Table 2 and have an average of 23.3 fpm and a standard deviation of 1.3 fpm.

Because of the anemometer's angular momentum, stopping speed is more difficult to determine than starting speed. Some preliminary runs indicated that a two minute interval between reductions in air velocity of approximately 2 fpm was sufficient for the anemometer to come to rest if the stopping speed had been reached. Ten such measurements are presented in Table 3 with an average of 18.2 fpm and a standard deviation of 0.4 fpm.

4. TEST RESULTS

Since a particular air speed in the wind tunnel cannot be exactly reset from run to run, scatter in the test data is distributed along a curve, thus prohibiting computing the standard deviation of the data from a simple average. Instead, deviations from a curve fit to the data were computed and the standard deviation approximated by the r.m.s. value of these deviations within a group. The groups are

	U < 28	fpm
28 fpm < U < 35		fpm
35 fpm < U < 45		fpm
45 fpm < U < 60		fpm
60 fpm < U < 80		fpm
80 fpm < U < 130		fpm
130 fpm < U < 180		fpm
180 fpm < U < 300		fpm
300 fpm < U < 600		fpm
600 fpm < U		

Since a curve fit to the data would have very little curvature and since the groups of data are compact (small range of U within a group; see Fig. 3), a straight line segment is used to approximate the curve within a group. The line segment passes through the point (\bar{U}, \bar{U}_i) , the group mean true velocity and the group mean indicated velocity. The slope of the line segment is computed as the average of the slopes of two lines, both passing through (\bar{U}, \bar{U}_i) of the group being considered, one line passing

through the (\bar{U}, \bar{U}_i) of the adjacent group higher in velocity, and one line passing through (\bar{U}, \bar{U}_i) of the adjacent group lower in velocity. For the highest group ($U > 600$ fpm) there is only one adjacent group, and thus the line segment for this highest group passes through (\bar{U}, \bar{U}_i) of that adjacent group. The line segment for the lowest group ($U < 28$ fpm) is similarly formed.

Designating the above line segments as U_{if} , the standard deviation, σ_i of the indicated velocity, U_i , about the fitted segments is determined by squaring the differences between the U_i data and U_{if} , i.e., $[U_i(U) - U_{if}(U)]^2$. Since the data within the specified groups are reasonably compact, the mean of the squared differences within a group is taken as an estimate of the variance of U_i about U_{if} within that group and specified at that group's mean true velocity, \bar{U} . To convert this to a standard deviation in terms of true velocity, designated σ , each $\sigma_i(\bar{U})$ is divided by the slope (dU_{if}/dU) of the line segment associated with the $\sigma_i(\bar{U})$. Note that this σ does not include the "scatter" in the U measurements (due to the inability to exactly reset the wind tunnel to a specified speed), but does include the uncertainty in a particular laser velocimeter measurement. This uncertainty may be estimated from repeated measurements of velocity at a particular fan setting, thus also including any unsteadiness in the velocity, and is estimated as $0.005U$ for this report. A standard deviation, σ_c , corrected for the laser velocimeter uncertainty may thus be computed from

$$\sigma_c = \sigma^2 - (0.005U)^2$$

for any given U . σ and σ_c are presented in Figure 4 as velocity and Figure 5 as percentage of \bar{U} . Since $\pm 2\sigma_c$ is extremely close to the 95 percent confidence interval for one measurement, curves of $\pm 2\sigma_c$ are also included in Figure 3 as dashed lines.

The actual differences between the true and indicated velocities, $U - U_i$, are presented in Figure 6 and as a percentage of U in Figure 7. The curves shown in each figure have been drawn for reference only.

5. DISCUSSION OF RESULTS

The instrument performed over the speed range tested with no erratic behavior. The repeatability of the starting and stopping speeds was quite good having standard deviations of 1.3 fpm (5.6%) and 0.4 fpm (2.2%), respectively. Some general comments concerning application of the instrument follow. With any measurement problem the instrument's capabilities should be matched to the required measurement.

This anemometer is intrusive, i.e., it must be placed in the flow.

This anemometer is entirely mechanical and does not require an outside source of power.

Many other factors that can affect the suitability of an instrument for a particular application, such as turbulence or unsteadiness of the air stream, rough handling (shock and vibration), dirt and other environmental factors, time, orientation to the velocity and gravity vectors, etc., have not been tested herein but should be considered.

6. SUMMARY

The performance of a 4-inch diameter low speed vane anemometer with ball bearings has been evaluated, including starting speed and stopping speed, at air speeds up to 724 fpm.

The starting and stopping speed measurements are presented and give an average starting speed of 23.3 fpm and an average stopping speed of 18.2 fpm.

7. REFERENCES

1. L. P. Purtell and P. S. Klebanoff, The NBS Low Velocity Airflow Facility, in preparation.

Table 1 A
 Davis Vane Anemometer
 Serial No. 24323 B

Indicated Air Speed, fpm	True Air Speed, fpm
712	692
205	211
466	455
80.4	93.0
56.5	72.0
33.2	50.4
12.4	30.3
23.1	40.8
5.8	24.0

T = 20.9 to 21.0 °C
 B = 745.7 mm Hg

Table 1 B
 Davis Vane Anemometer
 Serial No. 24323 B

Indicated Air Speed, fpm	True Air Speed, fpm
752	724
218	224
491	484
85.6	99.3
60.8	73.1
37.1	51.1
14.3	29.6
24.8	40.6
6.8	23.0
151	158

T = 21.7 to 21.9 °C
 B = 744.8 mm Hg

Table 1 C
 Davis Vane Anemometer
 Serial No. 24323 B

Indicated Air Speed, fpm	True Air Speed, fpm
717	690
206	209
468	458
80.5	94.4
57.5	71.1
35.0	51.5
12.2	30.7
22.7	41.7
8.1	26.4
144	150

T = 21.3 °C
 B = 747.1 mm Hg

Table 1 D
 Davis Vane Anemometer
 Serial No. 24323 B

Indicated Air Speed, fpm	True Air Speed, fpm
715	696
206	215
469	466
80.3	96.0
56.8	72.0
33.1	50.4
12.3	31.2
22.4	41.4
6.4	25.2
142	152

T = 22.1 °C
 B = 750.5 mm Hg

Table 1 E
Davis Vane Anemometer
Serial No. 24323 B

Indicated Air Speed, fpm	True Air Speed, fpm
718	682
207	212
471	461
78.8	97.2
56.0	70.8
33.8	50.4
13.6	32.2
26.9	43.4
11.5	29.5
114	153

T = 22.5 °C
B = 750.5 mm Hg

Table 2
 Davis Vane Anemometer
 Serial No. 24323 B

Starting Speed,
 fpm

21.8
 24.6
 23.0
 21.9
 22.9

Average starting speed,
 23.3 fpm
 Standard Deviation,
 1.3 fpm

26.0
 22.4
 23.3
 24.3
 22.9

Table 3
 Davis Vane Anemometer
 Serial No. 24323 B

Stopping Speed,
 fpm

17.9
 19.0
 17.6
 18.6
 17.8

Average stopping speed,
 18.2 fpm
 Standard Deviation
 0.4 fpm

18.4
 18.6
 17.9
 18.3
 18.0




FIGURE 1. THE ANEMOMETER MOUNTED IN THE TUNNEL,
SHOWING METHOD OF SUPPORT.




FIGURE 2. VARIATION IN VELOCITY WITH DISTANCE UPSTREAM FROM ANEMOMETER .




FIGURE 3. INDICATED VERSUS TRUE VELOCITY WITH $\pm 2\sigma$ CURVES.




FIGURE 4. STANDARD DEVIATION, σ , AND CORRECTED STANDARD DEVIATION σ_c , OF INDICATED VELOCITY IN TERMS OF TRUE VELOCITY.




FIGURE 5. STANDARD DEVIATION, σ , AND CORRECTED STANDARD DEVIATION, σ_c , AS PERCENT OF GROUP MEAN VELOCITY.




FIGURE 6. DEVIATION OF INDICATED VELOCITY FROM TRUE VELOCITY.




FIGURE 7. PERCENT DEVIATION OF INDICATED VELOCITY FROM TRUE VELOCITY.

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. NBSIR 78-1485	2. Gov't Accession No.	3. Recipient's Accession No.
4. TITLE AND SUBTITLE LOW VELOCITY PERFORMANCE OF A BALL BEARING VANE ANEMOMETER		5. Publication Date June 1978	
		6. Performing Organization Code	
7. AUTHOR(S) L. P. Purtell		8. Performing Organ. Report No. NBSIR 78-1485	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234		10. Project/Task/Work Unit No. 7320483	
		11. Contract/Grant No. H0166198	
12. Sponsoring Organization Name and Complete Address (Street, City, State, ZIP) Office of the Assistant Director - Mining Bureau of Mines United States Department of the Interior Washington, D. C. 20241		13. Type of Report & Period Covered Feb.1, 1977-Mar.31,1977	
		14. Sponsoring Agency Code	
15. SUPPLEMENTARY NOTES			
<p>16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.)</p> <p>Performance of a ball bearing vane anemometer is evaluated over the speed range of 23 to 724 feet per minute including starting speed and stopping speed. The tests were performed in the NBS Low Velocity Airflow Facility which provides a uniform flow of low turbulence and utilizes a laser velocimeter as the velocity standard.</p>			
<p>17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons)</p> <p>Airflow; anemometer; laser velocimeter; low velocity; performance; vane anemometer; wind tunnel.</p>			
<p>18. AVAILABILITY <input checked="" type="checkbox"/> Unlimited</p> <p><input type="checkbox"/> For Official Distribution. Do Not Release to NTIS</p>		<p>19. SECURITY CLASS (THIS REPORT)</p> <p>UNCLASSIFIED</p>	<p>21. NO. OF PAGES</p> <p>20</p>
<p><input type="checkbox"/> Order From Sup. of Doc., U.S. Government Printing Office Washington, D.C. 20402, SD Cat. No. C13</p> <p><input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS) Springfield, Virginia 22151</p>		<p>20. SECURITY CLASS (THIS PAGE)</p> <p>UNCLASSIFIED</p>	<p>22. Price</p> <p>\$4.00</p>



