


NBS IR 79-136C



TECHNICAL ASSOCIATION OF THE
PULP AND PAPER INDUSTRY

COLLABORATIVE REFERENCE PROGRAM
FOR PAPER

REPORT NO. 56G



U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards

NBS COLLABORATIVE REFERENCE PROGRAMS

TAPPI Paper and Board (6 times per year)

Bursting strength	Smoothness
Tearing strength	Surface pick strength
Tensile breaking strength	K & N ink absorption
Elongation to break	pH
Tensile energy absorption	Opacity
Folding endurance	Blue reflectance (brightness)
Stiffness	Specular gloss, 75°
Air resistance	Thickness
Grammage	Concora (flat crush)
	Ring crush

FKBG-API Containerboard (48 times per year)

Mullen burst of linerboard
Concora test of medium

MCCA Color and Appearance (4 times per year)

Gloss at 60°
Color and color difference
Retroreflectivity

Rubber (4 times per year)

Tensile strength, ultimate elongation and tensile stress
Hardness
Mooney viscosity
Vulcanization properties

ASTM Textiles (3 times per year)

Flammability (FF3-71 and FF5-74)

ASTM Cement (2 times per year)

Chemical (11 chemical components)
Physical (8 characteristics)

AASHTO Bituminous

Asphalt cement (2 times per year)
Cutbacks (once a year)



Collaborative Reference Programs
B360 Polymer Building
National Bureau of Standards
Washington, D.C. 20234

TECHNICAL ASSOCIATION OF THE
PULP AND PAPER INDUSTRY

**COLLABORATIVE REFERENCE PROGRAM
FOR PAPER**

Report No. 56G

R. G. Powell
TAPPI-NBS Research Associate
Collaborative Testing Services, Inc.

J. Horlick
Office of Testing Laboratory Evaluation Technology
Office of Engineering Standards
National Engineering Laboratory

NBSIR 79-1360

U. S. DEPARTMENT OF COMMERCE
National Bureau of Standards

INTRODUCTION

Reports 56S and 56G comprise the second set of reports for the 78-79 program year. Participants in tests which involve strength properties of paper will receive only the S report; those in tests which measure other properties will receive only the G report.

Notes and comments to individual laboratories and "Best Values" applicable to a particular method are given following Table 1 for each method. See page 4 of this report for an explanation of "Best Values". Please do not confuse these Best Values with provisional values included with the samples to detect serious discrepancies at the time of test. NBS results, identified as L502 in the optical tests, are included on some of the tables.

If there are any questions on the notes, the analyses, or the reports in general, contact Robert G. Powell or Jeffrey Horlick on 301/921-2946.



Jeffrey Horlick, Administrator
NBS-TAPPI Collaborative Reference Program
Office of Testing Laboratory Evaluation Technology

January 26, 1979

TAPPI-NBS COLLABORATIVE REFERENCE PROGRAM

BACKGROUND AND PURPOSE

In 1969, the National Bureau of Standards and the Technical Association of the Pulp and Paper Industry established a collaborative reference program to provide a participating laboratory with a means to check periodically the level and uniformity of its testing in comparison with that of other laboratories.

The interchange of paper and board products and of the raw materials for these products requires agreement among raw material suppliers, paper and board producers, converters, distributors, retailers, commercial testing laboratories, user organizations and the ultimate consumer as to the meaning of test results, an agreement that cannot be achieved without accurate and precise testing. This program is designed to help assure agreement.

HOW THE PROGRAM WORKS

Participants Select the Tests in which they wish to participate. This choice is made on joining the program, but additional tests may be added at any time. Also new participants may enter the program at any time.

Test Samples are Distributed Bimonthly; i.e. every 2 months.

Provisional Values are Provided with the Samples for one or both of the test levels, depending on method. The provisional values permit serious discrepancies to be detected without delay. (It is left to the discretion of the laboratory supervisor as to whether these values should be known to the operator.)

Each Participant Tests the Samples, following instructions provided for each test method. The full check on a single instrument should normally take no more than 30 minutes. The test results are then sent to NBS for analysis. The participant is also asked to report other information relevant to an accurate analysis, such as test conditions and the instruments used.

Industry Means, Best Values and Other Statistics are developed from the data by NBS. The best values are estimates based on a careful examination of all data, both current and past, with special attention to results obtained by the National Bureau of Standards and other recognized reference laboratories in this and other countries.

A Quick Report is Prepared for each participating laboratory reporting data on time. This report shows the industry mean values, and the deviations of the laboratory's results from these values for each test method.

A Longer Summary Report, Showing the Data from all Participants, is also prepared. In the summary report, of which this report is an example, each laboratory is identified by a code number so that the information is maintained on a confidential basis. However, instruments are identified by type so participants can compare their results with those obtained on similar instruments of different manufacture. This report includes test averages, best values and standard deviations for individual participants and for the group as a whole. A participant should be able to readily determine the level and variability of his results in comparison with those of the other laboratories.

Repeatability and Reproducibility Statements such as Contained in ASTM, TAPPI and ISO Standards are included at the end of the report. Participants can check their performance level against the precision statement given in the test method or specification.

TABLE OF CONTENTS

Analyses In This Report

PAGE

1	Introduction
ii	Description of Program
iv	Metric Conversion Table
1	Key to Tables and Graphs
5	40-1 Air Resistance, Gurley Oil type
8	40-2 Air Resistance, Sheffield type
11	41-1 Air Resistance, Gurley Mercury type
13	44-1 Smoothness, Parker Printsurf
14	45-1 Smoothness, Sheffield type
19	45-2 Smoothness, Bekk type
20	47-1 Smoothness, Bendtsen type
21	56-1 K & N Ink Absorption
22	57-1 pH, Cold Extraction
23	57-2 pH, Hot Extraction
24	60-1 Opacity, White (89%) Backing
29	60-2 Opacity, Paper Backing, B & L type
30	60-3 Opacity, Paper Backing, Elrepho type
32	65-1 Blue Reflectance (Brightness), Directional
35	65-2 Blue Reflectance, Diffuse, Elrepho (Gloss Trap)
37	65-3 Blue Reflectance, Diffuse, Elrepho (No Gloss Trap)
39	75-1 Specular Gloss, 75 degree
42	90-1 Thickness (Caliper)
46	95-1 Grammage (Basis Weight)
48	Summary

Analyses In The S Report

10-1	Bursting Strength - Up to 45 psi
10-2	Bursting Strength - Up to 45 psi, Air Clamps
11-1	Bursting Strength - Up to 100 psi
15-1	Tearing Strength - Deep Cutout
17-1	Tearing Strength - No Cutout
19-1	Tensile Breaking Strength - Packaging Papers
20-1	Tensile Breaking Strength - Printing Papers, CRE
20-2	Tensile Breaking Strength - Printing Papers, Pendulum
25-1	Tensile Energy Absorption - Packaging Papers
26-1	Tensile Energy Absorption - Printing Papers
28-1	Elongation to Break - Packaging Papers
29-1	Elongation to Break - Printing Papers
30-1	Folding Endurance, MIT type
30-2	Folding Endurance, MIT type, log (base 10)
35-1	Stiffness, Gurley
36-1	Stiffness, Taber
49-1	Surface Pick Strength, IGT
50-1	Surface Pick Strength, Wax
91-1	Concora (Flat Crush)
96-1	Ring Crush

TABLE OF CONVERSION FACTORS TO METRIC (SI) UNITS

<u>Physical Quantity</u>	<u>To Convert From</u>	<u>To</u>	<u>Multiply by</u>
Bursting strength	psi	kPa	6.895
	kg/cm ²	kPa	98.07
	bar	kPa	100.00
Tearing strength	g	mN	9.807
Tensile strength	lb/in.	kN/m	.1751
	lb/0.5 in.	kN/m	.3502
	lb/15 mm	kN/m	.2965
	kg/15 mm	kN/m	.6538
	kg/25 mm	kN/m	.3923
	kg/mm	kN/m	9.807
	Tensile energy absorption	ft-lb/ft ²	J/m ²
in.-lb/in. ²		J/m ²	175.1
kg-m/m ²		J/m ²	9.807
Bending stiffness	g·cm	μN·m	98.07
Flat-crush strength (Concora)	lb	N	4.448
Ring-crush (TAPPI)	lb	N	4.448
	(ISO) lb/6.00 in.	kN/m	0.0292
Thickness	mil	μm	25.40

KEY TO TABLES AND GRAPHS

- MEAN - The average of individual TEST DETERMINATIONS. The number of TEST DETERMINATIONS in the mean is given in the upper right corner of the first table (TEST D.) and again at the bottom of this table.
- GRAND MEAN - (GR. MEAN) The average of the individual laboratory MEANS, excluding laboratories flagged (see column F) with an X, #, or +. The GRAND MEAN is given in US customary units and, where applicable, in SI metric units.
- SD OF MEANS - (SD MEANS) The standard deviation of the laboratory MEANS about the GRAND MEAN; an index of the among-laboratory precision.
- DEV - The deviation or difference of the laboratory MEAN from the GRAND MEAN.
- N. DEV - The normal deviate or ratio of the DEV to the SD OF MEANS; an indication of the degree of divergence of the laboratory MEAN from the GRAND MEAN. A N. DEV of more than 2 or less than -2 may indicate that the participant is not following the procedure considered standard for this analysis.
- SDR - The standard deviation of repeated measurements; that is, of individual test determinations about their MEAN.
- AVERAGE SDR - The average of the individual laboratory SDR's; an index of the within-laboratory precision of repeated measurements.
- R. SDR - The relative standard deviation of repeated measurements; that is, the ratio of the SDR to the AVERAGE SDR; an indication of the ability of a participant to repeat his measurements relative to the average ability. The greater the number of TEST DETERMINATIONS the closer the R. SDR should be to unity. If R. SDR is outside the limits given below, the participant may not be following the procedure considered standard for this analysis:

<u>No. of test Determinations</u>	<u>Lower limit for R. SDR</u>	<u>Upper limit for R. SDR</u>
3	0.09	2.58
5	0.27	2.06
8	0.40	1.77
10	0.46	1.67
15	0.56	1.53
20	0.61	1.45
25	0.65	1.39

- VAR - Code for instrument type or variation in condition, see second table.
- F - Flag, with following meaning:
- + - Excluded from grand means because VAR non-standard for this analysis.
 - # - Excluded because data were not understood or because of a non-coded variation reported by the laboratory. (See NOTES following Table 1 for each method).
 - M - Excluded because data for one sample are missing.
 - X - Excluded because plotted point would fall outside of the 99% error ellipse, (see below for explanation of Graph).
 - * - Included in grand means but plotted point falls outside of the 95% error ellipse. The participants should take this as a warning to reexamine his testing procedure.
 - S - Included in grand mean but only after omission of one or more 'wild' values; that is, test determinations more than 3 times AVERAGE SDR from the laboratory's MEAN. Not more than 20% of the test determination may be excluded in this manner without rejecting the laboratory.
 - O - Included in grand mean and inside 95% error ellipse.
- COORDINATES - Distances along major and minor axes of error ellipse. If special additive or concurrent model of the measuring process applies to this method, the distance along the minor axis represents the random error within a laboratory while that along the major axis also includes a systematic laboratory component of error.

95% ELLIPSE -

Lengths of the major and minor axes of the ellipse and the angle that the major axis makes with the horizontal axis.

AVG R. SDR -

Average of the R. SDR for the two samples; an indication of the laboratory's precision of repeated measurements.

Graph -

For each laboratory the MEAN for the second sample is plotted against the MEAN for the first sample, with each point representing a laboratory. The horizontal and vertical lines are the GRAND MEANS. The dashed line is drawn at 45° . The solid sloping line, which may or may not lie close to the 45° line, is along the major axis of the error ellipse. The ellipse is drawn so that, on the average, it will include 95% of the points representing the laboratories.

Plotted symbols are as explained above (under F), except that an 'S' is plotted as an 'O'. A participant whose plotted point falls outside of the ellipse should carefully reexamine the testing procedure he is following.

The graph is plotted with an ellipse when there are 20 or more laboratories in the analysis. When there are 10 through 19 laboratories in the analysis the graph is plotted but the ellipse is omitted. When there are fewer than 10 laboratories retained in the analysis the graph is not plotted.

The International System of Units (SI) is used on the plots wherever possible to aid participants in familiarizing themselves with SI. Grand means in SI units are given at the top of the plot, and supplementary scales in SI units are drawn along the axes allowing the reader to compare means and variability in common units and SI units for the same data.

- Summary - In addition to several quantities already defined
(At end of above, the summary shows the following values for
report) each test method:
- REPL CRP - The number of replicate test determinations used
in this Collaborative Reference Program.
- REPL TAPPI - The number of replicate test determinations in a
test result required by the applicable TAPPI
Standard or assumed here if there is no TAPPI
Standard. This quantity is needed in the compu-
tation of TAPPI repeatability and reproducibility
from the SD OF MEANS and the AVER SDR. See TAPPI
Standard T1206 for definitions and computations.
- REPEAT - TAPPI repeatability, a measure of the within-
laboratory precision of a test result.
- REPROD - TAPPI reproducibility, a measure of the between-
laboratory precision of a test result.
- Best values - Given at the end of Table 1 for each method
for which sufficient information is available.
These best values are estimates based on a
careful examination of all data, both current
and past, with special attention to results
obtained by the National Bureau of Standards
and other recognized reference laboratories
in this and other countries. All participants
using equipment that is standard for the
analysis should be able to achieve results
within the plus-minus (+) limits, when these
are shown along with the best values.

ANALYSIS T40-1 TABLE 1
AIR RESISTANCE, GURLEY UNITS (SECONDS/100 CC)
TAPPI STANDARD T460 GS-75, AIR RESISTANCE OF PAPER

LAB CODE	SAMPLE J46 MEAN	PRINTING 86 GFAMS PER SQUARE METER				SAMPLE J48 MEAN	PRINTING 106 GRAMS PER SQUARE METER				TEST D. = 10		
		DEV	N.DEV	SDR	R.SDR		DEV	N.DEV	SDR	R.SDR	VAR	F	LAB
L107	12.52	.22	.31	1.01	1.10	31.05	.11	.07	1.99	1.15	40D	Ø	L107
L121	12.29	-.01	-.01	.81	.88	31.17	.23	.15	1.34	.77	40D	Ø	L121
L122	12.06	-.24	-.34	.88	.96	31.08	.14	.09	1.16	.67	40D	Ø	L122
L123	12.62	.32	.45	.82	.89	32.03	1.09	.69	3.02	1.74	40D	Ø	L123
L124G	11.61	-.69	-.97	.70	.77	28.47	-2.47	-1.56	1.09	.63	40D	Ø	L124G
L125	12.50	.20	.28	.95	1.03	31.66	.72	.46	1.62	.93	40D	Ø	L125
L128	13.00	.70	.98	.67	.73	32.10	1.16	.74	1.20	.69	40D	Ø	L128
L141	13.19	.89	1.25	.81	.89	32.30	1.36	.86	1.42	.82	40D	Ø	L141
L148	12.78	.48	.68	1.22	1.32	29.98	-.96	-.61	1.73	1.00	40D	Ø	L148
L153	12.61	.31	.44	.73	.79	29.55	-1.39	-.88	1.23	.71	40D	Ø	L153
L163	13.84	1.54	2.17	1.36	1.48	32.87	1.93	1.22	1.17	.67	40D	Ø	L163
L166	13.33	1.03	1.45	.78	.85	34.28	3.34	2.12	2.02	1.16	40D	Ø	L166
L182G	11.54	-.76	-1.07	.70	.76	29.60	-1.34	-.85	1.65	.95	40D	Ø	L182G
L183	12.84	.54	.76	1.07	1.17	33.70	2.76	1.75	1.25	.72	40D	Ø	L183
L190C	12.79	.49	.69	.54	.59	30.30	-.64	-.40	2.11	1.22	40D	Ø	L190C
L190R	12.38	.08	.11	.68	.74	30.75	-.19	-.12	1.40	.80	40D	Ø	L190R
L212	10.31	-1.99	-2.80	.75	.82	26.53	-4.41	-2.79	1.26	.73	40D	*	L212
L223	12.47	.17	.24	.90	.98	31.73	.79	.50	2.20	1.27	40D	Ø	L223
L224	12.44	.14	.20	.96	1.05	29.66	-1.28	-.81	2.85	1.64	40D	Ø	L224
L230G	12.00	-.30	-.42	.94	1.03	30.60	-.34	-.21	1.26	.73	40D	Ø	L230G
L232	12.04	-.26	-.36	1.07	1.17	28.90	-2.04	-1.29	3.77	2.17	40D	Ø	L232
L236	12.77	.47	.66	1.00	1.09	32.35	1.41	.89	1.88	1.08	40D	Ø	L236
L238A	12.98	.68	.96	.78	.84	31.90	.96	.61	1.45	.83	40D	Ø	L238A
L241	11.30	-1.00	-1.40	.67	.73	27.40	-3.54	-2.24	.97	.56	40D	Ø	L241
L242	11.13	-1.17	-1.64	.40	.44	31.36	.42	.27	1.72	.99	40D	*	L242
L254	12.67	.37	.52	.76	.83	32.32	1.38	.88	1.51	.87	40D	Ø	L254
L261	12.17	-.13	-.18	1.10	1.20	31.20	.26	.17	.91	.52	40D	Ø	L261
L262G	11.69	-.61	-.86	.41	.45	25.79	-5.15	-3.26	1.63	.94	40D	X	L262G
L265	12.50	.20	.28	.63	.69	30.00	-.94	-.60	1.11	.64	40D	Ø	L265
L274	12.23	-.07	-.10	.43	.46	30.14	-.80	-.51	.71	.41	40D	Ø	L274
L278	12.44	.14	.20	1.03	1.12	31.27	.33	.21	1.28	.74	40D	Ø	L278
L285	12.34	.04	.06	.64	.70	33.28	2.34	1.48	3.93	2.26	40D	Ø	L285
L301	12.14	-.16	-.22	.60	.65	31.10	.16	.10	1.87	1.08	40D	Ø	L301
L308	12.43	.13	.18	.84	.92	31.10	.16	.10	1.52	.88	40D	Ø	L308
L313	11.28	-1.02	-1.43	.58	.64	30.16	-.78	-.49	1.41	.81	40D	Ø	L313
L321	11.10	-1.20	-1.69	1.58	1.72	27.90	-3.04	-1.93	1.78	1.02	40D	Ø	L321
L324	12.01	-.29	-.41	1.12	1.22	29.45	-1.49	-.94	2.07	1.19	40D	Ø	L324
L326	13.48	1.18	1.66	1.05	1.14	33.70	2.76	1.75	1.83	1.05	40D	Ø	L326
L328	12.45	.15	.21	.79	.86	31.86	.92	.58	1.59	.92	40D	Ø	L328
L339	87.40	75.10	105.55	6.62	7.21	37.90	6.96	4.41	4.31	2.48	40D	#	L339
L344	12.00	-.30	-.42	1.39	1.51	29.68	-1.26	-.80	1.61	.93	40D	Ø	L344
L376	12.03	-.27	-.38	.90	.98	30.71	-.23	-.15	1.75	1.01	40D	Ø	L376
L380	12.30	.00	.00	.82	.90	29.70	-1.24	-.79	1.70	.98	40D	Ø	L380
L388	6.54	-5.76	-8.09	.62	.67	14.02	-16.92	-10.72	.98	.57	40D	#	L388
L394	10.50	-1.80	-2.53	.85	.93	30.10	-.84	-.53	1.85	1.07	40D	*	L394
L396M	13.76	1.46	2.05	1.14	1.24	33.02	2.08	1.32	1.03	.59	40D	Ø	L396M
L567	12.45	.15	.21	1.04	1.13	30.56	-.38	-.24	2.00	1.15	40D	Ø	L567
L576	11.97	-.33	-.46	.90	.98	30.68	-.26	-.16	3.26	1.88	40D	Ø	L576
L585	12.73	.43	.61	.86	.94	31.25	.31	.20	1.06	.61	40D	Ø	L585
L604	12.40	.10	.14	1.15	1.25	30.56	-.38	-.24	2.21	1.27	40D	Ø	L604
L616	11.65	-.65	-.91	1.56	1.70	32.00	1.06	.67	.94	.54	40D	Ø	L616
L651	12.00	-.30	-.42	1.33	1.45	31.60	.66	.42	2.27	1.31	40D	Ø	L651
L676	12.60	.30	.42	.86	.94	32.29	1.35	.86	2.47	1.42	40D	Ø	L676

GR. MEAN = 12.30 GURLEY UNITS GRAND MEAN = 30.94 GURLEY UNITS TEST DETERMINATIONS = 10
SD MEANS = .71 GURLEY UNITS SD OF MEANS = 1.58 GURLEY UNITS 50 LABS IN GRAND MEANS
AVERAGE SDR = .92 GURLEY UNITS AVERAGE SDR = 1.74 GURLEY UNITS

L115	12.40	.10	.14	.97	1.05	24.40	-6.54	-4.14	1.17	.68	40U	+	L115
L291	12.90	.60	.84	1.37	1.49	31.40	.46	.29	.97	.56	40U	+	L291
L484	11.67	-.63	-.88	.49	.54	28.36	-2.58	-1.63	2.70	1.56	40H	+	L484

TOTAL NUMBER OF LABORATORIES REPORTING = 56

Best values: J46 12.3 ± 1.2 Curley units
J48 31.0 ± 2.7 Curley units


The following laboratories were omitted from the grand means because of extreme test results: 339, 388.

ANALYSIS T40-1 TABLE 2
 AIR RESISTANCE, GURLEY UNITS (SECONDS/100 CC)
 TAPPI STANDARD T460 GS-75, AIR RESISTANCE OF PAPER

LAE CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J46	J48	MAJOR	MINOR	R.SDR	VAR			
L388	#	6.54	14.02	-17.87	-.18	.62	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L212	*	10.31	26.53	-4.82	.41	.77	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L394	*	10.50	30.10	-1.39	1.42	1.00	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L321	Ø	11.10	27.90	-3.26	.12	1.37	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L242	*	11.13	31.36	.01	1.24	.71	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L313	Ø	11.28	30.16	-1.07	.70	.73	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L241	Ø	11.30	27.40	-3.67	-.23	.65	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L182G	Ø	11.54	29.60	-1.52	.27	.86	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L124G	Ø	11.61	28.47	-2.56	-.17	.70	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L616	Ø	11.65	32.00	.79	.96	1.12	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L484	*	11.67	28.36	-2.64	-.26	1.05	40E	AIR RESISTANCE,	REGMED-TYPE GURLEY DENSOMETER	-OIL FLOTATION
L262G	X	11.69	25.79	-5.06	-1.13	.69	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L576	Ø	11.97	30.68	-.35	.22	1.43	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L344	Ø	12.00	29.68	-1.29	-.14	1.22	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L651	Ø	12.00	31.60	.52	.50	1.38	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L230G	Ø	12.00	30.60	-.42	.17	.88	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L324	Ø	12.01	29.45	-1.50	-.22	1.21	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L376	Ø	12.03	30.71	-.31	.18	.99	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L232	Ø	12.04	28.90	-2.01	-.43	1.67	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L122	Ø	12.06	31.08	.05	.27	.81	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L301	Ø	12.14	31.10	.10	.20	.87	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L261	Ø	12.17	31.20	.20	.21	.86	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L274	Ø	12.23	30.14	-.78	-.20	.44	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L121	Ø	12.29	31.17	.21	.09	.83	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L380	Ø	12.30	29.70	-1.17	-.41	.94	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L285	Ø	12.34	33.28	2.22	.74	1.48	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L190R	Ø	12.38	30.75	-.15	-.14	.77	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L604	Ø	12.40	30.56	-.32	-.22	1.26	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L115	*	12.40	24.40	-6.14	-2.26	.86	40U	AIR RESISTANCE,	SHEFFIELD IN GURLEY UNITS	
L308	Ø	12.43	31.10	.20	-.07	.90	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L224	Ø	12.44	29.66	-1.16	-.56	1.34	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L278	Ø	12.44	31.27	.36	-.02	.93	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L567	Ø	12.45	30.56	-.31	-.27	1.14	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L328	Ø	12.45	31.86	.92	.16	.89	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L223	Ø	12.47	31.73	.80	.10	1.12	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L265	Ø	12.50	30.00	-.82	-.50	.66	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L125	Ø	12.50	31.66	.75	.05	.98	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L107	Ø	12.52	31.05	.18	-.17	1.12	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L676	Ø	12.60	32.29	1.37	.16	1.18	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L153	Ø	12.61	29.55	-1.21	-.75	.75	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L123	Ø	12.62	32.03	1.14	.06	1.32	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L254	Ø	12.67	32.32	1.43	.11	.85	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L585	Ø	12.73	31.25	.44	-.30	.77	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L236	Ø	12.77	32.35	1.49	.02	1.08	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L148	Ø	12.78	29.98	-.75	-.77	1.16	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L190C	Ø	12.79	30.30	-.44	-.67	.90	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L183	Ø	12.84	33.70	2.78	.41	.94	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L291	*	12.90	31.40	.63	-.41	1.02	40U	AIR RESISTANCE,	SHEFFIELD IN GURLEY UNITS	
L238A	Ø	12.98	31.90	1.13	-.32	.84	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L128	Ø	13.00	32.10	1.33	-.28	.71	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L141	Ø	13.19	32.30	1.58	-.39	.85	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L166	Ø	13.33	34.28	3.49	.14	1.01	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L326	Ø	13.48	33.70	3.00	-.20	1.10	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L356M	Ø	13.76	33.02	2.45	-.69	.92	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L163	Ø	13.84	32.87	2.33	-.81	1.08	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
L339	#	87.40	37.90	31.49	-68.53	4.84	40D	AIR RESISTANCE,	GURLEY DENSOMETER	- OIL FLOTATION
GMEANS:		12.30	30.94			1.00				
		95% ELLIPSE:		4.25	1.21			WITH GAMMA = 70 DEGREES		

AIR RESISTANCE, GURLEY

SAMPLE J46 = 12.3 GURLEY UNITS SAMPLE J48 = 30.9 GURLEY UNITS



ANALYSIS T40-2 TABLE 1
 AIR RESISTANCE, SHEFFIELD UNITS (CC/MIN) FOR 0.442 SQ. IN (3/4 IN. DIA) ORIFICE
 SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS

LAB CODE	SAMPLE J46 MEAN	PRINTING 86 GRAMS PER SQUARE METER				SAMPLE J48 MEAN	PRINTING 106 GRAMS PER SQUARE METER				TEST D. = 10		
		DEV	N.DEV	SDR	R. SDR		DEV	N.DEV	SDR	R. SDR	VAR	F	LAB
L114	234.6	12.3	.97	15.1	1.24	107.6	3.1	.53	2.9	.63	40S	Ø	L114
L121	235.5	13.2	1.04	17.1	1.40	110.0	5.5	.95	4.7	1.04	40S	Ø	L121
L122S	222.4	.1	.01	15.5	1.27	114.1	9.6	1.65	4.7	1.02	40S	Ø	L122S
L124S	232.7	10.4	.82	15.5	1.27	102.0	-2.5	-.43	5.2	1.14	40S	Ø	L124S
L132	211.0	-11.3	-.89	15.4	1.27	101.2	-3.3	-.57	6.9	1.51	40S	Ø	L132
L148	220.1	-2.2	-.17	15.7	1.29	105.8	1.3	.22	6.5	1.43	40S	Ø	L148
L150	240.3	18.0	1.41	12.3	1.01	107.0	2.5	.43	6.8	1.49	40S	Ø	L150
L173B	222.0	-.3	-.02	2.6	.21	101.5	-3.0	-.52	2.4	.53	40S	Ø	L173B
L190C	225.5	3.2	.25	8.3	.68	107.0	2.5	.43	5.4	1.18	40S	Ø	L190C
L213	215.5	-6.8	-.53	15.0	1.23	106.7	2.2	.38	3.6	.78	40S	Ø	L213
L223	216.8	-5.5	-.43	12.1	1.00	92.7	-11.8	-2.03	2.5	.56	40S	Ø	L223
L228	251.0	28.7	2.26	11.0	.91	160.2	55.7	9.60	4.6	1.00	40S	#	L228
L230S	215.7	-6.6	-.52	14.1	1.16	96.9	-7.6	-1.31	4.1	.90	40S	Ø	L230S
L241	238.5	16.2	1.27	5.8	.48	102.5	-2.0	-.35	5.4	1.19	40S	Ø	L241
L249	206.7	-15.6	-1.23	12.7	1.05	101.0	-3.5	-.60	5.2	1.15	40S	Ø	L249
L255	231.0	8.7	.68	11.3	.93	117.6	13.1	2.26	3.2	.71	40S	Ø	L255
L257A	231.6	9.3	.73	9.3	.76	106.2	1.7	.29	4.7	1.03	40S	Ø	L257A
L257B	231.5	9.2	.72	13.7	1.13	104.5	-.0	-.00	7.5	1.65	40S	Ø	L257B
L257C	223.9	1.6	.13	8.1	.67	111.0	6.5	1.12	4.3	.95	40S	Ø	L257C
L260	227.3	5.0	.39	7.5	.62	104.7	.2	.03	3.4	.75	40S	Ø	L260
L262S	223.7	1.4	.11	6.9	.57	101.7	-2.8	-.48	4.5	.99	40S	Ø	L262S
L288	233.3	11.0	.86	10.2	.84	105.8	1.3	.22	2.5	.55	40S	Ø	L288
L301	219.5	-2.8	-.22	12.6	1.04	111.2	6.7	1.15	4.3	.94	40S	Ø	L301
L305	221.0	-1.3	-.10	7.0	.57	106.5	2.0	.34	4.7	1.04	40S	Ø	L305
L318	203.6	-18.7	-1.47	10.7	.88	101.4	-3.1	-.53	5.4	1.19	40S	Ø	L318
L352	216.0	-6.3	-.49	10.5	.86	107.8	3.3	.57	4.6	1.02	40S	Ø	L352
L354	246.1	23.8	1.87	9.0	.74	114.1	9.6	1.65	6.3	1.38	40S	Ø	L354
L360	213.5	-8.8	-.69	19.4	1.59	105.4	.9	.15	3.6	.79	40S	Ø	L360
L366	194.5	-27.8	-2.18	14.6	1.20	96.8	-7.7	-1.33	2.7	.60	40S	Ø	L366
L372	224.6	2.3	.18	17.6	1.45	108.2	3.7	.64	4.8	1.07	40S	Ø	L372
L390	231.0	8.7	.68	17.4	1.43	101.5	-3.0	-.52	4.1	.90	40S	Ø	L390
L562	233.2	10.5	.86	14.1	1.16	106.9	2.4	.41	5.6	1.24	40S	Ø	L562
L585	220.0	-2.3	-.18	12.7	1.04	98.0	-6.5	-1.12	2.6	.57	40S	Ø	L585
L597	224.4	2.1	.17	11.9	.98	105.0	.5	.09	2.7	.59	40S	Ø	L597
L600	207.5	-14.8	-1.16	12.1	.99	94.1	-10.4	-1.79	6.8	1.50	40S	Ø	L600
L626	185.7	-36.6	-2.88	4.5	.37	93.2	-11.3	-1.95	3.4	.74	40S	*	L626

GR. MEAN = 222.3 SHEFF. UNITS GRAND MEAN = 104.5 SHEFF. UNITS TEST DETERMINATIONS = 10
 SD MEANS = 12.7 SHEFF. UNITS SD OF MEANS = 5.8 SHEFF. UNITS 35 LABS IN GRAND MEANS
 AVERAGE SDR = 12.2 SHEFF. UNITS AVERAGE SDR = 4.6 SHEFF. UNITS

L182H	942.5	720.2	56.59	68.8	5.65	394.0	289.5	49.88	19.0	4.17	40B	*	L182H
L312	242.0	19.7	1.55	12.5	1.03	105.3	.8	.14	4.1	.91	40T	*	L312
L484	947.0	724.7	56.94	52.3	4.30	366.0	261.5	45.06	20.7	4.54	40H	*	L484
L587	224.0	1.7	.13	11.7	.96	108.0	3.5	.60	4.8	1.06	40T	*	L587

TOTAL NUMBER OF LABORATORIES REPORTING = 40

Best values: J46 223 ± 17 Sheffield units
 J48 105 ± 10 Sheffield units


The following laboratories were omitted from the grand means because of extreme test results: 228.

ANALYSIS T40-2 TABLE 2
 AIR RESISTANCE, SHEFFIELD UNITS (CC/MIN) FOR 0.442 SQ. IN (3/4 IN. DIA) ORIFICE
 SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS

LAH CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J46	J48	MAJOR	MINOR	R.SDR	VAR			
L626	*	185.7	93.2	-38.3	.0	.56	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L366	Ø	194.5	56.8	-28.8	.8	.90	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L318	Ø	203.6	101.4	-18.8	2.6	1.03	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L249	Ø	206.7	101.0	-15.9	1.3	1.10	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L600	Ø	207.5	94.1	-17.2	-5.6	1.25	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L132	Ø	211.0	101.2	-11.8	.2	1.39	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L360	Ø	213.5	105.4	-8.1	3.5	1.19	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L213	Ø	215.5	106.7	-5.8	4.1	1.01	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L230S	Ø	215.7	96.5	-8.5	-5.3	1.03	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L352	Ø	216.0	107.8	-5.0	5.0	.94	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L223	Ø	216.8	92.7	-8.7	-9.7	.78	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L301	Ø	219.5	111.2	-.7	7.2	.99	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L585	Ø	220.0	98.0	-4.1	-5.5	.80	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L148	Ø	220.1	105.8	-1.7	1.9	1.36	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L305	Ø	221.0	106.5	-.6	2.3	.81	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L173B	Ø	222.0	101.5	-1.2	-2.8	.37	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L122S	Ø	222.4	114.1	2.9	9.1	1.15	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L262S	Ø	223.7	101.7	.5	-3.1	.78	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L257C	Ø	223.9	111.0	3.5	5.7	.81	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L587	*	224.0	108.0	2.7	2.8	1.01	40T	AIR RESISTANCE,	SHEFFIELD	(3 INCH DIAMETER ORIFICE)
L597	Ø	224.4	105.0	2.2	-.1	.79	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L372	Ø	224.6	108.2	3.3	2.9	1.26	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L190C	Ø	225.5	107.0	3.8	1.4	.93	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L260	Ø	227.3	104.7	4.8	-1.3	.68	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L390	Ø	231.0	101.5	7.4	-5.4	1.17	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L255	Ø	231.0	117.6	12.2	9.9	.82	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L257H	Ø	231.5	104.5	8.8	-2.7	1.39	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L257A	Ø	231.6	106.2	9.4	-1.1	.90	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L124S	Ø	232.7	102.0	9.2	-5.5	1.21	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L562	Ø	233.2	106.9	11.1	-.9	1.20	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L288	Ø	233.3	105.8	10.9	-2.0	.69	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L114	Ø	234.6	107.6	12.7	-.7	.93	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L121	Ø	235.5	110.0	14.2	1.4	1.22	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L241	Ø	238.5	102.5	14.9	-6.7	.83	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L150	Ø	240.3	107.0	17.9	-2.9	1.25	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L312	*	242.0	105.3	19.1	-5.1	.97	40T	AIR RESISTANCE,	SHEFFIELD	(3 INCH DIAMETER ORIFICE)
L354	Ø	246.1	114.1	25.6	2.1	1.06	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L228	#	251.0	160.2	43.9	44.7	.95	40S	AIR RESISTANCE,	SHEFFIELD	(3/4 INCH DIAMETER ORIFICE)
L182B	*	942.5	394.0	773.6	63.9	4.91	40H	AIR RESISTANCE,	HENDTSEN,	WG 150
L484	*	947.0	366.0	769.6	35.9	4.42	40H	AIR RESISTANCE,	HENDTSEN,	WG 150
GMEANS:		222.3	104.5			1.00				
		95% ELLIPSH:	34.5	11.7		WITH GAMMA = 17 DEGREES				

AIR RESISTANCE. SHEFFIELD


SAMPLE J46 = 222. SHEFF. UNITS SAMPLE J48 = 105. SHEFF. UNITS



AIR RESISTANCE, GURLEY HG FLOTATION

SAMPLE E82 = 1684. SEC/10 CC

SAMPLE B47 = 1549. SEC/10 CC



TAPPI COLLABORATIVE REFERENCE PROGRAM
ANALYSIS T44-1 TABLE 1
SMOOTHNESS, PARKER PRINTSURF

LAB CODE	SAMPLE	PRINTING					SAMPLE	PRINTING					TEST D. - 10		
	J49 MEAN	94 GRAMS DEV	PER N.DEV	SQUARE SDR	METER R.SDR	J73 MEAN	76 GRAMS DEV	PER N.DEV	SQUARE SDR	METER R.SDR	VAR	P	LAB		
L122	6.98	.86	1.65	.06	.69	5.07	.58	1.42	.11	.89	44P	Ø	L122		
L136	5.87	-.25	-.48	.09	1.01	4.30	-.19	-.46	.13	1.07	44P	Ø	L136		
L182	5.96	-.16	-.31	.09	.95	4.52	.03	.08	.16	1.32	44P	Ø	L182		
L183	5.97	-.15	-.29	.07	.73	4.59	.10	.24	.10	.81	44P	Ø	L183		
L223	5.89	-.23	-.44	.08	.83	4.26	-.23	-.55	.13	1.03	44P	Ø	L223		
L288	7.01	.89	1.71	.12	1.30	5.11	.62	1.51	.09	.76	44P	Ø	L288		
L317	6.01	-.11	-.22	.11	1.19	4.58	.09	.22	.13	1.07	44P	Ø	L317		
L588	5.47	-.65	-1.26	.14	1.54	3.96	-.53	-1.29	.16	1.34	44P	Ø	L588		
L669	5.94	-.18	-.35	.07	.76	4.01	-.48	-1.17	.09	.71	44P	Ø	L669		

GR. MEAN = 6.12 MICRONS GRAND MEAN = 4.49 MICRONS TEST DETERMINATIONS = 10
SD MEANS = .52 MICRONS SD OF MEANS = .41 MICRONS 9 LABS IN GRAND MEANS
AVERAGE SDR = .09 MICRONS AVERAGE SDR = .12 MICRONS

TOTAL NUMBER OF LABORATORIES REPORTING = 9

Best values: J49 6.0 microns
J73 4.5 microns

TAPPI COLLABORATIVE REFERENCE PROGRAM
ANALYSIS T44-1 TABLE 2
SMOOTHNESS, PARKER PRINTSURF

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---TEST INSTRUMENT---CONDITIONS				
		J49	J73	MAJOR	MINOR	R.SDR	VAR	PROPERTY	TEST INSTRUMENT	CONDITIONS		
L588	Ø	5.47	3.96	-.84	-.02	1.44	44P	SMOOTHNESS,	PARKER PRINTSURF			
L136	Ø	5.87	4.30	-.31	.00	1.04	44P	SMOOTHNESS,	PARKER PRINTSURF			
L223	Ø	5.89	4.26	-.32	-.04	.93	44P	SMOOTHNESS,	PARKER PRINTSURF			
L669	Ø	5.94	4.01	-.44	-.27	.74	44P	SMOOTHNESS,	PARKER PRINTSURF			
L182	Ø	5.96	4.52	-.11	.13	1.13	44P	SMOOTHNESS,	PARKER PRINTSURF			
L183	Ø	5.97	4.59	-.06	.17	.77	44P	SMOOTHNESS,	PARKER PRINTSURF			
L317	Ø	6.01	4.58	-.03	.14	1.13	44P	SMOOTHNESS,	PARKER PRINTSURF			
L122	Ø	6.98	5.07	1.03	-.06	.79	44P	SMOOTHNESS,	PARKER PRINTSURF			
L288	Ø	7.01	5.11	1.08	-.05	1.03	44P	SMOOTHNESS,	PARKER PRINTSURF			
GMEANS:		6.12	4.49			1.00						
		95% ELLIPSE:	2.13	.44				WITH GAMMA = 37 DEGREES				

ANALYSIS T45-1 TABLE 1
SMOOTHNESS, SHEFFIELD UNITS
SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS

LAB CODE	SAMPLE J49 MEAN	PRINTING 94 GRAMS PER SQUARE METER				SAMPLE J73 MEAN	PRINTING 76 GRAMS PER SQUARE METER				TEST D. = 15		
		DEV	N.DEV	SDR	R. SDR		DEV	N.DEV	SDR	R. SDR	VAR	F	LAB
L107	261.7	-13.2	-1.24	9.6	1.37	99.7	12.7	1.69	7.7	1.48	45S	Ø	L107
L108	271.3	-3.5	-.33	4.8	.68	80.1	-6.9	-.91	2.8	.54	45S	Ø	L108
L114	285.4	10.5	.99	7.4	1.07	93.8	6.8	.91	7.1	1.37	45S	Ø	L114
L115	266.3	-8.5	-.80	9.3	1.34	86.7	-.3	-.04	5.9	1.13	45S	Ø	L115
L121	273.7	-1.2	-.11	10.4	1.50	89.3	2.4	.32	5.3	1.02	45S	Ø	L121
L122	272.8	-2.1	-.19	11.7	1.67	85.5	-1.4	-.19	4.9	.94	45S	Ø	L122
L124	268.6	-6.3	-.59	5.7	.82	84.5	-2.5	-.33	4.1	.79	45S	Ø	L124
L125	269.0	-5.9	-.55	8.7	1.25	93.7	6.7	.89	11.1	2.14	45S	Ø	L125
L126	283.8	8.9	.84	11.4	1.63	90.7	3.7	.49	7.2	1.39	45S	Ø	L126
L128	271.0	-3.9	-.36	5.4	.78	93.0	6.0	.80	4.6	.88	45S	Ø	L128
L132	275.7	.9	.08	5.3	.77	82.2	-4.8	-.63	6.7	1.29	45S	Ø	L132
L139S	274.0	-.9	-.08	9.1	1.31	100.0	13.0	1.73	5.3	1.03	45S	Ø	L139S
L148	279.3	4.4	.41	7.1	1.01	87.3	.3	.04	4.9	.95	45S	Ø	L148
L150	289.5	14.7	1.38	8.8	1.26	80.5	-6.5	-.86	5.2	.99	45S	Ø	L150
L152	252.4	-22.5	-2.11	4.5	.65	97.5	10.5	1.39	5.5	1.07	45S	*	L152
L153	303.5	28.6	2.68	7.1	1.03	109.8	22.8	3.03	4.0	.77	45S	X	L153
L162	273.3	-1.5	-.14	9.8	1.40	87.3	.4	.05	6.2	1.20	45S	Ø	L162
L166	263.3	-11.6	-1.05	7.7	1.11	84.3	-2.7	-.36	4.2	.81	45S	Ø	L166
L167	270.3	-4.5	-.43	4.0	.57	81.3	-5.6	-.75	2.3	.44	45S	Ø	L167
L173B	254.3	-20.5	-1.93	4.2	.60	88.0	1.0	.14	2.5	.49	45S	Ø	L173B
L183S	270.7	-4.2	-.39	5.4	.78	92.5	5.5	.73	8.7	1.68	45S	Ø	L183S
L190C	263.3	-11.5	-1.08	6.2	.89	88.0	1.0	.14	5.3	1.02	45S	Ø	L190C
L190R	258.1	-16.7	-1.57	6.2	.89	74.7	-12.3	-1.63	2.4	.46	45S	Ø	L190R
L195	275.4	.5	.05	7.1	1.03	74.5	-12.5	-1.66	5.9	1.14	45S	Ø	L195
L203	279.3	4.5	.42	7.5	1.08	80.3	-6.7	-.89	6.2	1.20	45S	Ø	L203
L206	269.3	-5.6	-.53	4.0	.57	91.1	4.1	.55	4.7	.92	45S	Ø	L206
L211	266.1	-8.8	-.83	8.6	1.23	78.2	-8.8	-1.16	5.9	1.13	45S	Ø	L211
L213	251.1	-23.8	-2.23	7.2	1.03	81.3	-5.6	-.75	10.1	1.95	45S	Ø	L213
L223	272.1	-2.8	-.26	9.0	1.29	76.1	-10.8	-1.44	3.5	.68	45S	Ø	L223
L224	291.9	17.0	1.59	6.3	.90	97.2	10.2	1.36	4.8	.93	45S	Ø	L224
L226B	269.8	-5.1	-.48	4.9	.71	77.8	-9.2	-1.21	5.6	1.08	45S	Ø	L226B
L228	285.2	10.3	.97	11.9	1.71	96.9	9.9	1.32	4.4	.84	45S	Ø	L228
L230S	280.0	5.1	.48	5.9	.84	82.6	-4.4	-.58	6.5	1.25	45S	Ø	L230S
L231	289.1	14.3	1.34	8.7	1.26	88.6	1.6	.22	4.4	.85	45S	Ø	L231
L232S	293.3	18.5	1.73	6.5	.93	87.7	.7	.09	5.3	1.02	45S	Ø	L232S
L237	276.0	1.1	.11	6.0	.87	85.3	-1.6	-.22	4.8	.93	45S	Ø	L237
L241	290.7	15.8	1.48	8.6	1.24	124.3	37.4	4.96	12.9	2.50	45S	X	L241
L249	281.1	6.3	.59	7.8	1.12	86.3	-.7	-.09	3.6	.70	45S	Ø	L249
L254	277.6	2.7	.26	4.4	.63	91.4	4.4	.59	6.5	1.25	45S	Ø	L254
L255	273.1	-1.8	-.17	3.8	.54	100.7	13.7	1.82	2.5	.48	45S	Ø	L255
L257A	270.0	-4.9	-.46	6.5	.93	78.1	-8.8	-1.17	4.8	.93	45S	Ø	L257A
L257B	272.9	-1.9	-.18	8.6	1.23	103.8	16.8	2.23	7.8	1.51	45S	Ø	L257B
L257C	272.7	-2.1	-.20	9.1	1.31	102.0	15.0	2.00	5.3	1.02	45S	Ø	L257C
L260	269.7	-5.1	-.48	6.0	.86	84.2	-2.8	-.37	3.9	.74	45S	Ø	L260
L261	279.7	4.8	.45	4.8	.69	83.0	-4.0	-.52	3.9	.74	45S	Ø	L261
L262	276.5	1.7	.16	5.1	.73	99.2	12.2	1.62	4.7	.90	45S	Ø	L262
L275	272.7	-2.2	-.21	9.7	1.40	82.5	-4.4	-.59	4.8	.93	45S	Ø	L275
L277	283.1	8.2	.77	7.5	1.07	94.5	7.6	1.01	4.7	.92	45S	Ø	L277
L278	295.3	20.5	1.92	6.1	.88	90.7	3.8	.50	5.2	1.01	45S	Ø	L278
L281	274.4	-.5	-.04	4.9	.71	84.7	-2.3	-.30	6.4	1.24	45S	Ø	L281
L285	269.2	-5.7	-.53	5.7	.83	81.4	-5.6	-.74	3.9	.74	45S	Ø	L285
L288	278.1	3.3	.31	5.3	.76	88.0	1.0	.14	4.1	.80	45S	Ø	L288
L290	281.9	7.1	.66	6.4	.92	73.9	-13.0	-1.73	7.0	1.34	45S	Ø	L290
L291S	280.1	5.3	.49	3.0	.44	93.7	6.7	.89	3.7	.72	45S	Ø	L291S
L301	248.5	-26.3	-2.47	4.0	.58	90.5	3.6	.47	4.9	.95	45S	*	L301
L305	273.0	-1.9	-.18	6.2	.89	82.3	-4.6	-.61	3.7	.72	45S	Ø	L305
L308	271.9	-2.9	-.28	7.5	1.08	79.9	-7.1	-.94	3.3	.63	45S	Ø	L308
L312	297.5	22.6	2.12	6.3	.90	93.9	6.9	.92	3.4	.66	45S	Ø	L312
L317	273.9	-1.0	-.09	8.2	1.18	78.8	-8.2	-1.08	5.2	1.00	45S	Ø	L317
L318	271.9	-3.0	-.28	9.5	1.37	92.5	5.5	.73	9.7	1.87	45S	Ø	L318
L321	260.0	-14.9	-1.40	.0	.00	70.7	-16.3	-2.16	1.8	.34	45S	Ø	L321
L323	275.3	.5	.04	7.4	1.07	90.5	3.6	.47	6.6	1.28	45S	Ø	L323
L326	304.3	29.5	2.76	4.0	.58	87.2	.2	.03	4.4	.85	45S	*	L326
L328	278.7	3.8	.36	4.6	.67	85.6	-1.4	-.18	4.9	.94	45S	Ø	L328
L352	275.7	.9	.08	5.9	.85	92.7	5.8	.77	7.0	1.35	45S	Ø	L352

TAPPI COLLABORATIVE REFERENCE PROGRAM
ANALYSIS 145-1 TABLE 1
SMOOTHNESS, SHEFFIELD UNITS
SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS

LAB CODE	SAMPLE J49 MEAN	PRINTING 94 GRAMS PER SQUARE METER				SAMPLE J73 MEAN	PRINTING 76 GRAMS PER SQUARE METER				TEST D. = 15		
		DEV	N.DEV	SDR	R.SDR		DEV	N.DEV	SDR	R.SDR	VAR	F	LAB
L360	276.4	1.5	.14	8.7	1.25	86.5	-.4	-.06	3.1	.61	45S	Ø	L360
L366	270.9	-4.0	-.38	8.5	1.22	91.7	4.8	.63	7.6	1.46	45S	Ø	L366
L372	276.0	1.1	.11	6.3	.90	81.7	-5.3	-.70	4.8	.93	45S	Ø	L372
L376	273.3	-1.5	-.14	7.9	1.13	98.7	11.8	1.56	6.7	1.30	45S	Ø	L376
L380	264.0	-10.9	-1.02	8.7	1.25	79.9	-7.1	-.94	2.6	.49	45S	Ø	L380
L382	294.3	19.5	1.83	5.1	.73	80.5	-6.5	-.86	3.8	.73	45S	Ø	L382
L390	276.7	1.8	.17	8.2	1.17	84.3	-2.6	-.35	5.0	.96	45S	Ø	L390
L396M	285.0	10.1	.95	6.8	.98	91.0	4.0	.54	6.0	1.16	45S	Ø	L396M
L554	281.7	6.9	.64	3.4	.49	82.4	-4.6	-.60	3.5	.68	45S	Ø	L554
L567	258.4	-16.5	-1.55	10.6	1.52	83.0	-4.0	-.52	5.9	1.13	45S	Ø	L567
L585	268.0	-6.9	-.64	10.7	1.53	70.3	-16.6	-2.21	4.8	.93	45S	Ø	L585
L587	268.0	-6.9	-.64	7.5	1.08	91.0	4.0	.54	4.7	.91	45S	Ø	L587
L597	303.7	28.9	2.71	7.1	1.03	93.0	6.0	.80	7.7	1.49	45S	*	L597
L600	281.8	6.9	.65	6.1	.88	86.3	-7	-.09	6.6	1.27	45S	Ø	L600
L626	268.6	-6.2	-.58	4.4	.63	75.4	-11.6	-1.53	2.2	.42	45S	Ø	L626
L648	273.7	-1.2	-.11	10.0	1.43	79.1	-7.8	-1.04	5.8	1.13	45S	Ø	L648
L651	235.3	-39.6	-3.72	3.5	.50	91.7	4.7	.63	6.6	1.27	45S	X	L651
L670	282.4	7.5	.71	8.0	1.15	89.5	2.6	.34	7.1	1.37	45S	Ø	L670
L679	276.0	1.1	.11	3.3	.47	98.3	11.4	1.51	4.2	.80	45S	Ø	L679

GR. MEAN = 274.9 SHEFF. UNITS	GRAND MEAN = 87.0 SHEFF. UNITS	TEST DETERMINATIONS = 15
SD MEANS = 10.7 SHEFF. UNITS	SD OF MEANS = 7.5 SHEFF. UNITS	81 LABS IN GRAND MEANS
AVERAGE SDR = 7.0 SHEFF. UNITS	AVERAGE SDR = 5.2 SHEFF. UNITS	
TOTAL NUMBER OF LABORATORIES REPORTING = 84		

Best values: J49 275 ± 20 Sheffield units
J73 87 ± 13 Sheffield units

TAPPI COLLABORATIVE REFERENCE PROGRAM
 ANALYSIS T45-1 TABLE 2
 SMOOTHNESS, SHEFFIELD UNITS
 SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS


LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J49	J73	MAJOR	MINOR	R. SDR	VAR			
L651	X	235.3	91.7	-37.6	13.3	.89	45S	SMOOTHNESS,	SHEFFIELD	
L301	*	248.5	90.5	-24.9	9.3	.76	45S	SMOOTHNESS,	SHEFFIELD	
L213	Ø	251.1	81.3	-24.5	-.2	1.49	45S	SMOOTHNESS,	SHEFFIELD	
L152	*	252.4	97.5	-19.6	15.2	.86	45S	SMOOTHNESS,	SHEFFIELD	
L173B	Ø	254.3	88.0	-19.8	5.5	.54	45S	SMOOTHNESS,	SHEFFIELD	
L190R	Ø	258.1	74.7	-19.0	-8.3	.68	45S	SMOOTHNESS,	SHEFFIELD	
L567	Ø	258.4	83.0	-16.9	-.2	1.33	45S	SMOOTHNESS,	SHEFFIELD	
L321	Ø	260.0	70.7	-18.1	-12.6	.17	45S	SMOOTHNESS,	SHEFFIELD	
L107	Ø	261.7	99.7	-10.1	15.3	1.43	45S	SMOOTHNESS,	SHEFFIELD	
L166	Ø	263.3	84.3	-11.9	-.1	.96	45S	SMOOTHNESS,	SHEFFIELD	
L190C	Ø	263.3	88.0	-11.0	3.6	.95	45S	SMOOTHNESS,	SHEFFIELD	
L380	Ø	264.0	79.9	-12.2	-4.5	.87	45S	SMOOTHNESS,	SHEFFIELD	
L211	Ø	266.1	78.2	-10.5	-6.6	1.18	45S	SMOOTHNESS,	SHEFFIELD	
L115	Ø	266.3	86.7	-8.4	1.6	1.24	45S	SMOOTHNESS,	SHEFFIELD	
L587	Ø	268.0	91.0	-5.8	5.5	.99	45S	SMOOTHNESS,	SHEFFIELD	
L585	Ø	268.0	70.3	-10.4	-14.7	1.23	45S	SMOOTHNESS,	SHEFFIELD	
L124	Ø	268.6	84.5	-6.7	-1.0	.81	45S	SMOOTHNESS,	SHEFFIELD	
L626	Ø	268.6	75.4	-8.6	-9.9	.52	45S	SMOOTHNESS,	SHEFFIELD	
L125	Ø	269.0	93.7	-4.2	7.8	1.70	45S	SMOOTHNESS,	SHEFFIELD	
L285	Ø	269.2	81.4	-6.8	-4.2	.78	45S	SMOOTHNESS,	SHEFFIELD	
L206	Ø	269.3	91.1	-4.6	5.2	.74	45S	SMOOTHNESS,	SHEFFIELD	
L260	Ø	269.7	84.2	-5.6	-1.6	.80	45S	SMOOTHNESS,	SHEFFIELD	
L226B	Ø	269.8	77.8	-7.0	-7.8	.89	45S	SMOOTHNESS,	SHEFFIELD	
L257A	Ø	270.0	78.1	-6.7	-7.5	.93	45S	SMOOTHNESS,	SHEFFIELD	
L167	Ø	270.3	81.3	-5.7	-4.5	.51	45S	SMOOTHNESS,	SHEFFIELD	
L183S	Ø	270.7	92.5	-2.9	6.3	1.23	45S	SMOOTHNESS,	SHEFFIELD	
L366	Ø	270.9	91.7	-2.9	5.5	1.34	45S	SMOOTHNESS,	SHEFFIELD	
L128	Ø	271.0	93.0	-2.4	6.7	.83	45S	SMOOTHNESS,	SHEFFIELD	
L108	Ø	271.3	80.1	-5.0	-5.9	.61	45S	SMOOTHNESS,	SHEFFIELD	
L318	Ø	271.9	92.5	-1.7	6.0	1.62	45S	SMOOTHNESS,	SHEFFIELD	
L308	Ø	271.9	79.9	-4.4	-6.3	.85	45S	SMOOTHNESS,	SHEFFIELD	
L223	Ø	272.1	76.1	-5.1	-9.9	.98	45S	SMOOTHNESS,	SHEFFIELD	
L275	Ø	272.7	82.5	-3.1	-3.8	1.16	45S	SMOOTHNESS,	SHEFFIELD	
L257C	Ø	272.7	102.0	1.2	15.1	1.16	45S	SMOOTHNESS,	SHEFFIELD	
L122	Ø	272.8	85.5	-2.3	-.9	1.31	45S	SMOOTHNESS,	SHEFFIELD	
L257B	Ø	272.9	103.8	1.8	16.9	1.37	45S	SMOOTHNESS,	SHEFFIELD	
L305	Ø	273.0	82.3	-2.8	-4.1	.80	45S	SMOOTHNESS,	SHEFFIELD	
L255	Ø	273.1	100.7	1.3	13.8	.51	45S	SMOOTHNESS,	SHEFFIELD	
L162	Ø	273.3	87.3	-1.4	.7	1.30	45S	SMOOTHNESS,	SHEFFIELD	
L376	Ø	273.3	98.7	1.1	11.8	1.22	45S	SMOOTHNESS,	SHEFFIELD	
L648	Ø	273.7	79.1	-2.9	-7.4	1.28	45S	SMOOTHNESS,	SHEFFIELD	
L121	Ø	273.7	89.3	-.7	2.6	1.26	45S	SMOOTHNESS,	SHEFFIELD	
L317	Ø	273.9	78.8	-2.8	-7.7	1.09	45S	SMOOTHNESS,	SHEFFIELD	
L139S	Ø	274.0	100.0	2.0	12.9	1.17	45S	SMOOTHNESS,	SHEFFIELD	
L281	Ø	274.4	84.7	-1.0	-2.1	.98	45S	SMOOTHNESS,	SHEFFIELD	
L323	Ø	275.3	90.5	1.2	3.4	1.17	45S	SMOOTHNESS,	SHEFFIELD	
L195	Ø	275.4	74.5	-2.2	-12.3	1.08	45S	SMOOTHNESS,	SHEFFIELD	
L132	Ø	275.7	82.2	-.2	-4.8	1.03	45S	SMOOTHNESS,	SHEFFIELD	
L352	Ø	275.7	92.7	2.1	5.4	1.10	45S	SMOOTHNESS,	SHEFFIELD	
L679	Ø	276.0	98.3	3.6	10.9	.63	45S	SMOOTHNESS,	SHEFFIELD	
L372	Ø	276.0	81.7	-.1	-5.4	.92	45S	SMOOTHNESS,	SHEFFIELD	
L237	Ø	276.0	85.3	.7	-1.8	.90	45S	SMOOTHNESS,	SHEFFIELD	
L360	Ø	276.4	86.5	1.4	-.7	.93	45S	SMOOTHNESS,	SHEFFIELD	
L262	Ø	276.5	99.2	4.3	11.6	.81	45S	SMOOTHNESS,	SHEFFIELD	
L390	Ø	276.7	84.3	1.2	-3.0	1.06	45S	SMOOTHNESS,	SHEFFIELD	
L254	Ø	277.6	91.4	3.6	3.7	.94	45S	SMOOTHNESS,	SHEFFIELD	
L288	Ø	278.1	88.0	3.4	.3	.78	45S	SMOOTHNESS,	SHEFFIELD	
L328	Ø	278.7	85.6	3.5	-2.2	.81	45S	SMOOTHNESS,	SHEFFIELD	
L148	Ø	279.3	87.3	4.4	-.7	.98	45S	SMOOTHNESS,	SHEFFIELD	
L203	Ø	279.3	80.3	2.9	-7.5	1.14	45S	SMOOTHNESS,	SHEFFIELD	
L261	Ø	279.7	83.0	3.8	-4.9	.72	45S	SMOOTHNESS,	SHEFFIELD	
L230S	Ø	280.0	82.6	4.0	-5.4	1.05	45S	SMOOTHNESS,	SHEFFIELD	
L291S	Ø	280.1	93.7	6.6	5.4	.58	45S	SMOOTHNESS,	SHEFFIELD	
L249	Ø	281.1	86.3	6.0	-2.1	.91	45S	SMOOTHNESS,	SHEFFIELD	
L554	Ø	281.7	82.4	5.7	-6.0	.58	45S	SMOOTHNESS,	SHEFFIELD	

TAPPI COLLABORATIVE REFERENCE PROGRAM
 ANALYSIS T45-1 TABLE 2
 SMOOTHNESS, SHEFFIELD UNITS
 SHEFFIELD TESTER IS STANDARD FOR THIS ANALYSIS

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J49	J73	MAJOR	MINOR	R.SDR	VAR			
L600	Ø	281.8	86.3	6.6	-2.2	1.08	45S	SMOOTHNESS,	SHEFFIELD	
L290	Ø	281.9	73.9	4.0	-14.3	1.13	45S	SMOOTHNESS,	SHEFFIELD	
L670	Ø	282.4	89.5	7.9	.9	1.26	45S	SMOOTHNESS,	SHEFFIELD	
L277	Ø	283.1	94.5	9.7	5.6	1.00	45S	SMOOTHNESS,	SHEFFIELD	
L126	Ø	283.8	90.7	9.5	1.7	1.51	45S	SMOOTHNESS,	SHEFFIELD	
L396M	Ø	285.0	91.0	10.8	1.7	1.07	45S	SMOOTHNESS,	SHEFFIELD	
L228	Ø	285.2	96.9	12.3	7.4	1.27	45S	SMOOTHNESS,	SHEFFIELD	
L114	Ø	285.4	93.8	11.8	4.4	1.22	45S	SMOOTHNESS,	SHEFFIELD	
L231	Ø	289.1	88.6	14.3	-1.5	1.05	45S	SMOOTHNESS,	SHEFFIELD	
L150	Ø	289.5	80.5	12.9	-9.5	1.13	45S	SMOOTHNESS,	SHEFFIELD	
L241	X	290.7	124.3	23.6	33.0	1.87	45S	SMOOTHNESS,	SHEFFIELD	
L224	Ø	291.9	97.2	18.8	6.3	.91	45S	SMOOTHNESS,	SHEFFIELD	
L232S	Ø	293.3	87.7	18.2	-3.4	.97	45S	SMOOTHNESS,	SHEFFIELD	
L382	Ø	294.3	80.5	17.6	-10.6	.73	45S	SMOOTHNESS,	SHEFFIELD	
L278	Ø	295.3	90.7	20.8	-.8	.94	45S	SMOOTHNESS,	SHEFFIELD	
L312	Ø	297.5	93.9	23.6	1.8	.78	45S	SMOOTHNESS,	SHEFFIELD	
L153	X	303.5	109.8	32.9	16.0	.90	45S	SMOOTHNESS,	SHEFFIELD	
L597	*	303.7	93.0	29.5	-.5	1.26	45S	SMOOTHNESS,	SHEFFIELD	
L326	*	304.3	87.2	28.8	-6.2	.71	45S	SMOOTHNESS,	SHEFFIELD	
GMEANS:		274.9	87.0			1.00				
		95% ELLIPSE:		27.1	18.4	WITH GAMMA = 12 DEGREES				

SMOOTHNESS, SHEFFIELD

SAMPLE J49 = 275. SHEFF. UNITS SAMPLE J73 = 87. SHEFF. UNITS



ANALYSIS T45-2 TABLE 1
SMOOTHNESS, BEKK SECONDS
TAPPI SUGGESTED METHOD T479 SU-71, SMOOTHNESS OF PAPER (BEKK METHOD)

LAB CODE	SAMPLE J49 MBAN	PRINTING 94 GRAMS PER SQUARE METER				SAMPLE J73 MBAN	PRINTING 76 GRAMS PER SQUARE METER				TEST D. = 15		
		DEV	N.DEV	SDR	R.SDR		DEV	N.DEV	SDR	R.SDR	VAR	F	LAH
L139B	11.00	1.06	1.76	.85	1.50	80.60	14.52	.99	7.36	1.28	45K	Ø	L139H
L162	4.93	-5.01	-8.29	.12	.22	97.47	31.39	2.15	7.63	1.33	45K	#	L162
L182K	9.31	-.63	-1.04	.76	1.35	61.87	-4.21	-.29	5.93	1.03	45K	Ø	L182K
L190C	10.36	.42	.70	.41	.72	79.00	12.92	.88	10.39	1.81	45K	Ø	L190C
L212	9.10	-.84	-1.39	.24	.43	44.53	-21.55	-1.47	3.00	.52	45K	Ø	L212
L230B	9.67	-.27	-.45	.72	1.28	77.60	11.52	.79	4.72	.82	45K	Ø	L230B
L232B	10.09	.16	.26	.55	.97	65.36	-.72	-.05	7.52	1.31	45K	Ø	L232B
L274K	9.83	-.10	-.17	.34	.60	45.27	-20.81	-1.42	1.53	.27	45K	Ø	L274K
L291K	13.19	3.25	5.38	.96	1.70	91.66	25.58	1.75	8.83	1.54	45K	#	L291K
L581	10.13	.20	.33	.64	1.13	74.40	8.32	.57	5.50	.96	45K	Ø	L581

GR. MEAN = 9.94 BEKK SECONDS GRAND MEAN = 66.08 BEKK SECONDS TEST DETERMINATIONS = 15
SD MEANS = .60 BEKK SECONDS SD OF MBANS = 14.62 BEKK SECONDS 8 LABS IN GRAND MEANS
AVERAGE SDR = .56 BEKK SECONDS AVERAGE SDR = 5.74 BEKK SECONDS

L250M	10.36	.42	.70	.75	1.32	64.00	-2.08	-.14	6.21	1.08	45L	*	L250M
L251	9.19	-.75	-1.24	.49	.86	66.76	.68	.05	4.38	.76	45L	*	L251
L274H	37.12	27.18	45.01	.87	1.54	62.54	-3.54	-.24	1.58	.27	45H	*	L274H

TOTAL NUMBER OF LABORATORIES REPORTING = 13

Best values: J49 10 Bekk seconds
J73 66 Bekk seconds

The following laboratories were omitted from the grand means because of extreme test results: 162, 291K.

ANALYSIS T45-2 TABLE 2
SMOOTHNESS, BEKK SECONDS
TAPPI SUGGESTED METHOD T479 SU-71, SMOOTHNESS OF PAPER (BEKK METHOD)

LAB CODE	P	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J49	J73	MAJOR	MINOR	R.SDR	VAR			
L162	#	4.93	97.47	31.23	5.89	.77	45K	SMOOTHNESS,	BEKK	
L212	Ø	9.10	44.53	-21.56	.23	.48	45K	SMOOTHNESS,	BEKK	
L251	*	9.19	66.76	.66	.77	.81	45L	SMOOTHNESS,	BEKK,	20 C, 65% RH
L182K	Ø	9.31	61.87	-4.23	.51	1.19	45K	SMOOTHNESS,	BEKK	
L230B	Ø	9.67	77.60	11.51	.59	1.05	45K	SMOOTHNESS,	BEKK	
L274K	Ø	9.83	45.27	-20.81	-.48	.43	45K	SMOOTHNESS,	BEKK	
L232B	Ø	10.09	65.36	-.71	-.18	1.14	45K	SMOOTHNESS,	BEKK	
L581	Ø	10.13	74.40	8.32	.04	1.05	45K	SMOOTHNESS,	BEKK	
L190C	Ø	10.36	79.00	12.93	-.06	1.27	45K	SMOOTHNESS,	BEKK	
L250M	*	10.36	64.00	-2.07	-.48	1.20	45L	SMOOTHNESS,	BEKK,	20 C, 65% RH
L139B	Ø	11.00	80.60	14.55	-.65	1.39	45K	SMOOTHNESS,	BEKK	
L291K	#	13.19	91.66	25.66	-2.53	1.62	45K	SMOOTHNESS,	BEKK	
L274H	*	37.12	62.54	-2.77	-27.27	.91	45B	SMOOTHNESS,	GURLEY OIL FLATATION	

GMEANS: 9.94 66.08 50.66 1.53 1.00
95% ELLIPSE: WITH GAMMA = 88 DEGREES

LAB CODE	SAMPLE J49 MEAN	PRINTING 94 GRAMS PER SQUARE METER				R. SDR	SAMPLE J73 MEAN	PRINTING 76 GRAMS PER SQUARE METER				TEST D. - 10	
		DEV	N. DEV	SDR	R. SDR			DEV	N. DEV	SDR	R. SDR	VAR	F LAB
L182B	463.0	-2.8	-.15	37.5	1.12	119.9	15.6	1.40	7.7	.93	47B	Ø	L182B
L236	499.0	33.2	1.74	67.9	2.03	114.5	10.2	.91	9.4	1.15	47B	Ø	L236
L242	461.0	-4.8	-.25	34.8	1.04	92.3	-12.0	-1.08	8.0	.97	47B	Ø	L242
L244	480.5	14.7	.77	19.2	.57	93.5	-10.8	-.97	9.9	1.20	47B	Ø	L244
L248	437.2	-28.6	-1.50	46.1	1.38	90.3	-14.0	-1.26	9.5	1.15	47B	Ø	L248
L313	473.0	7.2	.38	28.7	.86	104.5	.2	.02	11.7	1.41	47B	Ø	L313
L333	465.0	-.8	-.04	27.1	.81	110.8	6.5	.58	5.2	.63	47B	Ø	L333
L484	448.0	-17.8	-.94	6.3	.19	108.8	4.5	.40	4.6	.55	47B	Ø	L484

GR. MEAN = 465.8 ML/MIN
SD MEANS = 19.0 ML/MIN

GRAND MEAN = 104.3 ML/MIN
SD OF MEANS = 11.1 ML/MIN

TEST DETERMINATIONS = 10
8 LABS IN GRAND MEANS

AVERAGE SDR = 33.4 ML/MIN

AVERAGE SDR = 8.2 ML/MIN

TOTAL NUMBER OF LABORATORIES REPORTING = 8

Best values: J49 465 milliliter per minute
J73 105 milliliter per minute

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY	TEST INSTRUMENT	CONDITIONS
		J49	J73	MAJOR	MINOR	R. SDR	VAR			
L248	Ø	437.2	90.3	-31.4	-5.7	1.27	47B	SMOOTHNESS, BENDTSEN, WG 150		
L484	Ø	448.0	108.8	-16.0	9.1	.37	47B	SMOOTHNESS, BENDTSEN, WG 150		
L242	Ø	461.0	92.3	-7.9	-10.3	1.01	47B	SMOOTHNESS, BENDTSEN, WG 150		
L182B	Ø	463.0	119.9	1.5	15.8	1.03	47B	SMOOTHNESS, BENDTSEN, WG 150		
L333	Ø	465.0	110.8	.9	6.5	.72	47B	SMOOTHNESS, BENDTSEN, WG 150		
L313	Ø	473.0	104.5	6.9	-1.8	1.14	47B	SMOOTHNESS, BENDTSEN, WG 150		
L244	Ø	480.5	93.5	11.2	-14.4	.89	47B	SMOOTHNESS, BENDTSEN, WG 150		
L236	Ø	499.0	114.5	34.7	.8	1.59	47B	SMOOTHNESS, BENDTSEN, WG 150		
GMEANS:		465.8	104.3			1.00				
		95% ELLIPSE:		67.8	35.2	WITH GAMMA = 15 DEGREES				

LAB CODE	SAMPLE B59		PRINTING				SAMPLE B80		COATED OFFSET BOOK				TEST D. = 4		
	MEAN	DEV	106 GRAMS PBR	SQR N.DEV	SQR METER	R. SDR	MEAN	DEV	75 GRAMS PBR	SQR N.DEV	SQR METER	R. SDR	VAR	F	LAB
L126	58.70	-5.05	-.90	.20	.46	22.87	-1.66	-.59	.49	.87	56K	Ø	L126		
L149	56.00	-7.75	-1.38	.00	.00	20.00	-4.53	-1.62	.82	1.45	56K	Ø	L149		
L182	63.70	-.05	-.01	.57	1.30	26.17	1.64	.59	.50	.89	56K	Ø	L182		
L213	66.82	3.08	.55	.61	1.38	27.75	3.22	1.15	.13	.23	56K	Ø	L213		
L277	70.00	6.25	1.12	.00	.00	27.50	2.97	1.06	.58	1.02	56K	Ø	L277		
L291	66.80	3.05	.54	.45	1.04	22.57	-1.96	-.70	1.19	2.10	56K	Ø	L291		
L333	57.70	-6.05	-1.08	.29	.67	23.27	-1.26	-.45	.90	1.59	56K	Ø	L333		
L339	72.00	8.25	1.47	.41	.93	27.62	3.09	1.11	.48	.85	56K	Ø	L339		
L616	62.00	-1.75	-.31	1.41	3.22	23.00	-1.53	-.55	.00	.00	56K	Ø	L616		
GR. MEAN = 63.75 K & N UNITS			GRAND MEAN = 24.53 K & N UNITS				TEST DETERMINATIONS = 4								
SD MEANS = 5.60 K & N UNITS			SD OF MEANS = 2.79 K & N UNITS				9 LABS IN GRAND MEANS								
AVERAGE SDR = .44 K & N UNITS			AVERAGE SDR = .56 K & N UNITS												
L643	54.25	-5.50	-1.70	.96	2.18	21.25	-3.28	-1.17	.96	1.70	56Ø	•	L643		
L651	31.45	-32.30	-5.76	.66	1.49	53.80	29.27	10.47	.57	1.01	56Ø	•	L651		
TOTAL NUMBER OF LABORATORIES REPORTING = 11															
Best values: H59 64 K + N units															
B80 25 K + N units															

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		B59	B80	MAJOR	MINOR	R. SDR	VAR			
L651	•	31.45	53.80	-17.89	39.74	1.25	56Ø	INK ABSORPTION: OWN METHOD		
L643	•	54.25	21.25	-10.02	.79	1.94	56Ø	INK ABSORPTION: OWN METHOD		
L149	Ø	56.00	20.00	-8.91	-1.05	.72	56K	INK ABSORPTION, K&N INK TEST		
L333	Ø	57.70	23.27	-6.04	1.27	1.13	56K	INK ABSORPTION, K&N INK TEST		
L126	Ø	58.70	22.87	-5.29	.50	.66	56K	INK ABSORPTION, K&N INK TEST		
L616	Ø	62.00	23.00	-2.21	-.70	1.61	56K	INK ABSORPTION, K&N INK TEST		
L182	Ø	63.70	26.17	.61	1.53	1.09	56K	INK ABSORPTION, K&N INK TEST		
L291	Ø	66.80	22.57	2.02	-3.01	1.57	56K	INK ABSORPTION, K&N INK TEST		
L213	Ø	66.82	27.75	4.11	1.72	.81	56K	INK ABSORPTION, K&N INK TEST		
L277	Ø	70.00	27.50	6.92	.22	.51	56K	INK ABSORPTION, K&N INK TEST		
L339	Ø	72.00	27.62	8.80	-.46	.89	56K	INK ABSORPTION, K&N INK TEST		
GMEANS:		63.75	24.53			1.00				
		95% ELLIPSE:		20.00	4.95	WITH GAMMA = 23 DEGREES				

OPACITY (89% REFLECTANCE BACKING) IN PERCENT
TAPPI STANDARD T425 68-75, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - B&L TYPE

LAB CODE	SAMPLE K23 MEAN	PRINTING 103 GRAMS PER SQUARE METER				SAMPLE J58 MEAN	PRINTING 94 GRAMS PER SQUARE METER				TEST D. = 10		
		DEV	N.DEV	SDR	R.SDR		DEV	N.DEV	SDR	R.SDR	VAR	F	LAB
L105	95.75	.33	.79	.28	1.01	93.01	.32	.55	.30	.89	60B	Ø	L105
L108	95.24	-.18	-.43	.12	.42	95.29	2.60	4.53	.09	.26	60B	#	L108
L115	95.30	-.12	-.28	.22	.78	92.38	-.31	-.55	.29	.86	60B	Ø	L115
L121	95.69	.27	.65	.30	1.06	93.17	.48	.83	.32	.95	60B	Ø	L121
L122	95.50	.08	.20	.35	1.24	92.90	.21	.36	.27	.79	60D	Ø	L122
L123	95.57	.15	.36	.22	.79	92.63	-.06	-.11	.34	1.00	60W	Ø	L123
L124	94.86	-.56	-1.33	.32	1.15	91.89	-.80	-1.40	.44	1.30	60B	Ø	L124
L125	94.57	-.85	-2.03	.31	1.12	92.39	-.80	-.53	.40	1.18	60B	X	L125
L131	95.00	-.42	-1.00	.00	.00	92.10	-.59	-1.04	.32	.93	60R	Ø	L131
L132	94.95	-.47	-1.12	.21	.76	92.10	-.59	-1.04	.49	1.44	60B	Ø	L132
L136	95.14	-.28	-.66	.26	.93	92.02	-.67	-1.18	.33	.96	60B	Ø	L136
L139	95.61	.15	.46	.30	1.08	92.72	.03	.05	.35	1.02	60B	Ø	L139
L148B	95.13	-.29	-.69	.11	.38	92.34	-.35	-.62	.33	.96	60B	Ø	L148B
L150	95.80	.38	.91	.26	.93	93.40	.71	1.23	.52	1.51	60B	Ø	L150
L152	95.95	.53	1.27	.18	.64	93.37	.68	1.18	.31	.90	60B	Ø	L152
L153	94.35	-1.07	-2.55	.47	1.70	91.40	-1.29	-2.26	.39	1.16	60B	*	L153
L162	95.81	.39	.94	.21	.75	93.33	.64	1.11	.25	.74	60W	Ø	L162
L166	95.45	.03	.08	.51	1.84	92.44	-.25	-.44	.32	.95	60B	Ø	L166
L173A	95.58	.16	.39	.27	.97	93.06	.37	.64	.18	.54	60B	Ø	L173A
L190C	95.40	-.02	-.04	.35	1.27	92.63	-.06	-.11	.52	1.53	60B	Ø	L190C
L190R	95.60	.18	.44	.34	1.21	92.83	.14	.24	.35	1.02	60B	Ø	L190R
L206	95.45	.03	.08	.29	1.05	92.83	.14	.24	.24	.70	60B	Ø	L206
L210B	95.50	.08	.20	.27	.96	92.80	.11	.19	.38	1.11	60B	Ø	L210B
L210D	95.71	.29	.70	.19	.67	93.05	.36	.62	.37	1.07	60D	Ø	L210D
L211S	95.30	-.12	-.28	.40	1.45	92.78	.09	.15	.39	1.15	60R	Ø	L211S
L212	95.70	.28	.67	.67	2.42	93.00	.31	.53	.47	1.38	60B	Ø	L212
L213	95.31	-.11	-.26	.16	.57	93.31	.62	1.08	.28	.83	60B	X	L213
L223B	95.69	.27	.65	.32	1.14	92.76	.07	.12	.29	.85	60B	Ø	L223B
L225	95.93	.51	1.22	.38	1.38	92.83	.14	.24	.39	1.16	60B	*	L225
L226B	95.11	-.31	-.74	.29	1.05	92.44	-.25	-.44	.25	.75	60B	Ø	L226B
L228	95.00	-.42	-1.00	.35	1.26	92.27	-.42	-.74	.34	1.00	60H	Ø	L228
L230	96.13	.71	1.70	.23	.81	93.78	1.09	1.90	.39	1.15	60B	Ø	L230
L236B	94.31	-1.11	-2.65	.66	2.37	91.10	-1.59	-2.78	.51	1.49	60B	*	L236B
L238A	94.79	-.63	-1.50	.17	.60	91.81	-.88	-1.54	.25	.74	60R	Ø	L238A
L241	95.68	.26	.63	.27	.98	93.36	.67	1.16	.43	1.26	60B	Ø	L241
L254	95.73	.31	.75	.28	1.02	93.38	.69	1.20	.42	1.24	60B	Ø	L254
L255	95.36	-.06	-.14	.16	.59	93.02	.33	.57	.21	.61	60B	Ø	L255
L261	95.60	.18	.44	.52	1.85	92.95	.26	.45	.28	.83	60B	Ø	L261
L262	95.90	.48	1.15	.19	.68	93.18	.49	.85	.29	.86	60R	Ø	L262
L275	95.52	.10	.24	.19	.69	92.69	-.00	-.01	.26	.77	60R	Ø	L275
L278	95.25	-.17	-.40	.33	1.19	92.63	-.06	-.11	.32	.93	60B	Ø	L278
L281	95.83	.41	.99	.21	.74	93.18	.49	.85	.32	.92	60D	Ø	L281
L285D	95.11	-.31	-.74	.31	1.12	91.91	-.78	-1.37	.37	1.07	60D	Ø	L285D
L285R	95.24	-.18	-.43	.23	.82	92.34	-.35	-.62	.39	1.13	60R	Ø	L285R
L288	95.30	-.12	-.28	.16	.56	92.74	.05	.08	.25	.73	60D	Ø	L288
L301	94.89	-.53	-1.26	.20	.73	91.93	-.76	-1.33	.32	.93	60B	Ø	L301
L305	95.50	.08	.20	.28	1.00	92.78	.09	.15	.31	.91	60R	Ø	L305
L308	95.68	.26	.63	.25	.89	92.97	.28	.48	.40	1.18	60B	Ø	L308
L315	95.73	.31	.75	.32	1.16	93.01	.32	.55	.24	.71	60D	Ø	L315
L317	95.35	-.07	-.16	.25	.88	92.69	-.00	-.01	.63	1.83	60B	Ø	L317
L318	95.60	.18	.44	.46	1.65	93.40	.71	1.23	.46	1.35	60B	Ø	L318
L323	95.71	.25	.70	.24	.85	92.84	.15	.26	.24	.71	60W	Ø	L323
L326	96.10	.68	1.63	.22	.78	93.48	.79	1.37	.37	1.08	60B	Ø	L326
L328	96.00	.58	1.39	.00	.00	92.00	-.69	-1.21	.00	.00	60B	X	L328
L339	95.25	-.17	-.40	.49	1.75	92.45	-.24	-.43	.50	1.46	60B	Ø	L339
L352	95.30	-.12	-.28	.20	.72	92.73	.04	.06	.15	.44	60R	Ø	L352
L354	94.70	-.72	-1.72	.48	1.73	91.60	-1.09	-1.91	.52	1.51	60B	Ø	L354
L390	95.84	.42	1.01	.26	.95	93.37	.68	1.18	.33	.96	60B	Ø	L390
L523	95.34	-.08	-.19	.17	.62	92.48	-.21	-.37	.27	.80	60R	Ø	L523
L567	96.35	.93	2.23	.23	.82	93.96	1.27	2.21	.30	.86	60D	Ø	L567
L573	95.73	.31	.75	.19	.68	92.81	.12	.20	.20	.58	60H	Ø	L573
L581	95.45	.03	.08	.20	.70	92.91	.22	.38	.32	.94	60B	Ø	L581
L587	95.38	-.04	-.09	.32	1.16	92.72	.03	.05	.40	1.19	60B	Ø	L587
L592	94.70	-.72	-1.72	.21	.74	91.75	-.94	-1.65	.32	.94	60W	Ø	L592
L594	95.27	-.15	-.35	.31	1.11	92.61	-.08	-.15	.29	.85	60D	Ø	L594

ANALYSIS T60-1 TABLE 1

OPACITY (89% REFLECTANCE BACKING) IN PERCENT

TAPPI STANDARD T425 GS-75, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - B4L TYPE

LAB CODE	SAMPLE K23 MEAN	PRINTING 103 GRAMS PER SQUARE METER				SAMPLE J58 MEAN	PRINTING 94 GRAMS PER SQUARE METER				TEST D. = 10		
		DEV	N.DEV	SDR	R.SDR		DEV	N.DEV	SDR	R.SDR	VAR	P	LAB
L597	94.30	-1.12	-2.67	.48	1.73	91.40	-1.29	-2.26	.84	2.47	60B	*	L597
L599	95.40	-.02	-.04	.52	1.85	92.95	.26	.45	.28	.83	60B	Ø	L599
L673R	95.62	.20	.48	.29	1.05	92.78	.09	.15	.32	.92	60B	Ø	L673R
L673T	95.39	-.03	-.07	.21	.77	92.92	.23	.39	.50	1.47	60B	Ø	L673T

GR. MEAN = 95.42 PERCENT GRAND MEAN = 92.69 PERCENT TEST DETERMINATIONS = 10
 SD MEANS = .42 PERCENT SD OF MEANS = .57 PERCENT 65 LABS IN GRAND MEANS
 AVERAGE SDR = .28 PERCENT AVERAGE SDR = .34 PERCENT

L224	95.35	-.07	-.16	.52	1.86	92.29	-.40	-.70	.37	1.09	60P	*	L224
L232	95.70	.28	.67	.35	1.26	92.10	-.59	-1.04	.39	1.16	60P	*	L232
L249	95.21	-.21	-.50	.32	1.14	91.95	-.74	-1.30	.16	.46	60P	*	L249
L256	97.56	2.14	5.13	.15	.54	94.18	1.49	2.60	.23	.66	60N	*	L256
L260	95.62	.20	.48	.26	.92	92.19	-.50	-.88	.23	.67	60P	*	L260
L274P	95.65	.23	.56	.34	1.21	92.25	-.44	-.77	.26	.77	60P	*	L274P
L312	95.00	-.42	-1.00	.00	.00	92.00	-.69	-1.21	.00	.00	60P	*	L312
L380	95.00	-.42	-1.00	.00	.00	91.40	-1.29	-2.26	.39	1.16	60P	*	L380
L396	95.50	.08	.20	.33	1.20	92.85	.16	.27	.24	.71	60X	*	L396

TOTAL NUMBER OF LABORATORIES REPORTING = 78

Best values: K23 95.4 ± 0.6 percent
 J58 92.7 ± 0.9 percent

The following laboratories were omitted from the grand means because of extreme test results: 108.

OPACITY (89% REFLECTANCE BACKING) IN PERCENT
TAPPI STANDARD T425 6S-75, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - B&L TYPE

LAB CODE	F	MEANS		COORDINATES		AVG R.SDR	VAR	PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		K23	J58	MAJOR	MINOR					
L597	*	94.30	91.40	-1.70	.16	2.10	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L236B	*	94.31	91.10	-1.94	-.03	1.93	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L153	*	94.35	91.40	-1.67	.11	1.43	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L125	X	94.57	92.39	-.74	.51	1.15	60B	OPACITY (WHITE BACKING),	BUYGEN	
L592	0	94.70	91.75	-1.19	.03	.84	60B	OPACITY (WHITE BACKING),	HUYGEN	DIGITAL
L354	0	94.70	91.60	-1.31	-.05	1.62	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L238A	0	94.79	91.81	-1.08	-.00	.67	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L124	0	94.86	91.89	-.98	-.01	1.22	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L301	0	94.89	91.93	-.93	-.02	.83	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L132	0	94.95	92.10	-.76	.03	1.10	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L228	0	95.00	92.27	-.59	.09	1.13	60B	OPACITY (WHITE BACKING),	HUYGEN	
L380	*	95.00	91.40	-1.29	-.41	.58	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L312	*	95.00	92.00	-.81	-.06	.00	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L131	0	95.00	92.10	-.73	-.01	.46	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L285D	0	95.11	91.91	-.82	-.21	1.09	60D	OPACITY (WHITE BACKING),	BNL-2	
L226B	0	95.11	92.44	-.39	.10	.90	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L148H	0	95.13	92.34	-.46	.03	.67	60B	OPACITY (WHITE BACKING),	HUYGEN	
L136	0	95.14	92.02	-.71	-.17	.95	60B	OPACITY (WHITE BACKING),	HUYGEN	
L249	*	95.21	91.95	-.73	-.26	.80	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L285R	0	95.24	92.34	-.39	-.06	.97	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L108	#	95.24	95.29	2.01	1.66	.34	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L339	0	95.25	92.45	-.30	-.01	1.60	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L278	0	95.25	92.63	-.15	.10	1.05	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L594	0	95.27	92.61	-.15	.07	.98	60D	OPACITY (WHITE BACKING),	BNL-2	
L352	0	95.30	92.73	-.04	.12	.58	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L211S	0	95.30	92.78	.00	.15	1.30	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L288	0	95.30	92.74	-.03	.12	.65	60D	OPACITY (WHITE BACKING),	BNL-2	
L115	0	95.30	92.38	-.32	-.09	.82	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L213	X	95.31	93.31	.44	.45	.70	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L523	0	95.34	92.48	-.22	-.06	.71	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L224	*	95.35	92.29	-.37	-.18	1.48	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L317	0	95.35	92.69	-.04	.05	1.36	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L255	0	95.36	93.02	.23	.24	.60	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L587	0	95.38	92.72	-.00	.05	1.17	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L673T	0	95.39	92.92	.17	.15	1.12	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L190C	0	95.40	92.63	-.06	-.02	1.40	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L599	0	95.40	92.95	.20	.16	1.34	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L166	0	95.45	92.44	-.19	-.17	1.39	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L581	0	95.45	92.91	.19	.10	.82	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L206	0	95.45	92.83	.13	.05	.88	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L396	*	95.50	92.85	.17	.02	.95	60X	OPACITY: GIVE INSTR. MAKE, MODBL; () WHITE OR () PAPER BACKING		
L210B	0	95.50	92.80	.13	-.00	1.04	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L122	0	95.50	92.90	.22	.05	1.02	60D	OPACITY (WHITE BACKING),	BNL-2	
L305	0	95.50	92.78	.12	-.02	.96	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L275	0	95.52	92.69	.06	-.09	.73	60R	OPACITY (WHITE BACKING),	THWING-ALBERT	(FORMERLY SRL)
L123	0	95.57	92.63	.04	-.16	.90	60W	OPACITY (WHITE BACKING),	BUYGEN	DIGITAL
L173A	0	95.58	93.06	.39	.08	.75	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L261	0	95.60	92.95	.31	.00	1.34	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L190R	0	95.60	92.83	.22	-.07	1.11	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L318	0	95.60	93.40	.68	.26	1.50	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L139	0	95.61	92.72	.13	-.14	1.05	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L260	*	95.62	92.19	-.29	-.46	.80	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L673R	0	95.62	92.78	.19	-.11	.59	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L274P	*	95.65	92.25	-.23	-.45	.99	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L308	0	95.68	92.97	.38	-.05	1.04	60H	OPACITY (WHITE BACKING),	BUYGEN	
L241	0	95.68	93.36	.69	.17	1.12	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L121	0	95.69	93.17	.55	.06	1.01	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L223B	0	95.69	92.76	.21	-.18	1.00	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L232	*	95.70	92.10	-.32	-.58	1.21	60P	OPACITY (WHITE BACKING),	PB0T0V0LT	
L212	0	95.70	93.00	.41	-.05	1.90	60B	OPACITY (WHITE BACKING),	HAUSCH	* LOWB
L323	0	95.71	92.84	.29	-.15	.78	60W	OPACITY (WHITE BACKING),	BUYGEN	DIGITAL
L210D	0	95.71	93.05	.46	-.03	.87	60D	OPACITY (WHITE BACKING),	BNL-2	
L254	0	95.73	93.38	.74	.15	1.13	60B	OPACITY (WHITE BACKING),	BUYGEN	
L573	0	95.73	92.81	.28	-.19	.63	60B	OPACITY (WHITE BACKING),	HUYGEN	
L315	0	95.73	93.01	.44	-.07	.94	60D	OPACITY (WHITE BACKING),	BNL-2	

ANALYSIS T60-1 TABLE 2

OPACITY (89% REFLECTANCE BACKING) IN PERCENT


TAPPI STANDARD T425 6S-7S, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - H&L TYPE

LAB CODE	P	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		K23	J58	MAJOR	MINOR	R.SDR	VAR			
L105	Ø	95.75	93.01	.45	-.09	.95	60H	OPACITY (WHITE BACKING),	HUYGEN	
L150	Ø	95.80	93.40	.80	.10	1.22	60B	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L162	Ø	95.81	93.33	.75	.05	.75	60W	OPACITY (WHITE BACKING),	HUYGEN, DIGITAL	
L281	Ø	95.83	93.18	.64	-.05	.83	60D	OPACITY (WHITE BACKING),	HNL-2	
L390	Ø	95.84	93.37	.80	.05	.95	60H	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L262	Ø	95.90	93.18	.68	-.11	.77	60R	OPACITY (WHITE BACKING),	TEWING-ALBERT (FORMERLY SRL)	
L225	*	95.93	92.83	.41	-.34	1.27	60B	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L152	Ø	95.95	93.37	.86	-.04	.77	60H	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L328	X	96.00	92.00	-.22	-.88	.00	60H	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L326	Ø	96.10	93.48	1.04	-.10	.93	60B	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L230	Ø	96.13	93.78	1.30	.05	.98	60B	OPACITY (WHITE BACKING),	HAUSCH • LOMB	
L567	Ø	96.35	93.96	1.57	-.02	.84	60D	OPACITY (WHITE BACKING),	HNL-2	
L256	*	97.56	94.18	2.46	-.88	.60	60N	OPACITY (WHITE BACKING),	HUNTER	
GMEANS:		95.42	92.69			1.00				
		95% ELLIPSH:		1.77	.29			WITH GAMMA = 54 DEGREES		

OPACITY, B&L TYPE, 89% BACKING

SAMPLE K23 = 95.4 PERCENT

SAMPLE J58 = 92.7 PERCENT



TAPPI STANDARD T425 GS-75, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - B&L TYPE

LAB CODE	SAMPLE K23 MEAN	PRINTING 103 GRAMS PER SQUARE METER					SAMPLE J58 MEAN	PRINTING 94 GRAMS PER SQUARE METER					TEST D. = 10		
		DEV	N.DEV	SDR	R.SDR			DEV	N.DEV	SDR	R.SDR	VAR	P	LAB	
L115	96.04	.15	.92	.31	1.04	93.46	.37	1.11	.13	.38	60C	Ø	L115		
L190C	95.67	-.22	-1.35	.27	.89	93.33	.24	.72	.35	1.00	60C	Ø	L190C		
L190R	96.02	.13	.80	.33	1.10	92.94	-.15	-.43	.36	1.01	60C	Ø	L190R		
L236B	95.77	-.12	-.74	.43	1.43	93.10	.01	.04	.40	1.14	60C	Ø	L236B		
L274	95.95	.06	.37	.16	.53	92.60	-.49	-1.44	.52	1.47	60C	Ø	L274		
GR. MEAN = 95.89 PERCENT							GRAND MEAN = 93.09 PERCENT					TEST DETERMINATIONS = 10			
SD MEANS = .16 PERCENT							SD OF MEANS = .34 PERCENT					5 LABS IN GRAND MEANS			
		AVERAGE SDR = .30 PERCENT										AVERAGE SDR = .35 PERCENT			
TOTAL NUMBER OF LABORATORIES REPORTING = 5															
Best values: K23 95.9 percent															
J58 93.1 percent															

TAPPI STANDARD T425 GS-75, OPACITY OF PAPER (15 DEG./DIFFUSE, ILLUMINANT A) - B&L TYPE

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		K23	J58	MAJOR	MINOR	R.SDR	VAR			
L190C	Ø	95.67	93.33	-.27	-.19	.95	60C	OPACITY (PAPER BACKING),	PAUSCB	Ø LØMB
L236B	Ø	95.77	93.10	-.03	-.12	1.28	60C	OPACITY (PAPER BACKING),	BAUSCB	Ø LØMB
L274	Ø	95.95	92.60	.49	-.00	1.00	60C	OPACITY (PAPER BACKING),	BAUSCB	Ø LØMB
L190R	Ø	96.02	92.94	.16	.11	1.06	60C	OPACITY (PAPER BACKING),	BAUSCB	Ø LØMB
L115	Ø	96.04	93.46	-.35	.20	.71	60C	OPACITY (PAPER BACKING),	BAUSCB	Ø LØMB
GMEANS:		95.89	93.09			1.00				
		95% ELLIPSE:		1.72	.80	WITH GAMMA --82 DEGREES				

OPACITY (PAPER BACKING) IN PERCENT
TAPPI SUGGESTED METHOD T519 GS-78, DIFFUSE OPACITY OF PAPER - ILLUMINANT C, ELREPHO TYPE

LAB CODE	SAMPLE K23		PRINTING 103 GRAMS PER SQUARE METER				SAMPLE J58		PRINTING 94 GRAMS PER SQUARE METER				TEST D. = 10		
	MEAN	DEV	N.DEV	SDR	R.SDR	MEAN	DEV	N.DEV	SDR	R.SDR	VAR	F	LAE		
L150	96.29	-.02	-.11	.21	1.47	93.56	.01	.05	.18	.89	60J	Ø	L150		
L182E	96.25	-.05	-.33	.16	1.10	93.41	-.14	-.70	.13	.66	60J	Ø	L182E		
L236	96.31	.01	.04	.13	.90	93.46	-.09	-.46	.31	1.60	60J	Ø	L236		
L242	96.44	.14	.84	.12	.82	93.61	.06	.28	.23	1.16	60J	Ø	L242		
L244	96.12	-.18	-1.13	.19	1.31	93.32	-.23	-1.15	.20	1.01	60F	Ø	L244		
L250T	96.03	-.27	-1.68	.14	.99	93.35	-.20	-1.00	.31	1.60	60J	Ø	L250T		
L251	96.04	-.27	-1.65	.17	1.22	93.28	-.28	-1.37	.22	1.14	60F	Ø	L251		
L309	95.25	-1.05	-6.48	.27	1.90	91.83	-1.72	-8.50	.31	1.59	60J	#	L309		
L313	96.56	.26	1.57	.13	.88	93.88	.33	1.62	.16	.82	60F	Ø	L313		
L360	96.31	.01	.04	.12	.84	93.47	-.08	-.41	.18	.93	60F	Ø	L360		
L446	96.41	.11	.66	.13	.90	93.55	.00	.01	.15	.77	60J	Ø	L446		
L484	96.40	.10	.62	.14	.97	93.76	.21	1.01	.21	1.06	60F	Ø	L484		
L598	96.47	.17	1.02	.14	.99	93.91	.36	1.76	.12	.61	60J	Ø	L598		
L678	96.32	.02	.12	.09	.63	93.62	.07	.34	.15	.76	60J	Ø	L678		

GR. MEAN = 96.30 PERCENT GRAND MEAN = 93.55 PERCENT TEST DETERMINATIONS = 10
 SD MEANS = .16 PERCENT SD OF MEANS = .20 PERCENT 13 LABS IN GRAND MEANS
 AVERAGE SDR = .14 PERCENT AVERAGE SDR = .20 PERCENT

L626 96.00 -.30 -1.87 .00 .00 93.00 -.55 -2.73 .00 .00 60Q + L626
 TOTAL NUMBER OF LABORATORIES REPORTING = 15

Best values: K23 96.3 ± 0.3 percent
 J58 93.5 ± 0.4 percent

The following laboratories were omitted from the grand means because of extreme test results: 309.


OPACITY (PAPER BACKING) IN PERCENT
TAPPI SUGGESTED METHOD T519 GS-78, DIFFUSE OPACITY OF PAPER - ILLUMINANT C, ELREPHO TYPE

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---TEST INSTRUMENT---CONDITIONS
		K23	J58	MAJOR	MINOR	R.SDR	VAR	
L309	#	95.25	91.83	-2.01	-.23	1.74	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, PMY-C(10) FILTER
L626	*	96.00	93.00	-.62	-.10	.00	60Q	OPACITY (PAPER BACKING), PB0T0VOLT
L250T	Ø	96.03	93.35	-.33	.09	1.29	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L251	Ø	96.04	93.28	-.38	.04	1.18	60F	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) NO TRAP
L244	Ø	96.12	93.32	-.30	.00	1.16	60F	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) NO TRAP
L182E	Ø	96.25	93.41	-.15	-.05	.88	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L150	Ø	96.29	93.56	-.00	.02	1.18	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L236	Ø	96.31	93.46	-.07	-.06	1.25	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L360	Ø	96.31	93.47	-.06	-.06	.88	60F	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) NO TRAP
L678	Ø	96.32	93.62	.07	.03	.69	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L484	Ø	96.40	93.76	.22	.05	1.01	60F	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) NO TRAP
L446	Ø	96.41	93.55	.07	-.08	.83	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L242	Ø	96.44	93.61	.13	-.07	.99	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L598	Ø	96.47	93.91	.38	.09	.80	60J	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) FILTER
L313	Ø	96.56	93.88	.42	.00	.85	60F	OPACITY (PAPER BACKING), ZEISS ELREPHO, FMY-C(10) NO TRAP
GMEANS:		96.30	93.55			1.00		
		95% ELLIPSE:		.75	.17	WITH GAMMA = 51 DEGREES		

OPACITY, ELREPHO TYPE, PAPER BACKING

SAMPLE K23 = 96.30 PERCENT

SAMPLE J58 = 93.55 PERCENT



ANALYSIS T65-1 TABLE 1

DIRECTIONAL BLUE REFLECTANCE IN PERCENT

TAPPI STANDARD T452 GS-77, 'BRIGHTNESS'; MARTIN SWEETS (ACBT & GE) IS STANDARD FOR THIS ANALYSIS

LAB CODE	SAMPLE E78 116 GRAMS PER SQUARE METER PRINTING					SAMPLE J97 89 GRAMS PER SQUARE METER PRINTING					TEST D. ° 8		
	MEAN	DEV	N.DEV	SDR	R.SDR	MEAN	DEV	N.DEV	SDR	R.SDR	VAR	F	LAB
L108	95.94	-.37	-.81	.16	1.54	76.60	.69	1.36	.15	1.00	65M	Ø	L108
L122	96.00	-.30	-.67	.05	.52	75.61	-.30	-.60	.15	.97	65N	Ø	L122
L132	96.96	.66	1.46	.09	.88	76.11	.20	.40	.17	1.15	65N	Ø	L132
L190C	95.67	-.63	-1.39	.12	1.12	75.02	-.89	-1.76	.10	.69	65A	Ø	L190C
L210M	96.04	-.27	-.59	.07	.72	75.52	-.39	-.77	.07	.47	65M	Ø	L210M
L210N	95.87	-.43	-.95	.07	.68	75.37	-.54	-1.07	.13	.85	65N	Ø	L210N
L211	93.99	-2.32	-5.13	.30	2.94	74.81	-1.10	-2.18	.15	.97	65N	#	L211
L225	96.50	.20	.44	.09	.89	96.15	20.24	40.18	.11	.71	65N	#	L225
L275	95.91	-.39	-.87	.08	.81	75.50	-.41	-.82	.12	.79	65M	Ø	L275
L285	96.47	.17	.38	.24	2.35	76.25	.34	.67	.23	1.55	65N	Ø	L285
L288	96.49	.18	.41	.17	1.67	76.50	.59	1.17	.12	.79	65N	Ø	L288
L308	96.94	.63	1.40	.07	.72	76.79	.88	1.74	.12	.83	65N	Ø	L308
L315	96.49	.18	.41	.08	.81	76.17	.26	.52	.25	1.69	65N	Ø	L315
L523	96.01	-.29	-.64	.04	.34	76.17	.26	.52	.09	.59	65N	Ø	L523
L598	96.09	-.22	-.48	.08	.81	75.75	-.16	-.32	.17	1.12	65M	Ø	L598
L636	96.51	.21	.46	.14	1.31	75.76	-.15	-.30	.25	1.66	65M	Ø	L636
L673R	97.15	.65	1.88	.08	.73	75.54	-.38	-.74	.13	.86	65N	Ø	L673R

GR. MEAN ° 96.30 PERCENT GRAND MEAN ° 75.91 PERCENT TEST DETERMINATIONS ° 8
 SD MEANS ° .45 PERCENT SD OF MEANS ° .50 PERCENT 15 LABS IN GRAND MEANS

AVERAGE SDR ° .10 PERCENT AVERAGE SDR ° .15 PERCENT

L105	98.00	1.70	3.76	.15	1.46	75.86	-.05	-.10	.17	1.12	65T	*	L105
L213	97.76	1.46	3.23	.12	1.15	76.17	.26	.52	.15	.99	65T	*	L213
L223	97.70	1.40	3.09	.05	.52	76.71	.80	1.59	.20	1.30	65G	*	L223
L224	96.14	-.17	-.37	.12	1.15	75.90	-.01	-.02	.19	1.23	65B	*	L224
L232	97.00	.70	1.54	.53	5.16	77.25	1.34	2.66	.27	1.77	65P	*	L232
L241	96.11	-.19	-.42	.23	2.22	76.52	.61	1.22	.13	.85	65I	*	L241
L249	97.02	.72	1.60	.07	.68	77.72	1.81	3.60	.14	.92	65P	*	L249
L256	96.62	.32	.71	.09	.86	75.62	-.29	-.57	.10	.69	65B	*	L256
L260	96.05	-.25	-.56	.08	.73	77.04	1.13	2.23	.12	.79	65P	*	L260
L277	93.00	-3.30	-7.32	1.07	10.32	81.00	5.09	10.10	.00	.00	65P	*	L277
L278	97.82	1.52	3.37	.21	1.98	77.50	1.59	3.15	.28	1.88	65P	*	L278
L301	96.89	.58	1.29	.10	.96	75.81	-.10	-.20	.16	1.09	65G	*	L301
L312	96.25	-.05	-.12	.38	3.65	78.25	2.34	4.64	.27	1.77	65P	*	L312
L321	100.00	3.70	8.19	.00	.00	78.00	2.09	4.14	.00	.00	65P	*	L321
L328	99.42	3.12	6.91	.48	4.64	78.50	2.59	5.14	.00	.00	65P	*	L328
L339	96.94	.63	1.40	.32	3.09	76.87	.96	1.91	.23	1.53	65P	*	L339
L380	95.12	-1.18	-2.61	.23	2.23	78.00	2.09	4.14	.00	.00	65P	*	L380
L562	96.50	.20	.44	.00	.00	81.50	5.59	11.09	.00	.00	65P	*	L562
L587	96.07	-.23	-.51	.05	.45	74.96	-.95	-1.89	.09	.61	65I	*	L587
L591	98.67	2.36	5.24	.07	.71	74.84	-1.07	-2.13	.17	1.14	65H	*	L591
L617	94.45	-1.85	-4.11	.13	1.26	74.69	-1.22	-2.43	.11	.75	65G	*	L617
L626	96.62	.32	.71	.35	3.41	78.12	2.21	4.39	.10	.69	65P	*	L626

TOTAL NUMBER OF LABORATORIES REPORTING ° 39

Best values: E78 96.1 ± 0.9 percent
 J97 75.8 ± 0.8 percent

The following laboratories were omitted from the grand means because of extreme test results: 211, 225.


DIRECTIONAL BLUE REFLECTANCE IN PERCENT
TAPPI STANDARD T452 6S-77, 'BRIGHTNESS'; MARTIN SWEETS (ACHT & GE) IS STANDARD FOR THIS ANALYSIS

LAB CODE	F	MEANS		COORDINATES		AVG R. SDR	VAR	PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		E78	J97	MAJOR	MINOR					
L277	*	93.00	81.00	1.97	5.74	5.16	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L211	#	93.99	74.81	-2.29	1.15	1.95	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L617	*	94.45	74.69	-2.11	.71	1.01	65G	BLUE REFLECTANCE (DIRECTIONAL),	GARDNER	
L380	*	95.12	78.00	.92	2.21	1.12	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L190C	Ø	95.67	75.02	-1.09	-.05	.91	65A	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (ACHT),	S-2
L210N	Ø	95.87	75.37	-.69	.01	.77	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L275	Ø	95.91	75.50	-.57	.05	.80	65M	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (GE),	S-1
L108	Ø	95.94	76.60	.32	.71	1.27	65M	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (GE),	S-1
L122	Ø	96.00	75.61	-.42	.05	.74	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L523	Ø	96.01	76.17	.03	.39	.46	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L210M	Ø	96.04	75.52	-.47	-.03	.59	65M	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (GE),	S-1
L260	*	96.05	77.04	.73	.89	.76	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L587	*	96.07	74.96	-.89	-.41	.53	65I	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER D25D2A	
L598	Ø	96.09	75.75	-.26	.07	.96	65M	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (GE),	S-1
L241	*	96.11	76.52	.37	.53	1.53	65I	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER D25D2A	
L224	*	96.14	75.90	-.11	.12	1.19	65H	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER	
L312	*	96.25	78.25	1.81	1.48	2.71	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L285	Ø	96.47	76.25	.37	.07	1.95	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L315	Ø	96.49	76.17	.32	.02	1.25	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L288	Ø	96.49	76.50	.58	.22	1.23	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L562	*	96.50	81.50	4.52	3.29	.00	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L225	#	96.50	96.15	16.07	12.31	.80	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L636	Ø	96.51	75.76	.01	-.26	1.48	65M	BLUE REFLECTANCE (DIRECTIONAL),	MARTIN SWEETS (GE),	S-1
L626	*	96.62	78.12	1.94	1.11	2.05	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L256	*	96.62	75.62	-.03	-.43	.77	65H	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER	
L301	*	96.89	75.81	.28	-.52	1.02	65G	BLUE REFLECTANCE (DIRECTIONAL),	GARDNER	
L339	*	96.94	76.87	1.15	.09	2.31	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L308	Ø	96.94	76.79	1.08	.04	.77	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L132	Ø	96.96	76.11	.56	-.40	1.01	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L232	*	97.00	77.25	1.48	.27	3.47	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L249	*	97.02	77.72	1.87	.55	.80	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L673R	Ø	97.15	75.54	.23	-.90	.80	65N	BLUE REFLECTANCE (DIRECTIONAL),	TECHNIDYNE/DIANG/M.S.,	S-4
L223	*	97.70	76.71	1.49	-.61	.91	65G	BLUE REFLECTANCE (DIRECTIONAL),	GARDNER	
L213	*	97.76	76.17	1.11	-.59	1.07	65T	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER D25D2M	
L278	*	97.82	77.50	2.19	-.22	1.93	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L105	*	98.00	75.86	1.01	-1.37	1.29	65T	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER D25D2M	
L591	*	98.67	74.84	.61	-2.52	.92	65H	BLUE REFLECTANCE (DIRECTIONAL),	HUNTER	
L328	*	99.42	78.50	3.96	-.87	2.32	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
L321	*	100.00	78.00	3.92	-1.63	.00	65P	BLUE REFLECTANCE (DIRECTIONAL),	PHOTOVOLT	
GMEANS:		96.30	75.91			1.00				
95% ELLIPSE:				1.65	1.01			WITH GAMMA = 51 DEGREES		

BLUE REFLECTANCE, DIRECTIONAL

SAMPLE E78 = 96.3 PERCENT

SAMPLE J97 = 75.9 PERCENT



DIFFUSE BLUE REFLECTANCE IN PERCENT (GLOSS TRAP)
TAPPI SUGGESTED METHOD T525 SU-72, BRIGHTNESS OF PULP (DIFFUSE ILLUMINATION AND 0 DEG. OBSERVATION)

LAB CODE	SAMPLE E78		PRINTING 116 GRAMS PER SQUARE METER				SAMPLE J97		PRINTING 89 GRAMS PER SQUARE METER				TEST D. = 8		
	MEAN	DEV	N.DEV	SDR	R.SDR	MEAN	DEV	N.DEV	SDR	R.SDR	VAR	F	LAB		
L121	96.12	-.36	-.61	.05	.45	76.86	1.07	1.68	.10	.59	65K	Ø	L121		
L136	96.64	.16	.27	.08	.77	76.18	.39	.60	.12	.74	65F	Ø	L136		
L150	96.88	.40	.68	.06	.55	74.76	-1.03	-1.62	.16	.94	65Q	Ø	L150		
L182	96.45	-.03	-.05	.11	1.05	75.52	-.27	-.42	.11	.64	65P	Ø	L182		
L210K	95.56	-.92	-1.57	.33	3.20	76.70	.91	1.42	.18	1.09	65K	Ø	L210K		
L236	97.19	.71	1.20	.06	.58	75.73	-.06	-.10	.10	.56	65F	Ø	L236		
L242	96.55	.07	.12	.08	.74	75.24	-.55	-.86	.19	1.10	65F	Ø	L242		
L250T	96.85	.37	.63	.11	1.05	76.03	.24	.37	.14	.85	65F	Ø	L250T		
L280	96.19	-.29	-.49	.14	1.39	75.15	-.64	-1.00	.55	3.25	65Q	Ø	L280		
L325	97.60	1.12	1.90	.09	.90	76.41	.61	.96	.17	1.00	65F	Ø	L325		
L446	96.22	-.26	-.45	.08	.73	75.11	-.68	-1.06	.06	.37	65F	Ø	L446		
L573	98.84	2.36	4.00	.05	.51	77.61	1.81	2.84	.12	.71	65F	#	L573		
L598	95.51	-.97	-1.65	.10	.96	75.90	.11	.17	.15	.88	65K	Ø	L598		
L636	96.48	.00	.01	.06	.62	75.70	-.09	-.14	.17	.99	65K	Ø	L636		

GR. MEAN = 96.48 PERCENT GRAND MEAN = 75.79 PERCENT TEST DETERMINATIONS = 8
SD MEANS = .59 PERCENT SD OF MEANS = .64 PERCENT 13 LABS IN GRAND MEANS

AVERAGE SDR = .10 PERCENT AVERAGE SDR = .17 PERCENT

L289 96.72 .24 .42 .10 1.00 76.42 .63 .99 .13 .76 65Ø * L289
TOTAL NUMBER OF LABORATORIES REPORTING = 15
Best values: E78 96.5 ± 1.0 percent
J97 75.7 ± 1.1 percent

The following laboratories were omitted from the grand means because of extreme test results: 573.

DIFFUSE BLUE REFLECTANCE IN PERCENT (GLOSS TRAP)
TAPPI SUGGESTED METHOD T525 SU-72, BRIGHTNESS OF PULP (DIFFUSE ILLUMINATION AND 0 DEG. OBSERVATION)


LAB CODE	F	MEANS		COORDINATES		AVG R.SDR	VAR	PROPERTY---TEST INSTRUMENT---CONDITIONS				
		E78	J97	MAJOR	MINOR			PROPERTY	TEST INSTRUMENT	CONDITIONS		
L598	Ø	95.51	75.90	-.58	-.79	.92	65K	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAP,	MGØ (ZEISS) BASE	
L210K	Ø	95.56	76.70	-1.25	-.35	2.14	65K	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	MGØ (ZEISS) BASE	
L121	Ø	96.12	76.86	-1.11	.22	.52	65K	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	MGØ (ZEISS) BASE	
L280	Ø	96.19	75.15	.41	-.57	2.32	65Q	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	ZEISS ABSOLUTE BASE	
L446	Ø	96.22	75.11	.46	-.56	.55	65F	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L182	Ø	96.45	75.52	.22	-.16	.84	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L636	Ø	96.48	75.70	.08	-.04	.81	65K	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	MGØ (ZEISS) BASE	
L242	Ø	96.55	75.24	.51	-.21	.92	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L136	Ø	96.64	76.18	-.26	.33	.76	65F	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L289	*	96.72	76.42	-.43	.53	.88	65Ø	DIFFUSE REFLECTANCE,	ELREFHØ	GL.TRAF,	SPECIFIC CALIBRATION	
L250T	Ø	96.85	76.03	-.02	.44	.95	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L150	Ø	96.88	74.76	1.10	-.16	.75	65Q	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	ZEISS ABSOLUTE BASE	
L236	Ø	97.19	75.73	.40	.59	.57	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L325	Ø	97.60	76.41	.02	1.28	.95	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	
L573	#	98.84	77.61	-.41	2.95	.61	65F	DIFFUSE REFLECTANCE,	ELREFBØ	GL.TRAF,	NRC-FTB ABSOLUTE BASE	

GMEANS: 96.48 75.75 1.00
55% ELLIPSE: 1.95 1.66 WITH GAMMA = -60 DEGREES

BLUE REFLECTANCE, DIFFUSE, WITH TRAP

SAMPLE E78 = 96.5 PERCENT


SAMPLE J97 = 75.8 PERCENT



BLUE REFLECTANCE, DIFFUSE, NO TRAP

SAMPLE E78 = 95.0 PERCENT

SAMPLE J97 = 76.5 PERCENT



ANALYSIS T75-1 TABLE 1
 SPECULAR GLOSS AT 75 DEGREES, IN GLOSS UNITS
 TAPPI STANDARD T480, 6S-78, SPECULAR GLOSS OF PAPER AND PAPERBOARD AT 75 DEGREES

LAB CODE	CAST COATED					PRINTING					TEST D. = 10						
	E59 MEAN	211 GRAMS PER SQUARE METER DEV	N.DEV	SDR	R. SDR	J24 MEAN	116 GRAMS PER SQUARE METER DEV	N.DEV	SDR	R. SDR	VAR	F	LAB				
L108	85.1	.6	.62	1.2	1.16	67.2	.8	.49	.6	.63	75H	Ø	L108				
L121	83.8	-.8	-.85	.8	.73	64.4	-2.0	-1.17	1.4	1.35	75H	Ø	L121				
L122	82.9	-1.7	-1.86	1.3	1.24	66.7	.3	.19	1.3	1.24	75H	Ø	L122				
L128	85.8	1.2	1.39	1.0	.97	63.3	-3.0	-1.82	.9	.94	75G	*	L128				
L136	85.2	.6	.70	1.0	.90	70.2	3.8	2.29	.9	.85	75G	Ø	L136				
L149	80.2	-4.4	-4.90	1.1	1.07	56.1	-10.2	-6.13	2.0	1.94	75G	#	L149				
L153	85.1	.6	.66	.9	.89	68.5	2.2	1.30	.9	.90	75G	Ø	L153				
L162	85.7	1.1	1.26	1.3	1.25	70.7	4.4	2.61	.6	.56	75G	*	L162				
L173A	86.3	1.7	1.95	1.1	1.00	65.5	-.8	-.50	1.0	.96	75G	Ø	L173A				
L182	85.5	1.0	1.07	.9	.84	67.4	1.1	.66	.5	.52	75H	Ø	L182				
L189	84.7	.2	.18	1.0	.90	60.4	-5.9	-3.52	1.3	1.31	75P	X	L189				
L190C	83.9	-.7	-.75	1.2	1.13	64.6	-1.7	-1.04	1.4	1.41	75G	Ø	L190C				
L190R	83.5	-1.0	-1.14	.8	.79	66.5	.2	.12	.9	.86	75G	Ø	L190R				
L206	84.1	-.4	-.47	1.0	.98	66.8	.5	.28	.9	.84	75H	Ø	L206				
L210	85.9	1.3	1.51	1.8	1.74	69.1	2.8	1.66	1.1	1.08	75H	Ø	L210				
L211	83.8	-.8	-.85	1.3	1.23	66.1	-.2	-.12	1.0	.97	75H	Ø	L211				
L212	89.7	5.1	5.77	1.5	1.41	67.9	1.6	.94	3.5	3.47	75P	X	L212				
L213	84.6	.0	.04	1.3	1.27	67.9	1.6	.93	1.1	1.11	75H	Ø	L213				
L223	85.0	.4	.49	1.2	1.14	66.3	.0	.01	1.0	.95	75H	Ø	L223				
L224	83.9	-.7	-.79	.8	.79	64.5	-1.8	-1.10	.8	.81	75H	Ø	L224				
L230	84.1	-.5	-.52	1.1	1.04	65.1	-1.2	-.74	.6	.56	75H	Ø	L230				
L251	84.5	-.0	-.02	1.1	1.05	67.0	.7	.43	1.3	1.26	75G	Ø	L251				
L255	84.9	.3	.38	.6	.54	67.3	1.0	.58	.9	.94	75G	Ø	L255				
L256	84.1	-.5	-.55	.9	.84	66.7	.4	.24	1.1	1.10	75H	Ø	L256				
L262	85.2	.6	.71	.6	.55	68.0	1.7	1.00	.7	.66	75K	Ø	L262				
L274	85.2	.7	.77	.6	.60	64.9	-1.4	-.86	1.0	.98	75P	Ø	L274				
L277A	84.5	-.1	-.06	1.2	1.14	66.1	-.2	-.13	.7	.68	75H	Ø	L277A				
L277B	84.8	.2	.23	1.3	1.25	65.9	-.4	-.25	1.1	1.07	75H	Ø	L277B				
L278	84.3	-.2	-.24	1.2	1.11	67.8	1.5	.91	1.0	.95	75G	Ø	L278				
L279	83.1	-1.5	-1.65	1.2	1.13	63.4	-2.9	-1.76	1.3	1.25	75G	Ø	L279				
L291	83.4	-1.1	-1.29	1.2	1.17	62.9	-3.4	-2.06	.9	.85	75H	Ø	L291				
L301	84.2	-.4	-.42	.8	.73	65.9	-.4	-.23	1.1	1.11	75H	Ø	L301				
L315	84.9	.3	.38	1.3	1.21	66.0	-.3	-.20	1.2	1.14	75G	Ø	L315				
L317	85.0	.4	.49	1.3	1.26	65.4	-.9	-.56	1.0	.95	75H	Ø	L317				
L323	83.8	-.8	-.89	1.2	1.16	65.8	-.5	-.30	1.2	1.17	75H	Ø	L323				
L328	95.2	10.7	11.98	1.7	1.56	70.8	4.4	2.66	2.8	2.81	75H	#	L328				
L339	85.2	.7	.77	2.7	2.59	58.4	-7.9	-4.75	3.0	2.95	75P	X	L339				
L372	90.7	6.1	6.89	1.5	1.41	70.0	3.7	2.22	.7	.68	75B	X	L372				
L388	84.3	-.2	-.24	.8	.77	59.6	-6.7	-4.00	1.0	.96	75P	#	L388				
L396	84.3	-.2	-.24	.7	.70	66.1	-.2	-.14	1.5	1.50	75G	Ø	L396				
L456	84.1	-.5	-.52	1.1	1.03	65.9	-.5	-.28	.7	.66	75H	Ø	L456				
L483	84.3	-.2	-.28	1.2	1.15	65.4	-.9	-.54	1.1	1.07	75H	Ø	L483				
L573	82.2	-2.4	-2.66	1.1	1.07	65.0	-1.3	-.80	1.2	1.23	75G	*	L573				
L574	80.2	-4.3	-4.86	1.4	1.31	63.0	-3.3	-2.00	.4	.39	75G	X	L574				
L583	85.7	1.1	1.26	.9	.86	65.6	-.7	-.41	.7	.64	75H	Ø	L583				
L587	85.6	1.0	1.16	1.0	.91	68.1	1.8	1.06	1.0	.98	75H	Ø	L587				
L592	85.1	.6	.66	.8	.72	67.1	.7	.44	1.1	1.09	75H	Ø	L592				
L598	83.3	-1.3	-1.41	.9	.82	64.2	-2.2	-1.30	1.0	1.02	75H	Ø	L598				
L643	84.6	.0	.05	.9	.90	66.9	.5	.32	1.0	.98	75H	Ø	L643				
L668	85.6	1.0	1.15	1.3	1.23	66.3	-.1	-.04	1.4	1.39	75G	Ø	L668				
L670	85.0	.5	.52	1.1	1.07	67.7	1.4	.85	1.5	1.50	75H	Ø	L670				
GR. MEAN *	84.6	GLOSS UNITS				GRAND MEAN =	66.3	GLOSS UNITS				TEST DETERMINATIONS = 10					
SD MEANS *	.9	GLOSS UNITS				SD OF MEANS =	1.7	GLOSS UNITS				43 LABS IN GRAND MEANS					
		AVERAGE SDR =				1.1	GLOSS UNITS				AVERAGE SDR =			1.0	GLOSS UNITS		
L250	87.3	2.7	3.07	.9	.89	58.4	-7.9	-4.75	2.1	2.04	75Q	*	L250				
L288	83.0	-1.5	-1.70	1.4	1.33	65.7	-.6	-.39	1.3	1.25	75I	*	L288				
L321	84.3	-.3	-.30	.4	.40	64.9	-1.4	-.86	.3	.31	75F	*	L321				

TOTAL NUMBER OF LABORATORIES REPORTING = 54

Best values: E59 85 ± 2 gloss units
 J24 66 ± 3 gloss units


The following laboratories were omitted from the grand means because of extreme test results: 149, 328, 339, 388.

TAPPI STANDARD T480 GS-78, SPECULAR GLOSS OF PAPER AND PAPERBOARD AT 75 DEGREES

LAB CODE	F	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		B59	J24	MAJOR	MINOR	R _s SDR	VAR			
L149	#	80.2	56.1	-11.1	1.1	1.51	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L574	X	80.2	63.0	-4.5	3.1	.85	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L573	*	82.2	65.0	-2.0	1.9	1.15	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L122	Ø	82.9	66.7	-.2	1.7	1.24	75H	SPECULAR GLOSS (75 DEGREE),	EUNTER	
L288	*	83.0	65.7	-1.1	1.3	1.29	75I	SPECULAR GLOSS (75 DEGREE),	HUNTER, 20 C, 65% RH	
L279	Ø	83.1	63.4	-3.2	.5	1.19	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L598	Ø	83.3	64.2	-2.4	.6	.92	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L291	Ø	83.4	62.9	-3.6	.1	1.01	75E	SPECULAR GLOSS (75 DEGREE),	EUNTER	
L190R	Ø	83.5	66.5	-.1	1.0	.83	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L323	Ø	83.8	65.8	-.7	.6	1.17	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L121	Ø	83.8	64.4	-2.1	.1	1.04	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L211	Ø	83.8	66.1	-.4	.7	1.10	75E	SPECULAR GLOSS (75 DEGREE),	EUNTER	
L224	Ø	83.9	64.5	-2.0	.1	.80	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L190C	Ø	83.9	64.6	-1.9	.1	1.27	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L256	Ø	84.1	66.7	.2	.6	.97	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L456	Ø	84.1	65.9	-.6	.3	.85	75H	SPECULAR GLOSS (75 DEGREE),	EUNTER	
L230	Ø	84.1	65.1	-1.3	.1	.80	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L206	Ø	84.1	66.8	.3	.5	.91	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L301	Ø	84.2	65.9	-.5	.2	.92	75E	SPECULAR GLOSS (75 DEGREE),	EUNTER	
L321	*	84.3	64.9	-1.4	-.2	.35	75F	SPECULAR GLOSS (75 DEGREE),	ZEISS ELREPHØ, 20C, 65%RH	
L483	Ø	84.3	65.4	-.9	-.0	1.11	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L396	Ø	84.3	65.1	-.3	.1	1.10	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L388	#	84.3	59.6	-6.4	-1.8	.87	75P	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT	
L278	Ø	84.3	67.8	1.4	.7	1.03	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L277A	Ø	84.5	66.1	-.2	-.0	.91	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L251	Ø	84.5	67.0	.7	.2	1.16	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L213	Ø	84.6	67.9	1.5	.4	1.19	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L643	Ø	84.6	66.9	.5	.1	.94	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L189	X	84.7	60.4	-5.6	-1.9	1.10	75P	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT	
L277B	Ø	84.8	65.9	-.3	-.3	1.16	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L255	Ø	84.9	67.3	1.0	-.0	.74	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L315	Ø	84.9	66.0	-.2	-.4	1.18	75G	SPECULAR GLOSS (75 DEGREE),	GAEDNER	
L223	Ø	85.0	66.3	.1	-.4	1.05	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L317	Ø	85.0	65.4	-.8	-.7	1.11	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L670	Ø	85.0	67.7	1.5	-.0	1.28	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L108	Ø	85.1	67.2	1.0	-.3	.90	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L153	Ø	85.1	68.5	2.2	.1	.90	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L592	Ø	85.1	67.1	.9	-.3	.91	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L136	Ø	85.2	70.2	3.8	.5	.88	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L262	Ø	85.2	68.0	1.8	-.1	.61	75K	SPECULAR GLOSS (75 DEGREE),	GAERTNER (K-C TYPE)	
L339	#	85.2	58.4	-7.4	-3.0	2.77	75P	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT	
L274	Ø	85.2	64.9	-1.2	-1.1	.79	75P	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT	
L182	Ø	85.5	67.4	1.3	-.6	.68	75E	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L668	Ø	85.6	66.3	.2	-1.0	1.31	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L587	Ø	85.6	68.1	2.0	-.5	.95	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L162	*	85.7	70.7	4.5	.2	.90	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L583	Ø	85.7	65.6	-.3	-1.3	.75	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L128	*	85.8	63.3	-2.5	-2.1	.96	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L210	Ø	85.9	69.1	3.0	-.5	1.41	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
L173A	Ø	86.3	65.5	-.3	-1.9	.98	75G	SPECULAR GLOSS (75 DEGREE),	GARDNER	
L250	*	87.3	58.4	-6.8	-5.0	1.47	75Q	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT, 20 C, 65% RH	
L212	X	89.7	67.9	3.0	-4.4	2.44	75P	SPECULAR GLOSS (75 DEGREE),	PHOTOVOLT	
L372	X	90.7	70.0	5.4	-4.8	1.04	75B	SPECULAR GLOSS (75 DEGREE),	HAUSCH * LØMB	
L328	#	95.2	70.6	7.4	-8.9	2.18	75H	SPECULAR GLOSS (75 DEGREE),	HUNTER	
GMEANS:		84.6	66.3			1.00				
		95% ELLIPSE:		4.5	2.0	WITH GAMMA = 72 DEGREES				

SPECULAR GLOSS, 75 DEGREE

SAMPLE E59 = 84.6 GLOSS UNITS SAMPLE J24 = 66.3 GLOSS UNITS



TAPPI COLLABORATIVE REFERENCE PROGRAM
ANALYSIS T90-1 TABLE 1
THICKNESS (CALIFER), THOUSANDTHS OF AN INCH
TAPPI STANDARD T411 68-76

LAB CODE	SAMPLE J65 MEAN	PRINTING 93 GRAMS PER SQUARE METER				SAMPLE J81 MEAN	PRINTING 73 GRAMS PER SQUARE METER				TEST D. - 10		
		DEV	N. DEV	SDR	R. SDR		DEV	N. DEV	SDR	R. SDR	VAR	F	LAB
L105	6.448	.096	.94	.110	1.11	2.754	.044	.51	.030	.71	90Q	6	L105
L122	6.240	-.112	-1.09	.107	1.08	2.590	-.120	-1.40	.057	1.36	90V	6	L122
L123P	6.445	.093	.91	.263	2.64	2.895	.185	2.15	.044	1.05	90F	6	L123F
L125	6.788	.436	4.26	.111	1.12	2.622	-.088	-1.03	.044	1.06	90T	6	L125
L128	6.308	-.044	-.43	.154	1.54	2.712	.002	.02	.023	.56	90T	6	L128
L141	6.223	-.129	-1.26	.082	.82	2.693	-.017	-.20	.052	1.24	90T	6	L141
L153	6.145	-.207	-2.02	.085	.86	2.785	.075	.87	.022	.53	90T	*	L153
L162	6.310	-.042	-.41	.120	1.20	2.680	-.030	-.35	.042	1.01	90D	6	L162
L166	6.450	.098	.96	.067	.67	2.760	.050	.58	.026	.63	90T	6	L166
L173B	6.460	.108	1.06	.052	.52	2.800	.090	1.04	.000	.00	90F	6	L173B
L182	6.332	-.020	-.20	.089	.89	2.663	-.047	-.55	.033	.80	90L	6	L182
L183	6.288	-.064	-.62	.065	.66	2.794	.084	.98	.028	.67	90T	6	L183
L190C	6.260	-.092	-.90	.097	.97	2.630	-.080	-.94	.082	1.97	90T	6	L190C
L203A	6.410	.052	.57	.152	1.53	2.690	-.020	-.24	.057	1.36	90T	6	L203A
L203C	6.220	-.132	-1.29	.127	1.28	2.655	-.055	-.65	.069	1.64	90T	6	L203C
L212	6.483	.131	1.28	.077	.77	2.730	.020	.23	.047	1.13	90T	6	L212
L213	6.480	.128	1.25	.092	.92	2.770	.060	.70	.048	1.16	90T	6	L213
L223	6.508	.156	1.52	.055	.55	2.786	.076	.88	.025	.60	90V	6	L223
L228	6.350	-.002	-.02	.118	1.18	2.740	.030	.35	.070	1.67	90T	6	L228
L238A	6.300	-.052	-.51	.038	.38	2.596	-.114	-1.33	.018	.44	90T	6	L238A
L241	6.310	-.042	-.41	.088	.88	2.845	.135	1.57	.064	1.54	90T	6	L241
L249	6.319	-.033	-.32	.053	.53	2.720	.010	.11	.029	.69	90T	6	L249
L260	6.389	.037	.36	.064	.64	2.676	-.034	-.40	.034	.82	90T	6	L260
L261	6.470	.118	1.15	.061	.61	2.789	.079	.92	.027	.65	90T	6	L261
L262	6.400	.048	.47	.033	.33	2.640	-.070	-.82	.046	1.10	90T	6	L262
L274	6.380	.028	.28	.042	.42	2.950	.240	2.79	.053	1.26	90D	*	L274
L285	6.260	-.092	-.90	.171	1.72	2.570	-.140	-1.64	.095	2.27	90T	6	L285
L291	6.455	.143	1.40	.098	.99	2.820	.110	1.28	.063	1.51	90T	6	L291
L305	6.270	-.082	-.80	.195	1.95	2.615	-.095	-1.11	.078	1.88	90T	6	L305
L309	6.250	-.102	-.99	.135	1.36	2.520	-.190	-2.22	.035	.84	90T	6	L309
L318	6.340	-.012	-.11	.107	1.08	2.620	-.090	-1.05	.054	1.29	90T	6	L318
L323	6.168	-.184	-1.79	.082	.82	2.548	-.162	-1.89	.044	1.05	90T	6	L323
L324	6.390	.038	.37	.088	.88	2.710	-.000	-.00	.039	.94	90T	6	L324
L326	6.455	.103	1.01	.069	.69	2.720	.010	.11	.026	.62	90T	6	L326
L328	6.400	.048	.47	.105	1.06	2.740	.030	.35	.084	2.02	90T	6	L328
L331	6.492	.140	1.37	.220	2.21	2.800	.090	1.04	.027	.64	90T	6	L331
L339	6.337	-.015	-.14	.064	.65	2.687	-.023	-.27	.015	.36	90T	6	L339
L352	6.446	.094	.92	.081	.82	2.729	.019	.22	.038	.90	90Q	6	L352
L356	6.311	-.041	-.40	.104	1.04	2.696	-.014	-.17	.020	.48	90T	6	L356
L358	6.310	-.042	-.41	.115	1.15	2.714	.004	.04	.031	.73	90T	6	L358
L376	6.540	.188	1.84	.084	.85	2.740	.030	.35	.052	1.24	90T	6	L376
L380	6.385	.033	.32	.088	.89	2.800	.090	1.04	.000	.00	90T	6	L380
L382	6.515	.163	1.59	.053	.53	2.720	.010	.11	.026	.62	90T	6	L382
L390	6.328	-.024	-.23	.108	1.08	2.740	.030	.35	.041	.98	90T	6	L390
L556	6.306	-.046	-.45	.170	1.71	2.610	-.100	-1.17	.029	.70	90T	6	L556
L557	6.270	-.082	-.80	.125	1.26	2.630	-.080	-.94	.082	1.97	90T	6	L557
L560	5.911	-.441	-4.30	.054	.54	2.294	-.416	-4.85	.050	1.21	90T	#	L560
L567	6.200	-.152	-1.48	.141	1.42	2.680	-.030	-.35	.042	1.01	90V	6	L567
L574	6.216	-.136	-1.32	.051	.51	2.729	.019	.22	.029	.69	90V	6	L574
L581	6.475	.123	1.20	.136	1.36	2.800	.090	1.04	.041	.98	90T	6	L581
L585	6.440	.088	.86	.052	.52	2.700	-.010	-.12	.000	.00	90T	6	L585
L587	6.310	-.042	-.41	.057	.57	2.710	-.000	-.00	.057	1.36	90T	6	L587
L626	6.160	-.192	-1.87	.069	.69	2.578	-.132	-1.54	.048	1.14	90T	6	L626
L679	6.255	-.057	-.55	.050	.50	2.670	-.040	-.47	.042	1.01	90T	6	L679

GR. MEAN = 6.352 MILS
SD MEANS = .102 MILS

GRAND MEAN = 2.710 MILS
SD OF MEANS = .086 MILS

TEST DETERMINATIONS = 10
52 LABS IN GRAND MEANS

AVERAGE SDR = .100 MILS
GR. MEAN = 161.33 MICROMETER

AVERAGE SDR = .042 MILS
GRAND MEAN = 68.84 MICROMETER

TAPPI COLLABORATIVE REFERENCE PROGRAM
 ANALYSIS T90-1 TABLE 1
 THICKNESS (CALIPER), THOUSANDTHS OF AN INCH
 TAPPI STANDARD T411 GS-76

LAB CODE	SAMPLE J65 MEAN	PRINTING 93 GRAMS PER SQUARE METER				R. SDR	SAMPLE J81 MEAN	PRINTING 73 GRAMS PER SQUARE METER				TEST D. = 10		
		DEV	N. DEV	SDR	R. SDR			DEV	N. DEV	SDR	R. SDR	VAR	F	LAB
L185	6.220	-.132	-1.29	.063	.63	2.640	-.070	-.82	.052	1.24	90B	*	L185	
L203B	6.270	-.082	-.80	.170	1.71	2.530	-.180	-2.10	.095	2.27	90C	*	L203B	
L242G	6.328	-.024	-.24	.028	.28	2.671	-.039	-.46	.081	1.93	90G	*	L242G	
L242P	6.300	-.052	-.50	.086	.86	2.715	.004	.05	.022	.54	90F	*	L242P	
L251	6.233	-.119	-1.16	.061	.61	2.703	-.008	-.09	.020	.49	90W	*	L251	
L274C	6.350	-.002	-.02	.053	.53	2.970	.260	3.03	.048	1.16	90C	*	L274C	
L344	6.210	-.142	-1.38	.074	.74	2.640	-.070	-.82	.052	1.24	90U	*	L344	
L396M	60.600	54.248	529.30	1.430	14.35	26.600	23.890	278.54	.516	12.36	90S	*	L396M	
L484	6.142	-.210	-2.05	.149	1.50	2.736	.026	.30	.221	5.28	90E	*	L484	
L563	.001	-6.351	-61.97	.000	.00	.000	-2.710	-31.60	.000	.00	90V	*	L563	
L576	6.013	-.339	-3.31	.041	.41	2.910	.200	2.33	.031	.75	90C	*	L576	
L616	150.700	144.348	1408.40	1.252	12.56	65.600	62.890	733.25	.516	12.36	90C	*	L616	
TOTAL NUMBER OF LABORATORIES REPORTING *											66			

Best values: J65 6.36 ± 0.15 mils
 J81 2.70 ± 0.14 mils

The following laboratories were omitted from the grand means because of extreme test results: 125, 560.

TAPPI COLLABORATIVE REFERENCE PROGRAM
ANALYSIS T90-1 TABLE 2
THICKNESS (CALIPER), THOUSANDTHS OF AN INCH
TAPPI STANDARD T411 GS-76

LAB CODE	P	MEANS		COORDINATES		AVG		PROPERTY---	TEST INSTRUMENT---	CONDITIONS
		J65	J81	MAJOR	MINOR	R.SDR	VAR			
L563	*	.001	.000	-6.733	1.530	.00	90U	THICKNESS (CALIPER),	TMI,	HAND DRIVEN
L560	#	5.911	2.294	-.601	-.079	.87	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L576	*	6.013	2.910	-.157	.360	.58	90C	THICKNESS (CALIPER),	CADY,	HAND DRIVEN
L484	*	6.142	2.736	-.155	.144	3.39	90E	THICKNESS (CALIPER),	SCROPPER,	HAND DRIVEN
L153	*	6.145	2.785	-.124	.182	.69	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L626	Ø	6.160	2.578	-.233	.005	.91	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L323	Ø	6.168	2.548	-.244	-.024	.93	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L567	Ø	6.200	2.680	-.141	.064	1.21	90V	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN, DIGITIZED
L344	*	6.210	2.640	-.156	.026	.99	90U	THICKNESS (CALIPER),	TMI,	HAND DRIVEN
L574	Ø	6.216	2.729	-.099	.095	.60	90V	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN, DIGITIZED
L203C	Ø	6.220	2.655	-.139	.032	1.46	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L185	*	6.220	2.640	-.148	.020	.94	90E	THICKNESS (CALIPER),	AMTEOR,	HAND DRIVEN
L141	Ø	6.223	2.693	-.114	.061	1.03	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L251	*	6.233	2.703	-.101	.064	.55	90W	THICKNESS (CALIPER),	L * W,	MOTOR DRIVEN, 20 C, 65% RH
L122	Ø	6.240	2.590	-.161	-.032	1.22	90V	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN, DIGITIZED
L309	Ø	6.250	2.520	-.194	-.094	1.10	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L190C	Ø	6.260	2.630	-.121	-.011	1.47	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L285	Ø	6.260	2.570	-.157	-.060	1.99	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L203E	*	6.270	2.630	-.172	-.098	1.99	90C	THICKNESS (CALIPER),	CADY,	HAND DRIVEN
L557	Ø	6.270	2.630	-.113	-.017	1.61	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L305	Ø	6.270	2.615	-.122	-.029	1.91	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L183	Ø	6.288	2.754	-.003	.105	.66	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L679	Ø	6.295	2.670	-.070	.001	.75	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L238A	Ø	6.300	2.596	-.109	-.062	.41	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L242P	*	6.300	2.715	-.039	.034	.70	90P	THICKNESS (CALIPER),	MESSMER,	MOTOR DRIVEN, ISO R534
L556	Ø	6.306	2.610	-.096	-.054	1.21	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L128	Ø	6.308	2.712	-.034	.027	1.05	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L587	Ø	6.310	2.710	-.034	.024	.96	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L162	Ø	6.310	2.680	-.052	-.000	1.11	90D	THICKNESS (CALIPER),	CADY,	MOTOR DRIVEN
L241	Ø	6.310	2.845	.045	.134	1.21	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L358	Ø	6.310	2.714	-.032	.027	.94	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L356	Ø	6.311	2.696	-.041	.012	.76	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L249	Ø	6.319	2.720	-.021	.027	.61	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L242Ø	*	6.328	2.671	-.042	-.017	1.10	90E	THICKNESS (CALIPER),	MESSMER,	MOTOR DRIVEN, BS3983
L390	Ø	6.328	2.740	-.002	.038	1.03	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L182	Ø	6.332	2.663	-.044	-.026	.84	90L	THICKNESS (CALIPER),	L * W,	MOTOR DRIVEN
L339	Ø	6.337	2.687	-.026	-.010	.50	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L318	Ø	6.340	2.620	-.063	-.066	1.18	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L228	Ø	6.350	2.740	.016	.025	1.43	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L274C	*	6.350	2.970	.151	.211	.84	90C	THICKNESS (CALIPER),	CADY,	HAND DRIVEN
L274	*	6.380	2.950	.163	.178	.84	90D	THICKNESS (CALIPER),	CADY,	MOTOR DRIVEN
L380	Ø	6.385	2.800	.079	.053	.44	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L260	Ø	6.389	2.676	.010	-.050	.73	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L324	Ø	6.390	2.710	.031	-.023	.91	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L262	Ø	6.400	2.640	-.002	-.085	.72	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L328	Ø	6.400	2.740	.056	-.004	1.54	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L203A	Ø	6.410	2.690	.035	-.051	1.44	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L585	Ø	6.440	2.700	.065	-.060	.26	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L123P	Ø	6.445	2.895	.184	.095	1.84	90F	THICKNESS (CALIPER),	FEDERAL,	MOTOR DRIVEN
L352	Ø	6.446	2.729	.087	-.040	.86	90Q	THICKNESS (CALIPER),	EMVECO,	MOTOR DRIVEN
L105	Ø	6.448	2.754	.104	-.021	.91	90Q	THICKNESS (CALIPER),	EMVECO,	MOTOR DRIVEN
L166	Ø	6.450	2.760	.109	-.017	.65	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L326	Ø	6.455	2.720	.089	-.053	.65	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L173E	Ø	6.460	2.800	.140	.009	.26	90P	THICKNESS (CALIPER),	FEDERAL,	MOTOR DRIVEN
L261	Ø	6.470	2.789	.142	-.006	.63	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L581	Ø	6.475	2.800	.152	.000	1.17	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L213	Ø	6.480	2.770	.139	-.027	1.04	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L212	Ø	6.483	2.730	.118	-.061	.95	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L331	Ø	6.492	2.800	.166	-.010	1.42	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L291	Ø	6.495	2.820	.180	.005	1.25	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L223	Ø	6.508	2.786	.171	-.030	.58	90V	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN, DIGITIZED
L382	Ø	6.515	2.720	.138	-.088	.57	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L376	Ø	6.540	2.740	.170	-.086	1.04	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L125	#	6.788	2.622	.301	-.327	1.09	90T	THICKNESS (CALIPER),	TMI,	MOTOR DRIVEN
L396M	*	60.600	26.600	57.949	-12.472	13.35	90S	THICKNESS (CALIPER),	SCROPPER,	HAND DRIVEN
L616	*	150.700	65.600	153.797	-33.736	12.46	90C	THICKNESS (CALIPER),	CADY,	HAND DRIVEN
GMEANS:		6.352	2.710			1.00				
		95% ELLIPSE:		.301	.159			WIDE GAMMA = 35 DEGREES		


THICKNESS (CALIPER)

SAMPLE J65 = 6.35 MILS

SAMPLE J81 = 2.71 MILS

SAMPLE J65 = 161.3 MICROMETER


SAMPLE J81 = 68.8 MICROMETER



GRAMMAGE (MASS PER UNIT AREA)

SAMPLE D30 = 92.9 G/SQ.METER

SAMPLE D31 = 76.3 G/SQ.METER



SUMMARY TABLE

TEST METHOD	SAMPLE CODE	GRAND MEAN	SD OF MEAN	AVER SDR	REPL CRP	LABS INCL	LABS PARTIC	REPL TAPPI	REPEAT	REPROD
AIR RESISTANCE, GURLEY T40-1	J46 J48	12.30 30.94	.71 1.58	.92 1.74	10	50	56	10	.80 1.52	1.97 4.37
AIR RESISTANCE, SHEFFIELD T40-2	J46 J48	222.3 104.5	12.7 5.8	12.2 4.6	10	35	40	10	10.7 4.0	35.3 16.1
AIR RESISTANCE, GURLEY EG FLOTATION T41-1	B82 B47	1684. 1549.	244. 166.	532. 336.	10	12	14	10	466. 295.	677. 461.
SMOOTHNESS, PARKER PRINTSURF T44-1	J49 J73	6.12 4.49	.52 .41	.09 .12	10	9	9	10	.08 .11	1.44 1.13
SMOOTHNESS, SHEFFIELD T45-1	J49 J73	274.9 87.0	10.7 7.5	7.0 5.2	15	81	84	10	6.1 4.5	29.7 21.0
SMOOTHNESS, BEKK T45-2	J49 J73	9.94 66.08	.60 14.62	.56 5.74	15	8	13	10	.49 5.03	1.70 40.59
SMOOTHNESS, BENDTSEN T47-1	J49 J73	465.8 104.3	19.0 11.1	33.4 8.2	10	8	8	10	29.3 7.2	52.7 30.8
K & N INK ABSORPTION T56-1	B59 B80	63.75 24.53	5.60 2.79	.44 .56	4	9	11	4	.61 .78	15.52 7.74
PH, COLD T57-1	J18 J62	4.664 5.535	.081 .064	.025 .041	5	4	6	2	.050 .081	.229 .187
PH, HOT T57-2	J18 J62	4.321 4.974	.125 .197	.027 .054	5	4	4	2	.053 .105	.513 .552
OPACITY, B&L TYPE, 89% BACKING T60-1	K23 J58	95.42 92.69	.42 .57	.28 .34	10	65	78	5	.34 .42	1.18 1.62
OPACITY, B&L TYPE, PAPER BACKING T60-2	K23 J58	95.89 93.09	.16 .34	.30 .35	10	5	5	5	.37 .44	.52 .99
OPACITY, ELREPHO TYPE, PAPER BACKING T60-3	K23 J58	96.30 93.55	.16 .20	.14 .20	10	13	15	5	.18 .24	.47 .59
BLUE REFLECTANCE, DIRECTIONAL T65-1	E78 J97	96.30 75.91	.45 .50	.10 .15	8	15	39	6	.12 .17	1.25 1.40
BLUE REFLECTANCE, DIFFUSE, WITE TRAP T65-2	E78 J97	96.48 75.79	.59 .64	.10 .17	8	13	15	6	.12 .19	1.63 1.77
BLUE REFLECTANCE, DIFFUSE, NO TRAP T65-3	E78 J97	94.97 76.49	1.34 .78	.13 .11	8	16	16	6	.15 .13	3.72 2.15
SPECULAR GLOSS, 75 DEGREE T75-1	B59 J24	84.6 66.3	.9 1.7	1.1 1.0	10	43	54	5	1.3 1.3	2.6 4.7
THICKNESS (CALIPER) T90-1	J65 J81	6.352 2.710	.102 .086	.100 .042	10	52	66	10	.087 .037	.284 .238
GRAMMAGE (MASS PER UNIT AREA) T95-1	D30 D31	92.87 76.27	.40 .53	.80 .72	10	14	16	3	1.29 1.15	1.54 1.75

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. TAPPI CRP 56G	2. Gov't. Accession No.	3. Recipient's Accession No.
4. TITLE AND SUBTITLE Technical Association of the Pulp and Paper Industry COLLABORATIVE REFERENCE PROGRAM FOR PAPER Report #56G		5. Publication Date	
7. AUTHOR(S) R. G. Powell, J. Horlick		8. Performing Organ. Report No. NBSIR 79-1360	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, DC 20234		10. Project/Task/Work Unit No.	
12. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Collaborative Testing Services, Inc., 9241 Wood Glade Drive, Great Falls, Virginia 22066; and Technical Association of the Pulp and Paper Industry		13. Type of Report & Period Covered FINAL	
15. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.		14. Sponsoring Agency Code	
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) Collaborative Reference Programs provide participating laboratories with the means for checking periodically the level and uniformity of their testing in comparison with that of other participating laboratories. An important by-product of the programs is the provision of realistic pictures of the state of the testing art. This is one of the periodic reports showing averages for each participant, within and between laboratory variability, and other information for participants and standards committees.			
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Collaborative reference program; Laboratory evaluation; Paper; Precision; Reference samples, Testing calibration			
18. AVAILABILITY <input type="checkbox"/> Unlimited <input checked="" type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Sup. of Doc., U.S. Government Printing Office, Washington, DC 20402, SD Stock No. SN003-003- <input type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161		19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED	21. NO. OF PRINTED PAGES 55
		20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED	22. Price

