NBS

Publications

Ref



## NBSIR 79-1912

# Temperature Measurement on Operating Surface Mounted Lighting Fixtures

P. Michael Fulcomer

Product Safety Technology Division Center for Consumer Product Technology National Engineering Laboratory National Bureau of Standards Washington, D.C. 20234

September 1979

NBSIR 79-1912

TEMPERATURE MEASUREMENT ON OPERATING SURFACE MOUNTED LIGHTING FIXTURES

P. Michael Fulcomer

Product Safety Technology Division Center for Consumer Product Technology National Engineering Laboratory National Bureau of Standards Washington, D.C. 20234

September 1979

Sponsored by: Consumer Product Safety Commission 5401 Westbard Avenue Bethesda, Maryland 20016



U.S. DEPARTMENT OF COMMERCE, Juanita M. Kreps, Secretary Luther H. Hodges, Jr., Under Secretary Jordan J. Baruch, Assistant Secretary for Science and Technology NATIONAL BUREAU OF STANDARDS, Ernest Ambler, Director

National Bureau of Strangets DEC 12 1979 NOL ACC - REF RC100 USG



### SI CONVERSION UNITS

In view of the present accepted practice in this country for building technology, common U.S. units of measurement have been used throughout this document. In recognition of the position of the United States as a signatory to the General Conference on Weights and Measures, which gave official status to the metric SI system of units in 1960, assistance is given to the reader interested in making use of the coherent system of SI units by giving conversion factors applicable to U.S. units used in this document.

Mass	1	pound - mass $(lb_m) = 0.4535924$ kg
Length	1	inch = 0.0254  meter (m)
Temperature	t	(Celsius) = 5/9 [t(Fahr) - 32]

Torque	1	lbf•	in	1 =	0.113 г.	ewt	on	ne t	er	(Nm)
Time	1	hour	=	60	minutes	=	3,	600	sea	conds



### TEMPERATURE MEASUREMENT ON OPERATING SURFACE MOUNTED LIGHTING FIXTURES

P. Michael Fulcomer

### ABSTRACT

Potentially hazardous temperatures may result from adding thermal insulation in the attic above surface mounted incandescent lighting fixtures and/or operating these fixtures with lamps of higher wattage than specified. This study was concerned with the range of temperatures generated (1) within the fixture, (2) within the electric junction box associated with the fixture and (3) on the adjoining ceiling and attic surfaces.

Test results indicate that the addition of minimal insulation (equivalent to R-11) over a surface mounted lighting fixture which contains two or more rated lamps, is likely to cause normal household branch circuit supply wiring associated with the fixture to operate above its specified 60°C temperature rating. Overlamping (using lamps of higher wattage than specified for the fixture) and/or additional load current flowing through the branch circuit wire will cause even higher supply wire temperatures.

With all three conditions present (i.e., insulation over the fixture, overlamping, and an additional 15 ampere load current flowing through the supply wire), the tests indicate that the temperature of associated branch circuit wiring will exceed  $30^{\circ}$ C for a one lamp fixture and  $100^{\circ}$ C for fixtures with two or more lamps.

Key Words: Surface mounted incandescent lighting fixture; thermal insulation; overlamping; hazardous temperatures; branch circuit wiring; electrical junction box; load current; thermocouple

### TEMPERATURE MEASUREMENT ON OPERATING SURFACE MOUNTED LIGHTING FIXTURES

### Introduction

Rising utility rates and the decreasing supply of available energy have resulted in efforts to make both new and existing homes more energy efficient. For many older homes, one of the most cost effective ways to reduce energy consumption is to increase the depth of thermal insulation in the attic. When energy was cheap and plentiful, the extra cost of increased insulation was greater than the cost of energy saved over a considerable period of time, but this is no longer true. Accordingly, insulation is now an attractive means of saving energy economically. Unfortunately, the addition of thermal insulation over the electrical wiring and lighting fixtures of older homes may cause problems related to the safety of the household electrical system.

The Consumer Product Safety Commission (CPSC) is currently investigating various aspects of this potential household electrical system safety problem. This report is based upon work funded by CPSC to address one facet of the problem. Potentially hazardous temperatures can result from (1) adding thermal insulation in the attic above surface mounted incandescent lighting fixtures and/or (2) operating these fixtures with lamps of higher wattage than specified. This study was concerned with the range of temperatures generated (1) within the fixture, (2) within the electric junction box associated with the fixture and (3) on the adjoining ceiling and attic surfaces. A companion report, entitled Temperature Measurement on Operating Recessed Lighting Fixtures, NBSIR79-1913, concerns potentially hazardous temperatures which may result from adding thermal insulation in the attic above recessed incandescent lighting fixtures.

Test results presented herein indicate that the addition of minimal insulation (equivalent to R-11) over a surface mounted lighting fixture which contains two or more lamps, and which is operating with rated bulbs, is likely to cause normal household branch circuit supply wiring associated with the fixture to operate above its specified  $60^{\circ}$ C temperature rating. Overlamping (using lamps of higher wattage than specified for the fixture) and/or additional load on the branch circuit wire will cause even higher supply wire temperatures. Either overlamping or additional load current, when combined with minimal insulation over the fixture, may also cause the temperature of branch circuit wire associated with a one lamp fixture to exceed a  $60^{\circ}$ C rated value.

With all three conditions present (i.e., insulation over the fixture, overlamping, and an additional 15 ampere load current flowing through the supply wire), the tests indicate that the temperature of associated branch circuit wiring will exceed  $80^{\circ}$ C for a one lamp fixture and  $100^{\circ}$ C for fixtures with two or more lamps.

### General Method

To determine representative temperatures generated by surface mounted lighting fixtures, four such fixtures were individually installed in a controlled environment mock-up of a ceiling, complete with an overlying attic section. The four fixtures ranged from a one-lamp flush mounted (no space between the ceiling and the fixture enclosure) model to a four-lamp semi-flush mounted model. In the semi-flush mode, there is some space between the top of the fixture enclosure and the ceiling.

Each fixture was tested: (1) with no insulation in the attic; (2) with glass fiber batts equivalent to R-11; and (3) with glass fiber batts equivalent to R-33 installed in the attic. Under each of these conditions, temperature measurements were made with and without an additional 15 ampere current flowing through the associated branch circuit supply wiring. The above tests were made with rated 60 watt lamps and also under two conditions of overlamping, using 100 watt and 150 watt lamps.

Temperatures were recorded at various points on the fixture, the fixture mounting hardware, the associated ceiling electric box, the nearby attic and ceiling surfaces, and on the fixture and supply wires. The pertinent steady state temperatures obtained for each fixture are included in chart form with this report along with dimensional diagrams showing the size of and installation details for each fixture.

### Test Assembly Description

The test assembly consists of a 4 foot by 4 foot section of 1/2 inch sheetrock ceiling nailed to 2 X 5 inch wood joists spaced 16 inches on center. The lighting fixture under test was mounted equidistant between joists in the center of the test assembly using standard hardware. To reduce convective heat loss due to higher than normal air flow in the laboratory, the test assembly includes sides which extend 12 inches above and 24 inches below the ceiling.

Electrical connections to the fixture were made in a 3 1/2 inch by 1 1/2 inch deep ceiling box attached beneath a 2 X 4 which was fastened between the center two 6 inch joists. The fixture was mounted to the ceiling by machine screws which fastened into the ceiling box.

Supply wiring to the fixture was non-metallic sheath cable with two #14 copper conductors and a separate ground (type NM, 14-2 with ground). Wiring was arranged so that the cable carrying the branch circuit current passed through the ceiling box into which the light fixture was connected. Additional load could be put on the branch circuit wiring by connecting a 1500 watt electric space heater to the circuit through a variable voltage transformer. Current drawn by the space heater was adjusted by changing the transformer output.

### Lighting Fixtures Description and Installation

Dimensional diagrams of the four surface mounted lighting fixtures tested are shown in figures 1 through 4; all are rated for 60 watt lamps. Fixture A contains two lamps, fixture B three lamps, fixture C four lamps, and fixture D one lamp.

Both fixtures A and D were enclosed lamp types, designed for mounting flush to the ceiling. Fixture B was labeled as "flush mounted" on its packaging material, but both it and fixture C were actually designed to be mounted semi-flush, with the fixture frame separated from the ceiling. No instructions accompanied fixture B, however, and with minor changes in installation procedure, it could be mounted flush, thereby causing extremely high temperatures in the electrical box above the fixture. This will be discussed in greater detail later.

The canopies of fixtures A and D measured 8 1/2 inches and 6 3/4 inches in diameter, respectively. When installed, the upper edges of the canopies fit flush against the ceiling. In each case, the fixture attaches directly to the ceiling box above by two machine screws. For fixture D, a separate crossbar is connected between the outlet box ears, and the canopy is screwed to the crossbar. A glass cover, which completely encloses the lamps, is attached to each canopy by means of three small hand-tightened screws spaced equidistantly around the lower edge of the canopy. When installed, the overall depth from the ceiling was 4 3/4 inches for fixture A and 4 1/4 inches for fixture D.

Both fixtures A and D are designed so that there is a space approximately 3/4 inch deep between the ceiling surface and the canopy base. This space (not visible once the fixture is installed) was probably intended for a glass fiber insulation pad, equal to the diameter of the canopy and approximately 1 1/4 inches thick, which was supplied with each fixture. However, the installation instructions furnished with the fixtures made no mention of the insulation pad nor how it was to be installed. Therefore, testing of the fixtures was done both with and without the insulation pad installed in the canopy base.

Fixtures B and C are similar in the way that they are attached to the ceiling (see figures 2 and 3). The 4 1/2 inch diameter canopy of each is screwed to the electrical ceiling box via a crossbar which is connected between the box ears. The socket structure of each (for fixture B, three horizontally oriented sockets spaced 120 degrees apart, and for fixture C, four horizontally oriented sockets spaced 90 degrees apart) is attached to the canopy by a nut tightened down on the socket structure center post which protrudes up through a hole in the canopy center. The side frame of each fixture is supported by a glass bezel which is attached to the socket structure by means of a single decorative cap nut threaded onto the nipple protruding from the lower end of the socket structure. The bezel for fixture B is a convex opal glass 16 inches in diameter which supports a round, simulated walnut side frame. The bezel for fixture C is a 16 inch

square, flat glass diffuser which supports a square, simulated wood side frame.

No fixture insulation pad and no installation instructions were supplied with fixture B. The fixture also had no indication of being UL rated although it was purchased in Maryland, where UL rating is required. The fixture was packed in a box which described it as being a "flush mounted" fixture. When mounted with the painted side of the 4 1/2 inch diameter canopy facing down, however, the top of the 16 inch diameter frame was actually 3/4 inch below the ceiling surface (see figure 2). Inverting the canopy allowed the socket structure to be raised sufficiently so that the fixture frame could contact the ceiling and thereby constitute a true "flush mount." Testing of the fixture was done in both its semi-flush and flush mounting positions.

When installed, 60 watt lamps extended 2 1/4 inches beyond the outer edge of the canopy of fixture B; 150 watt lamps extended 3 1/4 inches beyond. Distance between the ceiling and the lamp surface for flush mounting was 1 1/4 and 1 1/8 inches, respectively, for 60 and 150 watt lamps. With the fixture mounted semi-flush, these distances were 2 1/8 and 2 inches, respectively.

Installation instructions were supplied with fixture C and a 4 1/2 inch diameter by 1 inch thick glass fiber insulation pad was attached inside the fixture pan. When mounted according to instructions, the top of the 16 inch square frame was approximately 2 3/4 inches below the ceiling and the distance between the ceiling and the lamp surface was 2 1/4 inches for 60 watt lamps, and 2 1/8 inches for 150 watt lamps. Overall fixture depth from the ceiling was 5 1/2 inches.

### Testing Procedures

Each fixture was tested with: (1) rated 60 watt lamps installed in all sockets; (2) 100 watt lamps in all sockets; and (3) 150 watt lamps in all sockets. Under each of these conditions, the fixtures were tested with and without an additional 15 ampere load current flowing through the branch circuit supply wiring. Total lamp current, lamp voltage and branch circuit load current (if any) were monitored by means of transducers connected into the test set-up. Prior to each test, supply voltage was adjusted so that the particular lamps installed would dissipate the total power for which they were labeled. During the test this adjusted voltage was held constant by an ac voltage regulator.

All fixtures were tested under the above conditions with no insulation in the attic and with attic insulation equivalent to R-33. In addition, fixtures B, C and D were tested with attic insulation equivalent to R-11. The latter was achieved with foil-backed glass fiber batts, approximately 3 1/2 inches thick, installed so that the foil side rested against the ceiling. The R-33 insulation was achieved by adding two more layers of the R-11 catts without a vapor barrier. The 1/2 inch unpainted sheetrock ceiling, the 3 1/2 inch ceiling box, and the 2 X 4 crosspiece to which the box was attached were all replaced when the next lighting fixture was installed for testing.

Temperatures were recorded at various points (1) in the ceiling box, (2) on the fixture, (3) on the fixture and supply wires (4) on the surrounding upper (attic) and lower (ceiling) sheetrock surfaces by means of #30 chromel-alumel thermocouples connected to a programmable data logging device. The thermocouples were held in place by teflon tape, .003 inches thick, installed so that the thermocouple was in contact with the subject surface and no more than partially covered by the tape.

The fixtures were tested in the order of their alphabetic designation. Two series of tests were performed on fixture B: the first set with the fixture mounted flush to the ceiling and the second set with the fixture mounted semi-flush. Prior to the second test series, the position of some thermocouples mounted on the upper and lower surfaces of the sheetrock ceiling were changed to better relate to the location of the lamps below the ceiling. Both attic and ceiling surface thermocouples were repositioned at various distances out from the center of the fixture, but either on a line which was directly over the axis of a lamp and lamp socket combination or on a line which bisected the angle between the axes of two adjacent lamp and lamp socket combinations.

The data logging device contained 40 input channels, of which only 25 were eventually used. Of the 25 channels, two were assigned to monitor lamp voltage and current, one to record branch circuit load current in excess of the lamp current, and the remaining 22 to monitor thermocouple outputs. Three ac-to-dc transducers were used to change ac voltage and current readings into the low voltage dc accepted by the data logger.

Fewer than 22 thermocouples were used in the tests of fixtures A and B in their flush mounted positions. Following these two tests, thermocouples were added to measure temperature at additional locations in the ceiling box and on the ceiling and attic surfaces. At that same time, more specific locations for measuring ceiling and attic surface temperature were introduced. Of the 22 points eventually monitored for temperature, five were in the electrical ceiling box or on associated fixture mounting hardware, three on the fixture and supply wires, five on the upper sheetrock surface (attic), three on the lower sheetrock surface (ceiling), one on the fixture canopy and one on the 2 X 4 wood support crosspiece. Three thermocouples were used to monitor air temperature at locations around the light fixture and one to monitor ambient room temperature.

More precise information on thermocouple location is included in the first column of the data sheet for each figure as shown in tables 1 through 4. Where a letter symbol appears in the second column, this corresponds to the thermocouple location indicated by an identical symbol on the dimensional diagram for that fixture (figures 1-4). Not all locations are indicated on the diagrams.

The data logging device was programmed to monitor voltage, currents and temperature every 15 minutes. Each test was continued until none of the recorded temperatures changed by more than 1°C in 3 hours or until a reliable prediction could be made of the final steady-state temperatures. Tests that were started with all points at room temperature required 2 to 3 hours before temperatures reached equilibrium with no thermal insulation above the fixture, and 5 to 9 hours with insulation above the fixture. However, only 45 and 90 minutes (first without and then with thermal insulation above the fixture) were required for temperatures to reach 80 to 90 percent of their equilibrium value on the supply wire, in the ceiling electrical box and on the upper sheetrock surface (attic side). Temperatures on the fixture wire and on the lower sheetrock surface reached 85 to 95 percent of equilibrium after only 30 and 45 minutes, respectively.

A return to room ambient temperature was not always required between tests. Tests proceeded without a cool-down period if temperatures in the following test were expected to be equal to or higher than those in the preceeding test. Examples of this occurred when an external 15 ampere load was added without changing the amount of insulation in the attic or when insulation in the attic was increased without reducing the load. A short cool down period was allowed when a reduction of some temperatures might be expected under the new conditions. An example of this occurred when a noload test with insulation equivalent to R-33 in the attic followed a test with R-11 insulation in the attic and a 15 ampere external load on the supply wire. In this case, the decrease in supply wire temperature resulting from the reduced load usually more than offset the slight temperature increase resulting from greater attic insulation depth.

### Results

The steady state temperatures recorded for each light fixture under the various testing conditions are listed in tables 1 through 4. Table 5 is an extraction and compilation of this data to show temperatures at five critical locations (one location is shown under two different conditions) for each light fixture tested. Table 5 includes results obtained both with rated lamps and with higher than rated lamps installed, but except for fixture B, it does not include the results obtained in testing a fixture without the fixture insulation pad in place. Reference must be made to the individual tables for this latter data. (Table 5 includes the results of testing fixture B without the fixture insulation pad in place because these are the only results available for this fixture. No insulation pad was supplied with fixture B.) All listed temperatures have been corrected for an ambient of 20°C\*. Temperatures exceeding the limits specified for each location are circled in table 5.

The critical temperature locations noted in table 5 and the limiting temperatures at each location are:

1. Fixture wire insulation - 150°C maximum. None of the fixtures tested indicate the rating of the fixture wire used. However,

<sup>\*</sup>Poom ambient temperature sometimes varied plus or minus a few degrees from the desired 20°C. In such cases this difference was either added (if the ambient was less than 20°C), or subtracted (if the ambient was greater than 20°C) from the actual reading to arrive at the temperature listed in the table.

three of the four fixtures are UL rated and as such must have fixture wire rated for at least 150°C. The wire of the non-UL rated fixture B was similar in composition to the other three.

- 2. Supply wire insulation 60°C maximum. Household branch circuit wiring is normally of the type rated for 60°C. Neither the wire insulation nor any of the surfaces which it may touch should exceed this temperature. Since the wire temperature increases if there is an external load on the branch circuit, both no-load and load conditions were tested and are included in table 5.
- 3. Attic and ceiling sheetrock surfaces 90°C maximum. Section 410-5 of the 1978 National Electric Code states that "Fixtures shall be so constructed, or installed, or equipped with shades or guards that combustible material will not be subjected to temperatures in excess of 90°C". Either the thermal insulation that touches the attic side of the sheetrock or the surface finish applied over the ceiling side of the sheetrock might be combustible.

The data contained in table 5 provides the basis for statements in the Summary section.

Table 1 for fixture A does not include all the same data that the other tables do because the decisions to include tests involving thermal insulation equivalent to R-11, to reposition attic and ceiling thermocouples, and to eliminate joist temperature measurements were made during the testing of fixture B. Table 1 does show, however, that the temperature on the branch circuit supply wire inside the ceiling box reached  $70^{\circ}$ C when operated with rated lamps installed in the fixture and with thermal insulation equivalent to R-33 above. Results from testing the other three fixtures showed that most of the temperature increase due to the addition of thermal insulation above a fixture is evident with an insulation thickness equivalent to R-11. The difference in temperatures with a thickness equivalent to R-11 and one equivalent to R-33 is usually less than  $5^{\circ}$ C, hence the temperature of branch circuit wire associated with fixture A would exceed its specified rating even with minimal thermal insulation equivalent to R11 over the fixture.

The insulation pad reduces lamp heat transferred to the parts above it, but increases the heat to parts below the pad. Therefore, temperatures in the ceiling box are somewhat lower with the fixture insulation pad installed, while temperatures on the fixture wire are actually somewhat higher.

The temperature of the fixture wire in fixture A exceeded 150°C when 100 watt lamps were installed and fixture insulation was in place. This was true with or without thermal insulation overhead. With the fixture insulation pad in place, the addition of attic thermal insulation caused only minor increases in fixture wire temperature. For fixture B, temperatures in the ceiling electrical box exceeded  $60^{\circ}$ C even under the least stringent conditions, with the fixture mounted in the less hazardous semi-flush position, operating with rated lamps, and with <u>no</u> thermal insulation overhead. Addition of minimal thermal insulation caused temperatures in the box to exceed 90°C. Use of 100 watt lamps (a real temptation with this fixture because of the poor light transmission through the opal glass bezel) resulted in temperatures over 120°C in the ceiling box and up to 140°C on the ceiling surface above the lamps.

Flush mounting of fixture B caused temperatures 15 to  $30^{\circ}$ C higher than those under comparable conditions with semi-flush mounting. Data for the fixture when flush mounted and overlamped with 150 watt lamps is not complete due to the occurrence of a short circuit failure in the ceiling electrical box. The high temperatures in the box (over 200°C) caused supply wire insulation to become brittle and subsequently crack, then fall away from the conductor at various locations. A resulting short circuit to ground caused the ground fault interrupter, which was installed in series with the electrical supply, to open and thus terminate the test. Less than 65 hours of fixture testing time had elapsed before the wire failure.

Fixture C, with rated lamps installed and R-11 thermal insulation overhead, caused temperatures to exceed  $70^{\circ}$ C on the supply wire and in the ceiling electrical box. Overlamping with 100 watt lamps combined with R-11 insulation overhead caused temperatures to exceed  $90^{\circ}$ C at these same locations. Although these temperatures are 30 to  $35^{\circ}$ C lower than those which resulted in fixture B under similar conditions, the temperatures are still considerably above the specified safe values.

While the lamps of fixtures B and C are located the same distance from the ceiling (see figures 3 and 4), the frame of fixture C is farther from the ceiling. The lower frame position presumably allows greater inflow of the cooler surrounding air to fixture C. Also, the lack of fixture insulation for fixture B causes temperatures on the supply wire and in the ceiling box for that fixture to be 3 to 7°C higher than they otherwise would have been.

A fixture wire rating of 150°C was not exceeded under any conditions for fixture C. Attic and ceiling surface temperatures were exceeded under overlamped conditions with thermal insulation above.

Fixture D, a one lamp fixture, caused no serious over-ratings when operated with its rated 60 watt lamps. The unloaded supply wire temperatures did not exceed  $60^{\circ}$ C, even with R-33 thermal insulation overhead. When loaded with an additional 15 amperes, however, the supply wire reached  $69^{\circ}$ C with R-33 thermal insulation. Overlamping in combination with thermal insulation and additional load, caused temperatures on the supply wire and on the ceiling box to exceed  $80^{\circ}$ C. Specified "safe" fixture wire and ceiling or attic temperatures were not exceeded under any conditions.

### Summary

These test results on surface mounted lighting fixtures indicate the following:

- 1. Addition of minimal insulation (equivalent to R-11) over a surface mounted lighting fixture containing two or more lamps and operating with rated bulbs, is likely to cause normal household branch circuit wiring associated with the fixture to operate above its specified 60 °C temperature rating.
- 2. Addition of minimal insulation (equivalent to R-11) over a surface mounted lighting fixture operating with two or more 100 watt lamps instead of the rated 60 watt lamps is likely to cause temperatures in excess of 90°C on the associated branch circuit wiring. Temperatures will likely exceed 60°C for a one lamp fixture under the same conditions.
- 3. Most of the temperature increase due to addition of thermal insulation above a surface mounted lighting fixture is evident with an insulation thickness equivalent to R-11. Increase in insulation thickness from an equivalence of R-11 to one of R-33, causes only a minor increase (usually less than 5°C) in temperatures measured in and around the lighting fixture.
- 4. Addition of a 15 ampere load current on the branch circuit supply wiring increases the wire temperature by 15 to 20°C, with the larger increase occurring for wire covered by thermal insulation.
- 5. The associated branch circuit wiring is likely to be the first component of a surface mounted lighting fixture to exceed its rating. (For the three multi-lamp fixtures tested, the 60°C rating for this wire was exceeded even when these fixtures were operating with rated lamps and no thermal insulation above them.)
- 6. For surface mounted fixtures containing more than one lamp, overlamping (using lamps of higher wattage than specified for the fixture) combined with minimal insulation over the fixture is likely to cause fixture wire temperature and attic and ceiling surface temperatures to exceed their rated "safe" values.

### Comment

The test results summarized above are based on the testing of four different surface mounted lighting fixtures. These four appeared to be representative of fixtures available at the time this investigation was initiated in 1978. Sufficient information was obtained from the tests to indicate that household branch circuit wiring is likely to operate above its present  $60^{\circ}$ C temperature rating when associated with surface mounted fixtures over which minimal thermal insulation has been placed or in which higher wattage lamps than specified are used. Further testing is necessary, however, to (1) establish the upper limit that the wire temperature may reach when used with various fixtures and conditions of operation, and (2) to determine whether wire currently rated for  $60^{\circ}$ C might actually be operated safely at somewhat higher temperatures. This information would provide a basis for future decisions involving either (1) raising the  $60^{\circ}$ C rating for currently used wire, (2) requiring the use of wire presently rated for 75, 90 or 120°C, or (3) some combination of the first two.

Testing should also be done on surface mounted fixtures which meet a recently imposed "insulated ceiling" (or IC) specification by Underwriters' Laboratories. This type of fixture was not available during the period when tests were in progress for this report.



Figure 1. Dimensional Diagram of Fixture A Installation.

A small circle accompanied by a letter indicates a thermocouple location. Not all locations are shown. The letter identifies temperature data from Table 1 which corresponds to the location shown.





Figure 2. Dimensional Diagram of Fixture 3 Installation.

A small circle accompanied by a letter indicates a thermocouple location. Not all locations are shown. The letter identifies temperature cata from Taple 2 which corresponds to the location shown.





Figure 3. Dimensional Diagram of Fixture C Installation.

A small circle accompanied by a letter indicates a thermocouple location. Not all locations are shown. The letter identifies temperature data from Table 3 which corresponds to the location shown.





Figure 4. Dimensional Diagram of Fixture D Installation.

A small circle accompanied by a letter indicates a thermocouple location. Not all locations are snown. The letter identifies temperature data from Table 4 which corresponds to the location shown.



### TABLE 1. TEMPERATURE DATA FOR FIXTURE A

Fixture rated for two 60 watt lamps

Temperatures in  $^{O}C$  are listed in the table. Readings have been corrected for an ambient room temperature of 20 $^{O}C$ . Top reading made with 15 amp additional load on supply wiring. Bottom reading made with no additional load.

Lamp Fixture Insulation		I	60W In Place		6 No	60W None		l 10 In F	100W In Place			150W In Place			150W None	
Attic Insulat	ion	อ	batts	batts	e	batts	batts	e	batts	batts	e	batts	batts	a	batts	batts
Thermocouple Location*	-	Non	L L L	R33	Non	L L N	R33	Non	L L N	R33	Non	เเม	R33	Non	<b>R11</b>	R33
Fixture Wire. 1/4 inch from socket	W	124 122		129 126	117		123 120	162 161		171 168	202 194		201 199	183 181		19 <b>1</b> 187
Fixture Canopy. At wire pass-through hole																
Fixture Canopy. Surface facing ceiling box																
Supply Wire. Inside ceiling box		66 50		89 70	74 62		97 81	75 62		119 99	86 69		135 114	110 96		147 129
Supply Wire Casing. 1/2 inch from box	S	49 38		74 60	54 43		79 66	54 44		101 85	62 45		114 97	76 60		118 102
Ceiling Box: inside, top of crossbar																
inside, top of ear																
inside, top center	Т	5 <b>7</b> 50		81 70	68 64		92 84	66 61		110 99	75 67		126 114	102 97		140 131
inside, on cable clamp		59 52		82 72	69 64		92 85	69 63		113 102	78 69		128 116	103 96		141 132
Attic Surface: overlamp, 4 inches from center	A	44 41		66 59	43 41		67 62	50 49		89 32	57 - 56		103 97	58 56		96 87
Ceiling Surface: 8 inches from center	с	31 29		44 38	26 25		41 38	35 35		53 49	43 42		65 60	40 39		65 59
Wood Joist: 1/2 inch up from ceiling	J <b>1</b>	31 29		52 42	28 26		51 44	32 31		67 59	36 34	•	78 70	38 36		81 70
Wood Joist: 1/2 inch up from ceiling	J2	30 28		52 44	28 26		51 46	33 32		67 62	37 35		79 73	38 35		79 74
Ambient: in test assembly																
Ambient: in test assembly																
Ambient Room.																

\*Symbols in second column (if any) indicate thermocouple locations on the corresponding diagram of figure 1.



### TABLE 2. TEMPERATURE DATA FOR FIXTURE 8 Fixture rated for three 60 watt lamps

1.

Temperatures in °C are listed in the table. Readings have been corrected for an ambient room temperature of 20°C. Top reading made with 15 Amperes additional load on supply wiring. Bottom reading made with no additional load.

Lamp Mounting Attic Insulation		Semi	60W Elu	ısh	60 F1	W .ush		Semi	100W Semi-flush			150W Semi-flush			150W Flush		
		None	RIL batts	RJJ batts	None	kil baccs	K13 batts	None	kll batts	k33 batts	None	RII batts	R33 batts	None	kl4 baccs	RJ3 parts	
Fixture Wire. 1/4 inch from socket		109 109	117	118 118	123 123	140	143 140	142 141	153 151	154 154	179 177	196 195	197	202 202	224		
Fixture Canopy. At wire pass-through hole	H	99 97	111	112 111				131 129	146 143	143 147	168 165	195 192	196				
Fixture Canopy. Surface facing ceiling box	F	95 93	110	112 110				125 123	146 142	149 147	159 156	195 191	196			:	
Supply Wire. Inside ceiling box		71 59	106	111 96	86 74	131	139 122	91 77	140 122	146 130	113 97	138 170	192	137 122	200		
Supply Wire Casing. 1/2 inch from box	S	56 47	96	104 92	64 36	116	125 111	66 59	130 115	137 124	69 60	173 158	179	94 35	183		
Ceiling Box: inside, top of crossbar	В	73 68	102	106 100				94 38	136 127	142 135	119 114	184 176	188				
inside, top of ear	E	68 64	99	104 99				89 85	133 125	139 134	114 109	181 175	185				
inside, top center	T	62 59	96	103 97	80 77	125	132 124	81 77	130 121	137 130	103 97	177 170	182	129 125	202		
inside, on cable clamp		61 58	96	102 97	83 79	128	135 127	79 75	128 122	136 131	100 95	177 171	131	140 135	205		
Attic Surface: over lamp, 3 inches from center	A3	52 51	38	9 <b>9</b> 94				58 54	121 114	130 125	62 61	163 161	173				
over lamp, 4 inches from center	A4	58 55	90	100 96	59 58	111	120 116	66 65	122 115	130 126	30 79	164 163	174	93 93	189		
over lamp, ó inches from center	A6	49 49	79	39 34				54 54	109 103	118 114	69 69	150 143	160				
between lamps, 4 inches from center	A	50 48	34	94 90				55 53	120 114	126 123	56 64	157 154	165				
Ceiling Surface: over lamp 4 inches from center	C4	91 90	112	114 113				117 116	142 139	145 143	166 164	204 201	205				
over lamp, 6 inches from center	C6	67 67	90	95 95				94 94	121 119	129 128	134 132	130 131	135				
Ambient: in test assembly, 3 inches below ceiling		24 24	26	26 27				26 26	30 28	29 30	29 28	31 32	32				
Ambient: in cest assembly, 13 inches below ceiling		21 22	22	22 22				22	24 23	23 24	24 23	24 25	24				
Ambient Room		: 20 19	20	20 13	20 20	19	20 20	20 19	20 20	21 19	20 20	19 17	19	20 20	20		

\*Symbols in second column (if any) indicate thermocouple locations on the corresponding diagram of figure 2.



### TABLE 3. TEMPERATURE DATA FOR FIXTURE C Fixture rated for four 60 watt lamps

~~

Temperatures in  $^{O}C$  are listed in the table. Readings have been corrected for an ambient room temperature of  $20^{O}C$ . Top readings made with 15 amp additional load on supply wiring. Bottom reading made with no additional load.

Lamp		60W		60W		100W			100W			15				
Fixture Insulation		In Place		None		In Place			None			In P				
Attic Insulat Thermocouple Location*	ion	None	Ril batts	R33 batts	None	R11 batts	R33 batts	None	RII batts	<b>K33 batts</b>	None	<b>RII batts</b>	R33 batts	None	<b>RIJ batts</b>	R33 batts
Fixture Wire.		8 <b>3</b>	95	94	86	91	91	115	121	122	111	120	119	122	132	135
1/4 inch from socket		87	93	94	85	90	90	113	120	123	109	118	117	120	130	131
Fixture Canopy.	Н	31	88	88	80	87	87	108	116	117	103	112	114	121	133	134
At wire pass-through hole		80	37	87	80	86	86	106	115	117	102	111	112	120	131	131
Fixture Canopy. Surface facing ceiling box	F				73 72	83 80	32 81				96 93	107 105	109 106			
Supply Wire.		61	89	91	64	86	86	74	114	118	78	107	112	81	13 <b>2</b>	137
Inside ceiling box		46	71	73	53	70	72	57	93	97	56	90	94	66	113	117
Supply Wire Casing.	S	51	84	86	46	82	82	60	107	112	55	102	109	58	126	132
1/2 inch from box		39	70	72	41	69	71	46	90	95	49	38	93	50	111	115
Ceiling Box: inside top of crossbar	В															
inside,	E	52	79	80	56	75	74	66	101	105	71	95	98	73	120	124
top of ear		49	73	75	54	71	73	61	95	99	68	91	94	70	114	117
inside,	T	50	80	82	55	77	77	61	102	107	68	96	101	67	122	127
top center		45	71	73	52	70	72	56	93	97	63	90	94	63	113	117
inside,		49	78	80	54	75	74	61	100	105	67	94	97	57	120	124
on cable clamp		45	72	73	51	70	72	56	93	98	54	39	93	54	113	116
Attic Surface: over lamp, 3 inches from center	A3	47 47	75 72	75 73	44 44	74 72	74 75		95 93	102 100	52 51	94 92	99 98	58 58	119 116	124 121
over lamp,	A4	47	75	75	45	73	76	48	94	101	52	93	98	57	117	123
4 inches from center		47	74	74	43	72	76	47	93	99	50	92	98	54	115	119
over lamp,	A6	42	70	69	38	63	67	48	83	92	13	83	38	50	109	115
6 inches from center		42	53	69	38	63	67	16	83	90	11	82	28	50	107	112
between lamps,	A	42	73	73	39	76	76	49	89	99	15	96	102	52	120	126
4 inches from center		41	70	71	39	72	73	47	93	95	45	92	98	51	116	121
Ceiling Surface: over lamp	C4	58	35	37	73	89	89	87	112	114	39	110	113	111	143	146
4 inches from center		58	32	85	73	37	38	35	110	112	36	107	110	110	140	142
overlamp, 6 incnes from center	C6	52 52	71 69	72 70	506	75 73	75 72	69 57	95 92	100 99	72 71	95 93	98 96	101 100	130 123	135 131
Ambient: in test assembly 3 inches below ceiling	1	27 27	29 29	29 29	26 26	28 28	27 28	30 30	33 33	32 32	29   28	31 30	31 31	33 32	35 34	35 34
Ambient: in test assembly 13 inches below ceiling		22 22	22 22	22 22	22 22	23 22	23 23	22 22	24 24	23 23	23	24 23	24 24	24	25 25	25 25
Ambient Room		20   19	18 18	20 18	21 20	20 19	21 19	20 19	21 19	20 19	21 21	21 20	21 20	21 20	21 20	21 21

 $\space{-} \space{-} \spa$ 



### TABLE 4. TEMPERATURE DATA FOR FIXTURE D.

11.

Fixture rated for one 60 watt lamp

Temperatures in  ${}^{0}C$  are listed in the table. Readings have been corrected for an ambient room temperature of 20 ${}^{0}C$ . Top readings made with 15 amp additional load on supply wiring. Bottom readings made with no additional load.

Lamp		60W			60W		100W			100W			150W			
Fixture Insulation		In Place			None		In Place			None			In Place			
Attic Insulation		Je	batts	3 batts	ţ¢	batts	8 batts	e	þätts	batts batts	e e	batts	batts	e	batts	l batts
Thermocouple Location*		NOI	ET B	133	NON	E	E	Nor	E H	R3	Not	Ξ	EX	Nor	E E	R33
Fixture Wire.		79	82	82	76	78	77	103	104	105	10 <b>0</b>	101	101	122	124	125
1/4 inch from socket		79	78	81	75	78	77	102	105	105	98	101	100	122	124	125
Fixture Canoby.	н	79	82	83	73	76	76	103	105	106	96	100	101	121	125	126
At wire pass-through hole		79	78	81	72	76	75	102	105	105	95	100	100	121	124	125
Fixture Canopy. Surface facing ceiling box	F				37 35	92 91	92 91			:	119 115	123 123	125 123			
Supply Wire.		54	68	69	66	79	30	67	80	84	84	101	104	75	99	100
Inside ceiling box		39	47	51	53	64	65	48	62	65	71	87	39	58	82	82
Supply Wire Casing.	S	43	58	59	52	66	67	51	65	69	62	83	36	55	32	82
1/2 inch from box		33	42	46	38	5 <b>5</b>	56	38	54	56	53	71	74	46	69	ō9
Ceiling Box: inside,	8	57	70	71	71	81	81	74	86	91	94	107	109	87	109	111
top of crossbar		52	57	61	64	75	75	56	79	32	89	101	103	32	102	103
inside,	ε	49	62	63	63	74	75	60	74	79	82	98	100	71	94	96
top of ear		45	52	56	59	70	70	55	69	72	79	93	96	66	88	39
inside,	T	45	58	61	62	74	74	56	71	76	80	97	99	66	91	93
top center		40	48	53	57	58	69	50	54	67	76	92	94	60	82	84
inside,		44	58	59	58	71	71	54	68	73	74	92	95	56	86	38
on cable clamp		40	48	52	53	66	67	47	63	66	71	87	89	56	80	81
Attic Surface: over lamp,	A3	36	52	53	40	55	55	42	58	63	47	71	74	59	85	86
3 inches from center		36	48	47	38	49	52	41	54	58	46	65	69	55	32	82
over lamp, 4 inches from center	A4	30 30	44 41	45 40				34 33	48 46	53 47				46 44	72 70	
over lamp, 6 inches from center	A6	25 25	37 34	38 34				28 27	40 38	44 40				33 32	57 54	
opposite side 4 inches from center	A	29 30	41 40	42 40				34 33	46 46	50 49	-			36 35	57 56	
, Ceiling Surface: over lamp	C4	40	46	18	38	46	46	49	55	58	46	58	50	74	86	87
4 inches from center		40	46	46	37	45	15	48	55	56	15	56	57	73	85	85
over lamp 6 inches from center	C5	29 29	36 35	37 34				34 33	41 40	43 41				46 46	59 58	
Ampient: in test assembly 3 inches pelow ceiling		22 21	22 20	22 22	23 22	22 21	23 22	23 22	22 22	23 21	21	23 22	23 22	24 22	24 24	25 24
Ambient: in test assembly	1	21	21	21	22	21	22	21	22	21	20	21	21	22	22	23
18 inches below ceiling		21	19	21	21	20	21	21	22	20	20	21	21	20	22	22 :
Ambient Room		21   20	20 13	20 20	21	20 19	21 20	20 21	21 20	20 19	20 20	20 19	20 20	21 19	21 21	21 20 .

\*Symbols in second column (if any) indicate thermocouple locations on the corresponding diagram of figure 4.



### TABLE 5. EXTRACTION AND COMPILATION OF CRITICAL TEMPERATURE DATA FROM TABLES 1, 2, 3 AND 4

All readings below were taken with the fixture insulation pad installed except those for fixture 8. No pad was supplied with this fixture. Temperature readings without the pad installed are  $3-7^{\circ}$ C higher on the supply wire and in the ceiling box but  $3-7^{\circ}$ C lower on the fixture wire. Readings below for fixture 8 were taken in a semi-flush mounting position. Flush mounting produced higher temperatures (see table 2).

		60 watt	100 watt	150 watt
Temperatu in table. Circled r the maxim that loca Fixture	res in <sup>O</sup> C listed readings are above num specified for ation (see text).	None R]] batts R33 batts	None R11 batts R33 batts	None RN1 batts R33 batts
A two lamps 60W	Fixture Mire - No Load Supply Wire - No Load Supply Wire - 15A Load Ceiling Box (maximum) Attic Surface (maximum Ceiling Surface (maximum)	$ \begin{array}{rrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrrr$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	(1) (1) (1) (1) (1) (1) (1) (1) (1) (1)
8 three lamps 60W	Fixture Wire Supply Wire - No Load Supply Wire - 15A Load Ceiling Box (maximum) Attic Surface (maximum) Ceiling Surface (maximum)	$ \begin{array}{c} 109 & 117 & 118 \\ 59 & 9) & 99 \\ \hline 71 & 109 & 111 \\ \hline 68 & 99 & 100 \\ 55 & 36 & 99 \\ \hline 90 & 11 & 11 \end{array} $	$ \begin{array}{c} 141 \\ (5) \\ (5) \\ (2) \\ (4) \\ (2) \\ (4) \\ (2) \\ (2) \\ (4) \\ (2) \\ (2) \\ (4) \\ (2) \\ (4) \\ (2) \\ (4) \\ (2) \\ (4) $	(77) $(77)$
C four lamps 60W	Fixture Wire Supply Wire - No Load Supply Wire - 15A Load Ceiling Box (maximum) Attic Surface (maximum) Ceiling Surface (maximum)	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{c} 113 & 120 & 123 \\ 57 & 9 & 9 \\ \hline 7 & 11 & 113 \\ 6 & 35 & 99 \\ 47 & 33 & 100 \\ 35 & 11 & 113 \\ \end{array}$	$\begin{array}{c} 120 & 130 & 131 \\ \hline 666 & 113 & 117 \\ \hline 311 & 132 & 133 \\ \hline 79 & 114 & 117 \\ \hline 588 & 116 & 121 \\ \hline 119 & 144 \\ \hline \end{array}$
D one lamo 60W	Fixture Wire Supply Wire - No Load Supply Wire - 15A Load Ceiling Box (maximum) Attic Surface (maximum) Ceiling Surface (maximum)	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$



NBS-114A (REV. 9-78)				
U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. NBSIR79-1912	2. Gover A	Coession No. 3. Recipient's Acc	ession No.
4. TITLE AND SUBTITLE			5. Publication Dat	1070
Temperature Measu Surface Mounted L	rement on Operating ighting Fixtures		6. Performing Org	anization Code
7. AUTHOR(S)			8. Performing Orga	an. Report No.
P. Michael Fulcom	er			
3. PERFORMING ORGANIZATIO	10.,Ptoject/Task/I	Monk Unit No.		
DEPARTMENT OF COMM WASHINGTON, DC 20234	ERCE		11. Contract/Grant	: No.
12. SPONSORING ORGANIZATIO Consumer Product 5401 Westbard AVe	IN NAME AND COMPLETE ADDRESS (S) Safety Commission nue	treet, City, State,	ZIP) 13. Type of Report	& Period Covered
Bethesda, Marylan	d 20016		14. Sponsoring Age	ency Code
15. SUPPLEMENTARY NOTES				
Document describes a con	nputer program; SF-185, FIPS Software Su	immary, is attach	ed.	ligeraphy or
literature survey, mention it l	ere.)			
Potentially hazar the attic above s these fixtures wi concerned with th (2) within the el adjoining ceiling	dous temperatures may res urface mounted incandesce th lamps of higher wattag e range of temperatures g ectric junction box asso and attic surfaces.	sult from a ent lightir ge than spe generated ( ciated with	idding thermal insula ng fixtures and/or op ecified. This study 1) within the fixtur n the fixture and (3)	etion in perating was re, on the
Test results indi over a surface mo is likely to caus the fixture to op (using lamps of h load current flow wire temperatures	cate that the addition o unted lighting fixture wh e normal household branch erate above its specified igher wattage than speci- ing through the branch c	f minimal i nich contai n circuit s d 60 <sup>0</sup> C temp fied for th ircuit wire	nsulation (equivaler ns two or more rated supply wiring associa perature rating. Ove ne fixture) and/or ac e will cause even hig	nt to Rll) d lamps, nted with erlamping dditional gher supply
With all three co and an additional indicate that the for a one lamp fi	nditions present (i.e., 15 ampere load current temperature of associat xture and 100°C for fixt	insulation flowing thr ed branch c ures with t	over the fixture, over rough the supply wire rircuit wiring will e two or more lamps.	verlamping, e), the tests exceed 80 <sup>0</sup> C
17. KEY WORDS (six to twelve e separated by semicolons)	ntries; alphabetical order; capitalize only	the first letter o	f the first key word unless a prop	er name;
Surface mounted i hazardous tempera current; thermoco	ncandescent lighting fix tures; branch circuit wi uple	ture; therm ring; elect	nal insulation; overl crical junction box;	amping; load
18. AVAILABILITY	XX Unlimited		19. SECURITY CLASS (THIS REPORT)	21. NO. OF PRINTED PAGES
For Official Distribution	. Do Not Release to NTIS			22
Order From Sup. of Doc. 20402 SD Stock No. SNG	, U.S. Government Printing Office, Washi	ngton, DC	20. SECURITY CLASS (THIS PAGE)	22. Price
Order From National Tec VA. 22161	chnical Information Service (NTIS), Spring	field,	UNCLASSIFIED	\$3.00





# NB51R 19-1912

. .

,

1 al