

NBSIR 81-2277

Control Strategies for Energy Conservation -- A Case Study of the Materials Building, National Bureau of Standards

James Y. Kao
E. Thomas Pierce

Building Equipment Division
Center for Building Technology
U.S. Department of Commerce
National Bureau of Standards
Washington, DC 20234

May 1981

Sponsored by
Plant Division
Office of the Director of Administration
and Information Systems
National Bureau of Standards
Washington, DC 20234

QC

100

.U56

81-2277

1981

c.2



JUL 20 1981

100-20-1000
Q6100
US6
100-20-1000
1081
30

NBSIR 81-2277

**CONTROL STRATEGIES FOR ENERGY
CONSERVATION -- A CASE STUDY OF
THE MATERIALS BUILDING, NATIONAL
BUREAU OF STANDARDS**

James Y. Kao
E. Thomas Pierce

Building Equipment Division
Center for Building Technology
U.S. Department of Commerce
National Bureau of Standards
Washington, DC 20234

May 1981

Sponsored by
Plant Division
Office of the Director of Administration
and Information Systems
National Bureau of Standards
Washington, DC 20234



U.S. DEPARTMENT OF COMMERCE, Malcolm Baldrige, *Secretary*
NATIONAL BUREAU OF STANDARDS, Ernest Ambler, *Director*

1. The first part of the document discusses the importance of maintaining accurate records of all transactions.

2. It is essential to ensure that all entries are supported by appropriate documentation.

3. The second part of the document outlines the procedures for handling discrepancies and errors.

4. Finally, it is recommended that regular audits be conducted to verify the accuracy of the records.

PREFACE

This study was funded by the Plant Division of the National Bureau of Standards (NBS). It is the objective of the NBS Plant Division to determine the annual energy savings that may be realized from implementation of new air handling system control strategies and thus to plan air handling system control retrofits Bureau wide. The retrofit of these controls will aid the Plant Division in obtaining their 20 percent reduction in energy consumption by FY 85 compared to FY 75, as required by the Department of Energy's Ten Year Energy Conservation Buildings Plan. The Plant Division presently has a boiler improvement study under way to determine the heating plant efficiency, and is planning to evaluate the refrigeration plant performance in the near future. Verification of the predicted results of some of the control strategies in this study is currently being prepared and will be evaluated in the future. The NBS energy monitoring and control system will be used to collect building energy consumption data and to implement enthalpy control and system shutdown strategies.

The control strategies selected in this study and the input data for the calculations were determined jointly by the Plant Division and the authors. The authors wish to express their appreciation to Christopher Conley and Kendall McDaniel of the Plant Division for their assistance.

ABSTRACT

The BLAST-2 computer program is used to investigate various heating, ventilating and air conditioning control strategies and their combinations to reduce the energy consumption of a laboratory building located at the National Bureau of Standards Gaithersburg site. The techniques of modeling the building load and air system performance are explained. The results are presented and discussed. Control strategies investigated include dry-bulb and enthalpy economizer cycles, resetting supply air temperatures by outside temperature and zone demand, shut-down of fan systems selectively, and converting interior systems to VAV systems. By combining the various control strategies, eight percent, twenty-nine percent and eight percent of heating, cooling and fan energy respectively may be saved.

Keywords: building energy analysis; computer modeling, control strategies; controls, energy conservation for non-residential buildings; load calculations.

CONVERSION FACTORS TO METRIC (SI) UNITS

Physical Quantity	Symbol	To Convert From	To	Multiply By
Length		ft	m	3.048×10^1
Temperature	T	°F	°C	$T_C = (T_F - 32)/1.8$
Volume Rate of Flow	V	CFM	m ³ /s	4.719×10^{-4}
Coil Capacity	Q _s	Btu/hr	J/s	2.931×10^{-1}
Energy		Btu	J	1.055×10^3

TABLE OF CONTENTS

	<u>Page</u>
PREFACE	iii
ABSTRACT	iv
CONVERSION FACTORS TO METRIC (SI) UNITS	v
1. INTRODUCTION	1
2. BUILDING AND BLAST IMPLEMENTATION	2
2.1 Building Description	2
2.2 BLAST Modeling	2
3. CONTROL STRATEGIES AND MODELING	6
3.1 Control Strategies	6
3.2 Air Balance	9
3.3 System Shut-down Modeling	12
4. RESULTS - DATA	19
5. CONCLUSIONS	28
REFERENCES	29
APPENDIX - Input Data for Base Case	30

1. INTRODUCTION

The Gaithersburg site of the National Bureau of Standards (NBS) has over 2.2 million square feet of floor space. Used mainly for office and laboratory functions, most of the buildings were constructed in the 1960's. Several years later, during the early 1970's, major efforts were made to reduce the energy consumption of the building heating, ventilation and air conditioning (HVAC) systems [1]*. Lighting reductions, office-space HVAC-system shut-downs, space thermostat adjustments, and raising the air-handling system discharge-air temperatures resulted in approximately a 12 percent electricity reduction and 18 percent heating fuel reduction. A further overall energy reduction of approximately 5 percent [2] was made during FY 1980 (using FY 1975 as a base). This reduction was attributed to the implementation of the Emergency Building Temperature Restriction [3], shutting down of additional mechanical equipment during non-occupied hours, and the implementation of new HVAC control systems.

Several of the HVAC control strategies compared in this study were previously evaluated at NBS. During the mid-1970's, a computer program and bin method were used to predict the energy savings of enthalpy control, supply-air temperature reset, and shutting down of office spaces during non-occupied hours.

As a continuing effort in energy conservation at NBS, the HVAC control strategies in the General Purpose Laboratory (GPL) buildings are examined in this study. At this site, there are seven GPL's with similar constructions and physical dimensions as well as similar HVAC-system arrangements. The energy conservation control strategies and energy saving predictions for one laboratory building should be applicable to all the others, with minor modifications. The building chosen for this study is Building 223, also known as the Materials Building.

One of the dominant factors influencing the amount of energy consumption in non-residential buildings, such as the NBS laboratories under study here, is the performance of automatic temperature and humidity controls that regulate the operation of the HVAC systems. Although these controls generally include the heating and cooling generation, as well as the air systems to deliver the desired heating and cooling energy to the occupied spaces, the present study is limited to the consideration of the latter only. At NBS, the heating and cooling media are generated in a central plant and are distributed to individual buildings through underground steam and chilled water pipes. This study investigates some of the control strategies which may be used for the air handling systems inside the Materials Building and therefore, the energy amount predictions are the energy required to be delivered at the building boundary.

*Figures in brackets indicate references on page 30.

2. BUILDING AND BLAST IMPLEMENTATION

2.1 BUILDING DESCRIPTION

The Materials Building is a three-story building, 385 feet long, and 105 feet wide, with the long axis along the true east-west direction. The result of this orientation is that all windows are facing either north or south. The building is of heavy reinforced concrete construction. The building is divided into interior and perimeter spaces. The interior rooms are used mainly for laboratories and the perimeter rooms are generally used for offices. Six air-handling units serve the interior zones, and an additional four air-handling units serve the perimeter offices, two units each for the north and south sides. Constant volume HVAC systems are located on the attic floor. The air-handling units are composed of air filters, steam preheat coils, steam humidifiers, chilled water cooling coils, supply-air fans and return-air fans. A simplified building floor plan and cross section are shown in figure 1.

A constant volume of air is supplied to the rooms with reheat provided by hot water reheat coils. The reheat coils for the laboratories are of the duct type, and those for the perimeter offices are of the induction type with the induction units located under the windows. There are over 80 laboratory exhaust fans discharging air through the roof. Steam at 150 psig and 42°F chilled water are supplied from the central plant. Closed-loop hot water is generated inside the building from steam.


2.2 BLAST MODELING

The computer program BLAST-2 [4] was used to calculate the building energy consumptions. BLAST, one of the public-domain building energy analysis programs, is recognized as representing the state-of-the-art. The basic design is to model each room as a single office or laboratory module, rather than to lump large sections together without separating partitions. These individual-space modules are to provide for radiation exchange between the walls, floor and ceiling of the module. Multipliers ("zone-multipliers" in the terminology of BLAST) then establish the correct number of spaces for each air handling system. The six interior (laboratory) air handlers were combined into a single interior air handler for this analysis, and the four perimeter (exterior offices) air handlers were modeled as in the real building.


The interior air handler of the model has 84 general purpose and 96 more critical laboratory spaces, a total of 180 module spaces, and is designated system twenty in this report. The four exterior air handlers are designated systems three, five, six, and eight, and serve 36, 45, 47, and 38 offices respectively.

A single BLAST plant simulation supplies heating, humidification and cooling to all of the air handlers, so as to summarize the overall steam and chilled water energy requirements for the building.

People, lights, and electrical equipment were scheduled so as to approximate the sensible and latent effects resulting from these sources of internal heat



Simplified building plan showing areas served by air handling systems



Typical cross section of building

Figure 1. Simplified building plan and cross section

Table 1. Internal Load Profiles

Hours	5	6	7	8	9	10	11	12	
From									
To	6	7	8	9	10	11	12	13	
People	.1	.1	.2	.8	1	1	1	.8	
Lights	.2	.2	.2	.5	1	1	1	1	
Equipment	.2	.2	.2	.2	1	1	1	1	

Hours	13	14	15	16	17	18	19	20	Nights
From									and
To	14	15	16	17	18	19	20	21	Weekends
People	1	1	1	1	.6	.2	.1	.1	.0
Lights	1	1	1	1	1	.2	.2	.2	.2
Equipment	1	1	1	.4	.2	.2	.2	.2	.2

gains, as shown in table 1. The numbers in the table are scaling factors, by which the peak magnitudes of people, lights and equipment for each space are multiplied to determine the hourly internal loads.

Weather data for the energy analysis requires hourly information about weather parameters. A Typical Meteorological Year (TMY) weather file for Washington, D.C. was used in the present study. TMY files are composed of "typical" months selected from SOLMET files for different years, and include solar intensity data. The year 1979 determined the position of the sun for any particular day, and the weather file established the location as latitude = 39.0, longitude = 77.7 degrees.

Five design days were also used during certain tests of the BLAST models. These are not the sort of design day used for sizing equipment, but rather are used to see how a building performs under a variety of conditions, as shown in table 2. Temperatures are in degrees Fahrenheit, and the wet-bulb temperature corresponds to the highest dry-bulb temperature of the day. At lower dry-bulb temperatures, BLAST holds the same humidity ratio until saturation is reached, and then tracks downward along the saturation curve (and back up along the same path). Design day DD5 is cloudy; the rest have clear skies.

BLAST heating and cooling capacities were established as follows: for a particular air handling system, the top floor receives 20 percent more supply air than the two lower floors. These supply-air quantities established the cooling capacities for each space according to the formula $Q_s = 1.085 \times V \times (T_{room} - T_{supply})$, where T_{room} and T_{supply} are the room and supply air temperature in °F dry bulb, V is the supply air volume in cubic feet per minute, and Q_s is the supply air capacity for those particular temperature conditions in Btu/hour. The heating capacities were considered adequately sized, so that the

Table 2. Design Days

Design Day Name	Temperature, °F			Date
	High	Low	Wet-Bulb	
DD1	91	71	77	21 July
DD2	78	58	65	21 April
DD3	62	42	52	21 April
DD4	33	13	27	21 January
DD5	13	13	11	21 January

space temperature would not drop below the local heating setpoint temperatures during non-shutdown hours.

During perimeter system night shutdown, it was considered that without the induction air the heating setpoint temperatures would not always be maintained, so that the resulting space temperature drift was simulated with a ramp control, fully on at 55°F and fully off at 65°F. The fully on heating capacity for use during system shutdown was set at the rate required to maintain the space at 65°F over the whole TMY year. This resulted in a simulated space temperature drift during night shutdown that went down to approximately 57°F with the design day DD5, and reached a low of approximately 58°F on the TMY-year weather file. During the office hours on design day DD1 with 60°F supply air temperature, the space temperature varied between 72°F and 75°F in the third floor perimeter offices on the south side of the building and between 74°F and 77°F in the north side third floor perimeter offices. During the night shutdown, the space temperature drifted to approximately 81°F and 82°F, respectively, in these offices. There was, of course, no cooling capacity available during the time when an air-handling system was shut down. The higher temperature in the north offices than the south offices was caused by lower supply air quantities to the north side than to the south side.

Each of the air-handling systems has a cooling coil designed for NBS conditions (rather than making use of the BLAST default coil). Other model system characteristics include steam humidification to 30 percent RH, a 1°F throttling range in the cold deck control, steam preheat in the mixed air chamber, and a 3 inch supply fan pressure rise.

3. CONTROL STRATEGIES AND MODELING

3.1 CONTROL STRATEGIES

A simple constant-volume, fixed discharge-air temperature (not necessarily the same temperature for all air-handling systems), fixed outside air amount, and space controlled reheat temperature model was used as a base case for energy consumption comparisons. The control strategies tested including raising the cooling coil discharge air temperature, adding dry-bulb return air economizer control, adding enthalpy economizer control, resetting the perimeter system supply air temperature seasonally or by outside air temperature, converting interior systems to variable air volume (VAV), controlling interior system supply air temperature by zone demand, selectively shutting down perimeter systems during non-office hours, and different combinations of these strategies. Finally, an architectural retrofit, using double-glazed windows for the single-pane windows, was modeled for the base case. The modeling of some of these strategies is described in detail below.

Case 1. BLAST Base Case

For the basic BLAST base case, as few BLAST options as reasonable were used, so that the effect of existing as well as new control options could be studied. Hence, the case 1 configuration has a constant volume, fixed outside air quantity (no damper control), 30 percent minimum relative humidity in the space, with the off-coil air temperature of the cooling coils at 57°F for interior systems and 60°F for perimeter systems. Complete input data of the base case may be found in the Appendix.

Case 2. Raising Perimeter System Supply Air Temperature to 65°F in Winter

This is the same as case 1, except that the supply air (SA) temperature for perimeter systems is set at 65°F during the months of November through April. The BLAST input form is

COLD DECK TEMPERATURE = 65;.

Cooling and reheat energy should both be saved, since the cold supply air is closer to the room temperature. However, depending on the outside air conditions, more steam may be required to attain the required space humidity.

Case 3. Dry-Bulb Economizer for All Air-Handling Systems

The BLAST input form is

MIXED AIR CONTROL = RETURN AIR ECONOMY CYCLE;.

This is a damper control in which the outside air (OA) dampers range between a minimum established by the exhaust air (EA) quantity and a maximum of 100 percent. Return air and outside air are mixed to achieve mixed air (MA) at the cold deck dry bulb temperature, if possible.

Case 4. Dry-Bulb Economizer with Perimeter Winter Supply Air Temperature at 65°F

The perimeter system supply air temperature is seasonally adjusted as in case 2. This is a combination of cases 2 and 3.

Case 5. Enthalpy Economizer for Perimeter Systems

An enthalpy test permits dry-bulb control of the OA dampers in those cases where the OA-enthalpy is less than that of the return air. The enthalpy test decides whether minimum or 100 percent outside air should be admitted. If the outside air enthalpy and dry-bulb temperature are less than those of the return air, the outside air damper is controlled to give mixed air temperature not lower than that of the supply air. The BLAST input form is

MIXED AIR CONTROL = ENTHALPY ECONOMY CYCLE;.

Case 6. All 10 Systems have Enthalpy Economizer

Similar to Case 5, all 10 systems add enthalpy economizer cycle to the base case.

Case 7. Perimeter System OA-Reset

The BLAST input form is

COLD DECK CONTROL = OUTSIDE AIR CONTROLLED;
COLD DECK CONTROL SCHEDULE = (65 AT 65, 60 AT 66);.

The supply air temperature is 65°F when outside temperature is 65°F and below, and changes to 60°F when outside is 66°F and over. It simulates a flip-over type of supply air temperature control for the perimeter systems. The one degree (65°F to 66°F) is to allow for the BLAST throttling range in the cold deck control. An error in the BLAST program code (previously uncorrected even at CERL) was discovered during this study and was corrected by NBS.

Case 8. Perimeter System OA-Reset

This is similar to Case 7, except that a linear reset schedule is established between two sets of outdoor air and supply air temperatures. In this case, the supply air temperature is set at 65°F when the outside is at 40°F and below, the supply air is at 60°F when the outside air is at 80°F and above. In between 40°F and 80°F outside temperature, the supply air is controlled linearly between 65°F and 60°F. The BLAST input form is changed for case 7 to

COLD DECK CONTROL SCHEDULE = (65 AT 40, 60 AT 80);.

Cases 9, 10, and 11. Perimeter Systems Shut-Downs During Non-Office Hours

These cases are for shutting down the perimeter systems and toilet exhaust fans during non-office hours (nights and weekends). Due to the requirement for constant laboratory exhaust air, and to the heating of the reheat-induction units during heating seasons, more complicated modeling schemes are needed. These will be discussed later in this section.

Case 12. Interior Systems Converting to VAV

The supply air volume is controlled to maintain 65°F in the non-critical laboratory spaces. That is, there is a quite narrow throttling range for the zone dampers to move from fully open to minimum positions. In this case, only the non-critical laboratories are converted to VAV systems.

Case 13. Interior System VAV Adding Enthalpy Economizer Cycle

This is similar to case 12, adding enthalpy economizer cycles to the interior systems.

Case 14 to 17. Interior System Supply Air Temperature Reset by Zone Demand and Selected Combinations

Instead of converting interior systems to VAV as assumed in case 12, the interior non-critical laboratories may be retrofitted to have varying discharge air temperature which is set by the most demanding zones. Case 14 is a single strategy case, to vary the supply air temperature from 50°F to 60°F. Case 15 is case 14 modified by a seasonal change, reset supply air temperature from 50°F to 60°F between May 1 and September 30, and from 50°F to 70°F between October 1 and April 30. Case 16 is similar to case 14, adding enthalpy economizer cycles to all systems. Case 17 is similar to case 15, also adding enthalpy economizer cycles to all systems. The reason for having the seasonal reset schedules in cases 15 and 17 is to achieve maximum reset benefit yet to avoid unacceptably high space humidity during the summer seasons.

Case 18 and 19. Comprehensive Combined Control Strategies

Case 18 combines the perimeter system supply air reset to 65°F when outside is 65°F and below, and to 60°F when outside is 66°F and above (as in case 7), shutting down ACU #6 and the toilet-exhaust fans during non-office hours (as in case 9), interior system supply air temperature reset by zone demand from 50°F to 60°F (as in case 14), and all systems under enthalpy economizer cycle (as in case 6). Case 19 is similar to case 18 except that the perimeter supply air temperature reset is changed to 65°F when outside is 40°F and below, to 60°F when outside is 80°F above, and controlled linearly between the 60°F and 65°F conditions (as in case 8).

Case 20. Base Case with Double-Glazed Windows

This is the only case for which architectural retrofit was involved in this investigation.

3.2 AIR BALANCE

In order to obtain the best energy consumption calculation results, it is important that the actual building operating data, including air balance data, be used in this kind of study. Therefore, the system air balance data had been measured by a combination of tracer gas and pitot tube techniques, as shown in figure 2. Tracer gas measurements were used to find the ratio of supply to return air (SA/RA), and pitot measurements measured return and exhaust air quantities. Table 1A shows those data as determined by these techniques. The return and exhaust columns show the directly measured data, and the supply and outside air quantities are derived by the equations

$$SA = (SA/RA)RA, \text{ and}$$

$$OA = ((SA/RA)-1)RA$$

The outside and exhaust air totals differ by four percent of the supply air total, which is a measure of the possible accuracy of these results. Since the tracer gas is believed to provide quite accurate results, the exhaust data were considered less significant in developing the magnitudes used in BLAST, as shown in table 1B.

The building is assumed to be balanced in the baseline condition. That is, for the building as a whole, the net infiltration is zero, and the total of the exhaust air and return air exactly equals the supply air to the spaces of the building. Thus the outside air is equal to the exhaust air.

$$SA = RA + EA, \quad OA = EA$$

This assumption is conservative in that additional infiltration might result in additional energy consumption, and is consistent with the observation that in fact the building pressure varies from neutral to very slight exfiltration.

Within the building, the individual space air handlers are not balanced. For the exterior systems, there is no exhaust, and the supply air exceeds the return air with the excess conditioned air (CA) going to the interior systems:

$$SA = RA + CA, \quad EA = 0.$$

For the interior systems, this excess conditioned air plus the interior supply air is equal to the return air plus the exhaust air:

$$SA + CA = RA + EA.$$

The exhaust air includes the air taken by laboratory hoods, general exhausts, and toilet exhausts. No exhaust is assigned to the exterior systems.




Figure 2. Measurement of air quantities. Tracer-gas determines ratio SA/RA; EA and RA are measured directly.

Table 1A. Available Data on Real Air Balance

	<u>SA/RA</u>	<u>Return</u>	<u>Exhaust</u>	<u>Supply</u>	<u>Outside</u>
		cfm	cfm	cfm	cfm
Labs	1.853	46 870	62 300	86 860	39 990
Toilets	---	0	2 250	0	0
ACU-3	1.548	7 630	0	11 800	4 170
ACU-5	1.862	7 490	0	13 940	6 450
ACU-6	2.008	5 400	0	10 840	5 440
ACU-8	<u>1.572</u>	<u>5 850</u>	<u>0</u>	<u>9 200</u>	<u>3 350</u>
		73 240	64 550	132 640	59 410

Table 1B. Air Balance for BLAST

	<u>Return</u>	<u>Exhaust</u>	<u>Supply</u>	<u>Outside</u>
	cfm	cfm	cfm	cfm
Labs	46 870	57 160	86 860	39 990
Toilets	0	2 250	0	0
ACU-3	7 630	0	11 800	4 170
ACU-5	7 490	0	13 940	6 450
ACU-6	5 400	0	10 840	5 440
ACU-8	<u>5 850</u>	<u>0</u>	<u>9 200</u>	<u>3 350</u>
	73 240	59 410	132 640	59 410

Note: The air quantities under the outside columns do not add up to the total quantities due to round-offs.

In the BLAST model, the program parameters to be input are the supply and exhaust air volumes, and BLAST derives the return air and outside air quantities. For the exterior systems, the excess conditioned air is designated exhaust air, and the actual supply air volume is used. This forces an exterior system to condition an equal quantity of outside air, and again we have

$$SA = RA + EA, \quad OA = EA$$

For the interior systems, the excess conditioned air is exhausted without further energy transfer, so the measured outside air quantity is designated exhaust air, and again the actual supply air volume is used.

These concepts and assumptions are illustrated by figures 3, 4, and 5.

3.3 SYSTEM SHUTDOWN MODELING

Several of the energy conserving strategies considered involve shutting down the fans for one or more of the perimeter systems during nights and weekends. Such a shutdown here includes turning off the toilet exhausts, and may also involve switching one or more of the remaining perimeter systems to 100 percent outside air in order to have satisfactory laboratory exhaust. Thus a shutdown may cause changes in the air balance of the building, relative to the initial assumption that the base case building is balanced.

In the BLAST model, such changes in air balance were considered to result in changes in the quantity of system outside air, and were applied as an increase or decrease in the exhaust air of the interior (laboratories) system so that the outside air and exhaust air remain exactly balanced. That is, it was assumed that an increase in outside air came in through the systems, rather than as infiltration, and required energy to reach space conditions. Similarly, a decrease in outside air was assumed to decrease energy consumption.

As described above, there are two view points from which to consider the air balance data. Quantities relevant to both points of view are presented in table 2. Case 1 shows a repeat of the data from table 1B, and follows the same format. The return air quantities correspond to the data for the real building return air fan -- the total of the air returned. Similarly, the exhaust air and supply air columns correspond to data for the real building. The column "outside air" has a dual function: it is the real-building estimate of outside air, and it is also the BLAST model data for exhaust air.

Cases 9, 10, and 11 are the system shutdown cases. The toilet exhausts are off in each, and 100 percent outside air is used for those perimeter air-handling units that are in cases 10 and 11. The resulting assumptions about air balance for these cases are also shown in the table.

BLAST does not easily model a system shutdown for a building operating under NBS conditions. The system changes in air balance described above could not be modeled in a single computer run, since for each space the supply and return air quantities are input only once, and stay the same year round (except for VAV).




Figure 3. Air balance assumption

FOR THE BUILDING AS A WHOLE, BALANCE IS ASSUMED: NO RELIEF AIR, AND NO INFILTRATION.




Figure 4. Air transfer between systems

WITHIN THE ACTUAL BUILDING, CONDITIONED AIR IS TRANSFERRED FROM THE OFFICE TO THE LABS.




Figure 5. BLAST air balance

AS MODELED IN BLAST, THE EXCESS CONDITIONED AIR FROM THE OFFICES IS DESIGNATED EXHAUST AIR, AND THE LAB EXHAUST AIR IS REDUCED TO EQUAL THE LAB OUTSIDE AIR.

Table 2. Air Balance for BLAST During Shutdowns
(All Air Quantities are in cfm)

	<u>Return</u> <u>(Real Bldg)</u>	<u>Exhaust</u> <u>(Real Bldg)</u>	<u>Supply</u> <u>(Both)</u>	<u>Outside and Exhaust</u> <u>(In BLAST)</u>
<u>BLAST Base-Case, Case 1</u>				
Labs	46 870	57 160	86 860	39 990
Toilets	0	2 250	0	0
ACU-3	7 630	0	11 800	4 170
ACU-5	7 490	0	13 940	6 450
ACU-6	5 400	0	10 840	5 440
ACU-8	5 850	0	9 200	3 350
	<u>73 240</u>	<u>59 410</u>	<u>132 640</u>	<u>59 410</u>
	<u>Return</u>	<u>Exhaust</u>	<u>Supply</u>	<u>Outside and Exhaust</u>
<u>ACU-6 Shutdown, Case 9</u>				
Labs	43 680	57 160	86 860	43 190
ACU-3	7 630	0	11 800	4 170
ACU-5	7 490	0	13 940	6 450
ACU-8	5 850	0	9 200	3 350
	<u>64 650</u>	<u>57 160</u>	<u>121 800</u>	<u>57 160</u>
	<u>Return</u>	<u>Exhaust</u>	<u>Supply</u>	<u>Outside and Exhaust</u>
<u>ACU's-3 and 6 Shutdown, Case 10</u>				
Labs	52 840	57 160	86 860	34 020
ACU-5	0	0	13 940	13 940
ACU-8	0	0	9 200	9 200
	<u>52 840</u>	<u>57 160</u>	<u>110 000</u>	<u>57 160</u>
	<u>Return</u>	<u>Exhaust</u>	<u>Supply</u>	<u>Outside and Exhaust</u>
<u>ACU's-3, 6, and 8 Shutdown, Case 11</u>				
Labs	43 640	57 160	86 860	43 220
ACU-5	0	0	13 940	13 940
	<u>43 640</u>	<u>57 160</u>	<u>100 800</u>	<u>57 160</u>

Also, when the air is off, the window induction units are to continue to provide heat, although somewhat less efficiently as convection heaters, but BLAST would turn on the supply fan whenever such heat is supplied.

Thus it was necessary to devise a way to model the energy results of a shutdown option. This was done by combining the data from four computer runs: 1) the heat load during shutdown for the shutdown offices (a loads-calculation only); 2) heating and cooling during the shutdown hours for the rest of the building, in its normal (daytime) operation mode; 3) the same as run 2 with the parameters modified to the shutdown air balance, including the return fans off where a system went 100 percent OA; 4) The whole building heating and cooling energy, excluding shutdown offices during shutdown hours, based on the daytime operation mode air quantities. Note that runs 1, 2, and 3 operate only during nights and weekends. Run 1 provides correct data, but runs 2 and 3 include pulldown or startup errors when the systems are on at the beginning of the night. Fortunately, those errors are probably similar for the two runs, since they are subtracted one from the other to obtain the effect of the change in air balance. Finally, the pulldown or startup effects in run 4 are real: the shutdown offices will have drifted slightly in temperature in the summer, and cooling energy will be expended to return them to their daytime conditions. The building energy consumption is obtained by subtracting the results of run 2 from the sum of runs 1, 3, and 4.

An example of this procedure is given in table 3. The columns are labeled with the above run-numbers. Case 9 involves the shutting down of exterior system 6, as well as turning off the toilet exhausts. Note that although the data of runs 2 and 3 are relatively large, their differences are much smaller. Also, note how little energy is used for space heating (run 1). Most of the heating and cooling energy of a commercial building comes from cooling and reheating the circulating air, and from conditioning the outside air.

Table 3. Shutdown Example - Case 9

Month	Run 3	Run 2	(Run 3) -(Run 2)	Run 1	Run 4	(Run 3) -(Run 2) +(Run 1) +(Run 4)
<u>Heating Energy (in 10⁹ Btu)</u>						
1	1.4250	1.3201	.1049	.0168	1.8080	1.9297
2	1.2179	1.1455	.0724	.0142	1.4984	1.5850
3	.8570	.7876	.0694	.0031	1.0927	1.1652
4	.4903	.4718	.0185	.0003	.7413	.7601
5	.3971	.3970	.0001	--	.6668	.6669
6	.3551	.3555	-.0004	--	.5818	.5814
7	.3684	.3693	-.0009	--	.5712	.5703
8	.3403	.3410	-.0007	--	.5663	.5656
9	.3914	.3918	-.0004	--	.6043	.6039
10	.4773	.4713	.0060	--	.7458	.7518
11	.6899	.6487	.0412	.0023	.9483	.9918
12	<u>1.1458</u>	<u>1.0499</u>	<u>.0959</u>	<u>.0115</u>	<u>1.4016</u>	<u>1.5090</u>
Σ	8.1554	7.7495	.4060	.0482	11.2265	11.6807
<u>Cooling Energy (in 10⁹ Btu)</u>						
1	.0316	.0429	-.0113	--	.0819	.0706
2	.0348	.0443	-.0095	--	.0849	.0754
3	.1521	.1699	-.0178	--	.3129	.2951
4	.4232	.4446	-.0214	--	.7088	.6874
5	.8076	.8119	-.0043	--	1.2513	1.2470
6	1.2164	1.1982	.0182	--	1.8631	1.8813
7	1.7449	1.7007	.0442	--	2.5902	2.6344
8	1.4535	1.4234	.0301	--	2.2990	2.3291
9	1.2873	1.2673	.0200	--	1.8461	1.8661
10	.5328	.5512	-.0184	--	.8775	.8591
11	.2046	.2283	-.0237	--	.4613	.3926
12	<u>.0354</u>	<u>.0491</u>	<u>-.0137</u>	<u>--</u>	<u>.1043</u>	<u>.0906</u>
Σ	7.9242	7.9319	-.0076	--	12.4362	12.4287

4. RESULTS-DATA

The base case monthly heating and cooling energy consumptions for the interior, north and south perimeter systems are shown in tables 4, 5, and 6. The base case monthly heating, cooling and fan (including supply, return and exhaust fans) energy consumptions for the entire building are shown in table 7. These energy quantities, except for fan energy, are also plotted in figure 6. From these tables and figure 6, some of the energy consumption characteristics of the building may be seen, and possible opportunities for reducing energy consumption may be assumed. Of the total building heating energy, about 74.5 percent is consumed by the interior systems, 12.2 percent is consumed by the north systems and 13.3 percent is used by the south systems. For cooling, the distributions are 74.4 percent, 11.3 percent, and 14.2 percent, respectively. The large ratio of the interior system consumption to that of the perimeter system consumption indicates that emphasis of energy conservation controls should be placed on the interior systems. Of the 8.732×10^9 Btu interior heating consumption, 0.655×10^9 Btu is spent for preheat coil load, 0.957×10^9 Btu is used for humidifying load, yet 7.119×10^9 Btu is consumed by the reheat coils. This amounts to over 80 percent (81.5 percent to be exact) of the interior heating load being used by the reheat coils. For the whole building, over 60 percent of the entire heating load is spent in the interior reheat coils. Part of the high interior load is attributed to the larger interior floor areas (the ratio of interior to perimeter floor areas is 1.4 to 1), high equipment load, and the heat needed to raise the winter fan discharge air (around 60°F) to the space conditions; but the pure reheat effect on the energy consumption should be examined. This is also evident from table 4 and figure 6 that the interior system reheat energy consumption during the summer months is over $.53 \times 10^9$ Btu per month. The control strategy cases 12, 14, and 15 (interior system VAV conversion and reset by zone demand) should have major impact on the overall building energy reduction. On the other hand, cases such as 7 and 8 (perimeter reset) may not have large effects, on overall building percentage basis.

The yearly heating and cooling energies and fan electric energies of the building for the various control strategies are as tabulated in table 8. As described in the previous section, the base case has a fixed outside air quantity. The supply air temperature is set at 57°F for the interior systems and 60°F for the perimeter systems. Table 9 shows the normalized energy consumption for the same control strategies as listed in table 8 using the base case yearly energy consumption as one.

In all cases, when economy cycle control is added, either dry-bulb return air comparison or enthalpy comparison, the cooling energy is decreased but the heating energy is increased. The reason for the increase in heating energy is mainly due to the added humidifying load during the time when the dry outside air is introduced into the air-handling systems. Figure 7 compares the monthly humidifying loads for the base case and case 6 (enthalpy economizer cycle). The highest humidifying load occurs in January, but the highest increase between the two cases occurs in March and April. Of the yearly total heating energy, 11.2 percent is consumed by the humidifiers in the base case while 15.5 percent is used in the case with enthalpy control. Therefore, it is feasible to minimize the heating energy increase under the economizer cycle by reducing the humidity requirements during the non-cooling seasons.

Table 4. Monthly Heating and Cooling Energy for Interior Systems
Base Case

Month	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹
1	1.2334	.0739
2	1.0261	.0757
3	.7984	.2637
4	.6067	.5715
5	.5879	.9745
6	.5426	1.4150
7	.5436	1.9360
8	.5378	1.7190
9	.5582	1.4040
10	.6271	.6986
11	.7081	.3448
12	<u>.9622</u>	<u>.0942</u>
Yearly Total	8.7321	9.5709

Table 5. Monthly Heating & Cooling Energy for North Perimeter
Systems Base Case

Month	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹
1	.3366	.0032
2	.2757	.0037
3	.1799	.0221
4	.0776	.0668
5	.0352	.1402
6	.0121	.2335
7	.0063	.3454
8	.0079	.2995
9	.0178	.2301
10	.0699	.0825
11	.1488	.0317
12	<u>.2584</u>	<u>.0036</u>
Yearly Total	1.4262	1.4583

Table 6. Monthly Heating & Cooling Energy for South Perimeter Systems Base Case

Month	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹
1	.3543	.0053
2	.2918	.0061
3	.1901	.0321
4	.0903	.0889
5	.0530	.1772
6	.0249	.2858
7	.0190	.4165
8	.0141	.3663
9	.0259	.2844
10	.0729	.1125
11	.1534	.0253
12	<u>.2713</u>	<u>.0065</u>
Yearly Total	1.5540	1.8269

Table 7. Monthly Energy Consumption for the Building Base Case

Month	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹	Fan Energy Btu x 10 ⁹
1	1.9246	.0825	.2581
2	1.5935	.0855	.2396
3	1.1682	.3180	.2581
4	.7747	.7272	.2498
5	.6760	1.2919	.2581
6	.5796	1.9344	.2498
7	.5619	2.6976	.2581
8	.5599	2.3852	.2581
9	.6019	1.9138	.2498
10	.7703	.8936	.2581
11	1.0102	.4219	.2498
12	<u>1.4919</u>	<u>.1043</u>	<u>.2581</u>
Total	11.7127	12.8560	3.0455




Figure 6. Heating and cooling energy consumption--base case

Table 8. Yearly Energy Consumption of Various Control Strategies

Cases	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹	Fan Energy Btu x 10 ⁹
1. Base case	11.71	12.86	3.04
2. Same as base case, except, 65°F supply air temperature in winter for perimeter systems	11.57	12.68	3.04
3. Dry-bulb economizer for all systems	12.36	11.33	3.04
4. Same as 2, adding dry-bulb economizer for all systems	12.21	11.23	3.04
5. Enthalpy economizer for perimeter systems	11.77	12.54	3.04
6. Enthalpy economizer for all systems	12.37	11.01	3.04
7. Perimeter system supply air temperature reset from outside air temperature: 65°F at 65°F, 60°F at 66°F	11.58	12.36	3.04
8. Same as 7 except, 65°F at 40°F, 60°F at 80°F	11.51	12.38	3.04
9. ACU #6 and toilet exhaust fans off during non-office hours	11.68	12.43	2.79
10. ACU #3 and 6 off, toilet exhaust fan off, ACU's #5 and 8 on 100 percent OA during non-office hours	11.62	12.43	2.52
11. ACU's #3, 6 and 8 off, toilet exhaust fans off, ACU #5 on 100 percent OA during non-office hours	11.88	11.87	2.32
12. Interior systems on VAV	11.15	11.32	2.48
13. Interior systems on VAV and enthalpy economizer	11.50	10.32	2.48
14. Interior system supply air temperature reset between 50°F and 60°F by zone demand	10.65	11.13	3.04
15. Same as 14 except 50°F-60°F between May 1 and Sept. 30, 50°F-70°F between Oct. 1 and April 30	10.53	10.93	3.04
16. Same as 14, adding enthalpy economizer for all systems	11.08	9.65	3.04
17. Same as 15, adding enthalpy economizer for all systems	10.89	9.56	3.04
18. Perimeter system supply air temperature reset from outside air temperature, 65°F at 65°F, 60°F at 66°F; ACU #6 and exhaust fans off during non-office hours; interior system supply air temperature reset by zone demand, 50°F-60°F; enthalpy economizer for all systems	10.85	9.18	2.79
19. Same as 18, changing perimeter system supply air temperature reset from outside air temperature 65°F at 40°F and 60°F at 80°F	10.79	9.12	2.79
20. Base case with double-glazed windows	11.42	12.83	3.04

Table 9. Yearly Energy Consumption Comparison of Various Control Strategies

Cases	Heating Energy Btu x 10 ⁹	Cooling Energy Btu x 10 ⁹	Fan Energy Btu x 10 ⁹
1. Base case	1.00	1.00	1.00
2. Same as base case, except, 65°F supply air temperature in winter for perimeter systems	.99	.99	1.00
3. Dry-bulb economizer for all systems	1.06	.88	1.00
4. Same as 2, adding dry-bulb economizer for all systems	1.04	.87	1.00
5. Enthalpy economizer for perimeter systems	1.01	.98	1.00
6. Enthalpy economizer for all systems	1.06	.86	1.00
7. Perimeter system supply air temperature reset from outside air temperature: 65°F at 65°F, 60°F at 66°F	.99	.96	1.00
8. Same as 7 except, 65°F at 40°F, 60°F at 80°F	.98	.96	1.00
9. ACU #6 and toilet exhaust fans off during non-office hours	1.00	.97	.83
10. ACU #3 and 6 off, toilet exhaust fan off, ACU's #5 and 8 on 100 percent OA during non-office hours	.99	.97	.83
11. ACU's #3, 6 and 8 off, toilet exhaust fans off, ACU #5 on 100 percent OA during non-office hours	1.01	.92	.76
12. Interior systems on VAV	.95	.88	.82
13. Interior systems on VAV and enthalpy economizer	.98	.80	.82
14. Interior system supply air temperature reset between 50°F and 60°F by zone demand	.91	.87	1.00
15. Same as 14 except 50°F-60°F between May 1 and Sept. 30, 50°F-70°F between Oct. 1 and April 30	.90	.85	1.00
16. Same as 14, adding enthalpy economizer for all systems	.95	.75	1.00
17. Same as 15, adding enthalpy economizer for all systems	.93	.74	1.00
18. Perimeter system supply air temperature reset from outside air temperature, 65°F at 65°F, 60°F at 66°F; ACU #6 and exhaust fans off during non-office hours; interior system supply air temperature reset by zone demand, 50°F-60°F; enthalpy economizer for all systems	.93	.71	.92
19. Same as 18, changing perimeter system supply air temperature reset from outside air temperature 65°F at 40°F and 60°F at 80°F	.92	.71	.92
20. Base case with double-glazed windows	.98	1.00	1.00




Figure 7. Comparison of humidifer energy consumption

The energy reductions for the perimeter system shutdown cases (cases 9, 10, and 11, and other combinations) are smaller than one would anticipate. As discussed in the previous section, the techniques modeled assumed the air-handling system outside air equaled the exhaust fan capacities. This is not completely true in reality. When some perimeter systems are turned off, the building is starved for air, but it "balances" itself by increasing air infiltration, increasing outside air coming into the air-handling systems, and reducing the exhaust air quantities. Therefore, the results of cases 9, 10, 11, 18, and 19 are conservative. Without measured data on air quantities during shutdown cases, it is difficult to judge quantitatively the additional energy savings caused by the reduced exhaust.

Although the overall building energy reduction, in percentage, is small for the perimeter temperature reset option, the savings on a system basis are substantial. Table 10 shows the yearly energy consumptions of the north and south systems and table 11 shows the percentage energy savings compared to the base case for the north, south, and the combined systems.

Table 10. Annual Heating and Cooling Energy for Perimeter System Supply Air Temperature Reset

	<u>North Systems</u>		<u>South Systems</u>	
	Heating 10 ⁹ Btu	Cooling 10 ⁹ Btu	Heating 10 ⁹ Btu	Cooling 10 ⁹ Btu
Base Case	1.4262	1.4583	1.5540	1.8269
Case 7 Reset, 65°F at 65°F, 60°F at 66°F	1.3625	1.2481	1.4880	1.5392
Case 8 Reset 65°F at 40°F, 60°F at 80°F	1.3340	1.2572	1.4463	1.5570

Table 11. Annual Savings for Perimeter System Supply
Air Temperature Reset

	<u>North Systems</u>		<u>South Systems</u>		<u>North and South Systems Combined</u>	
	Heating	Cooling	Heating	Cooling	Heating	Cooling
Case 7	4.5%	14.4%	4.2%	15.7%	4.4%	15.2%
Case 8	6.5%	13.8%	6.9%	14.8%	6.7%	14.3%

Table 11 shows that over 4 percent in heating energy and over 14 percent in cooling energy savings may be obtained by either of these temperature resets. These savings result from shaving the unnecessary cooling capacities during the part-load conditions to match closer to the space loads. It is interesting to note that when the strategies are combined, the overall saving trends may not agree with those of the individual strategies. For the perimeter system supply air temperature reset cases, case 7 (65° at 65°F and 60°F at 66°F) saves more than case 8 (65°F at 40°F and 60°F at 80°F) in heating but saves less in cooling. When the same resets are applied with other strategies, as in cases 18 and 19, the savings of both heating and cooling favor case 19.

It is obvious from tables 8 and 9 that installing double-glazed windows in this building is hardly a viable retrofit option for energy conservation.

5. CONCLUSION

Ranking of the control strategies investigated in this report is not feasible, since that would require the investigation of the efficiencies of the heating and cooling plants and the fuel costs for their generation, which would go beyond the boundaries of this building and the scope of this report (see Preface). From the individual heating, cooling, and fan energy consumptions of this building, the following conclusions are stated:

1. All of the basic control strategies (case 20 is not considered a control strategy) should save considerable amounts of energy, even though the percentage of savings of some of the strategies to the total building consumption are small. The costs for control strategy modifications *seem minimal.*
2. Both dry-bulb and enthalpy economizer cycles are energy saving controls. The enthalpy type has a two percent saving edge in cooling over the dry-bulb type. The heating energy increase caused by these controls may be reduced, if the minimum indoor humidity requirement during the non-cooling seasons is reduced.
3. The overall building energy reduction from the perimeter system supply air temperature reset by outdoor temperature is relatively small (four percent).
4. The energy reduction from perimeter system shutdowns may save a considerable amount of energy. The actual savings should be larger than those predicted here.
5. The largest energy saving should be possible with the interior systems. Resetting interior system supply air temperature by zone demand saves slightly (three percent in cooling and five percent in heating) more than converting to VAV system, fan energy savings from VAV being ignored.
6. Annual energy savings of 0.29×10^9 Btu in heating, 3.66×10^9 Btu in cooling and 0.25×10^9 Btu in fan operation may be achieved by combining various control strategies (case 19). This amounts to eight percent, twenty-nine percent, and eight percent in heating, cooling and fan energy savings, respectively, as compared to the base case.

Obviously, it must be emphasized that these conclusions are drawn from the results for this particular laboratory building under the Washington, D.C. weather conditions.

REFERENCES

1. Hoffman, J.D., "Energy Conservation at the NBS Laboratories," NBSIR 74-593, 1974.
2. Conversation with Chris Conley of NBS Plant Division, October 1980.
3. "Emergency Building Temperature Restrictions," Federal Register, Volume 44, Number 130, Thursday, July 5, 1979, pp. 39354-39369.
4. Hittle, D.C., The Building Loads Analysis and System Thermodynamics (BLAST) Program, Version 2.0: Users Manual, Volume I, U.S. Army Construction Engineering Research Laboratory, 1979. Available from NTIS, Springfield, VA. 22151.

APPENDIX

Input Data for Base Case

1. INTRODUCTION

This appendix is presented here for the readers who are familiar with the BLAST-2 program applications and wish to examine how the building and the air-handling system control details for the base case were handled. Specific modelling methods and other control strategies are as described in the text.

2. INPUT DATA

```

PA
1   BEGIN INPUT;
2   RUN CONTROL?
3   NEW ZONES,
4   NEW AIR SYSTEMS,
5   CENTRAL PLANT,
6   UNITS(IN=ENGLISH,OUT=ENGLISH);
7   DEFINE LOCATION?
8   WASHING=
9   (LAT= 38.85, LONG= 77.03, TZ= 5);
10  END LOCATION;
11  DEFINE DESIGN DAYS?
12  DD1=(HIGH=91,LOW=71,WB=77, DATE=21 JUL);
13  END DESIGN DAYS;
14  DEFINE SCHEDULE (NBS PEOPLE)?
15  MONDAY THRU FRIDAY   =(21 TO 5 - 0.0, .1,.1,.2,.8,
16                        9 TO 12 - 1.0, .8,
17                        13 TO 17 - 1.0, .6,.2,.1,.1);
18  SATURDAY THRU SUNDAY =( 0 TO 24 - 0.0), HOLIDAY=SUNDAY;
19  END SCHEDULE;
20  DEFINE SCHEDULE (NBS LIGHTS)?
21  MONDAY THRU FRIDAY   =(18 TO 8 - 0.2, .5,
22                        9 TO 18 - 1.0);
23  SATURDAY THRU SUNDAY =( 0 TO 24 - 0.2), HOLIDAY=SUNDAY;
24  END SCHEDULE;
25  DEFINE SCHEDULE (NBS ELECTRIC EQUIPMENT)?
26  MONDAY THRU FRIDAY   =(18 TO 9 - 0.2,
27                        9 TO 16 - 1.0,0.4,0.2);
28  SATURDAY THRU SUNDAY =( 0 TO 24 - 0.2), HOLIDAY=SUNDAY;
29  END SCHEDULE;
30  DEFINE CONTROLS(GENERAL LAB)?      **SA=57, REHEAT=65
31  PROFILES?
32  P7=(1.0 AT 64, 0.0 AT 65, -0.286 AT 65, -1.0 AT 85);
33  SCHEDULES?
34  SUNDAY THRU SATURDAY = (00 TO 24 - P7), HOLIDAY=SUNDAY;
35  END CONTROLS;
36  DEFINE CONTROLS(CRITICAL LAB)?     **SA=57, REHEAT=72
37  PROFILES?
38  P8=(1.0 AT 71.5, 0.0 AT 72, -0.536 AT 72, -1.0 AT 85);
39  SCHEDULES?
40  SUNDAY THRU SATURDAY = (00 TO 24 - P8), HOLIDAY=SUNDAY;
41  END CONTROLS;
42  DEFINE CONTROLS(OFFICE SIXTY)?     **SA=60
43  PROFILES?
44  P10=(1.0 AT 64, 0.0 AT 65, -0.2 AT 65, -1.0 AT 85);
45  SCHEDULES?
46  SUNDAY THRU SATURDAY = (00 TO 24 - P10), HOLIDAY=SUNDAY;
47  END CONTROLS;
48  DEFINE MATERIALS?
49  ACOUSTIC TILE=
50  (L=0.0625,K=0.033,D=20.0,CP=0.2);
51  AIRSPACE VERTICAL=
52  (R=1.01,AIR);
53  FACE BRICK=
54  (L=0.3229,K=0.75,D=130.0,CP=0.2);
55  CONC 6=
56  (L=0.5000,K=1.0,D=140.0,CP=0.2);
57  CONC 8=
58  (L=0.6667,K=1.0,D=140.0,CP=0.2);
59  FLOOR TILE=
60  (R=0.05);
61  GYP BOARD=
62  (L=0.0417,K=0.0938,D=50.0,CP=0.2);
63  METAL ROOF DECK=
64  (L=0.0052,K=26.2,D=489.0,CP=0.12);
65  METAL WALL SKIN=

```

66 (L=0.0052,K=26.2,D=489.0,CP=0.12);
67 MOCK EARTH R10=
68 (L=1.0,K=0.100,D=100.0,CP=0.2);
69 MOCK EARTH THICK=
70 (R=100.0);
71 PLATE GLASS 1-4 CLEAR=
72 (R=0.048,GLASS,TRANS=.80,VERY SMOOTH);
73 RIGID INS 1.5=
74 (L=0.125,K=0.027,D=15.0,CP=0.17);
75 BUILT UP ROOFING=
76 (L=0.0313,K=0.094,D=70.0,CP=0.35,VERY ROUGH);
77 ROOF INS=
78 (R=8.0);
79 VENETIAN BLIND=
80 (R=0.00004,SHADE,TRANS=0.18,ABS=0.40,REF=0.42);
81 END MATERIALS;
82 DEFINE WALLS?
83 BRICK WALL=
84 (FACE BRICK,
85 AIRSPACE VERTICAL,
86 CONC 8,
87 AIRSPACE VERTICAL,
88 METAL WALL SKIN);
89 CONC DIAGONAL WALL=
90 (CONC 8);
91 CURTAIN WALL INS PANEL=
92 (METAL WALL SKIN,
93 RIGID INS 1.5,
94 METAL WALL SKIN);
95 LAB WALL=
96 (METAL WALL SKIN,
97 AIRSPACE VERTICAL,
98 METAL WALL SKIN);
99 OFFICE WALL=
100 (METAL WALL SKIN,
101 GYP BOARD,
102 METAL WALL SKIN,
103 AIRSPACE VERTICAL,
104 METAL WALL SKIN,
105 GYP BOARD,
106 METAL WALL SKIN);
107 END WALLS;
108 DEFINE ROOFS?
109 FLAT ROOF INS=
110 (BUILT UP ROOFING,
111 ROOF INS,
112 METAL ROOF DECK);
113 FLOOR-CEILING ATTIC=
114 (CONC 6,
115 ACOUSTIC TILE);
116 MIDDLE FLOOR-CEILING=
117 (FLOOR TILE,
118 CONC 6);
119 END ROOFS;
120 DEFINE FLOORS?
121 FLOOR ATTIC=
122 (ACOUSTIC TILE,
123 CONC 6);
124 MIDDLE FLOOR=
125 (CONC 6,
126 FLOOR TILE);
127 INTERIOR GROUND FLOOR=
128 (MOCK EARTH THICK,
129 CONC 6);
130 PERIMETER GROUND FLOOR=
131 (MOCK EARTH R10,

132 CONC 6);
133 END FLOORS;
134 DEFINE WINDOWS?
135 SINGLE PANE GLASS=
136 (PLATE GLASS 1-4 CLEAR,
137 VENETIAN BLIND);
138 END WINDOWS;
139 PROJECT=@JK47Z NBS GP LAB AND OFFICE, BLDG 223@;
140 LOCATION=WASHING;
141 GROUND TEMPERATURES=(60,60,60,60,60,68,68,68,68,60,60,60);
142 DESIGN DAYS=DD1;
143 **WEATHER TAPE FROM 01 JAN 79 THRU 31 DEC 79;
144 BEGIN BUILDING DESCRIPTION;
145 NORTH AXIS=0;
146 ATTIC 1 #ATTIC#?
147 NORTH AXIS=0;
148 EXTERIOR WALLS?
149 STARTING AT (383,103,0) FACING (0)
150 CURTAIN WALL INS PANEL (383 BY 12)
151 ,
152 STARTING AT (383,0,0) FACING (90)
153 CURTAIN WALL INS PANEL (103 BY 12)
154 ,
155 STARTING AT (0,0,0) FACING (180)
156 CURTAIN WALL INS PANEL (383 BY 12)
157 ,
158 STARTING AT (0,103,0) FACING (270)
159 CURTAIN WALL INS PANEL (103 BY 12)
160 ;
161 PARTITIONS?
162 STARTING AT (87,13,24) FACING (0)
163 CONC DIAGONAL WALL (87 BY 12)
164 ,
165 STARTING AT (87,0,24) FACING (90)
166 CONC DIAGONAL WALL (13 BY 12)
167 ,
168 STARTING AT (383,0,0) FACING (15)
169 CONC DIAGONAL WALL (396 BY 12)
170 ,
171 STARTING AT (0,0,0) FACING (165)
172 CONC DIAGONAL WALL (396 BY 12)
173 ,
174 STARTING AT (0,103,0) FACING (195)
175 CONC DIAGONAL WALL (396 BY 12)
176 ,
177 STARTING AT (383,103,0) FACING (345)
178 CONC DIAGONAL WALL (396 BY 12)
179 ;
180 ROOF?
181 STARTING AT (0,0,12) FACING (180)
182 FLAT ROOF INS (383 BY 103)
183 ;
184 ATTIC FLOOR?
185 STARTING AT (0,103,0) FACING (180)
186 FLOOR ATTIC (383 BY 103)
187 ;
188 END ZONE;
189 ZONE 2 #LOWER GENERAL LABS#?
190 NORTH AXIS =0;
191 LIGHTS=5.460, NBS LIGHTS;
192 PEOPLE=3.0, NBS PEOPLE;
193 ELECTRIC EQUIPMENT=4.436, NBS ELECTRIC EQUIPMENT;
194 CONTROLS=GENERAL LAB, 1000000 HEATING, 29.321 COOLING;
195 PARTITIONS?
196 STARTING AT (11,24,0) FACING (0)
197 LAB WALL (11 BY 22.333)

198 ,
199 STARTING AT (11,0,0) FACING (90)
200 LAB WALL (24 BY 22.333)
201 ,
202 STARTING AT (0,0,0) FACING (180)
203 LAB WALL (11 BY 22.333)
204 ,
205 STARTING AT (0,24,0) FACING (270)
206 LAB WALL (24 BY 22.333)
207 ;
208 CEILING?
209 STARTING AT (0,0,22.333) FACING (180)
210 MIDDLE FLOOR-CEILING (22 BY 24)
211 ;
212 SLAB ON GRADE FLOOR?
213 STARTING AT (0,24,0) FACING (180)
214 INTERIOR GROUND FLOOR (11 BY 24)
215 ;
216 FLOOR?
217 STARTING AT (0,24,0) FACING (180)
218 MIDDLE FLOOR (11 BY 24)
219 ;
220 END ZONE;
221 ZONE 3 #UPPER GENERAL LAB#?
222 NORTH AXIS =0;
223 LIGHTS=2.730, NBS LIGHTS;
224 PEOPLE=1.5, NBS PEOPLE;
225 ELECTRIC EQUIPMENT=2.218, NBS ELECTRIC EQUIPMENT;
226 CONTROLS=GENERAL LAB, 1000000 HEATING, 14.660 COOLING;
227 PARTITIONS?
228 STARTING AT (11,24,0) FACING (0)
229 LAB WALL (11 BY 11.167)
230 ,
231 STARTING AT (11,0,0) FACING (90)
232 LAB WALL (24 BY 11.167)
233 ,
234 STARTING AT (0,0,0) FACING (180)
235 LAB WALL (11 BY 11.167)
236 ,
237 STARTING AT (0,24,0) FACING (270)
238 LAB WALL (24 BY 11.167)
239 ;
240 CEILING UNDER ATTIC?
241 STARTING AT (0,0,24) FACING (180)
242 FLOOR-CEILING ATTIC (11 BY 24)
243 ;
244 FLOOR?
245 STARTING AT (0,24,0) FACING (180)
246 MIDDLE FLOOR (11 BY 24)
247 ;
248 END ZONE;
249 ZONE 4 #LOWER CRITICAL LABS#?
250 SAME AS ZONE 2 EXCEPT?
251 CONTROLS=CRITICAL LAB, 1000000 HEATING, 29.321 COOLING;
252 END ZONE;
253 ZONE 5 #UPPER CRITICAL LAB#?
254 SAME AS ZONE 3 EXCEPT?
255 CONTROLS=CRITICAL LAB, 1000000 HEATING, 14.660 COOLING;
256 END ZONE;
257 ZONE 6 #LOWER OFFICES SIXTY SOUTH#?
258 NORTH AXIS =0;
259 LIGHTS=3.0, NBS LIGHTS;
260 PEOPLE=3.0, NBS PEOPLE;
261 ELECTRIC EQUIPMENT=0.3412, NBS ELECTRIC EQUIPMENT;
262 CONTROLS=OFFICE SIXTY, 1000000 HEATING, 16.17 COOLING;
263 EXTERIOR WALLS?

264 STARTING AT (0,0,0) FACING (180)
265 BRICK WALL (11 BY 22.333)
266 WITH WINDOWS OF TYPE
267 SINGLE PANE GLASS (4.5 BY 16) AT (3,2.5)
268 ;
269 PARTITIONS?
270 STARTING AT (11,0,0) FACING (90)
271 OFFICE WALL (23 BY 22.333)
272 ,
273 STARTING AT (11,23,0) FACING (0)
274 OFFICE WALL (11 BY 22.333)
275 ,
276 STARTING AT (0,23,0) FACING (270)
277 OFFICE WALL (23 BY 22.333)
278 ;
279 CEILING?
280 STARTING AT (0,0,22.333) FACING (180)
281 MIDDLE FLOOR-CEILING (22 BY 23)
282 ;
283 SLAB ON GRADE FLOOR?
284 STARTING AT (0,23,0) FACING (180)
285 PERIMETER GROUND FLOOR (11 BY 23)
286 ;
287 FLOOR?
288 STARTING AT (0,23,0) FACING (180)
289 MIDDLE FLOOR (11 BY 23)
290 ;
291 END ZONE;
292 ZONE 7 #UPPER OFFICE SIXTY SOUTH#?
293 NORTH AXIS =0;
294 LIGHTS=1.5, NBS LIGHTS;
295 PEOPLE=1.5, NBS PEOPLE;
296 ELECTRIC EQUIPMENT=0.1706, NBS ELECTRIC EQUIPMENT;
297 CONTROLS=OFFICE SIXTY, 1000000 HEATING, 9.71 COOLING;
298 EXTERIOR WALLS?
299 STARTING AT (0,0,0) FACING (180)
300 BRICK WALL (11 BY 11.667)
301 WITH WINDOWS OF TYPE
302 SINGLE PANE GLASS (4.5 BY 8) AT (3,2.5)
303 ;
304 PARTITIONS?
305 STARTING AT (11,0,0) FACING (90)
306 OFFICE WALL (23 BY 11.167)
307 ,
308 STARTING AT (11,23,0) FACING (0)
309 OFFICE WALL (11 BY 11.167)
310 ,
311 STARTING AT (0,23,0) FACING (270)
312 OFFICE WALL (23 BY 11.167)
313 ;
314 CEILING UNDER ATTIC?
315 STARTING AT (0,0,11.167) FACING (180)
316 FLOOR-CEILING ATTIC (11 BY 23)
317 ;
318 FLOOR?
319 STARTING AT (0,23,0) FACING (180)
320 MIDDLE FLOOR (11 BY 23)
321 ;
322 END ZONE;
323 ZONE 8 #LOWER OFFICES SIXTY NORTH#?
324 NORTH AXIS =180;
325 SAME AS ZONE 6 EXCEPT?
326 CONTROLS=OFFICE SIXTY, 1000000 HEATING, 11.72 COOLING;
327 END ZONE;
328 ZONE 9 #UPPER OFFICE SIXTY NORTH#?
329 NORTH AXIS =180;

```

330     SAME AS ZONE 7 EXCEPT?
331     CONTROLS=OFFICE SIXTY,      1000000 HEATING,  7.54 COOLING;
332     END ZONE;
333     END BUILDING DESCRIPTION;
334     BEGIN FAN SYSTEM DESCRIPTION;
335     VARIABLE VOLUME SYSTEM 20 #INTERIOR 20# SERVING ZONE 2,3,4,5;
336     **VAV BECAUSE IT-S AN OPTION TO BE TRIED
337     FOR ZONE 2? **LOWER FLOORS GENERAL PURPOSE LABS
338     SUPPLY AIR VOLUME= 965.13;
339     EXHAUST AIR VOLUME= 444.36;
340     REHEAT CAPACITY=1000000;
341     ZONE MULTIPLIER=28;
342     END ZONE;
343     FOR ZONE 3? **TOP FLOOR GENERAL PURPOSE LAB
344     SUPPLY AIR VOLUME= 482.57;
345     EXHAUST AIR VOLUME= 222.18;
346     REHEAT CAPACITY=1000000;
347     ZONE MULTIPLIER=28;
348     END ZONE;
349     FOR ZONE 4? **LOWER FLOORS CRITICAL LABS
350     SUPPLY AIR VOLUME= 965.13;
351     EXHAUST AIR VOLUME= 444.36;
352     MINIMUM AIR FRACTION=1.0;
353     REHEAT CAPACITY=1000000;
354     ZONE MULTIPLIER=32;
355     END ZONE;
356     FOR ZONE 5? **TOP FLOOR CRITICAL LAB
357     SUPPLY AIR VOLUME= 482.57;
358     EXHAUST AIR VOLUME= 222.18;
359     MINIMUM AIR FRACTION=1.0;
360     REHEAT CAPACITY=1000000;
361     ZONE MULTIPLIER=32;
362     END ZONE;
363     OTHER SYSTEM PARAMETERS?
364     HUMIDISTAT LOCATION=4;
365     MIXED AIR CONTROL=FIXED PERCENT;
366     HOT DECK TEMPERATURE=1000.0;
367     COLD DECK TEMPERATURE=57.0;
368     COLD DECK THROTTLING RANGE=1.0;
369     SUPPLY FAN PRESSURE= 3.0;
370     EXHAUST FAN PRESSURE=0.5;
371     RETURN FAN PRESSURE= 1.25;
372     SUPPLY FAN EFFICIENCY= 0.75;
373     EXHAUST FAN EFFICIENCY=0.50;
374     RETURN FAN EFFICIENCY= 0.70;
375     HUMIDIFIER TYPE=STEAM;
376     HUMIDISTAT SET POINT=30;
377     PREHEAT COIL LOCATION=MIXED AIR DUCT;
378     PREHEAT COIL CAPACITY=1000000;
379     PREHEAT ENERGY SUPPLY=STEAM;
380     WEEKDAY MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
381     WEEKEND MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
382     VAV MINIMUM AIR FRACTION=1.0; **CONSTANT VOLUME
383     VAV VOLUME CONTROL TYPE=INLET VANES;
384     END OTHER SYSTEM PARAMETERS;
385     EQUIPMENT SCHEDULES?
386     SYSTEM OPERATION=INTERMITTENT;
387     WEEKDAY SYSTEM SCHEDULE=(7 TO 18 - 1, 18 TO 7 - 1);
388     WEEKEND SYSTEM SCHEDULE=(0 TO 24 - 1);
389     END EQUIPMENT SCHEDULES;
390     COOLING COIL DESIGN PARAMETERS?
391     AIR VOLUME FLOW RATE=86862;
392     WATER VOLUME FLOW RATE=77.107;
393     ENTERING AIR DRY BULB TEMPERATURE=85;
394     ENTERING AIR WET BULB TEMPERATURE=64;
395     ENTERING WATER TEMPERATURE=42;

```



```

396 LEAVING AIR DRY BULB TEMPERATURE=54;
397 LEAVING AIR WET BULB TEMPERATURE=53.3;
398 LEAVING WATER TEMPERATURE=54;
399 BAROMETRIC PRESSURE=405;
400 AIR FACE VELOCITY=360;
401 WATER VELOCITY=275;
402 END COOLING COIL DESIGN PARAMETERS;
403 END SYSTEM;
404 VARIABLE VOLUME SYSTEM 3 #SOUTH EXTERIOR 3# SERVING ZONE 6,7;
405 FOR ZONE 6? **LOWER FLOORS
406 SUPPLY AIR VOLUME= 596;
407 EXHAUST AIR VOLUME= 246;
408 REHEAT CAPACITY=1000000;
409 ZONE MULTIPLIER=12;
410 END ZONE;
411 FOR ZONE 7? **TOP FLOOR
412 SUPPLY AIR VOLUME= 358;
413 EXHAUST AIR VOLUME= 148;
414 REHEAT CAPACITY=1000000;
415 ZONE MULTIPLIER=12;
416 END ZONE;
417 OTHER SYSTEM PARAMETERS?
418 HUMIDISTAT LOCATION=6;
419 MIXED AIR CONTROL=FIXED PERCENT;
420 COLD DECK TEMPERATURE=60.0;
421 COLD DECK THROTTLING RANGE=1.0;
422 SUPPLY FAN PRESSURE= 3.0;
423 EXHAUST FAN PRESSURE=0.5;
424 RETURN FAN PRESSURE= 1.25;
425 SUPPLY FAN EFFICIENCY= 0.75;
426 EXHAUST FAN EFFICIENCY=0.50;
427 RETURN FAN EFFICIENCY= 0.70;
428 HUMIDIFIER TYPE=STEAM;
429 HUMIDISTAT SET POINT=30;
430 PREHEAT COIL LOCATION=MIXED AIR DUCT;
431 PREHEAT COIL CAPACITY=1000000;
432 PREHEAT ENERGY SUPPLY=STEAM;
433 WEEKDAY MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
434 WEEKEND MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
435 VAV MINIMUM AIR FRACTION=1.00;
436 VAV VOLUME CONTROL TYPE=INLET VANES;
437 END OTHER SYSTEM PARAMETERS;
438 EQUIPMENT SCHEDULES?
439 SYSTEM OPERATION=INTERMITTENT;
440 WEEKDAY SYSTEM SCHEDULE=(7 TO 18 - 1, 18 TO 7 - 1);
441 WEEKEND SYSTEM SCHEDULE=(0 TO 24 - 1);
442 END EQUIPMENT SCHEDULES;
443 COOLING COIL DESIGN PARAMETERS?
444 AIR VOLUME FLOW RATE=11448;
445 WATER VOLUME FLOW RATE=10.162;
446 ENTERING AIR DRY BULB TEMPERATURE=85;
447 ENTERING AIR WET BULB TEMPERATURE=64;
448 ENTERING WATER TEMPERATURE=42;
449 LEAVING AIR DRY BULB TEMPERATURE=54;
450 LEAVING AIR WET BULB TEMPERATURE=53.3;
451 LEAVING WATER TEMPERATURE=54;
452 BAROMETRIC PRESSURE=405;
453 AIR FACE VELOCITY=360;
454 WATER VELOCITY=275;
455 END COOLING COIL DESIGN PARAMETERS;
456 END SYSTEM;
457 VARIABLE VOLUME SYSTEM 5 #SOUTH EXTERIOR 5# SERVING ZONE 6,7;
458 FOR ZONE 6?
459 SUPPLY AIR VOLUME= 596;
460 EXHAUST AIR VOLUME= 246;
461 REHEAT CAPACITY=1000000;

```

```

462     ZONE MULTIPLIER=15;
463     END ZONE;
464     FOR ZONE 7?
465         SUPPLY AIR VOLUME= 358;
466         EXHAUST AIR VOLUME= 148;
467         REHEAT CAPACITY=1000000;
468         ZONE MULTIPLIER=15;
469         END ZONE;
470     OTHER SYSTEM PARAMETERS?
471         HUMIDISTAT LOCATION=6;
472         MIXED AIR CONTROL=FIXED PERCENT;
473         COLD DECK TEMPERATURE=60.0;
474         COLD DECK THROTTLING RANGE=1.0;
475         SUPPLY FAN PRESSURE= 3.0;
476         EXHAUST FAN PRESSURE=0.5;
477         RETURN FAN PRESSURE= 1.25;
478         SUPPLY FAN EFFICIENCY= 0.75;
479         EXHAUST FAN EFFICIENCY=0.50;
480         RETURN FAN EFFICIENCY= 0.70;
481         HUMIDIFIER TYPE=STEAM;
482         HUMIDISTAT SET POINT=30;
483         PREHEAT COIL LOCATION=MIXED AIR DUCT;
484         PREHEAT COIL CAPACITY=1000000;
485         PREHEAT ENERGY SUPPLY=STEAM;
486         WEEKDAY MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
487         WEEKEND MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
488         VAV MINIMUM AIR FRACTION=1.00;
489         VAV VOLUME CONTROL TYPE=INLET VANES;
490     END OTHER SYSTEM PARAMETERS;
491     EQUIPMENT SCHEDULES?
492         SYSTEM OPERATION=INTERMITTENT;
493         WEEKDAY SYSTEM SCHEDULE=(7 TO 18 - 1, 18 TO 7 - 1);
494         WEEKEND SYSTEM SCHEDULE=(0 TO 24 - 1);
495     END EQUIPMENT SCHEDULES;
496     COOLING COIL DESIGN PARAMETERS?
497         AIR VOLUME FLOW RATE=14310;
498         WATER VOLUME FLOW RATE=12.703;
499         ENTERING AIR DRY BULB TEMPERATURE=85;
500         ENTERING AIR WET BULB TEMPERATURE=64;
501         ENTERING WATER TEMPERATURE=42;
502         LEAVING AIR DRY BULB TEMPERATURE=54;
503         LEAVING AIR WET BULB TEMPERATURE=53.3;
504         LEAVING WATER TEMPERATURE=54;
505         BAROMETRIC PRESSURE=405;
506         AIR FACE VELOCITY=360;
507         WATER VELOCITY=275;
508     END COOLING COIL DESIGN PARAMETERS;
509     END SYSTEM;
510     VARIABLE VOLUME SYSTEM 6 #NORTH EXTERIOR 64 SERVING ZONE 8,9;
511     FOR ZONE 8?
512         SUPPLY AIR VOLUME= 432;
513         EXHAUST AIR VOLUME= 189;
514         REHEAT CAPACITY=1000000;
515         ZONE MULTIPLIER=16;
516         END ZONE;
517     FOR ZONE 9?
518         SUPPLY AIR VOLUME= 278;
519         EXHAUST AIR VOLUME= 122;
520         REHEAT CAPACITY=1000000;
521         ZONE MULTIPLIER=15;
522         END ZONE;
523     OTHER SYSTEM PARAMETERS?
524         HUMIDISTAT LOCATION=8;
525         MIXED AIR CONTROL=FIXED PERCENT;
526         COLD DECK TEMPERATURE=60.0;
527         COLD DECK THROTTLING RANGE=1.0;

```

```

528     SUPPLY FAN PRESSURE= 3.0;
529     EXHAUST FAN PRESSURE=0.5;
530     RETURN FAN PRESSURE= 1.25;
531     SUPPLY FAN EFFICIENCY= 0.75;
532     EXHAUST FAN EFFICIENCY=0.50;
533     RETURN FAN EFFICIENCY= 0.70;
534     HUMIDIFIER TYPE=STEAM;
535     HUMIDISTAT SET POINT=30;
536     PREHEAT COIL LOCATION=MIXED AIR DUCT;
537     PREHEAT COIL CAPACITY=1000000;
538     PREHEAT ENERGY SUPPLY=STEAM;
539     WEEKDAY MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
540     WEEKEND MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
541     VAV MINIMUM AIR FRACTION=1.00;
542     VAV VOLUME CONTROL TYPE=INLET VANES;
543     END OTHER SYSTEM PARAMETERS;
544     EQUIPMENT SCHEDULES?
545     SYSTEM OPERATION=INTERMITTENT;
546     WEEKDAY SYSTEM SCHEDULE=(7 TO 18 - 1, 18 TO 7 - 1);
547     WEEKEND SYSTEM SCHEDULE=(0 TO 24 - 1);
548     END EQUIPMENT SCHEDULES;
549     COOLING COIL DESIGN PARAMETERS?
550     AIR VOLUME FLOW RATE=11082;
551     WATER VOLUME FLOW RATE= 9.837;
552     ENTERING AIR DRY BULB TEMPERATURE=85;
553     ENTERING AIR WET BULB TEMPERATURE=64;
554     ENTERING WATER TEMPERATURE=42;
555     LEAVING AIR DRY BULB TEMPERATURE=54;
556     LEAVING AIR WET BULB TEMPERATURE=53.3;
557     LEAVING WATER TEMPERATURE=54;
558     BAROMETRIC PRESSURE=405;
559     AIR FACE VELOCITY=360;
560     WATER VELOCITY=275;
561     END COOLING COIL DESIGN PARAMETERS;
562     END SYSTEM;
563     VARIABLE VOLUME SYSTEM 8 NORTH EXTERIOR 8 SERVING ZONE 8,9;
564     FOR ZONE 8?
565     SUPPLY AIR VOLUME= 432;
566     EXHAUST AIR VOLUME= 189;
567     REHEAT CAPACITY=1000000;
568     ZONE MULTIPLIER=13;
569     END ZONE;
570     FOR ZONE 9?
571     SUPPLY AIR VOLUME= 278;
572     EXHAUST AIR VOLUME= 122;
573     REHEAT CAPACITY=1000000;
574     ZONE MULTIPLIER=12;
575     END ZONE;
576     OTHER SYSTEM PARAMETERS?
577     HUMIDISTAT LOCATION=0;
578     MIXED AIR CONTROL=FIXED PERCENT;
579     COLD DECK TEMPERATURE=60.0;
580     COLD DECK THROTTLING RANGE=1.0;
581     SUPPLY FAN PRESSURE= 3.0;
582     EXHAUST FAN PRESSURE=0.5;
583     RETURN FAN PRESSURE= 1.25;
584     SUPPLY FAN EFFICIENCY= 0.75;
585     EXHAUST FAN EFFICIENCY=0.50;
586     RETURN FAN EFFICIENCY= 0.70;
587     HUMIDIFIER TYPE=STEAM;
588     HUMIDISTAT SET POINT=30;
589     PREHEAT COIL LOCATION=MIXED AIR DUCT;
590     PREHEAT COIL CAPACITY=1000000;
591     PREHEAT ENERGY SUPPLY=STEAM;
592     WEEKDAY MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);
593     WEEKEND MINIMUM OUTSIDE AIR SCHEDULE=(0 TO 24 - 0.0);

```

```

594     VAV MINIMUM AIR FRACTION=1.00;
595     VAV VOLUME CONTROL TYPE=INLET VANES;
596     END OTHER SYSTEM PARAMETERS;
597     EQUIPMENT SCHEDULES?
598     SYSTEM OPERATION=INTERMITTENT;
599     WEEKDAY SYSTEM SCHEDULE=(7 TO 18 - 1, 18 TO 7 - 1);
600     WEEKEND SYSTEM SCHEDULE=(0 TO 24 - 1);
601     END EQUIPMENT SCHEDULES;
602     COOLING COIL DESIGN PARAMETERS?
603     AIR VOLUME FLOW RATE=10290;
604     WATER VOLUME FLOW RATE= 9.134;
605     ENTERING AIR DRY BULB TEMPERATURE=85;
606     ENTERING AIR WET BULB TEMPERATURE=64;
607     ENTERING WATER TEMPERATURE=42;
608     LEAVING AIR DRY BULB TEMPERATURE=54;
609     LEAVING AIR WET BULB TEMPERATURE=53.3;
610     LEAVING WATER TEMPERATURE=54;
611     BAROMETRIC PRESSURE=405;
612     AIR FACE VELOCITY=360;
613     WATER VELOCITY=275;
614     END COOLING COIL DESIGN PARAMETERS;
615     END SYSTEM;
616     END FAN SYSTEM DESCRIPTION;
617     BEGIN CENTRAL PLANT DESCRIPTION;
618     PLANT 1 #PLANT 1# SERVING SYSTEMS 3,5,6,8,20;
619     EQUIPMENT SELECTION?
620     1 BOILER OF SIZE 5200.0;
621     1 CHILLER OF SIZE 6800.0;
622     END EQUIPMENT SELECTION;
623     END PLANT;
624     END CENTRAL PLANT DESCRIPTION;
625     END INPUT;

```


U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET (See <i>Instructions</i>)		1. PUBLICATION OR REPORT NO. NBSIR 81-2277	2. Performing Organ. Report No.	3. Publication Date June 1981
4. TITLE AND SUBTITLE Control Strategies for Energy Conservation, A Case Study of the Materials Building, National Bureau of Standards				
5. AUTHOR(S) James Y. Kao and E. Thomas Pierce				
6. PERFORMING ORGANIZATION (If joint or other than NBS, see instructions) NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234			7. Contract/Grant No.	8. Type of Report & Period Covered Final
9. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Plant Division Office of the Director of Administrative and Information Systems National Bureau of Standards Washington, D.C. 20234				
10. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.				
11. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here) The BLAST-2 Computer Program is used to investigate various heating, ventilating and air conditioning control strategies and their combinations to reduce the energy consumption of a laboratory building located at the National Bureau of Standards, Gaithersburg site. The techniques of modeling the building load and air system performance are explained. The results are presented and discussed. Control strategies investigated include dry-bulb and enthalpy economizer cycles, resetting supply air temperatures by outside temperature and zone demand, shut-down of fan systems selectively, and converting interior systems to VAV systems. By combining the various control strategies, eight percent, twenty-nine percent and eight percent of heating, cooling and fan energy respectively may be saved.				
12. KEY WORDS (Six to twelve entries; alphabetical order; capitalize only proper names; and separate key words by semicolons) Building energy analysis, computer modeling, controls, control strategies, energy conservation for non-residential buildings, load calculations.				
13. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. <input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161			14. NO. OF PRINTED PAGES 115 15. Price \$11.00	



