NIST TIME AND FREQUENCY BULLETIN NISTIR 6630-02

NO. 554 FEBRUARY 2004

1.	GENERAL BACKGROUND INFORMATION	2
	TIME SCALE INFORMATION	
3.	PHASE DEVIATIONS FOR WWVB AND LORAN-C	. 4
	BROADCAST OUTAGES OVER FIVE MINUTES AND WWVB PHASE PERTURBATIONS	Ę
5.	NOTES ON NIST TIME SCALES AND PRIMARY STANDARDS	5
6.	BIBLIOGRAPHY	Ę
7.	SPECIAL ANNOUNCEMENTS	7

Eyvon M. Petty, Editor

This bulletin is published monthly. Address correspondence to:

Time and Frequency Division National Institute of Standards and Technology 325 Broadway Boulder, CO 8O3O5-3328 (3O3) 497-3295

Email: pettye@boulder.nist.gov



U.S. DEPARTMENT OF COMMERCE, DONALD L. EVANS, Secretary TECHNOLOGY ADMINISTRATION, Mr. Phillip J. Bond, Under Secretary of Commerce for Technology NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, Dr. Arden L. Bement, Jr., Director

1. GENERAL BACKGROUND INFORMATION

ACRONYMS AND ABBREVIATIONS USED IN THIS BULLETIN

ACTS - Automated Computer Time Service

BIPM - Bureau International des Poids et Mesures

Cs - Cesium standard

GPS - Global Positioning System

IERS - International Earth Rotation Service

LORAN - Long Range Navigation

MC - Master Clock
MJD - Modified Julian Date

NVLAP - National Voluntary Laboratory Accreditation Program
NIST - National Institute of Standards and Technology

- National Oceanic and Atmospheric Administration NOAA - nanosecond ns SI - International System of Units microsecond μs - Atomic Time TΑ ms - millisecond TAI - International Atomic Time - second USNO - United States Naval Observatory min - minute

UTC - Coordinated Universal Time

2. TIME SCALE INFORMATION

The values listed below are based on data from the IERS, the USNO, and NIST. The UTC(USNO,MC) - UTC(NIST) values are averaged measurements from all available common-view GPS satellites (see bibliography on page 5). **UTC - UTC(NIST)** data are on page 3.

0000 HOURS COORDINATED UNIVERSAL TIME								
JAN 2004	MJD	UT1-UTC(NIST) (±5 ms)	UTC(USNO,MC) - UTC(NIST) (±20 ns)					
1	53005	-390 ms	-19 ns					
8	53012	-390 ms	-21 ns					
15	53019	-396 ms	-24 ns					
22	53026	-400 ms	-22 ns					
29	53033	-405 ms	-21 ns					

The master clock pulses used by the WWV, WWVH, and WWVB time-code transmissions are referenced to the UTC(NIST) time scale. Occasionally, 1 s is added to the UTC time scale. This second is called a leap second. Its purpose is to keep the UTC time scale within ± 0.9 s of the UT1 astronomical time scale, which changes slightly due to variations in the Earth's rotation.

NOTE: No leap second will be added at the end of June 2004.

Positive leap seconds, beginning at 23 h 59 min 60 s UTC and ending at 0 h 0 min 0 s UTC, were inserted in the UTC timescale on 30 June 1972, 1981-1983, 1985, 1992, 1993, 1994, and 1997, and on 31 December 1972-1979, 1987, 1989, 1990,1995, and 1998.

The use of leap seconds ensures that UT1 - UTC will always be held within ± 0.9 s. The current value of UT1 - UTC is called the DUT1 correction. DUT1 corrections are broadcast by WWV, WWVH, WWVB, and ACTS and are printed below. These corrections may be added to received UTC time signals in order to obtain UT1.

	+0.1 s beginning 0000 UTC 19 October 2000
	+0.0 s beginning 0000 UTC 01 March 2001
DUT1 = UT1 - UTC =	-0.1 s beginning 0000 UTC 04 October 2001
	-0.2 s beginning 0000 UTC 14 February 2002
	-0.3 s beginning 0000 UTC 24 October 2002
	-0.4 s beginning 0000 UTC 03 April 2003

The difference between UTC(NIST) from UTC has been within +/–100 ns since July 6, 1994. The table below shows values of UTC - UTC(NIST) as supplied by the BIPM in their Circular T publication for the most recent 310-day period in which data are available. Data are given at ten-day intervals. Five-day interval data are available in Circular T.

0000 Hours Coordinated Universal Time

DATE	MJD	UTC-UTC(NIST) ns
Dec. 26, 2003	52999	-4.0
Dec. 16, 2003	52989	-2.8
Dec. 6, 2003	52979	-0.2
Nov. 26, 2003	52969	-1.1
Nov. 16, 2003	52959	2.0
Nov. 6, 2003	52949	2.1
Oct. 27, 2003	52939	1.8
Oct. 17, 2003	52929	1.2
Oct. 7, 2003	52919	3.9
Sep. 27, 2003	52909	7.9
Sep. 17, 2003	52899	7.5
Sep. 7, 2003	52889	7.6
Aug. 28, 2003	52879	7.7
Aug. 18, 2003	52869	8.0
Aug. 8, 2003	52859	10.2
Jul. 29, 2003	52849	10.7
Jul. 19, 2003	52839	12.7
Jul. 9, 2003	52829	12.6
Jun. 29, 2003	52819	9.2
Jun. 19, 2003	52809	7.5
Jun. 9, 2003	52799	3.8
May 30, 2003	52789	0.6
May 20, 2003	52779	4.0
May 10, 2003	52769	10.4
Apr. 30, 2003	52759	8.9
Apr. 20, 2003	52749	10.7
Apr. 10, 2003	52739	10.9
Mar. 31, 2003	52729	11
Mar. 21, 2003	52719	12
Mar. 11, 2003	52709	11
Mar. 1, 2003	52699	7

3. PHASE DEVIATIONS FOR WWVB AND LORAN-C

WWVB - The values shown for WWVB are the time differences between the time markers of the UTC(NIST) time scale and the first positive-going zero voltage crossover measured at the transmitting antenna. The uncertainty of the individual measurements is $\pm 0.5~\mu s$. The values listed are for 1300 UTC.

LORAN-C - The values shown for Loran-C represent the daily accumulated phase shift (in ns). The phase shift is measured by comparing the output of a Loran receiver to the UTC(NIST) time scale for a period of 24 h. If data were not recorded on a particular day, the symbol (-) is printed. The stations monitored are Baudette, ND (8970-Y) and Fallon, NV (9940). The monitoring is done from the NIST laboratories in Boulder, Colorado.

Note: The values shown for Loran-C are in nanoseconds.

		UTC(NIST)-WWVB (60 kHz)	3 (60 kHz) UTC(NIST) - LORAN PHA	
DATE	MJD	ANTENNA PHASE (µs)	LORAN-C (BAUDETTE) (8970)	LORAN-C (FALLON) (9940)
01/01/04	53005	5.52	-3	-162
01/02/04	53006	5.52	-74	+24
01/03/04	53007	5.51	-6	+29
01/04/04	53008	5.51		
01/05/04	53009	5.50	+87	-202
01/06/04	53010	5.50	+113	-412
01/07/04	53011	5.50	-51	+253
01/08/04	53012	5.51	-99	+65
01/09/04	53013	5.50	+169	-269
01/10/04	53014	5.51	+38	+135
01/11/04	53015	5.51	+50	+66
01/02/04	53016	5.51	-36	-173
01/13/04	53017	5.51	+184	+347
01/14/04	53018	5.51	+2	-386
01/15/04	53019	5.50	+78	+212
01/16/04	53020	5.51	-198	-41
01/17/04	53021	5.51	-92	+382
01/18/04	53022	5.51	+89	+119
01/19/04	53023	5.51	-13	+157
01/20/04	53024	5.51	-28	+54
01/21/04	53025	5.51	-101	+419
01/22/04	53026	5.51	+284	-264
01/23/04	53027	5.52	-135	-267
01/24/04	53028	5.50	+221	-244
01/25/04	53029	5.50	-47	-5
01/26/04	53030	5.50	-124	-365
01/27/04	53031	5.50	-136	+150
01/28/04	53032	5.50	-74	-104
01/29/04	53033	5.50	-3	-319
01/30/04	53034	5.50	+151	-341
01/31/04	53035	5.50	-29	+390

4. BROADCAST OUTAGES OVER FIVE MINUTES AND WWVB PHASE PERTURBATIONS

	OUTAGES OF 5 MINUTES OR MORE							SE PERTU 2 ms		IS
Station	JAN 2004	MJD	Began UTC	Ended UTC	Freq.		JAN 2004	MJD	Began UTC	End UTC
WWVB	01-02-04	53006	1018	1113	60 kHz					
WWVB	01-01-04	53005	1232	1328	60 MHz					
WWV										

5. NOTES ON NIST TIME SCALES AND PRIMARY STANDARDS

Primary frequency standards developed and operated by NIST are used to provide accuracy (rate) input to the BIPM. NIST-7 was the U.S. primary standard from 1994 to 1999, when it was replaced by NIST-F1, a cold-atom cesium fountain frequency standard. The uncertainty of NIST-F1 is currently about 1 part in 10¹⁵.

The AT1 scale is run in real-time by use of data from an ensemble of cesium standards and hydrogen masers. It is a free-running scale whose frequency is maintained as nearly constant as possible by choosing the optimum weight for each clock that contributes to the computation.

UTC(NIST) is generated as an offset from our real-time scale AT1. It is steered in frequency towards UTC by use of data published by the BIPM in its Circular T. Changes in the steering frequency will be made, if necessary, at 0000 UTC on the first day of the month, and occasionally at mid-month. A change in frequency is limited to no more than ± 2 ns/day. The frequency of UTC(NIST) is kept as stable as possible at other times.

UTC is generated at the BIPM using a post-processed time-scale algorithm and is not available in real-time. The parameters that we use to generate UTC(NIST) in real-time are therefore based on an extrapolation of UTC from the most recent available data.

6. BIBLIOGRAPHY

Allan, D.W.; Hellwig, H.; and Glaze, D.J., "An accuracy algorithm for an atomic time scale," Metrologia, Vol.11, No.3, pp.133-138 (1975).

Allan, D.W.; Davis, D.D.; Weiss, M.A.; Clements, A.; Guinot, B.; Granveaud, M.; Dorenwendt, K.; Fischer, B.; Hetzel, P.; Aoki, S.; Fujimoto, M.; Charron, L.; and Ashby, N., "Accuracy of International Time and Frequency Comparisons Via Global Positioning System Satellites in Common-view," IEEE Transactions on Instrumentation and Measurement, Vol. IM-34, pp.118-125, 1985.

Jefferts, S.R.; Shirley, J.; Parker, T.E.; Heavner, T.P.; Meekhof, D.M.; Nelson, C., Levi, F.; Costanza, G.; De Marchi, A.; Drullinger, R.; Hollberg, L.; Lee, W.D.; and Walls, F.L., "Accuracy evaluation of NIST-F1," Metrologia, Vol. 39, pp. 321-336, (2002).

Lewandowski, W. and Thomas, C.; "GPS Time transfer," Proceedings of the IEEE, Vol. 79, pp. 991-1000, 1991.

Shirley, J.H.; Lee, W.D.; Drullinger, R.E.; "Accuracy evaluation of the primary frequency standard NIST-7," Metrologia, Vol. 38, pp. 427-458, (2001).

Weiss, M.A.; Allan, D.W.; "An NBS Calibration Procedure for Providing Time and Frequency at a Remote Site by Weighting and Smoothing of GPS Common View Data," IEEE Transactions on Instrumentation and Measurement, Vol. IM-36, pp. 572-578, 1987.

Table 7.1 lists parameters that are used to define UTC(NIST) with respect to our real-time scale AT1. To find the value of UTC(NIST) - AT1 at any time T (expressed as a Modified Julian Day, including a fraction if needed), the appropriate equation to use is the one for which the desired T is greater than or equal to the entry in the T_0 column and less than the entry in the last column. The values of $x_{\rm ls}$, x, and y for that month are then used in the equation below to find the desired value. The parameters x and y represent the offset in time and in frequency, respectively, between UTC(NIST) and AT1; the parameter $x_{\rm ls}$ is the number of leap seconds applied to both UTC(NIST) and UTC as specified by the IERS. Leap seconds are not applied to AT1.

Table 7.1 UTC(NIST) - AT1 = $x_{ls} + x + y^*(T - T_0)$							
Month	X _{Is} (S)	x (ns)	y (ns/d)	T₀ (MJD)	Valid until 0000 on: (MJD)		
Feb 04	-32	259963.7	-39.55*	53036	53065*		
Jan 04	-32	-259410.0	-39.55	53022	53036		
Jan 04	-32	-258738.5	-39.5	53005	53022†		
Dec 03	-32	-258343.5	-39.5	52995	53005		
Dec 03	-32	-257516.1	-39.4	52974	52995†		
Nov 03	-32	-256925.1	-39.4	52959	52974		
Nov 03	-32	-256334.85	-39.35	52944	52959†		
Oct 03	-32	-255783.95	-39.35	52930	52944		
Oct 03	-32	-255112.45	-39.5	52913	52930†		
Sep 03	-32	-253927.745	-39.5	52883	52913		
Aug 03	-32	-252702.95	-39.5	52852	52883		
Jul 03	-32	-252228.95	-39.5	52840	52852		
Jul 03	-32	-251473.7	-39.75	52821	52840†		
Jun 03	-32	-251076.2	-39.75	52811	52821		
Jun 03	-32	-250276.2	-40.0	52791	52811†		
May 03	-32	-249652.2	-39.0	52775	52791		
May 03	-32	-249052.2	-40.0	52760	52775†		
Apr 03	-32	-248495.7	-39.75	52746	52760		
Apr 03	-32	-247855.7	-40.0	52730	52746†		
Mar 03	-32	-247415.7	-40.0	52719	52730		
Mar 03	-32	-246607.7	-40.4	52699	52719†		
Feb 03	-32	-246284.9	-40.35	52691	52699		
Feb 03	-32	-245474.9	-40.5	52671	52691†		
Jan 03	-32	-244906.5	-40.6	52657	52671		
Jan 03	-32	-244218.0	-40.5	52640	52657†		

[†] Rate change in mid-month

^{††} Rate change one day early

^{*}Provisional value

7. SPECIAL ANNOUNCEMENTS

NOTICE TO DISCONTINUE INVOLVEMENT WITH GOES TIME CODE SERVICE

NIST has announced that it will discontinue its involvement with the time code broadcast from the GOES WEST and GOES EAST satellites operated by the National Oceanic and Atmosphere Administration (NOAA) on January 1, 2005. This decision has been jointly made by NIST and NOAA in response to the fact that nearly all users requiring time more accurate than 1 ms now use the Global Positioning System (GPS), and as a result, commercial sources for GOES timing receivers no longer exist.

NOAA is expected to continue to provide a GOES time code indefinitely after January 1, 2005, and existing receivers should be able to continue to receive and decode the time signal. However, the time code will no longer be controlled and checked by NIST, and the received time is expected to be less accurate when NIST discontinues its involvement. The GOES satellites currently broadcast continuously updated position information in addition to the time, so that GOES receivers can automatically correct for path delay changes caused by satellite motion. This allows the current system to have a time uncertainty of less than 100 ms. NOAA is expected to continuously broadcast a fixed position from the satellites, which could increase the time uncertainty to 1 ms or more.

The GOES time broadcasts began in 1974 and have served many applications and thousands of users. NIST will continue to control and monitor the time code through January 1, 2005 to allow users who require a high accuracy signal sufficient time to replace their existing receivers. If you have additional questions, please contact Michael Lombardi, 303-497-3212, or email lombardi@boulder.nist.gov.

IMPORTANT NOTICE!

Effective January 1, 2004, NIST will discontinue sending the bulletin by mail.

The Time and Frequency Bulletin data are now online at

www.boulder.nist.gov/timefreq/pubs/bulletin/timescaleindex.htm