

NISTIR 89-3908

INTERLABORATORY COMPARISON OF TWO TYPES OF LINE-SOURCE THERMAL-CONDUCTIVITY APPARATUS MEASURING FIVE INSULATING MATERIALS

Jerome G. Hust
David R. Smith

National Institute of Standards and Technology
(formerly National Bureau of Standards)
U.S. Department of Commerce
Boulder, Colorado 80303-3328

January 1989

NISTIR 89-3908

INTERLABORATORY COMPARISON OF TWO TYPES OF LINE-SOURCE THERMAL-CONDUCTIVITY APPARATUS MEASURING FIVE INSULATING MATERIALS

Jerome G. Hust
David R. Smith

Chemical Engineering Science Division
Center for Chemical Engineering
National Engineering Laboratory
National Institute of Standards and Technology
Boulder, Colorado 80303-3328

January 1989

Sponsored, in part, by
U.S. Department of Energy
Oak Ridge National Laboratory
Oak Ridge, Tennessee 37830



U.S. DEPARTMENT OF COMMERCE, C. William Verity, Secretary

Ernest Ambler, Acting Under Secretary for Technology

NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, Raymond G. Kammer, Acting Director

CONTENTS

	Page
LIST OF TABLES.....	iv
LIST OF FIGURES.....	v
ABSTRACT.....	1
1. Introduction.....	2
2. Scope.....	2
3. Experimental Data.....	3
4. Data Analysis.....	3
5. Summary and Conclusions.....	4
6. References.....	4

LIST OF TABLES

Page

Table 1.	Dimensions and Densities of Specimens Used in the Interlaboratory Comparison.....	5
Table 2.	Laboratory Codes and Features of Apparatus.....	5
Table 3.	Thermal Conductivity of the Fibrous Glass Specimens..	6
Table 4.	Thermal Conductivity of the Expanded Polystyrene Specimens.....	7
Table 5.	Thermal Conductivity of the Extruded Polystyrene Specimens.....	8
Table 6.	Thermal Conductivity of the Ottawa Silica Sand Specimens.....	9
Table 7.	Thermal Conductivity for the Paraffin Wax Specimens..	10
Table 8.	Mean Thermal Conductivity and Percent Standard Deviation from the Mean for Each Type of Apparatus and Each Material.....	11

LIST OF FIGURES

Page

- Figure 1.** Interlaboratory comparison of thermal conductivity of fibrous glass insulation with a density of 45 kg/m³. The solid line indicates the trend of data from the literature on similar material..... 12
- Figure 2.** Interlaboratory comparison of thermal conductivity of expanded polystyrene insulation with a density of 21 kg/m³. The solid line indicates the trend of data from the literature on similar material..... 13
- Figure 3.** Interlaboratory comparison of thermal conductivity of extruded polystyrene insulation with a density of 32 kg/m³. The solid line indicates the trend of data from the literature on similar material..... 14
- Figure 4.** Interlaboratory comparison of thermal conductivity of paraffin wax with a density of 850 kg/m³. The solid line indicates the trend of data from the literature on similar material..... 15
- Figure 5.** Interlaboratory comparison of thermal conductivity of Ottawa silica sand with a density of 1640 kg/m³. Downward-pointing triangles represent data for sand containing 3.5 percent by weight of moisture; all other symbols are for dry sand..... 16
- Figure 6.** Interlaboratory comparison of thermal conductivity of dry Ottawa silica sand with a density of 1640 kg/m³. The solid line indicates the trend of data from the literature on similar material..... 17
- Figure 7.** Interlaboratory comparison of thermal conductivity of Ottawa silica sand with a density of 1640 kg/m³ and containing 3.5 percent by weight of moisture..... 18

Interlaboratory Comparison of Two Types of Line-Source Thermal-Conductivity Apparatus Measuring Five Insulating Materials

Jerome G. Hust
David R. Smith

Center for Chemical Engineering
National Engineering Laboratory
National Institute of Standards and Technology
Boulder, CO 80303-3328

We compare measurements of apparent thermal conductivity performed by five different laboratories. Subcommittee C-16.30 (Thermal Measurements) of the American Society for Testing and Materials (ASTM) sponsored this interlaboratory comparison. Two different types of line-source apparatus were used: the needle and the hot wire. The five laboratories measured thermal conductivity of Ottawa silica sand, paraffin wax, and three insulating materials (fibrous glass, expanded polystyrene, and extruded polystyrene). Comparison of the test results illustrates the interlaboratory reproducibility. The standard deviation of the thermal conductivity results for the needle apparatus is 26 percent, whereas the standard deviation of the results for the hot-wire apparatus is 17 percent. For the insulating materials the mean values of the test results from the needle apparatus lie about 35 percent below those for the hot-wire apparatus. For the more dense materials, Ottawa sand and paraffin wax, the difference is about 15 percent. We do not at present know which apparatus is the more accurate. Further work needs to be done to establish and/or improve the reliability of each of these methods for use in a laboratory environment such as for quality control or research.

Key words: ambient temperature; apparent thermal conductivity; expanded polystyrene; extruded polystyrene; fibrous glass; hot wire; interlaboratory comparison; line-source apparatus; needle probe; Ottawa silica sand; paraffin wax; thermal insulation.

This work was funded, in part, by DOE/ORNL under contract ORNL/IA-21428.

1. Introduction

During the last two decades equipment and techniques for measuring thermal resistance of thermal insulations have been appreciably improved, particularly for measurements at ambient temperature. There is considerable interest in using apparatus that measure thermal conductivity more rapidly than can steady-state apparatus such as the guarded hot plate and heat flow meter. Rapid measurements are especially important for production-line analysis. Transient measurement techniques, such as the needle probe and the hot wire, are attractive from the standpoint of speed.

However, little is known about the precision and bias of these transient methods. As a consequence, a committee was formed under the auspices of Subcommittee C-16.30 of the American Society of Testing and Materials to perform an interlaboratory comparison (ILC) using line-source apparatus at ambient temperatures. The ILC was initiated in 1985 under the direction of Mark Bomberg of the National Research Council (NRC) of Canada. He prepared most of the specimens for distribution to the participants. However, due to a change in his duties, the direction of the task was transferred to the first author, at the Boulder, Colorado Laboratory of the National Institute of Standards and Technology (NIST), formerly the National Bureau of Standards (NBS). The available specimens were transferred from NRC to NIST-Boulder, which characterized and distributed them to the participants.

2. Scope

This report presents and analyzes thermal conductivity data obtained in the ILC for five different materials. Prior to shipping the specimens to the participants, the densities were measured at NIST-B. The specimens are characterized in table 1. The densities of the specimens of paraffin wax and Ottawa silica sand could not be determined at NIST because these specimens were prepared in place by the participants. In addition, only two specimens of sand, and four of paraffin wax, were distributed. These specimens were sent from one participant to another for testing.

The names of the six testing laboratories participating in the ILC are given here to identify the sources of the data presented. Listing the names of the five commercial firms does not in any way imply endorsement of the companies or of their products by the National Institute of Standards and Technology or by the U.S. government. The participants were:

Dynatech R/D Company (now Holometrix, Inc.), Cambridge, Mass.
Geotherm Inc., Newmarket, Ontario, CANADA
Manville Corporation, Denver, Colo.
National Refractories and Minerals, Pleasanton, Cal.

Ontario Hydro, Toronto, Ontario, CANADA
U.S. National Institute of Standards and Technology (NIST),
(formerly National Bureau of Standards), Boulder, Colo.

Random numbers and symbols were assigned to the data sets from these laboratories for use throughout this report. These laboratory codes are given in table 2. Also given in table 2 are some of the salient features, where known, of the apparatus used by each participant. Some laboratories did not report the lengths or diameters of their hot wires or needle probes.

3. Experimental Data

We compiled the experimental data for thermal conductivity of the different materials into tabular files for analysis by computer. Tables 3 through 7 contain the raw data as supplied by the five participants in the ILC and converted by the authors to SI units.

4. Data Analysis

Thermal conductivity test results for each of the five materials are shown in figures 1 through 7. Due to the large scatter in the data, no functional dependence of thermal conductivity on temperature is deducible. Table 8 lists the mean value of thermal conductivity and the standard deviation from the mean, for each material and for both types of apparatus.

Thermal conductivity test results on the insulating materials (fibrous glass; expanded and extruded polystyrene) all exhibit the same trend (figs. 1-3). For these materials the mean values from the needle apparatus all lie about 35% below those of the hot-wire apparatus. For the paraffin wax and Ottawa sand the results for the needle device are also appreciably different from those of the hot-wire apparatus (figs. 4-6).

Each solid line in figures 1-4 and figure 6 is an estimate of the thermal conductivity of the corresponding material, obtained from a limited examination of literature data for similar materials. Uncertainties in moisture content and density for the literature material, and for each material as measured by the participants, preclude matching literature data exactly with the data for the particular specimens used here. However, the slopes of the solid lines suggest trends of thermal conductivity with temperature that are helpful in comparing the results. Different mean values of conductivity for each laboratory may be due to uncorrected biases, but if the biases are insensitive to temperature over the range studied, correct slopes might still be obtained. Even these slopes cannot be deduced here due to the scatter in the data collection taken as a whole. The slope of conductivity with temperature for some individual laboratories is consistent with that suggested by the solid line.

Figure 4 shows the results for paraffin wax. Again there is a clear difference between the results from the needle probe and those from the hot-wire apparatus, with data from the needle probe generally lying 7 percent higher than those from the hot wire (Table 8).

Figure 5 shows the results for Ottawa silica sand. This composite plot contains data for both dry sand and sand containing 3.5 percent by weight of moisture (downward-pointing triangles). Figures 6 and 7 show these data separately. The moist sand shows a significantly greater apparent thermal conductivity. This is not surprising, for moisture, as a condensed phase, would be expected to contribute its thermal conductivity to that of the sand grains. Moisture would bridge across between sharp points and edges of adjoining grains, greatly reducing the inter-grain contact resistance. For a transient measurement method, represented here by both the needle and the hot wire, moisture migration would contribute heat transfer along with the mass transfer. The mean values of the test results from the needle apparatus are 14 percent lower than values obtained with the hot-wire apparatus.

5. Summary and Conclusions

With the exception of the results for paraffin wax, thermal conductivity test results measured in this ILC with the needle probe lie 14 to 35 percent lower than the results with the hot wire. This large difference in results from the two apparatus casts doubt on the accuracy of measurements performed on either apparatus. At present there are no measurements that would permit the establishment of the accuracy of either apparatus by direct comparison with results from guarded hot plates or from heat-flow meters. Furthermore, these results are considerably more scattered than those obtained from steady-state methods as recently reported [1]. Thus it is debatable whether either apparatus is suitable even for use in comparative measurements, such as might be used in quality control. It is not now clear what the principal source of the scatter is. Further work needs to be done to establish and/or improve the reliability of each of these methods for use in a laboratory environment such as quality control or research.

6. References

1. Hust, J.G. and Pelanne, C.M., "Round robins on the apparent thermal conductivity of low-density glass fiber insulations using guarded hot plate and heat flow meter apparatus", NBSIR 85-3026, U.S. National Institute of Standards and Technology, 1985.

Table 1. Dimensions and Densities of Specimens Used in the Inter-laboratory Comparison.

Mat'l	Specimen	Length (cm)	Thickness (cm)	Width (cm)	Mass (g)	Density (kg/m ³)
Fibrous glass:	Fib(1)	61.00	12.70	11.73	402.90	44.34
	Fib(4)	61.00	12.67	11.81	424.00	46.45
	Fib(5)	60.90	12.67	11.76	425.40	46.88
	Fib(6)	60.70	12.50	11.66	405.10	45.79
	Fib(7)	60.70	12.45	11.68	422.90	47.91
Expanded Poly- styrene:	Exp(1)	59.90	9.47	17.68	216.10	21.55
	Exp(4)	59.60	9.40	17.73	200.30	20.16
	Exp(5)	59.80	9.40	17.73	206.00	20.67
	Exp(6)	59.80	9.40	17.70	209.60	21.07
	Exp(7)	59.70	9.37	17.73	208.30	21.00
Extruded Poly- styrene:	Ext(1)	60.90	10.11	17.75	346.70	31.72
	Ext(4)	61.00	9.98	17.70	360.70	33.47
	Ext(5)	60.90	10.01	17.78	361.30	33.33
	Ext(6)	61.20	10.03	17.68	360.50	33.22
	Ext(7)	60.90	10.11	17.75	360.50	32.99
Paraffin:	PWX(1)					830, 890
	PWX(3)					900.
	PWX(4)					
Ottawa silica sand:	OSS(1)					1640.
	OSS(2)					1640.

Table 2. Laboratory Codes and Features of Apparatus.

Lab. No.	Apparatus Type	Active Length (cm)	Diameter (mm)	Symbols used in Figures
1	Needle	10	3.2	○
2	Wire	15	0.37	△
3	Wire	20	NR*	□
4	Needle	15	3	▽
5	Wire	NR	NR	◇

*NR = Not Reported

Table 3. Thermal Conductivity of the Fibrous Glass Specimens

Lab Code	Specimen Identifier	Test Duration (s)	Temp. Rise (K)	Mean Temp. (K)	Thermal Conductivity mW/(m.K)
1	FIB(5)	600	6.00	295.00	24.00
1	FIB(5)	600	3.00	295.00	24.00
1	FIB(5)	600	2.20	296.50	22.00
1	FIB(5)	600	8.50	295.00	22.00
2	FIB(1)	564	1.55	298.06	36.40
2	FIB(1)	564	4.66	301.12	37.00
2	FIB(1)	564	10.16	306.45	37.40
3	FIB(7)	NR	20.00	305.15	33.80
3	FIB(7)	NR	20.00	307.15	35.00
3	FIB(7)	NR	20.00	307.15	34.30
3	FIB(7)	NR	20.00	308.15	34.80
3	FIB(7)	NR	20.00	307.15	34.70
3	FIB(7)	NR	20.00	308.15	35.50
3	FIB(7)	NR	20.00	308.15	34.30
3	FIB(7)	NR	20.00	308.15	33.30
3	FIB(7)	NR	20.00	308.15	34.00
3	FIB(7)	NR	20.00	308.15	34.90
3	FIB(7)	NR	39.00	317.15	37.00
3	FIB(7)	NR	39.00	317.15	36.80
4	FIB(6)	600	2.27	300.54	23.00
4	FIB(6)	600	2.37	300.20	21.00
4	FIB(6)	600	4.89	301.58	18.00
4	FIB(6)	1200	-3.34	300.01	21.00
4	FIB(6)	1200	-3.42	299.67	21.00
4	FIB(6)	1200	6.22	300.91	28.00
5	FIB(4)	NR	NR	295.95	35.00
5	FIB(4)	NR	NR	295.95	36.20
5	FIB(4)	NR	NR	297.35	37.00

NR = Not Reported

Table 4. Thermal Conductivity of the Expanded Polystyrene Specimens.

Lab Code	Specimen Identifier	Test Duration (s)	Temp. Rise (K)	Mean Temp. (K)	Thermal Conductivity mW/(m.K)
1	EXP(5)	600	7.00	295.00	21.00
1	EXP(5)	606	3.00	295.00	20.00
1	EXP(5)	600	2.30	296.50	22.00
1	EXP(5)	600	8.70	295.00	22.00
2	EXP(1)	564	1.48	296.93	32.40
2	EXP(1)	564	5.02	299.86	33.00
2	EXP(1)	564	10.82	305.17	33.40
3	EXP(7)	NR	20.00	307.15	31.00
3	EXP(7)	NR	20.00	307.15	29.70
3	EXP(7)	NR	20.00	308.15	30.50
3	EXP(7)	NR	20.00	309.15	30.90
3	EXP(7)	NR	20.00	308.15	30.80
3	EXP(7)	NR	20.00	306.15	29.70
3	EXP(7)	NR	20.00	308.15	30.10
3	EXP(7)	NR	20.00	308.15	29.30
3	EXP(7)	NR	20.00	308.15	29.10
3	EXP(7)	NR	20.00	308.15	29.10
3	EXP(7)	NR	20.00	308.15	29.40
3	EXP(7)	NR	20.00	309.15	29.50
3	EXP(7)	NR	20.00	308.15	29.70
3	EXP(7)	NR	38.00	317.15	31.10
3	EXP(7)	NR	38.00	319.15	31.50
4	EXP(6)	600	5.91	301.45	15.00
4	EXP(6)	600	2.46	300.67	21.00
4	EXP(6)	1200	-6.66	301.07	17.00
4	EXP(6)	1200	-3.77	300.02	28.75
5	EXP(4)	NR	NR	296.05	33.58
5	EXP(4)	NR	NR	295.85	31.56
5	EXP(4)	NR	NR	295.75	32.42

NR = Not Reported

Table 5. Thermal Conductivity of the Extruded Polystyrene Specimens.

Lab Code	Specimen Identifier	Test Duration (s)	Temp. Rise (K)	Mean Temp. (K)	Thermal Conductivity mW/(m.K)
1	EXT(5)	600	7.00	295.00	19.00
1	EXT(5)	600	4.00	295.00	18.00
1	EXT(5)	600	2.30	296.50	20.00
1	EXT(5)	600	8.90	295.00	21.00
2	EXT(1)	564	1.58	297.50	29.70
2	EXT(1)	564	5.43	300.82	28.60
2	EXT(1)	564	11.41	306.07	29.00
3	EXT(7)	NR	20.00	306.15	28.40
3	EXT(7)	NR	20.00	307.15	29.20
3	EXT(7)	NR	20.00	308.15	29.50
3	EXT(7)	NR	20.00	308.15	28.10
3	EXT(7)	NR	20.00	306.15	28.00
3	EXT(7)	NR	20.00	308.15	29.70
3	EXT(7)	NR	20.00	308.15	28.60
3	EXT(7)	NR	20.00	308.15	27.50
3	EXT(7)	NR	20.00	308.15	30.10
3	EXT(7)	NR	20.00	308.15	29.30
3	EXT(7)	NR	20.00	308.15	28.00
3	EXT(7)	NR	37.50	317.15	29.90
3	EXT(7)	NR	37.50	318.15	29.90
4	EXT(6)	600	5.64	303.26	17.00
4	EXT(6)	600	2.70	300.72	19.00
4	EXT(6)	1200	-7.34	302.41	16.00
4	EXT(6)	1200	-3.74	300.20	18.00
5	EXT(4)	NR	NR	295.75	26.08
5	EXT(4)	NR	NR	295.65	27.38
5	EXT(4)	NR	NR	296.25	26.80

NR = Not Reported

Table 6. Thermal Conductivity of the Ottawa Silica Sand Specimens.

Lab Code	Specimen Identifier	Test Duration (s)	Temp. Rise (K)	Mean Temp. (K)	Thermal Conductivity mW/(m.K)
1	OSS(1)	600	7.00	295.00	287.00
1	OSS(1)	600	4.00	295.00	288.00
1	OSS(1)	600	2.50	295.00	266.00
1	OSS(1)	600	7.30	295.00	289.00
2	OSS(2)	564	0.61	300.14	365.80
2	OSS(2)	564	5.91	305.62	371.00
2	OSS(2)	564	16.84	316.15	349.40
3	OSS(2)	NR	20.00	309.15	269.00
3	OSS(2)	NR	20.00	308.15	288.00
3	OSS(2)	NR	20.00	308.15	293.00
3	OSS(2)	NR	20.00	309.15	300.00
3	OSS(2)	NR	20.00	310.15	288.00
3	OSS(2)	NR	20.00	312.15	291.00
3	OSS(2)	NR	20.00	310.15	278.00
4	OSS(1-0)	600	0.40	298.22	291.00
4	OSS(1-0)	600	6.51	314.23	294.00
4	OSS(1-0)	600	4.09	308.04	287.00
4	OSS(1-0)	1200	-1.08	297.88	232.00
4	OSS(1-0)	1200	-18.20	308.38	216.00
4	OSS(1-0)	1200	-11.46	304.35	216.00
4	OSS(1-3.5)	600	0.08	298.08	1194.00
4	OSS(1-3.5)	600	0.44	299.40	1819.00
4	OSS(1-3.5)	600	2.30	311.54	848.00
4	OSS(1-3.5)	1200	-0.42	297.91	1084.00
4	OSS(1-3.5)	1200	-2.42	298.41	1299.00
4	OSS(1-3.5)	1200	-15.43	304.97	1220.00

NR = Not Reported

Table 7. Thermal Conductivity for the Paraffin Wax Specimens.

Lab Code	Specimen Identifier	Test Duration (s)	Temp. Rise (K)	Mean Temp. (K)	Thermal Conductivity mW/(m.K)
1	PWX(1)	600	7.50	295.00	245.00
1	PWX(1)	600	4.50	295.00	242.00
1	PWX(1)	600	2.70	295.00	239.00
1	PWX(1)	600	7.80	295.00	251.00
2	PWX(3)	564	1.00	298.39	201.00
2	PWX(3)	564	3.43	299.94	194.00
2	PWX(3)	564	6.69	302.77	190.00
3	PWX(4)	NR	15.00	305.15	276.00
3	PWX(4)	NR	15.00	306.15	291.00
3	PWX(4)	NR	15.00	305.15	300.00
3	PWX(4)	NR	15.00	305.15	281.00
3	PWX(4)	NR	15.00	306.15	280.00
3	PWX(4)	NR	15.00	307.15	292.00
3	PWX(4)	NR	15.00	307.15	255.00
3	PWX(4)	NR	15.00	307.15	264.00
4	PWX(1)	600	4.56	310.14	296.00
4	PWX(1)	600	4.56	309.80	292.00
4	PWX(1)	600	0.60	299.35	242.00
4	PWX(1)	600	4.90	310.50	261.00
4	PWX(1)	600	0.50	300.20	214.00
4	PWX(1)	600	0.40	299.75	336.00
4	PWX(1)	600	3.90	309.40	373.00
4	PWX(1)	600	6.40	313.65	300.00
4	PWX(1)	1200	-8.80	305.65	324.00
4	PWX(1)	1200	-8.40	305.55	335.00
4	PWX(1)	1200	-1.00	298.95	223.00
4	PWX(1)	1200	-9.90	305.50	263.00
4	PWX(1)	1200	-1.30	299.60	152.00
4	PWX(1)	1200	-0.91	299.30	239.00
4	PWX(1)	1200	-8.00	304.85	340.00
4	PWX(1)	1200	-14.00	309.85	286.00
5	PWX(3)	NR	NR	296.05	244.25
5	PWX(3)	NR	NR	295.25	247.71
5	PWX(3)	NR	NR	294.95	242.23

NR = Not Reported

Table 8. Mean Thermal Conductivity k and Percent Standard Deviation from the Mean for Each Type of Apparatus and Each Material.

Material	Needle Apparatus		Hot Wire Apparatus	
	Mean k mW/(m.K)	Percent Std.Dev.	Mean k mW/(m.K)	Percent Std.Dev.
Fibrous glass	22.4	11.7	35.4	3.6
Polystyrene: extruded	18.5	8.9	28.6	4.1
Polystyrene: expanded	20.8	20.2	30.8	4.6
Paraffin wax	273.	23.8	254.	16.8
Ottawa silica sand: dry	267.	13.7	309.	11.5
Ottawa silica sand: moist (3.5% moisture by weight)	1244.	26.0	---	----




Figure 1. Interlaboratory comparison of thermal conductivity of fibrous glass insulation with a density of 45 kg/m^3 . The solid line indicates the trend of data from the literature on similar material.




Figure 2. Interlaboratory comparison of thermal conductivity of expanded polystyrene insulation with a density of 21 kg/m³. The solid line indicates the trend of data from the literature on similar material.




Figure 3. Interlaboratory comparison of thermal conductivity of extruded polystyrene insulation with a density of 32 kg/m³. The solid line indicates the trend of data from the literature on similar material.




Figure 4. Interlaboratory comparison of thermal conductivity of paraffin wax with a density of 850 kg/m^3 . The solid line indicates the trend of data from the literature on similar material.




Figure 5. Interlaboratory comparison of thermal conductivity of Ottawa silica sand with a density of 1640 kg/m³. Downward-pointing triangles represent data for sand containing 3.5 percent by weight of moisture; all other symbols are for dry sand.




Figure 6. Interlaboratory comparison of thermal conductivity of dry Ottawa silica sand with a density of 1640 kg/m³. The solid line indicates the trend of data from the literature on similar material.




Figure 7. Interlaboratory comparison of thermal conductivity of Ottawa silica sand with a density of 1640 kg/m^3 and containing 3.5 percent by weight of moisture.

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET (See instructions)	1. PUBLICATION OR REPORT NO. NISTIR 89-3908	2. Performing Organ. Report No.	3. Publication Date January 1989
4. TITLE AND SUBTITLE Interlaboratory Comparison of Two Types of Line-Source Thermal-Conductivity Apparatus Measuring Five Insulating Materials			
5. AUTHOR(S) Jerome G. Hust and David R. Smith			
6. PERFORMING ORGANIZATION (If joint or other than NBS, see instructions) National Institute of Standards and Technology U.S. DEPARTMENT OF COMMERCE DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234		7. Contract/Grant No.	8. Type of Report & Period Covered
9. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) U.S. Department of Energy Oak Ridge National Laboratory Oak Ridge, Tennessee 37830			
10. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.			
11. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here) <p>We compare measurements of apparent thermal conductivity performed by five different laboratories. Subcommittee C-16.30 (Thermal Measurements) of the American Society for Testing and Materials (ASTM) sponsored this interlaboratory comparison. Two different types of line-source apparatus were used: the needle and the hot wire. The five laboratories measured thermal conductivity of Ottawa silica sand, paraffin wax, and three insulating materials (fibrous glass, expanded polystyrene, and extruded polystyrene). Comparison of the test results illustrates the interlaboratory reproducibility. The standard deviation of the thermal conductivity results for the needle apparatus is 26 percent, whereas the standard deviation of the results for the hot-wire apparatus is 17 percent. For the insulating materials the mean values of the test results from the needle apparatus lie about 35 percent below those for the hot-wire apparatus. For the more dense materials, Ottawa sand and paraffin wax, the difference is about 15 percent. We do not at present know which apparatus is the more accurate. Further work needs to be done to establish and/or improve the reliability of each of these methods for use in a laboratory environment such as for quality control or research.</p>			
12. KEY WORDS (Six to twelve entries; alphabetical order; capitalize only proper names; and separate key words by semicolons) ambient temperature; apparent thermal conductivity; expanded polystyrene; extruded polystyrene; fibrous glass; hot wire; interlaboratory comparison; line-source apparatus; needle probe; Ottawa silica sand; paraffin wax; thermal insulation			
13. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. <input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161		14. NO. OF PRINTED PAGES 28	15. Price

