

~~NOT FOR PUBLICATION OR FOR REFERENCE~~  
~~IN ANY PUBLICATION~~

# NATIONAL BUREAU OF STANDARDS REPORT

10 083

R7202294

FIRE GROWTH AND FLASHOVER  
IN MODEL ENCLOSURES  
SIMULATING AIRPLANE CABINS

Progress Report No. 2

~~NOT FOR PUBLICATION OR FOR REFERENCE~~

BRD FILE COPY

DO NOT REMOVE



U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS

~~NOT FOR PUBLICATION OR FOR REFERENCE~~

BUILDING RESEARCH

## NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards<sup>1</sup> was established by an act of Congress March 3, 1901. Today, in addition to serving as the Nation's central measurement laboratory, the Bureau is a principal focal point in the Federal Government for assuring maximum application of the physical and engineering sciences to the advancement of technology in industry and commerce. To this end the Bureau conducts research and provides central national services in four broad program areas. These are: (1) basic measurements and standards, (2) materials measurements and standards, (3) technological measurements and standards, and (4) transfer of technology.

The Bureau comprises the Institute for Basic Standards, the Institute for Materials Research, the Institute for Applied Technology, the Center for Radiation Research, the Center for Computer Sciences and Technology, and the Office for Information Programs.

**THE INSTITUTE FOR BASIC STANDARDS** provides the central basis within the United States of a complete and consistent system of physical measurement; coordinates that system with measurement systems of other nations; and furnishes essential services leading to accurate and uniform physical measurements throughout the Nation's scientific community, industry, and commerce. The Institute consists of an Office of Measurement Services and the following technical divisions:

Applied Mathematics—Electricity—Metrology—Mechanics—Heat—Atomic and Molecular Physics—Radio Physics<sup>2</sup>—Radio Engineering<sup>2</sup>—Time and Frequency<sup>2</sup>—Astrophysics<sup>2</sup>—Cryogenics.<sup>2</sup>

**THE INSTITUTE FOR MATERIALS RESEARCH** conducts materials research leading to improved methods of measurement standards, and data on the properties of well-characterized materials needed by industry, commerce, educational institutions, and Government; develops, produces, and distributes standard reference materials; relates the physical and chemical properties of materials to their behavior and their interaction with their environments; and provides advisory and research services to other Government agencies. The Institute consists of an Office of Standard Reference Materials and the following divisions:

Analytical Chemistry—Polymers—Metallurgy—Inorganic Materials—Physical Chemistry.

**THE INSTITUTE FOR APPLIED TECHNOLOGY** provides technical services to promote the use of available technology and to facilitate technological innovation in industry and Government; cooperates with public and private organizations in the development of technological standards, and test methodologies; and provides advisory and research services for Federal, state, and local government agencies. The Institute consists of the following technical divisions and offices:

Engineering Standards—Weights and Measures—Invention and Innovation—Vehicle Systems Research—Product Evaluation—Building Research—Instrument Shops—Measurement Engineering—Electronic Technology—Technical Analysis.

**THE CENTER FOR RADIATION RESEARCH** engages in research, measurement, and application of radiation to the solution of Bureau mission problems and the problems of other agencies and institutions. The Center consists of the following divisions:

Reactor Radiation—Linac Radiation—Nuclear Radiation—Applied Radiation.

**THE CENTER FOR COMPUTER SCIENCES AND TECHNOLOGY** conducts research and provides technical services designed to aid Government agencies in the selection, acquisition, and effective use of automatic data processing equipment; and serves as the principal focus for the development of Federal standards for automatic data processing equipment, techniques, and computer languages. The Center consists of the following offices and divisions:

Information Processing Standards—Computer Information—Computer Services—Systems Development—Information Processing Technology.

**THE OFFICE FOR INFORMATION PROGRAMS** promotes optimum dissemination and accessibility of scientific information generated within NBS and other agencies of the Federal government; promotes the development of the National Standard Reference Data System and a system of information analysis centers dealing with the broader aspects of the National Measurement System, and provides appropriate services to ensure that the NBS staff has optimum accessibility to the scientific information of the world. The Office consists of the following organizational units:

Office of Standard Reference Data—Clearinghouse for Federal Scientific and Technical Information<sup>3</sup>—Office of Technical Information and Publications—Library—Office of Public Information—Office of International Relations.

<sup>1</sup> Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

<sup>2</sup> Located at Boulder, Colorado 80302.

<sup>3</sup> Located at 5285 Port Royal Road, Springfield, Virginia 22151.

# NATIONAL BUREAU OF STANDARDS REPORT

## NBS PROJECT

4212427

September 11, 1969

## NBS REPORT

10 083

FIRE GROWTH AND FLASHOVER  
IN MODEL ENCLOSURES  
SIMULATING AIRPLANE CABINS

Progress Report No. 2

by

D. Gross

For  
Federal Aviation Administration  
Project No. 510-001-11X  
Agreement No. FA67NF-AP-21

### IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS  
for use within the Government. Before  
and review. For this reason, the public  
whole or in part, is not authorized  
Bureau of Standards, Washington, D.C.  
the Report has been specifically pre-

Approved for public release by the  
director of the National Institute of  
Standards and Technology (NIST)  
on October 9, 2015

Accounting documents intended  
jected to additional evaluation  
ling of this Report, either in  
ffice of the Director, National  
e Government agency for which  
is for its own use.



U.S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS



FIRE GROWTH AND FLASHOVER  
IN MODEL ENCLOSURES  
SIMULATING AIRPLANE CABINS

Progress Report No. 2

by

D. Gross

1.0 INTRODUCTION

A previous report [1] described preliminary experiments on laboratory models of fire development in enclosed spaces. Using a 20 x 20 x 40 inch chamber it was found that within certain ventilation and physical property limits flaming ignition of a wall lining specimen by radiant heating would occur; and outside these limits flaming ignition would not occur.

This report summarizes additional tests performed in this chamber using small cubes of polyurethane cushioning foam, similar to that used in seat cushions. A larger chamber, 24 x 24 x 192 inch long, was constructed to examine the conditions under which flames would propagate down a long chamber. The polyurethane foam was exposed in a variety of ways, viz. open flame ignition, radiant heating, and internal heating using an embedded electrical heater.

At this time only a summary of the experimental work is being presented. The analysis of the data and a projection of the findings will be presented in a later report.

## 2.0 MATERIALS IN TEST

Three types of polyurethane foam were used as listed below:

<u>Designation</u>	<u>Type</u>	<u>Source</u>	<u>Nominal Thickness in</u>	<u>Measured Density pcf</u>
A	Polyether urethane B. F. Goodrich untreated airplane seat cushioning	NAFEC	4	1.3
B	Polyether urethane B. F. Goodrich fire-retardant treated airplane seat cushioning	NAFEC	4	1.3
C	Urethane bed foam	Local	1	1.3

The wall lining materials used were as follows:

FBD	Unfinished fiberboard	Storeroom	1/2	25
HBD	Unfinished, oil- tempered hardboard	Commercial	3/16	60

## 3.0 EXPERIMENTAL RESULTS

### 3.1 Small Chamber Tests

Except as noted, all tests were conducted using the insulated asbestos lined 20 x 20 x 40 inch chamber. These tests were made using cubes assembled from one-inch thick layers of polyurethane foam which is normally used in bed mattresses, and was purchased locally. Small cubes of polyurethane foam were placed within the chamber to simulate the principal fuel load (seat cushions) in airplane cabins. Table 1 is a summary of test results.

Using two-inch polyurethane cubes, with a glowing electrical ignitor placed on top of one cube, fire spread to all cubes only when corners touched. When spaced apart one-quarter inch or more, only the ignited cube burned.



Using nine three-inch polyurethane cubes subject to radiation from Calrod heaters, flaming occurred with vent openings between one-quarter inch and four inches but not at six inches. A minimum time to initial flaming (14 and one-half minutes) occurred with an opening of one inch, although repeat tests produced active flaming at times up to twenty-one and one-half minutes. (See Figure 1.) At a fixed vent opening of two inches, the same or shorter times to initial flashing were observed with only three, four, or five cubes. Usually, flaming occurred initially near the electrical Calrod heater, although flashing occasionally involved all the cubes.

In Test 28, using a fiberboard lined wall opposite the Calrod heaters, the fiberboard did not affect the ignition time of the polyurethane cubes and did not ignite by itself.

Test No. 30 employed foam from standard airplane cushions; Tests 31 to 33 foam from retardant-treated airplane cushions received from NAFEC. The cubes were trimmed to three inches from the standard four-inch thickness.

Whereas the regular (untreated) foam ignited at one and four inch vent openings, the fire retardant-treated foam did not ignite at these same vent openings.

In every case, the temperature of the air close to the ceiling at the center of the unlined box reached a value between 270 and 290 °C (520 to 550 °F) just prior to ignition. The temperature of the air near the floor was approximately 100 °C lower.

### 3.2 Large Chamber Tests

A larger and longer insulated asbestos board chamber was constructed and used for all subsequent tests. Figure 2 shows the vent end of the 24 x 24 x 192 inch chamber and instrumentation for gas analysis alongside. The electrical Calrod heating elements are mounted on one wall of the chamber and are shown in Figure 3. The principal test results are summarized in Table 2.

An exploratory series of tests was conducted in the uninsulated asbestos-wall chamber (Tests 5 to 13). All subsequent tests were conducted with the chamber insulated with a one-inch layer of glass fiber batting, comparable to that covering the small chamber. Ceiling temperatures were generally lower and ignition times generally shorter compared to tests in the small chamber; but the radiant heater supply, the urethane fuel, and the spatial separations were not similar.

Tests 28 to 32 were made without any foam using combustible hardboard or fiberboard wall linings opposite the Calrod heating elements in a manner similar to that employed in previous tests in the smaller chamber. With the hardboard wall lining and vent openings of one-half and two inches, flames were noted at 58 and one-quarter and 65 minutes respectively. No ignition was obtained using an eight-inch vent opening, although the hardboard reached a glowing state after 80 minutes. In a test in a small chamber with a two-inch vent, (data reported previously [1]) flames were noted at the specimen after 34 minutes. Using a fiberboard wall lining and vent openings of one-half and two inches in the large chamber, flames were noted in approximately 55 minutes compared to about 20 minutes in the small chamber.

During Tests 14 and 15 measurements were made of the combustion gas concentration above the polyurethane cubes. The CO content reached two percent and the oxygen content dropped to a minimum of nine percent in Test No. 14. The readings in Test No. 15 were CO 0.6 percent maximum, CO<sub>2</sub> 0.2 percent maximum, and O<sub>2</sub> 20.5 percent minimum. No comparative gas concentration measurements are available for the other tests.

Figure 4 shows typical vertical profiles of gas temperature at the quarter-point locations shortly before the first indication of fire. The high temperature noted at six inches below the ceiling in Position A is due to the heat produced by the polyurethane cubes which were mounted eighteen inches above the floor.

In Tests 33 to 41, with the heaters placed on the floor, four-inch polyurethane cubes placed two inches above the heaters; and using a bottom end vent of two inches ignition occurred either near the cubes or at the heaters in times ranging from 6:50 to 8:00 minutes. In this case, ignition occurred at ceiling temperatures from 110 to 126 °C (210 to 250 °F). Placing the cubes at six and nine inches above the heater resulted in no ignition or very much delayed ignition.

Tests 52 to 64, using a 2,150 watt electrical barbecue heater sandwiched between layers of polyurethane foam produced ignition in every case. The temperature in the middle of the sandwich reached 400 to 500 °C when flame broke out. Usually the onset of flaming was accompanied by a sudden pressure rise which simultaneously blew out a twelve-inch square plug at the far end of the chamber. Active flaming then continued in the polyurethane stack until it was consumed. In one instance where a row of urethane cubes was lined up adjacent to the stack, the flames did not propagate to



these cubes. The simultaneous ignition and plug blowout occurred with conventional foam and with untreated and fire retardant treated airplane cushioning foam in times ranging from one and one-half to six minutes. The quantity of foam, as measured by the height of the stack, appeared to have a slight affect upon the time to initial fire for two types of polyurethane foam (See Figure 5). The shortest times were obtained with the thinnest stack (one inch). The air temperature near the ceiling (above the stack) was generally below 50 °C (120 °F) at the time of ignition and was somewhat lower elsewhere in the chamber. After ignition occurred, temperatures rose rapidly to over 500 °C above the polyurethane stack. In several tests, temperatures in excess of 400 °C and sometimes over 500 °C were recorded two to four feet down the box, indicating the passage of flame or hot gases. Temperature profiles during the peak burning stage in two tests is shown in Figure 6. The elevated temperature toward the vent end (thirteen feet from the polyurethane) may have been due to a pocket of high temperature products, a likely condition, since the chamber was tilted up toward the vent end for this series of tests. The slight reversal of temperatures between two and four feet from the polyurethane is so far unexplained.

In Tests 47 to 51, several open flame sources (a candle, a bunsen burner, and a pan of heptane) were used to examine whether flame propagation with a space above a 4 x 12 x 12 inch urethane stack would occur. For the given test conditions, there was no indication of flames extending along the chamber beyond the burning polyurethane.

#### 4.0 DISCUSSION

The test series covered by this report have shown that flaming would not propagate readily between small polyurethane cubes within a model enclosure. Whether ignition was initiated indirectly by thermal radiation, directly by contact with an electrically-heated ignitor, or by an open flame source, flames did not involve the entire chamber and did not spread to adjacent polyurethane cubes spaced one-quarter inch or more apart. (In these tests, the simplest cabin geometry was used; no attempt was made to simulate actual cabin conditions of rounded cross-section; the presence of seat backs, hat racks, and other space-defining components; or of the use of curtains, upholstery and other materials capable of igniting and spreading flame.) Where thermal radiation was used to initiate decomposition, flaming occurred principally in the gaseous products near the glowing electrical heaters. The gasification and accumulation of combustible products under these heating conditions and fuel element size was apparently insufficient to produce a propagating self-sustaining flame. For most hydrocarbon

vapors at room temperature, the lower limit of flammability is approximately 45 to 50 mg of combustible vapor per liter (0.045 to 0.050 oz/ft<sup>3</sup>) of air at standard conditions [2].

An electrical heater sandwiched between layers of polyurethane foam produced a more rapid local concentration of combustible products and resulted in ignition in every case. Usually the onset of flaming was preceded by a sudden pressure rise which blew out a plug at the far end of the chamber. Here again the flaming intensity was apparently insufficient to increase the mean concentration of CO or other combustible gases to permit flaming over an extensive area or to involve adjacent polyurethane cubes. The limits of flammability for mixtures containing CO is shown in Figure 7. The limited number and accuracy of gas measurements to date has precluded any judgment as to whether sufficient CO and/or other products were being accumulated for flame propagation to be possible.

#### 5.0 FUTURE TESTS

Additional tests are planned in the large chamber, and will include the following conditions:

- Materials (e.g., vinyl cloth) mounted along the ceiling.
- Horizontal and vertical spatial separators to more closely simulate airplane cabin configurations.
- More accurate measurements of CO concentrations using a recently purchased infrared analyzer with 0 to 2 percent range.

#### 6.0 REFERENCES

- [1] Gross, D., "Fire Growth and Flashover in Model Enclosures Simulating Airplane Cabins", NBS Report No. 9931, October 4, 1968.
- [2] Zabetakis, M. G., "Flammability Characteristics of Combustible Gases and Vapors", Bureau of Mines Bulletin No. 627, 1965.

Table 1

Summary of Test Results  
20 x 20 x 40 in Chamber

Test	Cubes		Vent Opening	Time to Ignition	Ceiling Air Temperature Prior to Ignition °C	Notes
	No.	Size in				
		Spacing in	in	min:sec		
<u>Ignition by Electrical Wire</u>						
<u>Foam Type C</u>						
<u>Foam Type A</u>						
30	9	3	1/2	1	20:10	289
						All cubes ignited
<u>Foam Type B</u>						
31	9	3	1/2	1	----	No ignition; 60 min.
32	9	3	1/2	4	----	No ignition; 45 min.
33	9	3	1/2	10	----	No ignition; 45 min.



Table 1

Summary of Test Results  
20 x 20 x 40 in Chamber

Test	Cubes			Vent Opening in	Time to Ignition min:sec	Ceiling Air Temperature Prior to Ignition °C	Notes
	No.	Size in	Spacing in				

<u>Ignition by Electrical Wire</u>							
<u>Foam Type C</u>							
2,3,4	11	2	1	2			No spread between cubes
5	11	2	1/2	1/2			No spread between cubes
6	11	2	1/4	1/2			No spread between cubes
7	11	2	Corners touching	1/2	4:00		All cubes burned
<u>Radiant Heating - 2 Calrod Units</u>							
<u>Foam Type C</u>							
19	9	3	1/2	1/4	17:35	280	Flash from Calrod heater to ceiling; occasional flashing until 18:10 when all cubes ignited; intermittent flashing to 27 min.
15	9	3	1/2	1/2	20:27	289	Sudden flash preceded by pulsation.
16	9	3	1/2	1	14:30	270	Flash at Calrod heater; cubes ignited at 15:04 min.
27	9	3	1/2	1	18:27	290	All cubes ignited
29	9	3	1/2	1	21:34	288	All cubes ignited
14	9	3	1/2	2	17:37	271	All cubes ignited
17	9	3	1/2	4	21:50	285	Flash from heater top down; all cubes ignited
18	9	3	1/2	6	----	---	50 min. test
28	9	3	1/2	1	17:21	298	Homasote wall opposite Calrod units did not ignite; cubes ignited
21	3	3	1/2	2	15:45	278	Flash across ceiling; intermittent to 16:15; cubes not ignited
22	4	3	1/2	2	16:38	288	Sudden flash; all cubes ignited
20	5	3	1/2	2	14:25	283	Flash across ceiling; cubes ignited
<u>Foam Type A</u>							
30	9	3	1/2	1	20:10	289	All cubes ignited
<u>Foam Type B</u>							
31	9	3	1/2	1	----	---	No ignition; 60 min.
32	9	3	1/2	4	----	---	No ignition; 45 min.
33	9	3	1/2	10	----	---	No ignition; 45 min.





Table 2A

## Summary of Test Results

32	1/2	None		55:15	58:32	307	ignition Homasote (did not ignite)
<u>Heaters (4) on Floor</u>							
33	9	20	9	33:50	35:15	200	Intermittent flaming; cubes--50% burned, 50% melted
34	2	20	6				Melting of cubes only; test terminated at 35 min.
35	2	20	2	7:55	7:48	110	Intermittent flaming; cubes--50% burned, 50% melted
36	2	20	2	8:00	7:58	120	Intermittent flaming; cubes--50% burned, 50% melted
37	2	12	2	6:50	6:48	116	Electrical ignitor at ceiling used at 30 sec. intervals. No significant difference noted. Cubes-- 50% burned
38	2	6	2				Two heaters only. No ignition; cubes--25% melted
40	2	8	2	8:20			Single slight momentary flame only
41	2	10	2	7:35	7:38	126	Intermittent burning; cubes 80% burned



Table 2A  
Summary of Test Results  
24 x 24 x 192 in Chamber

Test	Vent  in	No.	4" Cubes		Ignition Time, min:sec			Ceiling Air Temperature Prior to Ignition °C	Remarks
			Distance to Heater in	Height Above Floor in	Flash	Sustained Fire	Sudden Temp Rise		
Foam Type C									
Asbestos-Wall Chamber									
5	2	7	3	18		12:10		187	Spark ignition (10 sec)
6	2	7	3	18		14:10		180	Spark ignition
7	2	7	3	18		13:45	13:40	152	
8	2	7	10	18				---	
9	2	7	8	12				---	
10	10	7	3	18	10:20		10:24	144	
11	6	7	3	18		11:25	10:48	150	
12	4	7	3	18		10:30	10:00	150	
13	4	7	3	18		10:40	10:48	153	
Chamber Insulated									
14	4	7	3	18		10:55	11:06	121	
15	4	8	3	12				---	
16	4	12	3	18	10:50		12:30	159	
17	15	12	3	18		18:10	18:08	150	
18	1/2	12	3	18		12:00	12:04	150	
19	0	12	3	18	14:26	-----	-----	---	Momentary flash
20	23+	12	3	18				---	
21	1/4	12	3	18		12:00	12:00	130	
22	8	12	3	18		10:50	10:52	139	Momentary flash
23	1	12	2	6	12:20			---	
24	8	40	2.5 to 17.5	18	83:00	95:00	94:26		Flash (from Homasote) down Homasote wall from ceiling to floor
25	8	20	3	18					No ignition
26	8	26	3	18	11:05	-----	-----	---	Momentary flash; cubes 90% melted
27	2	33	3	18		12:30	12:46	147	12 cubes entirely burned; remainder melted
28	2	None				65:00	65:00	300	Hardboard wall only; 276 °C prior to ignition
29	1/2	None			57:15	58:15	58:30	295	Hardboard wall; 291 °C prior to ignition
30	8	None							Hardboard split apart at 77 min; glowing at 80 min
31	2	None			54:10	56:55	54:54	310	Homasote 320 °C prior to ignition
32	1/2	None			55:15		58:32	307	Homasote (did not ignite)
Heaters (4) on Floor									
Foam Type C									
33	9	20		9	33:50	35:15	35:18	200	Intermittent flaming; cubes--50% burned, 50% melted
34	2	20		6					Melting of cubes only; test terminated at 35 min.
35	2	20		2	7:55		7:48	110	Intermittent flaming; cubes--50% burned, 50% melted
36	2	20		2	8:00		7:58	120	Intermittent flaming; cubes--50% burned, 50% melted
37	2	12		2	6:50		6:48	116	Electrical ignitor at ceiling used at 30 sec. intervals. No significant difference noted. Cubes-- 50% burned
38	2	6		2					Two heaters only. No ignition; cubes--25% melted
40	2	8		2	8:20	---			Single slight momentary flame only
41	2	10		2	7:35		7:38	126	Intermittent burning; cubes--80% burned





Table 2B  
Various Ignition Sources

Test	Vent	Type	Urethane			Ignition Source & Location	Remarks
			No.	Size in	Distance Above Floor in		
47	Removable 12" plug	A	1	4 x 12 x 12	5	Candle at corner	No flash fire beyond stack
48	Removable 12" plug	A	1	4 x 12 x 12	9-1/2	Bunsen burner at bottom center	No flash fire beyond stack
49	Removable 12" plug	A	1	4 x 12 x 12	9-1/2	20 ml heptane in pan	No flash fire beyond stack. Chamber sloped 1 ft/16 ft. Heptane burned 1:40 min. Flames to 2:15 min.
50	Removable 12" plug	A	1	4 x 12 x 12	9-1/2	100 ml heptane in pan	No flash fire beyond stack. Chamber sloped 1 ft/16 ft. Heptane burned 1:25 min. Flames to 2:00 min.
51	2	A	1	4 x 12 x 12	9-1/2	100 ml heptane in pan	No flash fire beyond stack. Chamber sloped 1 ft/16 ft. Heptane burned 1:10 min (70% remained). No contin- uing flames from urethane (40% remained).



Table 2C

## Electric Barbecue Heater in Sandwich

Test	Vent	Urethane			Ignition Time, min:sec			Ceiling Air Temperature Prior to Ignition °C	Remarks	
		Type	No.	Size in	Distance Above Floor in	Flash	Sustained Flaming			Sudden Temp Rise
Small Barbecue Heater										
44	See Remarks	C	1	2 x 12 x 12	4		4:45	4:50	38	Vent closed with 12 in. square plug; plug *
60	See Remarks	C	*	(1 x 8 x 16) *	4		1:30	1:36	50	Urethane pieces matched to heater element.
61	See Remarks	C	*	(1 x 12 x 16) *	4		1:30	1:36	54	*Urethane pieces matched to heater element. Fire; plug blew out
62	See Remarks	A	*	(1 x 12 x 16) *	4		1:33	1:36	48	*Fire; plug blew out. Same as above.
63	See Remarks	A	1	16 x 16 x 16	2		2:15	2:18	48	Fire; plug blew out
64	See Remarks	C	1	16 x 16 x 16	2		2:55	2:56	48	Fire; plug blew out

Vent closed with 12 in. square plug; plug  
Urethane pieces  
matched to heater  
element.

\*Urethane pieces  
matched to heater  
element. Fire; plug  
blew out

\*Fire; plug blew out.  
Same as above.

Fire; plug blew out

Fire; plug blew out



Table 2C

## Electric Barbecue Heater in Sandwich

Test	Vent	Urethane				Ignition Time, min:sec			Ceiling Air Temperature Prior to Ignition °C	Remarks
		Type	No.	Size in	Distance Above Floor in	Flash	Sustained Flaming	Sudden Temp Rise		
<u>Small Barbecue Heater</u>										
44	See Remarks	C	1	2 x 12 x 12	4		4:45	4:50	38	Vent closed with 12 in. square plug; plug removed at 6:00 min. Flames out at 6:15 min.
45	See Remarks	C	1	4 x 12 x 12	4		6:00	6:02	41	Vent plug blew out. Seven 4" cubes placed in line near sandwich did not ignite.
46	See Remarks	A	1	4 x 12 x 12	4		4:45	4:50	56	Vent plug blew out. Seven 4" cubes placed in line near sandwich did not ignite.
<u>Large Barbecue Heater (2150 Watts)</u>										
52	See Remarks	A	1	4 x 16 x 16	9-1/2		4:30			Plug opened slightly
53	See Remarks	A	1	4 x 16 x 16	12		2:30	2:24		Plug blew out. Urethane burned com- pletely
54	See Remarks	B	1	4 x 16 x 16	12		3:05	3:12		Plug blew out. Urethane burned com- pletely
55	See Remarks	A	1	8 x 16 x 16	12		2:00	2:02		Plug blew out. Urethane burned com- pletely. Flames for 1 min. then out. Urethane 50% consumed.
56	See Remarks	C	1	8 x 16 x 16	12		2:10	2:12		Plug blew out; (new) urethane 100% consumed
(New TC set-up)										
57	See Remarks	C	1	4 x 16 x 16	4		1:57	2:00	36	Plug blew out. Urethane 100% con- sumed.
58	See Remarks	C	1	2 x 16 x 16	4		1:50	1:54	48	Plug blew out. Urethane 100% con- sumed.
59	See Remarks	C	1	1 x 16 x 16	4		1:30	1:36	45	Plug blew out.
60	See Remarks	C	*	(1 x 8 x 16)*	4		1:30	1:36	50	* Urethane pieces matched to heater element.
61	See Remarks	C	*	(1 x 12 x 16)*	4		1:30	1:36	54	* Urethane pieces matched to heater element. Fire; plug blew out
62	See Remarks	A	*	(1 x 12 x 16)*	4		1:33	1:36	48	*Fire; plug blew out. Same as above.
63	See Remarks	A	1	16 x 16 x 16	2		2:15	2:18	48	Fire; plug blew out
64	See Remarks	C	1	16 x 16 x 16	2		2:55	2:56	48	Fire; plug blew out








FIG. 1 -- FLAMING TIME FOR POLYURETHANE CUBES IN  
20 x 20 x 40 INCH CHAMBER

Previous Results with Wall Linings For  
Comparison





Fig. 2 - Large Chamber for Model  
Enclosure Tests Arranged With  
4 Inch End Vent. Note Gas  
Analysis Instrumentation at Left







Fig. 3 - Electrical Calrod Heating  
Element Mounted Along Wall  
of Large Chamber






FIG. 4 GAS TEMPERATURE VERTICAL PROFILES  
TEST NO. 14 10 MINUTES



FIG. 5 FIRE IN URETHANE SANDWICH  
INITIATED BY ELECTRIC HEATER

- AIRPLANE SEAT CUSHIONING, UNTREATED
- CONVENTIONAL BED FOAM









FIG. 6 TEMPERATURE PROFILE  
DURING PEAK BURNING PHASE










Fig. 7 Limits of Flammability of Carbon Monoxide-Carbon Dioxide-Air and Carbon Monoxide-Nitrogen-Air Mixtures at Atmospheric Pressure and 26°C [Ref. 2, Fig 126]





