

NATIONAL BUREAU OF STANDARDS REPORT

10 329

**PRELIMINARY TESTS OF NON-COMBUSTIBILITY
OF MATERIALS USING CRUCIBLE METHOD**



**U.S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS**

NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards¹ was established by an act of Congress March 3, 1901. Today, in addition to serving as the Nation's central measurement laboratory, the Bureau is a principal focal point in the Federal Government for assuring maximum application of the physical and engineering sciences to the advancement of technology in industry and commerce. To this end the Bureau conducts research and provides central national services in four broad program areas. These are: (1) basic measurements and standards, (2) materials measurements and standards, (3) technological measurements and standards, and (4) transfer of technology.

The Bureau comprises the Institute for Basic Standards, the Institute for Materials Research, the Institute for Applied Technology, the Center for Radiation Research, the Center for Computer Sciences and Technology, and the Office for Information Programs.

THE INSTITUTE FOR BASIC STANDARDS provides the central basis within the United States of a complete and consistent system of physical measurement; coordinates that system with measurement systems of other nations; and furnishes essential services leading to accurate and uniform physical measurements throughout the Nation's scientific community, industry, and commerce. The Institute consists of an Office of Measurement Services and the following technical divisions:

Applied Mathematics—Electricity—Metrology—Mechanics—Heat—Atomic and Molecular Physics—Radio Physics²—Radio Engineering²—Time and Frequency²—Astrophysics²—Cryogenics.²

THE INSTITUTE FOR MATERIALS RESEARCH conducts materials research leading to improved methods of measurement standards, and data on the properties of well-characterized materials needed by industry, commerce, educational institutions, and Government; develops, produces, and distributes standard reference materials; relates the physical and chemical properties of materials to their behavior and their interaction with their environments; and provides advisory and research services to other Government agencies. The Institute consists of an Office of Standard Reference Materials and the following divisions:

Analytical Chemistry—Polymers—Metallurgy—Inorganic Materials—Physical Chemistry.

THE INSTITUTE FOR APPLIED TECHNOLOGY provides technical services to promote the use of available technology and to facilitate technological innovation in industry and Government; cooperates with public and private organizations in the development of technological standards, and test methodologies; and provides advisory and research services for Federal, state, and local government agencies. The Institute consists of the following technical divisions and offices:

Engineering Standards—Weights and Measures—Invention and Innovation—Vehicle Systems Research—Product Evaluation—Building Research—Instrument Shops—Measurement Engineering—Electronic Technology—Technical Analysis.

THE CENTER FOR RADIATION RESEARCH engages in research, measurement, and application of radiation to the solution of Bureau mission problems and the problems of other agencies and institutions. The Center consists of the following divisions:

Reactor Radiation—Linac Radiation—Nuclear Radiation—Applied Radiation.

THE CENTER FOR COMPUTER SCIENCES AND TECHNOLOGY conducts research and provides technical services designed to aid Government agencies in the selection, acquisition, and effective use of automatic data processing equipment; and serves as the principal focus for the development of Federal standards for automatic data processing equipment, techniques, and computer languages. The Center consists of the following offices and divisions:

Information Processing Standards—Computer Information—Computer Services—Systems Development—Information Processing Technology.

THE OFFICE FOR INFORMATION PROGRAMS promotes optimum dissemination and accessibility of scientific information generated within NBS and other agencies of the Federal government; promotes the development of the National Standard Reference Data System and a system of information analysis centers dealing with the broader aspects of the National Measurement System, and provides appropriate services to ensure that the NBS staff has optimum accessibility to the scientific information of the world. The Office consists of the following organizational units:

Office of Standard Reference Data—Clearinghouse for Federal Scientific and Technical Information³—Office of Technical Information and Publications—Library—Office of Public Information—Office of International Relations.

¹ Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

² Located at Boulder, Colorado 80302.

³ Located at 5285 Port Royal Road, Springfield, Virginia 22151.

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

4219402

August 27, 1970

NBS REPORT

10 329

PRELIMINARY TESTS OF NON-COMBUSTIBILITY OF MATERIALS USING CRUCIBLE METHOD

by

J. B. Fang

IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS
for use within the Government. Before
and review. For this reason, the public
whole or in part, is not authorized or
Bureau of Standards, Washington, D.C.
the Report has been specifically prepar

Approved for public release by the
director of the National Institute of
Standards and Technology (NIST)
on October 9, 2015

Printing documents intended
ed to additional evaluation
of this Report, either in
of the Director, National
Government agency for which
or its own use.



U.S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

Preliminary Tests of Non-Combustibility
of Materials Using Crucible Method

by J. B. Fang

1.0 INTRODUCTION

The crucible method for determining non-combustibility was developed by CSTB. This procedure uses a special apparatus which measures the heat content of the volatile components of a material. A duplicate of the apparatus was given to NBS to study the use of the procedure for determining non-combustibility.

2.0 TEST METHOD

The apparatus consists of a crucible, having a lid fitted with a small diameter pipe. As material in the crucible is heated the volatiles evolve from the pipe and are burned by a pilot light. The heat content of the volatiles is then determined by measuring the temperature rise of a container of water. The apparatus is described in detail in ISO/TC92 WG2 (France 8).

All the samples used were crushed, mixed, conditioned for about 20 hours in a well ventilated oven maintained at 60 ± 5 °C. They were then placed in a desiccator prior to the test. A weighed sample was mixed homogeneously with furnace-dried and pulverized vermiculite, which served as an inert filler, and then placed in the crucible. The amount of sample used was varied according to its calorific value and was limited to ensure complete combustion without condensation of water on the hollow bottom of the water container.

The crucible was placed in the furnace and heated by a premixed propane/air flame from the gas burner. A diffusion propane flame was employed as a pilot to initiate flaming of combustible volatiles issuing from the mixture in the crucible. The temperature rise of the water container of known water equivalent was measured by means of a chromel/alumel thermocouple whose output emf as a function of time was continuously monitored by a potentiometric recorder. For each sample, four tests were performed: three tests were made with the pilot flame; and one without the pilot flame.

3.0 TEST RESULTS AND OBSERVATIONS

Table 1 presents the results of volatile calorific potential measurements made on five samples of materials which were being used in the current ISO program on studying reaction to fire. In general, the variability in volatile calorific value for repeat tests was noted to be of the order of ± 5 to $\pm 10\%$. The amount of fine vermiculite used for each test was about 6 g due to the limitation of available volume in the crucible.

Examination of the table shows that with the exception of red oak, the amount of heat transferred to the container by the volatiles evolved from the sample undergoing pyrolysis when no pilot was used was less than 5% of the total measured when the pilot was used. This low value of heat content may be attributed to a drop in the temperature of the volatiles due to endothermic chemical reactions for phase changes, and a lower convection heat transfer coefficient because of the physical and thermal properties of the volatile products.

An attempt was made to compare the results of with and without using the vermiculite filler to mix with the sample. Tests conducted for red oak, shown in Table 1, indicate that the volatile calorific potentials were approximately 25% less than those for samples mixed with vermiculite. This may be due to incomplete combustion caused by a rapid evolution of a large amount of volatile products and an insufficient air entrainment for stoichiometric combustion.

The volumetric flow rates of propane supplied to the pilot under a pressure of 0.52 mm water and to the Meker burner at 370 mm water were found to be 2.52 cc/min and 996 cc/min (based on 21°C and 1 atm.) respectively by means of a soap bubble tube and a gas flow meter.

A blank test was made by determining the temperature rise of the water container due to the pilot flame, the crucible filled with about 6 g of vermiculite and the burner flame. The increase in its temperature was found to be 2.5°C in 20 minutes with a container of 372.8 g equivalent in water. This corresponds to a rate of heat addition of 47 cal/min.

In order to estimate calorific efficiency of the apparatus, a metaldehyde/vermiculite mixture with calorific values ranging from 0 to 380 cal/g was used as a standard specimen. Different calorific values of the mixture were obtained by varying the mass of Metaldehyde (heat of combustion 6300 cal/g), using a constant weight of vermiculite. The experimental results are shown in Figure 1 where the calorific potential of volatiles evolved from the mixture is plotted against the calorific value of the mixture. The details are summarized in Table 2. The figure indicates that the volatile calorific potential increases with an increase in the mixture calorific value, and at the calorific value greater than about 120 cal/g the data tend to lie along a straight line. The data for the calorific efficiency of the apparatus, which is defined as the ratio of the volatile calorific potential to the mixture calorific value, are also plotted in terms of the mixture calorific value in Figure 1. As the mixture calorific potential increases, the calorific efficiency raises rapidly up to about 60% and then increases at a relatively moderate rate to approximately 71% over the range examined.

As would be expected the radiation emitted from the combustion of the distilled volatiles, for the case of the mixture with lower calorific value, because of its low flaming temperature and small flame, becomes important. However by mixing with small amounts of Metaldehyde, at the pilot with a large portion of the entrained air, most of the heat liberated by combustion are lost to the surroundings. The present results are inconsistent with those presented in the CSTB report (CR No. 990 R 234) where the calorific efficiency was constant throughout the range of the mixture calorific power investigated, and of the order of $73 \pm 3\%$. This discrepancy may be the result of NBS using different amounts of metaldehyde and vermiculite for each test although the calorific value of the two materials was maintained in the same range.

4.0 COMMENTS

- 4.1 A unified procedure to determine the water equivalent of the container is desirable to be included in the test method.
- 4.2 In order to let the volatile outlet pipe of the crucible lid pass right through the opening in the water screen without hitting the asbestos around it, a mechanical improvement for the crucible support can be made.
- 4.3 The appropriate range for operation of the apparatus should be that in which the calorific efficiency is almost constant with respect to the calorific value of the mixture in the crucible. This value should be determined by using a standard specimen.
- 4.4 The amounts of propane supplied to the pilot and to the burner should be expressed in terms of volumetric flow rates instead of static pressures in the gaseous fuel lines.
- 4.5 A study is needed of the effects of variables, such as size and amount of the sample, proportion of the inert filler and porosity of the mixture in the crucible on the volatile calorific value to provide a basis for determining their influences on the calorific efficiency of the apparatus.
- 4.6 Some modifications of the apparatus to increase its calorific efficiency may be possible since the test is primarily concerned with the materials which have low calorific potential or consist of small amounts of the combustibles.

5.0 CONCLUSIONS

On the basis of the preliminary tests conducted to date, it can be concluded that :

1. The calorific efficiency of the apparatus varies with the calorific value of the metaldehyde/vermiculite mixture.
2. Red oak samples which were mixed with an inert filler had higher values of volatile calorific potential than those without it.

Table 1 Data for Heat Released by the Volatiles Evolved from Five ISO Specimens

Material	Test No.	Weight of Sample (g)	Weight of Vermiculate (g)	Weight Loss (%)	Heat Released (cal/g)	Volatile Calorific Potential (cal/g)
Danish Hardboard	1	0.4610	6.45	87.2	1383	1278
	2	0.5039	6.25	86.6	1295	
	3	0.4966	6.23	91.6	1314	
	Ave.				1331	
	*W/OP	0.5008	6.30	79.0	53	
Melamine Chip Board	1	0.5549	6.18	86.1	1259	1163
	2	0.5268	6.23	89.8	1238	
	3	0.5025	6.34	82.0	1113	
	Ave.				1203	
	*W/OP	0.5028	5.73	87.5	40	
Red Oak	1	0.4977	6.25	93.3	1220	1142
	2	0.5030	6.25	87.9	1445	
	3	0.5039	6.25	92.4	1258	
	Ave.				1308	
	*W/OP	0.5157	6.23	96.1	166	
Styrofoam (Fire Retardant Treated)	1	0.1446	6.41	95.2	1340	1305
	2	0.1509	6.19	89.9	1235	
	3	0.1496	6.26	85.2	1420	
	Ave.				1332	
	*W/OP	0.3704	5.60	91.8	27	

Calorific Value of Volatiles Produced from the Mixture, cal/g

300

200

100

0

80

70

60

50

40

30

20

10

0

Calorific Value of the Mixture, cal/g

400

300

200

100

FIG. 1. Volatile Calorific Potential of the Metaldehyde/Vermiculite Mixture and Calorific Efficiency of the Apparatus

• Efficiency
X Calorific Value




Table 1 (Continued)

Material	Test No.	Weight of Sample (g)	Weight of Vermiculite (g)	Weight Loss (%)	Heat Released (cal/g)	Volatile Calorific Potential (cal/g)
Polyurethane	1	0.5035	6.10	77.3	2254	2102
	2	0.5109	5.60	76.9	2028	
	3	0.4992	5.58	74.9	2075	
	Ave.				2119	
	*W/OP	0.5041	5.98	79.6	17	
Red Oak (No filler)	1	6.80	0	79.4	1200	839
	2	6.80	0	80.9	1180	
	3	6.80	0	79.4	1040	
	Ave.				1140	
	*W/OP	6.80	0	80.9	301	

*W/OP = with pilot flame.

Table 2 Data for Calorific Efficiency of the Apparatus

Test No.	Weight of Metaldehyde (g)	Weight of Vermiculite (g)	Calorific Value of the Mixture (cal/g)	Volatile Calorific Potential (cal/g)	Calorific Efficiency (%)
1	0.0399	6.2054	40.3	12.0	29.9
2	0.0391	6.1987	39.5	12.0	30.5
3	0.0699	6.1981	70.3	30.3	43.1
4	0.1005	6.1947	100.6	44.4	44.6
5	0.1521	6.2061	150.7	88.6	58.8
6	0.2052	6.1963	202.0	123.5	61.1
7	0.2993	6.1952	290.3	193.3	66.6
8	0.4016	6.2101	382.7	272.5	71.2

