

3854
421.02
6043

NATIONAL BUREAU OF STANDARDS REPORT

10 404

FIRE ENDURANCE TEST OF A STEEL FLOOR CONSTRUCTION FOR SINGLE FAMILY HOUSING



U.S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards¹ was established by an act of Congress March 3, 1901. Today, in addition to serving as the Nation's central measurement laboratory, the Bureau is a principal focal point in the Federal Government for assuring maximum application of the physical and engineering sciences to the advancement of technology in industry and commerce. To this end the Bureau conducts research and provides central national services in four broad program areas. These are: (1) basic measurements and standards, (2) materials measurements and standards, (3) technological measurements and standards, and (4) transfer of technology.

The Bureau comprises the Institute for Basic Standards, the Institute for Materials Research, the Institute for Applied Technology, the Center for Radiation Research, the Center for Computer Sciences and Technology, and the Office for Information Programs.

THE INSTITUTE FOR BASIC STANDARDS provides the central basis within the United States of a complete and consistent system of physical measurement; coordinates that system with measurement systems of other nations; and furnishes essential services leading to accurate and uniform physical measurements throughout the Nation's scientific community, industry, and commerce. The Institute consists of an Office of Measurement Services and the following technical divisions:

Applied Mathematics—Electricity—Metrology—Mechanics—Heat—Atomic and Molecular Physics—Radio Physics²—Radio Engineering²—Time and Frequency²—Astrophysics²—Cryogenics.²

THE INSTITUTE FOR MATERIALS RESEARCH conducts materials research leading to improved methods of measurement standards, and data on the properties of well-characterized materials needed by industry, commerce, educational institutions, and Government; develops, produces, and distributes standard reference materials; relates the physical and chemical properties of materials to their behavior and their interaction with their environments; and provides advisory and research services to other Government agencies. The Institute consists of an Office of Standard Reference Materials and the following divisions:

Analytical Chemistry—Polymers—Metallurgy—Inorganic Materials—Physical Chemistry.

THE INSTITUTE FOR APPLIED TECHNOLOGY provides technical services to promote the use of available technology and to facilitate technological innovation in industry and Government; cooperates with public and private organizations in the development of technological standards, and test methodologies; and provides advisory and research services for Federal, state, and local government agencies. The Institute consists of the following technical divisions and offices:

Engineering Standards—Weights and Measures—Invention and Innovation—Vehicle Systems Research—Product Evaluation—Building Research—Instrument Shops—Measurement Engineering—Electronic Technology—Technical Analysis.

THE CENTER FOR RADIATION RESEARCH engages in research, measurement, and application of radiation to the solution of Bureau mission problems and the problems of other agencies and institutions. The Center consists of the following divisions:

Reactor Radiation—Linac Radiation—Nuclear Radiation—Applied Radiation.

THE CENTER FOR COMPUTER SCIENCES AND TECHNOLOGY conducts research and provides technical services designed to aid Government agencies in the selection, acquisition, and effective use of automatic data processing equipment; and serves as the principal focus for the development of Federal standards for automatic data processing equipment, techniques, and computer languages. The Center consists of the following offices and divisions:

Information Processing Standards—Computer Information—Computer Services—Systems Development—Information Processing Technology.

THE OFFICE FOR INFORMATION PROGRAMS promotes optimum dissemination and accessibility of scientific information generated within NBS and other agencies of the Federal government; promotes the development of the National Standard Reference Data System and a system of information analysis centers dealing with the broader aspects of the National Measurement System, and provides appropriate services to ensure that the NBS staff has optimum accessibility to the scientific information of the world. The Office consists of the following organizational units:

Office of Standard Reference Data—Clearinghouse for Federal Scientific and Technical Information³—Office of Technical Information and Publications—Library—Office of Public Information—Office of International Relations.

¹ Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

² Located at Boulder, Colorado 80302.

³ Located at 5285 Port Royal Road, Springfield, Virginia 22151.

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

4218375

January 14, 1972

NBS REPORT

10 404

FIRE ENDURANCE TEST OF A STEEL FLOOR CONSTRUCTION FOR SINGLE FAMILY HOUSING

by
B. C. Son
Fire Research Section
Building Research Division
Institute for Applied Technology
National Bureau of Standards
Washington, D. C. 20234

IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS
for use within the Government. Before
and review. For this reason, the present
whole or in part, is not authorized for
Bureau of Standards, Washington, D. C.
the Report has been specifically prepared

Approved for public release by the
director of the National Institute of
Standards and Technology (NIST)
on October 9, 2015

accounting documents intended
subjected to additional evaluation
ting of this Report, either in
office of the Director, National
the Government agency for which
as for its own use.



U.S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

Abstract

As a part of the evaluation of Operation BREAKTHROUGH housing systems, a standard fire test performed in accordance with the requirements of procedure ASTM E119-69 was conducted on December 17, 1970, at the National Bureau of Standards on a steel floor system.

Time of failure was 8 minutes:45 seconds. The initial mode of failure was by flame-through of the floor assembly which was then followed by structural failure.

For flame spread, smoke density and gases on unexposed surfaces (carpet over plywood backing), refer to NBS Report No. FR3747.

The test results are only applicable to this particular construction with a load of 40 psf, a span of 10'7-1/4", joist spacings of 48" or 35-1/2", as described in this report.

Table of Contents

	Page
1.0 Introduction	1
2.0 Test Specimen	1
3.0 Instrumentation	2
4.0 Test Procedures	3
5.0 Test Results	4
6.0 Observations After Test and Discussion	4
7.0 Summary.	5
8.0 Reference.	6
Figures	

.

1.0 Introduction

A steel sandwich panel floor system for single family housing for the Operation BREAKTHROUGH program was submitted for a standard fire test. The sandwich panels which were 4'-0" x 10'-7 $\frac{1}{4}$ " and 2'-11 $\frac{1}{2}$ " x 10'-7 $\frac{1}{4}$ ", consisted of a paper honeycomb core with a sheet steel bottom surface and a plywood top covered with carpet. The floor panels were supported on all four edges on unprotected steel joists and beams and are therefore considered suitable only for complete perimeter support. The test was carried out in accordance with the requirements of ASTM E119-69 with a normal design load applied to the specimen.

2.0 Test Specimen

The floor consisted of five individual panels, three of which were 4'-0" x 10'-7 $\frac{1}{4}$ " and two of which were 2'-11 $\frac{1}{2}$ " x 10'-7 $\frac{1}{4}$ ". These rested on thin-wall steel joists and steel stringer beams. The steel joists were thin-wall steel C-sections, thickness 0.075 inch, width 3 inches, height 8 inches. Each floor panel was composed of a 3 inch thick paper honeycomb core, a 3/8 inch thick (grade C-D plugged interior with exterior glue) plywood top surface and a 0.02 inch thick galvanized and phosphatized steel bottom surface. The edges of the panels were closed by 3-1/8 x 1-1/2 inch (actual size) pine wood members. The construction gap between adjacent panels was measured and varied from 0 to 1/16 inch. The floor was finished with carpeting which was attached with a carpet adhesive (Stripler No. 161). The details are shown in figures 1 and 2.

Since the size of the test specimen (17'-11" x 10'-7 $\frac{1}{4}$ ") was smaller than the opening (18'-0" x 13'-6") of the NBS Floor Furnace, it was necessary to place the test specimen on two support beams and to close in the spaces between the edges of the support beams consisted of a W 10 x 21 steel section. These support beams were protected with two layers of gypsum board (type X, 5/8" thick) and finished with sprayed fine protective vermiculite plaster. The closures were made of 2 x 10 lumber protected by two layers of gypsum board on the bottom surface and plaster spray.

Butyl sealant strips $3/8$ inch wide were placed between the floor panels and butyl sealant strips $7/32$ inch wide were placed on the edge beams and outside joints.

During the erection of the test specimen, it was necessary to use a gun-type butyl sealant to complete a 14 foot long section along the perimeter floor beams. The gun-type butyl sealant was used after consultation with the Floor Panel Manufacturers. This change had no apparent effect on the fire endurance of the assembly.

Around the outer edges of the floor assembly, steel angles (18 gage, $3\frac{1}{4}$ inch, 9.25 lb/ft) were placed. These angles served as corner edge closures and were attached to the panels with $\frac{1}{2}$ inch No. 6 sheet metal screws on 16 inch centers.

See Fig. 3 for details of the steel stringers and joists resting with complete perimeter support on the WF beams. Also shown is the butyl sealant strip on the top flange of the stringer beam. Fig. 4 shows the details of the underside of the completed test specimen.

3.0 Instrumentation

The instrumentation consisted of thermocouples, floor deflection indicators and loading equipment. A total of 20 chromel-alumel (type K) thermocouples were used; 5 on top of the unexposed surface away from the joint, 4 on the joints, 6 in the second and third panels from the north end, 2 on the sides of the WF beams, 1 under the carpet, 1 on the joist and 1 at a plywood joint. The surface thermocouples were placed under standard 6" x 6" felted asbestos pads. See Fig. 5 for the locations of the thermocouples.

The temperatures of the thermocouples were printed out at 1 minute intervals on a data logger from which they were punched on cards for processing and plotting by computer.

The deflection indicators consisted of wires attached to nails placed at 5 points on the surface: at the north quarter

point, at the center of the floor assembly, at the centers of the WF beams and at the center of the east edge of the floor panel. Each wire passed over a pulley and was loaded with small weights which kept them taut. Indicating riders were attached to the wires and they passed over a vertical scale just above the small weights. Each rider indicated the amount of movement at the corresponding point of the floor during the test. Each pulley was also connected to a linear deflection potentiometer, the millivolt output of which was connected to a recorder.

4.0 Test Procedures

The design load of 40 psf was applied to the floor panels eleven minutes before the test started. This load was distributed through 24 points and approximated a uniform load.

The average temperature inside the furnace was measured by 12 protected thermocouples and followed the standard ASTM E119-69 temperature-time curve by automatic control of the gas flow to the burners. The furnace temperatures are shown in Fig. 6.

The fire endurance of a construction according to the criteria of failure in ASTM E119-69 is as follows:

- a. The construction shall have sustained the applied load during the fire endurance test without passage of flame or gases hot enough to ignite cotton waste for a period equal to that for which classification is desired.
- b. Transmission of heat through the construction during the fire endurance that shall not have been such as to raise the average temperature on its unexposed surface more than 250°F (139°C), or 325°F (181°C) at one point, above its initial temperature.

A test shall be regarded as successful if the above conditions are met.

5.0 Test Results

Flame penetration occurred at the joint between the 4th and 5th floor panels at 8 min:45 sec. test time. See Fig. 7 for location. There was a concurrent load failure at 9:00 minutes as evidenced by the inability to maintain hydraulic pressure in the loading system.

The locations where flaming occurred, the char region and the pattern of deflection after completion of the fire test and release of the applied load are shown in Fig. 7.

The average temperature rise of unexposed surface thermocouples away from the joints was less than 35°C while the maximum temperature at the joints rose over 300°C . See Fig. 8 for details.

The deflections increased steadily during the test and are shown in Fig. 9.

Figs. 10 and 11 show closeups of the deformations at a joint. Because the C-shaped joists are unsymmetrical, unless restrained, their mode of failure is in torsion bending with the open side down.

Figs. 12 and 13 show the temperature history of the six thermocouples which were placed in the floor and of the five thermocouples which were placed at the supporting beam: at the joints, under the carpet and on the C-beam respectively.

6.0 Observations After Test and Discussion

During the test the floor assembly was supported along its perimeter so the results of this test can be applied to similar assemblies that are also completely supported along their perimeters.

Delamination and charring were noted at the top and bottom surfaces of the paper honeycomb. At 1 min. 30 sec., the temperature at the bottom of the honeycomb was 540°F (see Fig. 12), which exceeds the pyrolysis temperature for the glue and probably initiated the observed delamination and charring.

It is probable that the deflection and torsion bending

of the C-beam was the main cause of test failure since this initiated the structural failure, opening the gap at the joints thereby permitting flame-through at the joints.

The honeycomb was apparently ignited by both the flame penetration at the joints and by the high temperature of the bottom steel sheet.

7.0 Summary

The fire endurance of the floor was 8 min:45 sec. Failure was by flame-through of the floor assembly.

The test results are only applicable to this particular construction with a load of 40 psf, a span of 10'7-1/4", joist spacings of 48" or 35-1/2", as described in this report.

Further informations of this test can be found in Laboratory Notebook No. 168, Test No. 480, in the Fire Research Section, National Bureau of Standards.

8.0 Reference

1. American Society for Testing and Materials, 1970
"Standard Methods of Fire Tests of Building Construction and Materials ASTM Designation E119-69" Available from the American Society for Testing Materials, 1916 Race St., Philadelphia, Pennsylvania.




Figure 1 Structure of Stringer Beams and Floor Beams (Joists)





Figure 2 Details of Specimen Constructions




Figure 3 The Steel Stringers and Joists Resting on the WF Beams. Arrow Points to Butyl Sealant Strip




Figure 4 The Underside of Completed
Test Specimen









Figure 5 Locations of Thermocouples

Figure 6







Figure 7 The Locations Where Flaming
Occurred and Associated Char
Region

Figure 8






Figure 9 Increase of Deflection During the Test



Figure 10 The Deformation of Joist




Figure 11 The Deformation of Joist

Figure 12




Figure 13

