

EVC
839

~~DOT~~
B.O. Files

NATIONAL BUREAU OF STANDARDS REPORT

5839

PERFORMANCE TESTS OF A SMITH "LIFETIME"
INPINGEMENT TYPE AIR FILTER

M

by

Thomas W. Watson and Henry E. Robinson

Report to
General Services Administration
Public Buildings Service
Washington 25, D. C.



U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

THE NATIONAL BUREAU OF STANDARDS

Functions and Activities

The functions of the National Bureau of Standards are set forth in the Act of Congress, March 3, 1901, as amended by Congress in Public Law 619, 1950. These include the development and maintenance of the national standards of measurement and the provision of means and methods for making measurements consistent with these standards; the determination of physical constants and properties of materials; the development of methods and instruments for testing materials, devices, and structures; advisory services to Government Agencies on scientific and technical problems; invention and development of devices to serve special needs of the Government; and the development of standard practices, codes, and specifications. The work includes basic and applied research, development, engineering, instrumentation, testing, evaluation, calibration services, and various consultation and information services. A major portion of the Bureau's work is performed for other Government Agencies, particularly the Department of Defense and the Atomic Energy Commission. The scope of activities is suggested by the listing of divisions and sections on the inside of the back cover.

Reports and Publications

The results of the Bureau's work take the form of either actual equipment and devices or published papers and reports. Reports are issued to the sponsoring agency of a particular project or program. Published papers appear either in the Bureau's own series of publications or in the journals of professional and scientific societies. The Bureau itself publishes three monthly periodicals, available from the Government Printing Office: The Journal of Research, which presents complete papers reporting technical investigations; the Technical News Bulletin, which presents summary and preliminary reports on work in progress; and Basic Radio Propagation Predictions, which provides data for determining the best frequencies to use for radio communications throughout the world. There are also five series of nonperiodical publications: The Applied Mathematics Series, Circulars, Handbooks, Building Materials and Structures Reports, and Miscellaneous Publications.

Information on the Bureau's publications can be found in NBS Circular 460, Publications of the National Bureau of Standards (\$1.25) and its Supplement (\$0.75), available from the Superintendent of Documents, Government Printing Office, Washington 25, D. C.

Inquiries regarding the Bureau's reports should be addressed to the Office of Technical Information, National Bureau of Standards, Washington 25, D. C.

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

NBS REPORT

1000-30-4890

April 3, 1958

5839

PERFORMANCE TESTS OF A SMITH "LIFETIME" IMPINGEMENT TYPE AIR FILTER

by

Thomas W. Watson and Henry E. Robinson

Heat Transfer Section
Building Technology Division

Report to
General Services Administration
Public Buildings Service
Washington 25, D. C.

IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS
Intended for use within the
to additional evaluation and
listing of this Report, either
the Office of the Director, NBS
however, by the Government
to reproduce additional copies

Approved for public release by the
Director of the National Institute of
Standards and Technology (NIST)
on October 9, 2015.

progress accounting documents
ormally published It is subjected
, reproduction, or open-literature
ssion is obtained in writing from
Such permission is not needed,
prepared if that agency wishes



U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

THE UNIVERSITY OF CHANGUNG
ECONOMICS DEPARTMENT

PERFORMANCE TESTS OF A SMITH "LIFETIME"
IMPINGEMENT TYPE AIR FILTER

by

Thomas W. Watson and Henry E. Robinson

1. INTRODUCTION*

At the request of the Public Buildings Service, General Services Administration, the performance characteristics of a cleanable impingement type air filter were determined to provide information to assist in the preparation of new air filter specifications.

The test results presented herein were obtained on a specimen filter submitted by its manufacturer at the request of the Public Buildings Service and included determinations of dust-arresting efficiency with two aerosols (atmospheric air and Cottrell precipitate), pressure drop, dirt load performance characteristics, and cleanability of the specimen.

2. DESCRIPTION OF THE FILTER SPECIMEN

The filter was manufactured by the Smith Filter Corporation, Moline, Illinois, and was of the cleanable viscoid type, 20 by 20 by 2 inches in nominal size. It was identified by nameplate as a Smith "Lifetime" air filter. The filtering media was composed of successive layers of vee-cripped expanded aluminum sheet arranged, with the vees of adjacent sheets at right angles, as follows, starting at the upstream face: one layer expanded metal $3/4$ by $1/4$ mesh; eight layers EM $5/16$ by $1/8$ mesh. The layers of media were compressed to a thickness of about two inches and surrounded at the edges by an aluminum frame. The filter had actual outside dimensions of 20 by 20 by 2 inches, leaving a free opening $18\ 1/4$ inches square ($2.31\ \text{ft.}^2$ net face area), and weighed 4.4 lb. when clean and oiled.

The manufacturer submitted an adhesive designated as "S-2 Filter Oil" for oiling the filter. This was done in preparation for the test by spraying the filter faces with the oil and letting the excess fluid drain off with the filter standing on edge with one corner low for 19 hours prior to the test.

*This report is submitted for information only, and is not released for use in connection with advertising or sales promotion.

3. TEST METHOD AND PROCEDURE

Efficiency determinations were made by the NBS "Dust-Spot" method using the following aerosols: (a) outdoor atmospheric air drawn through the laboratory without addition of other dust or contaminant; and (b) Cottrell precipitate, dispersed in the outdoor atmospheric air. The test method is described in the paper "A Test Method for Air Filters" by R. S. Dill (ASHVE Transactions, Vol. 44, p. 379, 1938). In conducting the tests air was sampled from the test duct at equal rates, from points one foot upstream and eight feet downstream of the filter, and passed through known areas of Whatman No. 41 filter paper. The areas of the filter papers used upstream and downstream, or the times during which the air was sampled upstream and downstream, were selected experimentally so that the change in transmission of light through the two filter paper spots would be about the same. The filter efficiency was calculated by means of the formula

$$\text{Efficiency, percent} = 100 \left[1 - \frac{A_2}{A_1} \cdot \frac{O_2}{O_1} \cdot \frac{T_1}{T_2} \right]$$

where A represents the dust spot area, O the change in light transmittance of the filter paper as measured before and after the deposition of dust, and T the time during which the air sample was drawn. Subscripts 1 and 2 refer to the upstream and downstream positions, respectively.

Two efficiency-measuring techniques, or modifications based on the above formula were used, depending on the apparent efficiency of the filter with the different aerosols. For the tests made, techniques M and N were used, as indicated in Table 2.

All light transmission measurements were made with the photometer illumination at a constant intensity, as determined by measurements on a reference of constant transmission characteristics. The filter papers used upstream and downstream were selected to have equal light transmissions when clean.

The efficiency of the filter in arresting particulate matter in atmospheric air was determined by means of two tests of the M type, as described above, with the filter clean. Following these, the efficiency of the filter in arresting Cottrell precipitate was measured by means of the N-type tests, after which was begun the process of loading the filter with a mixture of 4 percent of cotton lint and



96 percent of Cottrell precipitate, by weight, separately dispersed in the air stream. The lint used for this purpose was No. 7 cotton linters previously ground in a Wiley mill with a 4-millimeter screen. At suitable periods as loading progressed, the efficiency of the filter was determined using Cottrell precipitate in outdoor air. The pressure drop was recorded at intervals during the test. The dirt-loading was continued until the pressure drop increased to approximately 0.50 inch W.G. The efficiency was again determined with Cottrell precipitate and then with atmospheric air as the aerosols.

The filter was then removed from the test duct and cleaned by means of a stream of cold water from a high pressure hose nozzle, directed at and into the filter media.

After being dried, the filter was reoiled by spraying and, after draining approximately 20 hours, was reinstalled in the test duct for pressure drop measurements at various air flows.

4. TEST RESULTS

Table 1 presents data as to the pressure drop, at several rates of air flow, of the clean and oiled filter, and also of the same filter after it had been loaded with dirt, cleaned, and reoiled.

The performance of the filter at 800 cfm is summarized in Table 2, for both aerosols A and C. The performance of the filter in regard to aerosol C (Cottrell precipitate in atmospheric air) is also shown graphically in Figure 1. The efficiency of the filter in arresting aerosol A (atmospheric particulate matter), both initially, and after its resistance had been increased to 0.5 inch W.G., is indicated in Table 2.

Observation of the filter at the end of the dirt-loading test revealed that the greater part of the arrested dust and lint was found on the upstream face and had not penetrated the media beyond a depth of about one inch. The downstream face of the media was slightly darkened with dust at the end of the loading test.

The pressure drops recorded in Table 1 indicate that, after the filter had been subjected to loading with the dust-lint mixture and had been cleaned and reoiled, its pressure drop at 800 cfm was substantially the same. It is believed that the filter can be considered as satisfactorily cleanable.

After the unit had been removed from the test duct, the section of the duct 5 feet long downstream of the unit, and upstream of a 3/4 inch thick wood strip fastened flat across the bottom of the test duct, was carefully swept out with a fine brush. The amount of material obtained from the duct by this sweeping was 11.5 grams, or 2.0 percent of the dust load reaching the filter, constituting the fall-out in the first 5 feet of the duct from the air passed through the filter, and consisting for the most part of large dust particles with some visible lint.

Cellophane tapes, stretched across the test duct downstream of the filter with the adhesive side facing upstream, indicated upon visual and microscopic examination after exposure to the air stream that large numbers of particles of sizes up to approximately 200 microns, and some lint, had passed through the filter during the dirt-loading tests. Particles much smaller than 5 microns were observed in quantity by microscopic examination of the downstream filter papers obtained in tests with both aerosols.

TABLE 1

Pressure Drop of Clean Oiled Filter

<u>Air Flow</u> cfm	<u>Face</u> <u>Velocity</u> fpm	<u>Pressure</u> <u>Drop (1)</u> in. W.G.	<u>Pressure</u> <u>Drop (2)</u> in. W.G.
1200	520	0.170	0.176
1000	433	.121	.125
800	346	.077	.080
600	260	.047	.048

- (1) Initial values for the clean oiled filter.
- (2) Values for the filter after the dirt-loading test, cleaning operation, and reoiling.

TABLE 2

Performance of Filter at 800 CFM

<u>Inlet Aerosol (1)</u>	<u>Total Dirt Load (2) grams</u>	<u>Pressure Drop in. W.G.</u>	<u>Eff. Meas. Technique (3)</u>	<u>Efficiency percent</u>
A	-	0.077	M	11
	-	.077	M	3
C	7	.077	N	51
	14	.077	N	51
	22	.078	N	52
	50	.087	N	52
	265	.167	N	59
	340	.215	N	61
	396	.266	N	66
	489	.380	N	70
	571	.511	N	72
A	571	.511	M	28

(1) Aerosol A: Particulate matter in atmospheric air at NBS.
Aerosol C: Cottrell precipitate in atmospheric air
(1 gram per 1000 cf).

(2) Average mixture: 4 percent lint, 96 percent Cottrell precipitate, by weight.

(3) Efficiency measuring technique:

M: Air sampled at equal rates through equal areas of filter paper for equal times.

N: Air sampled at equal rates for equal times; downstream area selected to obtain approximately equal dust-spot opacities upstream and downstream.




FIG. 1

LOAD REACHING FILTER, GRAMS

EFFICIENCY, PERCENT

PRESSURE DROP, INCH W.G.

U. S. DEPARTMENT OF COMMERCE

Sinclair Weeks, *Secretary*

NATIONAL BUREAU OF STANDARDS

A. V. Astin, *Director*



THE NATIONAL BUREAU OF STANDARDS

The scope of activities of the National Bureau of Standards at its headquarters in Washington, D. C., and its major laboratories in Boulder, Colo., is suggested in the following listing of the divisions and sections engaged in technical work. In general, each section carries out specialized research, development, and engineering in the field indicated by its title. A brief description of the activities, and of the resultant publications, appears on the inside front cover.

WASHINGTON, D. C.

Electricity and Electronics. Resistance and Reactance. Electron Devices. Electrical Instruments. Magnetic Measurements. Dielectrics. Engineering Electronics. Electronic Instrumentation. Electrochemistry.

Optics and Metrology. Photometry and Colorimetry. Optical Instruments. Photographic Technology. Length. Engineering Metrology.

Heat. Temperature Physics. Thermodynamics. Cryogenic Physics. Rheology. Engine Fuels. Free Radicals Research.

Atomic and Radiation Physics. Spectroscopy. Radiometry. Mass Spectrometry. Solid State Physics. Electron Physics. Atomic Physics. Neutron Physics. Nuclear Physics. Radioactivity. X-rays. Betatron. Nucleonic Instrumentation. Radiological Equipment.

Chemistry. Organic Coatings. Surface Chemistry. Organic Chemistry. Analytical Chemistry. Inorganic Chemistry. Electrodeposition. Molecular Structure and Properties of Gases. Physical Chemistry. Thermochemistry. Spectrochemistry. Pure Substances.

Mechanics. Sound. Mechanical Instruments. Fluid Mechanics. Engineering Mechanics. Mass and Scale. Capacity, Density, and Fluid Meters. Combustion Controls.

Organic and Fibrous Materials. Rubber. Textiles. Paper. Leather. Testing and Specifications. Polymer Structure. Plastics. Dental Research.

Metallurgy. Thermal Metallurgy. Chemical Metallurgy. Mechanical Metallurgy. Corrosion. Metal Physics.

Mineral Products. Engineering Ceramics. Glass. Refractories. Enameled Metals. Concreting Materials. Constitution and Microstructure.

Building Technology. Structural Engineering. Fire Protection. Air Conditioning, Heating, and Refrigeration. Floor, Roof, and Wall Coverings. Codes and Safety Standards. Heat Transfer.

Applied Mathematics. Numerical Analysis. Computation. Statistical Engineering. Mathematical Physics.

Data Processing Systems. SEAC Engineering Group. Components and Techniques. Digital Circuitry. Digital Systems. Analog Systems. Application Engineering.

* Office of Basic Instrumentation.

* Office of Weights and Measures.

BOULDER, COLORADO

Cryogenic Engineering. Cryogenic Equipment. Cryogenic Processes. Properties of Materials. Gas Liquefaction.

Radio Propagation Physics. Upper Atmosphere Research. Ionospheric Research. Regular Propagation Services. Sun-Earth Relationships. VHF Research.

Radio Propagation Engineering. Data Reduction Instrumentation. Modulation Systems. Navigation Systems. Radio Noise. Tropospheric Measurements. Tropospheric Analysis. Radio Systems Application Engineering. Radio Meteorology.

Radio Standards. High Frequency Electrical Standards. Radio Broadcast Service. High Frequency Impedance Standards. Calibration Center. Microwave Physics. Microwave Circuit Standards.

