

~~DEF~~  
10.0

# NATIONAL BUREAU OF STANDARDS REPORT

6250

PERFORMANCE TESTS OF AN AUTOMATIC RENEWABLE MEDIA AIR FILTER  
WITH TWO FILTER MEDIA,  
CONOMATIC, MODEL 3-C90

MANUFACTURED BY  
CONTINENTAL AIR FILTERS, INC.  
LOUISVILLE, KENTUCKY

by

Carl W. Coblenz and Paul R. Achenbach

Report to  
General Services Administration  
Public Buildings Service  
Washington 25, D. C.



U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS

FOR OFFICIAL USE ONLY

## THE NATIONAL BUREAU OF STANDARDS

### Functions and Activities

The functions of the National Bureau of Standards are set forth in the Act of Congress, March 3, 1901, as amended by Congress in Public Law 619, 1950. These include the development and maintenance of the national standards of measurement and the provision of means and methods for making measurements consistent with these standards; the determination of physical constants and properties of materials; the development of methods and instruments for testing materials, devices, and structures; advisory services to Government Agencies on scientific and technical problems; invention and development of devices to serve special needs of the Government; and the development of standard practices, codes, and specifications. The work includes basic and applied research, development, engineering, instrumentation, testing, evaluation, calibration services, and various consultation and information services. A major portion of the Bureau's work is performed for other Government Agencies, particularly the Department of Defense and the Atomic Energy Commission. The scope of activities is suggested by the listing of divisions and sections on the inside of the back cover.

### Reports and Publications

The results of the Bureau's work take the form of either actual equipment and devices or published papers and reports. Reports are issued to the sponsoring agency of a particular project or program. Published papers appear either in the Bureau's own series of publications or in the journals of professional and scientific societies. The Bureau itself publishes three monthly periodicals, available from the Government Printing Office: *The Journal of Research*, which presents complete papers reporting technical investigations; the *Technical News Bulletin*, which presents summary and preliminary reports on work in progress; and *Basic Radio Propagation Predictions*, which provides data for determining the best frequencies to use for radio communications throughout the world. There are also five series of nonperiodical publications: *The Applied Mathematics Series*, *Circulars*, *Handbooks*, *Building Materials and Structures Reports*, and *Miscellaneous Publications*.

Information on the Bureau's publications can be found in NBS Circular 460, *Publications of the National Bureau of Standards* (\$1.25) and its *Supplement* (\$0.75), available from the Superintendent of Documents, Government Printing Office, Washington 25, D. C.

Inquiries regarding the Bureau's reports should be addressed to the Office of Technical Information, National Bureau of Standards, Washington 25, D. C.

# NATIONAL BUREAU OF STANDARDS REPORT

**NBS PROJECT**  
1000-30-4830

**NBS REPORT**  
6250

December 23, 1958

**PERFORMANCE TESTS OF AN AUTOMATIC RENEWABLE MEDIA AIR FILTER  
WITH TWO FILTER MEDIA,  
CONOMATIC, MODEL 3-C90**

**MANUFACTURED BY  
CONTINENTAL AIR FILTERS, INC.  
LOUISVILLE, KENTUCKY**

by

**Carl W. Coblentz and Paul R. Achenbach  
Air Conditioning, Heating and Refrigeration Section  
Building Technology Division**

to

**General Services Administration  
Public Buildings Service  
Washington 25, D. C.**

## IMPORTANT NOTICE

**NATIONAL BUREAU  
Intended for use with  
to additional evaluation  
listing of this Report,  
the Office of the Director  
however, by the Government  
to reproduce additional**

Approved for public release by the  
Director of the National Institute of  
Standards and Technology (NIST)  
on October 9, 2015.

progress accounting documents  
ormally published it is subjected  
reproduction, or open-literature  
ation is obtained in writing from  
Such permission is not needed,  
prepared if that agency wishes



**U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS**



PERFORMANCE TESTS OF AN AUTOMATIC RENEWABLE MEDIA  
AIR FILTER WITH TWO FILTER MEDIA,  
CONOMATIC, MODEL 3-C90

by

Carl W. Coblentz and Paul R. Achenbach

1. Introduction

At the request of the Public Buildings Service, General Services Administration, the performance characteristics of a Conomatic, automatically-renewable media type air filter were determined with a glass fiber and with a plastic fiber filter media. The scope of this investigation included the determination of arrestance of atmospheric dust and Cottrell precipitate, the dust holding capacity per unit area of filter media and the characteristics of the automatic movement of the filter media.

2. Description of Test Specimen

The test specimen was manufactured and supplied for test by Continental Air Filters, Inc., of Louisville, Kentucky, and was identified as their type "Conomatic 3-C90". It was modified for installation in the NBS test apparatus by building a sheet metal housing around it and providing upstream and downstream transition sections, 24 in. square inside, to fit the test duct. This modification was necessary for the adaptation of the filter and did not affect the performance of the equipment.

The "Conomatic" filter was designed to move a long blanket or mat of filter medium across the air flow opening in the housing by intermittent feed under automatic control. A roll of the clean medium was held at the top of the housing from which it was unrolled as needed by a spool at the bottom of the housing. The lower spool was driven by a 1/6 HP electric motor and a reduction gear which was connected to a sprocket wheel by a standard gear chain. This sprocket wheel was directly coupled to the empty spool at the bottom of the housing on which the soiled filter media was rolled up. In passing from the clean roll at the top to the bottom roll the media was backed up by a stationary vertical grid that prevented the media from being stretched by the air flow as it passed across the air stream.



The movement of the blanket was controlled by a differential pressure switch built by the Republic Auto Gas Corporation. This control started the electric motor when the pressure drop across the medium had risen to a preselected value and stopped it when the pressure drop was reduced by an increment of almost 0.05 in. W.G. by feeding some clean media into the air stream. The speed of the lower spool while moving the media was about 1 RPM. Depending on how much media had been wound up on the lower spool the rate of feed of the filter media during these periods varied from about 1 ft/min to 3 ft/min.

Two different filter media were furnished with the unit. One was a 2-inch thick Fiberglas mat for general use and the other one consisted of a 1/2-inch thick light plastic felt for use in food processing plants or where the user wanted to guard against the possible contamination of the air with glass fiber particles. The media width was 32 in. for both materials.

### 3. Test Method and Procedure

Arrestance determinations were made with the NBS "Dust Spot Method" using the following aerosols: (a) air drawn from the laboratory without addition of other dust or contaminant and (b) Cottrell precipitate. The test method is described in the paper "A Test Method for Air Filters" by R. S. Dill (ASHVE Transactions, Vol. 44, p. 379, 1938).

For this test, the unit was installed in the test duct and carefully sealed to prevent inleakage of air except through the measuring orifice. The desired rate of air flow through the filter was established and samples of air were drawn from the center points of the test duct one foot upstream and eight feet downstream of the test specimen at equal rates and passed through known areas of Whatman No. 41 filter paper. The ratios of the upstream and downstream filter paper areas were selected to obtain a similar increase of opacity, and with air drawn through both samplers for the full period, the arrestance was computed by the following formula:

$$A = 100 - \left[ \frac{A_D}{A_U} \times \frac{\Delta D}{\Delta U} \right] \times 100$$





where  $A_D$  and  $A_U$  are the downstream and upstream filter paper areas and  $\Delta D$  and  $\Delta U$  the respective changes in opacity of the samplers.

Each test with atmospheric dust required from one to two hours and, in order to make the increase of opacity of the two samplers more nearly equal, the upstream sampling air was drawn through the sampler for only part of the time. If "T" is the percentage of the time during which air was drawn through the upstream sampler while air through the downstream sampler was drawn continuously, the formula for computing arrestance would be:

$$A = 100 - \left[ T \times \frac{A_D}{A_U} \times \frac{\Delta D}{\Delta U} \right] \times 100$$

The two filter papers used for each test were selected to have the same opacity readings when clean.

During operation, the pressure drop of an automatic self-cleaning air filter of this type increases due to the accumulating dust load until it reaches the value at which the pressure switch is set to operate the roller mechanism. As clean media is then moved into the air stream, the pressure drop decreases until the pressure switch stops the roller drive. The filter then operates repetitively in the on-off range of the pressure switch, the differential controlling the amount of clean media that is moved into the air stream and the rate of dust accumulation determining the frequency of the cycles. Since the operation of this type of filter at a high pressure drop increases the dust load per unit area of filter media it reduces the consumption of the material but the increased blower power tends to offset the saving on filter material. For this test, the pressure switch was adjusted to start the roller mechanism at about 0.50 in. W.G. and stop it at about 0.45 in. W.G. which was in line with common operating practice for self-cleaning air filters at a face velocity of 500 ft/min.

The following procedure was used for determining the performance of the test specimen: The unit was installed between the upstream and downstream sections of the test apparatus and carefully sealed against extraneous leakage of air.



With the clean filter media in the air stream the pressure drop was measured at the rated face velocity of 500 ft/min and also at 400 and 600 ft/min. The arrestance of the filter at the rated face velocity was determined first with only the particulate matter in the laboratory air as the aerosol and thereafter with Cottrell precipitate. The loading of the filter was performed with a mixture of 96 parts by weight of Cottrell precipitate to 4 parts of cotton lint in a concentration of one gram per 1000 cu ft of air. The Cottrell precipitate and the lint were dispersed separately into the air stream. The lint used for this purpose was No. 7 cotton linters previously ground in a Wiley mill with a 4-millimeter screen. It was dispersed into the air stream through an aspirator operating at approximately 35 psi inlet air pressure. At intervals, the arrestance determinations with Cottrell precipitate and with the particulate matter in the laboratory air as the aerosol were repeated.

Markers were fastened to the filter media which could be observed through a glass window in the test duct to determine the amounts of clean media fed into the air stream at each roller operation. A pilot light was connected in parallel with the roller motor which lighted when the motor was operating the shift mechanism. This arrangement enabled the operator to record the pressure drop at the beginning and at the end of each advance of the filter media and also provided information on the consumption of filter media.

Each of the two filter mats was tested as follows. A total of 10 arrestance values were made of the fiber glass mat until it had advanced a total of 40 inches during 12 roller cycles. The Dycon mat was tested during 21 roller cycles with a total advance of 46.5 inches and 12 arrestance determinations were made on this material. In both cases, the test was continued until the arrestance values became steady indicating that repetitive conditions existed during each roller cycle.

#### 4. Test Results

The results of the tests are shown in four tables. Tables 1 and 2 summarize for the two different filter media the arrestance values determined with both the particulate matter in the laboratory air and Cottrell precipitate. They also give the accumulated dust loads in grams per 1 ft width of the filter media, the total media travel and the pressure drop of the filter at the



Table 1

Summary of Arrestance Tests  
Conomatic, Model 3-C90  
With Fiberglas Filter Mat

Dust Load g/ft	Total Mat Travel in.	Pressure Drop in. W.G.	Arrestance %	Aerosol**
0	0	0.233	17*	A
10	0	0.245	80*	C
109	0	0.477	85	C
135	7-1/2	0.451	20	A
291	29	0.418	20	A
301	29	0.432	84	C
368	37-1/2	0.488	84	C
383	40	0.437	20	A

\* Average of two tests

\*\* Aerosol A- Particulate matter in the laboratory air.

Aerosol B- Cottrell precipitate in the laboratory air.



Table 2

Summary of Arrestance Tests  
Conomatic, Model 3-C90, With Dycon Filter Mat

Dust Load g/ft	Total Mat Travel in.	Pressure Drop in. W.G.	Arrestance %	Aerosol**
0	0	0.206	9*	A
10	0	0.217	67*	C
130	3-1/2	0.494	74	C
337	25-1/2	0.464	78	C
342	25-1/2	0.483	18	A
430	35-1/2	0.458	74*	C
436	35-1/2	0.470	17	A
498	44-1/2	0.434	20	A
524	46-1/2	0.475	20	A

\* Average of two tests

\*\* Aerosol A- Particulate matter in the laboratory air.

Aerosol C- Cottrell precipitate in the laboratory air.





end of each arrestance measurement. The average initial arrestance of the Fiberglas media with atmospheric dust was 17 percent and with Cottrell precipitate was 80 percent. As the test continued, these values increased and they leveled out at 20 percent and 84 percent, respectively. The initial arrestance of the Dycon mat was found to be 9 percent and 67 percent, respectively. However, the steady state value for particulate matter in the laboratory air was also 20 percent, the same as determined for the Fiberglas mat, and the arrestance of Cottrell precipitate was 74 percent.

Tables 3 and 4 present a summary of the mat travel of the two media during each shift and also cumulatively. The values for the dust loads reported in these tables were interpolated between the 20 g loaded into the feeder hopper at one time and are correct to within  $\pm 3$  g. It will be noted that the increments of advance of the filter mat during individual roller cycles, varied from 1-1/2 in. to 3 in. with the exception of the two first advances of the Dycon mat, which were 4 and 3-1/2 inches, respectively. The values shown for the travel of the mat are correct to  $\pm 1/2$  in.

The differential pressure started the roller drive mechanism at 0.494 in. W.G. at the beginning of the test with the Dycon mat, whereas at the end of this test the cut-in pressure had decreased to 0.480 in. W.G. and further decreased during the test of the Fiberglas mat to 0.470 in. W.G. This condition was not noticed during the test. It may have been caused by not properly securing the adjustment screw of the pressure switch. The differential pressure remained practically steady during the whole test at slightly below 0.05 in. W.G.

Fig 1 and 2 are graphs of the arrestance determinations and of the mat travel values plotted against the dust load for the two filter media.

The amount of Cottrell precipitate collected on a unit area of filter media during the steady state operation of the unit provides some measure of the consumption of filter media during actual use. Disregarding the relatively small amounts of particulate matter collected during the tests in which the arrestance of the filter was determined with laboratory air, the slope of the straight portion of the lower curves in Fig 1 and 2 (during the steady state condition) indicates the unit dust-holding capacity of the filter media.



Table 3

Dust Load, Mat Travel and Pressure Drop Characteristics  
 Conomatic, Model 3-C90 With Fiberglas Filter Mat

Dust Load g/ft	Mat Travel, in.		Pressure Drop, in. W. G.	
	Advance	Total	Before Advance	After Advance
0	0	0	0.233	-
110	4	4	0.480	0.431
116	3-1/2	7-1/2	0.480	0.429
140	3	10-1/2	0.478	0.424
165	3	13-1/2	0.478	0.424
182	2-1/2	16	0.475	0.428
200	2-1/2	18-1/2	0.478	0.424
222	2-1/2	21	0.474	0.424
246	2-1/2	23-1/2	0.470	0.420
268	2-1/2	26	0.471	0.420
290	3	29	0.470	0.418
314	3	32	0.470	0.421
336	2-1/2	34-1/2	-	0.420
360	3	37-1/2	0.470	0.419
384	2-1/2	40	0.470	0.422



Table 4

Dust Load, Mat Travel and Pressure Drop Characteristics  
 Conomatic, Model 3-C90 With Dycon Filter Mat

<u>Dust Load</u> g/ft	<u>Travel of Mat, in.</u>		<u>Pressure Drop, in. W. G.</u>	
	Advance	Total	Before Advance	After Advance
0	0	0	0.206	-
130	3-1/2	3-1/2	0.494	0.438
145	2-1/2	6	0.490	0.444
165	3	9	0.494	0.445
190	2-1/2	11-1/2	0.495	0.446
209	2	13-1/2	0.494	0.450
230	2-1/2	16	0.493	0.446
252	2	18	0.490	0.444
270	1-1/2	19-1/2	0.490	0.443
282	2	21-1/2	0.490	0.442
299	2	23-1/2	0.488	0.444
320	2	25-1/2	0.490	0.443
340	2	27-1/2	0.490	0.440
360	2-1/2	30	0.488	0.430
376	1-1/2	31-1/2	0.480	0.436
397	2	33-1/2	0.481	0.430
410	2	35-1/2	0.480	0.432
429	2	37-1/2	0.480	0.436
446	2-1/2	40	0.480	0.432
470	2	42	0.480	0.430
492	2-1/2	44-1/2	0.480	0.431
512	2	46-1/2	-	0.430



According to Fig 1, the Fiberglas mat traveling from position 16 inch to 40 inch, a distance 2 ft, was fed dust in the amount of 207 g/ft width, indicating a dust-holding capacity 103.5 g/sq ft. Correspondingly, from Fig 2, the Dycon mat traveling from position 20 inch to 44 inch, a distance of 2 ft, was fed dust in the amount of 214 g/ft width, indicating a dust-holding capacity of 107 g/sq ft.

A summary of the performance of both filter media is presented in Table 5 below.

Table 5

Summary of Test Results  
Conomatic Automatic Renewable Media Air Filter

	<u>Fiberglas Mat</u>	<u>Dycon Mat</u>
Face Velocity, ft/min	500	500
Pressure Drop, clean, in. W.G.	0.233	0.206
Average Operating Pressure Drop Range, in. W.G.	0.475 to 0.425	0.487 to 0.438
Arrestance, %		
Mat Clean: Laboratory Air	17	9
Cottrell Precipitate	80	67
Steady State: Laboratory Air	20	20
Cottrell Precipitate	84	74
Dust-Holding Capacity, g/sq ft	103.5	107.0
Pressure Drop of Clean Filter, in. W.G.		
at 400 ft/min Face Velocity	0.169	0.148
at 600 ft/min Face Velocity	0.305	0.270








FIG. 1





CONOMATIC WITH DYCON FILTER MAT




FIG. 2





U. S. DEPARTMENT OF COMMERCE

Lewis L. Strauss, *Secretary*

NATIONAL BUREAU OF STANDARDS

A. V. Astin, *Director*



## THE NATIONAL BUREAU OF STANDARDS

The scope of activities of the National Bureau of Standards at its headquarters in Washington, D. C., and its major laboratories in Boulder, Colo., is suggested in the following listing of the divisions and sections engaged in technical work. In general, each section carries out specialized research, development, and engineering in the field indicated by its title. A brief description of the activities, and of the resultant publications, appears on the inside front cover.

### WASHINGTON, D. C.

- Electricity and Electronics.** Resistance and Reactance. Electron Devices. Electrical Instruments. Magnetic Measurements. Dielectrics. Engineering Electronics. Electronic Instrumentation. Electrochemistry.
- Optics and Metrology.** Photometry and Colorimetry. Optical Instruments. Photographic Technology. Length. Engineering Metrology.
- Heat.** Temperature Physics. Thermodynamics. Cryogenic Physics. Rheology. Engine Fuels. Free Radicals Research.
- Atomic and Radiation Physics.** Spectroscopy. Radiometry. Mass Spectrometry. Solid State Physics. Electron Physics. Atomic Physics. Neutron Physics. Radiation Theory. Radioactivity. X-rays. High Energy Radiation. Nucleonic Instrumentation. Radiological Equipment.
- Chemistry.** Organic Coatings. Surface Chemistry. Organic Chemistry. Analytical Chemistry. Inorganic Chemistry. Electrodeposition. Molecular Structure and Properties of Gases. Physical Chemistry. Thermochemistry. Spectrochemistry. Pure Substances.
- Mechanics.** Sound. Mechanical Instruments. Fluid Mechanics. Engineering Mechanics. Mass and Scale. Capacity, Density, and Fluid Meters. Combustion Controls.
- Organic and Fibrous Materials.** Rubber. Textiles. Paper. Leather. Testing and Specifications. Polymer Structure. Plastics. Dental Research.
- Metallurgy.** Thermal Metallurgy. Chemical Metallurgy. Mechanical Metallurgy. Corrosion. Metal Physics.
- Mineral Products.** Engineering Ceramics. Glass. Refractories. Enamelled Metals. Concreting Materials. Constitution and Microstructure.
- Building Technology.** Structural Engineering. Fire Protection. Air Conditioning, Heating, and Refrigeration. Floor, Roof, and Wall Coverings. Codes and Safety Standards. Heat Transfer.
- Applied Mathematics.** Numerical Analysis. Computation. Statistical Engineering. Mathematical Physics.
- Data Processing Systems.** SEAC Engineering Group. Components and Techniques. Digital Circuitry. Digital Systems. Analog Systems. Application Engineering.
- Office of Basic Instrumentation.
  - Office of Weights and Measures.

### BOULDER, COLORADO

- Cryogenic Engineering.** Cryogenic Equipment. Cryogenic Processes. Properties of Materials. Gas Liquefaction.
- Radio Propagation Physics.** Upper Atmosphere Research. Ionospheric Research. Regular Propagation Services. Sun-Earth Relationships. VHF Research. Ionospheric Communication Systems.
- Radio Propagation Engineering.** Data Reduction Instrumentation. Modulation Systems. Navigation Systems. Radio Noise. Tropospheric Measurements. Tropospheric Analysis. Radio Systems Application Engineering. Radio-Meteorology.
- Radio Standards.** High Frequency Electrical Standards. Radio Broadcast Service. High Frequency Impedance Standards. Electronic Calibration Center. Microwave Physics. Microwave Circuit Standards.

