

~~SECRET~~

# NATIONAL BUREAU OF STANDARDS REPORT

**NBS PROJECT**  
1003-20-4891

May 5, 1959

**NBS REPORT**  
6401

CAPACITY TESTS OF A REMOTE AIR-COOLED  
SIZE B, CLASS I REFRIGERANT CONDENSER

MANUFACTURED BY  
THERMO KING CORPORATION

by

F. J. J. Drapeau and C. W. Phillips  
Air Conditioning, Heating, and Refrigeration Section  
Building Technology Division

to

Mechanical Engineering Division  
Headquarters,  
Quartermaster Research and Engineering Command  
Natick, Massachusetts

IMPORTANT NOTICE

NATIONAL BUREAU OF  
intended for use within  
to additional evaluation  
listing of this Report, at  
the Office of the Director  
however, by the Government  
to reproduce additional

Approved for public release by the  
Director of the National Institute of  
Standards and Technology (NIST)  
on October 9, 2015.

or progress accounting documents  
is formally published it is subjected  
ting, reproduction, or open-literature  
permission is obtained in writing from  
.C. Such permission is not needed,  
cally prepared If that agency wishes



U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS



CAPACITY TESTS OF A REMOTE AIR-COOLED  
SIZE B, CLASS I REFRIGERANT CONDENSER

MANUFACTURED BY  
THERMO KING CORPORATION

by

F. J. J. Drapeau and C. W. Phillips

1. Introduction

Capacity tests were made of a remote air-cooled refrigerant condenser, Size B, Class I, manufactured by the Thermo King Corporation of Minneapolis, Minnesota. This specimen was identified for testing purposes as NBS 178-58.

The tests were made with an apparatus conforming in most details to that described in the proposed ASRE Standard, PS 2.4, for remote air-cooled condensers. This apparatus provided a means for measuring the heat transfer capacity of this specimen by the psychrometric method and by the refrigerant flow method.

2. Test Procedure

Capacity tests were made at two values of saturation temperature of the refrigerant vapor entering the condenser, following the procedure and test conditions set forth in ASRE PS 2.4. At the higher saturation temperature of 130°F, tests were made at three air flow rates; namely, at the free discharge capacity of the fan, and at one lower and one higher value, ranging from 2950 cfm to 4100 cfm. In addition, one test was made at the high ambient temperature of 110°F, established as a standard for QMR&E application.

These tests are a part of a series of tests planned under the Condenser Standardization Project, QMREL-M P.O. 57-26, to determine the possibility of standardizing air-cooled condenser performance on the basis of maximum overall dimensions and minimum air flow rate.

This condenser was tested with a Torrington propeller fan with air delivery capacity meeting the minimum requirement of the QMR&E Purchase Description dated March 22, 1957. However,



this condenser did not come equipped with a shroud or bellmouth orifice plate. To facilitate the tests, these parts were fabricated by the Sheet Metal Shop at NBS. A bellmouth radius of approximately  $3/8$ " , somewhat less than the QMR&E established minimum of  $1/2$ " ; and an orifice diameter varying from the QMR&E specified value of  $24\ 1/2$ " by not more than  $\pm 1/8$ " were constructed for the tests.

### 3. Test Results

The results obtained and the dimensional data describing this condenser are attached. Fig. 1 indicates the shape and tube arrangement, and uses letter symbols to identify the dimensions of the specimen as summarized in Table 1. Table 1 describes the materials and construction of the condenser and lists significant dimensions of coil, fins, and complete unit.

Table 2 summarizes the test data and the heat rejection capacity ratings and heat transfer coefficients computed therefrom. Fig. 2 is a pressure-enthalpy diagram labeled with the symbols used in the proposed ASRE Standard, PS 2.4. This diagram indicates the changes in state conditions of the refrigerant occurring between the condenser inlet and outlet.

In order to provide a further means for comparing the performance of the various arrangements of tubes, tube arrangements, fins, etc., of the several condensers in this test program, two additional coefficients, which can be considered as Items 24 and 25 of Table 2, are as follows:

Item 24 Heat Rejection per Unit of Total Surface Area per Degree F Log Mean Temperature Difference, Btu/hr  $(ft)^2(^{\circ}F)$

Item 25 Heat Rejection per Unit of Total Surface Area per Degree F Log Mean Temperature Difference per cfm of Standard Air, Btu/hr  $(ft)^2(^{\circ}F)(cfm)$



Addition to Table 2

<u>Item</u>	<u>ASRE High Sat'n. Temp.</u>			<u>ASRE Low Sat'n. Temp.</u>	<u>QMR&amp;E High Ambient Temp.</u>
	<u>High</u>	<u>Free Discharge</u>	<u>Low</u>		
24	7.77	7.18	6.74	5.81	7.30
25	.00207	.00207	.00250	.00175	.00230

It should be noted that the heat rejection capacity of this condenser at the QMR&E High Ambient Temperature conditions was 102.5 percent of the required value of 35,600 Btu per hour.





CONDENSER SPECIMEN

MFR. Thermo King Corp.

NBS NO. 178-58

SIZE - B

CLASS - 1





Fig 1



PRESSURE - ENTHALPY  
DIAGRAM  
NO SCALE



NOTE 1  
LABELED IN ACCORDANCE  
WITH ASRE PS 2.4

CONDENSER SPECIMEN  
DIAGRAM




Fig 2



## CONDENSER SPECIMEN

MFR. Thermo King, Corp.		SIZE - B
NBS NO. 178-58		CLASS - 1
ITEM	PROPERTY	REMARKS
<b>COIL TUBE CHARACTERISTICS</b>		
1 MATERIAL	Copper	Type L
2 NUMBER OF ROWS DEEP	3	
3 NUMBER OF TUBES HIGH	26	
4 NUMBER OF CIRCUITS IN PARALLEL	3	
5 NUMBER OF TUBES PER CIRCUIT	26	
6 TUBE DIAMETER, O.D., IN.	1/2	
7 TUBE WALL THICKNESS, IN.	0.042	
8 TUBE RETURN BEND DIAMETER, O.D., IN.	1/2	
9 GAS INLET CONNECTION DIAM., O.D., IN.	7/8	
10 LIQUID OUTLET CONN. DIAMETER, O.D., IN.	5/8	
11 VERTICAL TUBE SPACING, IN.      S	1.3	
12 PRIMARY SURFACE AREA, SQ. FT.	23.2	
<b>COIL FIN CHARACTERISTICS</b>		
1 MATERIAL	Aluminum	
2 TYPE OF FIN	Flat	Rolled Collar
3 FIN SPACING, PER INCH	8	191 Fins
4 FIN THICKNESS, IN.	0.015	
5 SECONDARY SURFACE AREA, SQ. FT.	238.3	
<b>COIL DIMENSIONS</b>		
1 FINNED HEIGHT, IN.      K	32.5	
2 FINNED WIDTH, IN.      F	27.0	
3 FINNED DEPTH, IN.      V	3.0	
4 COIL HEIGHT, IN.      H	31.9	
5 COIL WIDTH, IN.      W	29.5	
6 COIL DEPTH, IN.      D	2.0	
7 COIL DEPTH, OVERALL, IN.      N	10.8	
8 FACE AREA, SQ. FT.	6.2	
9 TOTAL SURFACE AREA, SQ. FT.	261.5	
<b>OVERALL CONDENSER DIMENSIONS</b>		
1 WIDTH, OVERALL, IN.      A	32.5	
2 WIDTH, SHROUD, IN.      B	27.5	Manufactured by NBS
3 HEIGHT, IN.      C	34.1	
4 DEPTH, IN.      E	11.0	
5 BELLMOUTH ORIFICE DIAMETER, IN.      X	24.5	Manufactured by NBS
6 BELLMOUTH RADIUS, IN.      R	3/8	Manufactured by NBS

Table 1



# CONDENSER SPECIMEN

MFR. Thermo King Corp. NBS NO. 178-58 SIZE - B CLASS - I

ITEM	ASRE HIGH SATURATION TEMPERATURE				ASRE LOW SATURATION TEMPERATURE			QMR & HIGH AMBIENT TEMPERATURE	
	OBSERVED CONDITION		OBSERVED CONDITION		OBSERVED CONDITION		OBSERVED CONDITION		FREE DISCHARGE
	HIGH	FREE DISCH.	HIGH	LOW	STANDARD CONDITION	AIR FLOW RATE CFM	AIR FLOW RATE CFM	AIR FLOW RATE CFM	
AIR CIRCULATING EQUIPMENT AND REFRIGERANT USED FAN MFR. Torrington FAN SERIAL NO. E-2420-4 FAN SPEED 1140 MOTOR HP RATING 0.500 REFRIGERANT Freon-12									
1. BAROMETRIC PRESSURE	P <sub>ab</sub>	"Hg	29.921	29.921	29.921	29.921	29.921	29.921	29.62
2. DRY BULB TEMPERATURE OF AIR ENTERING COIL	t <sub>ae</sub>	°F	95	95.2	95.0	95.0	95	95.0	110.0
3. WET BULB TEMPERATURE OF AIR ENTERING COIL	t <sub>we</sub>	°F	75±5	75.2	77.0	77.0	75±5	75.2	74.2
4. DRY BULB TEMPERATURE OF AMBIENT AIR	t <sub>ae</sub>	°F	95	95.2	95.0	95.0	95	95.0	110.0
5. SATURATION TEMPERATURE OF ENTERING REFRIGERANT VAPOR	t <sub>sc</sub>	°F	130	130.0	129.8	129.8	105	105.4	135.5
6. ENTERING REFRIGERANT VAPOR	t <sub>sc</sub>	°F	195*10	194.6	195.2	195.2	170*10	172.0	195.1
AIR FLOW METHOD									
7. NOZZLE AIR AND WATER VAPOR MIXTURE FLOW RATE	Q <sub>ad</sub>	CFM	4100	3620	2950	2950		3610	3540
8. TOTAL HEAT REJECTION CAPACITY	q <sub>tc</sub>	BTUH	57650	51250	46500	46500		13850	37850
REFRIGERANT FLOW METHOD									
9. REFRIGERANT FLOW RATE	W <sub>r</sub>	lb/min	14.47	12.95	11.73	11.73		3.29	9.79
10. CONDENSER COIL INTERNAL PRESSURE DROP	ΔP <sub>c</sub>	PSI	3.12	2.45	2.44	2.44		0.55	1.33
11. SUBCOOLING OF LEAVING REFRIGERANT LIQUID	ΔT <sub>s</sub>	°F	10* MAX.	3.7	3.8	3.8	5* MAX.	1.0	3.7
12. TOTAL HEAT REJECTION CAPACITY	q <sub>tr</sub>	BTUH	56500	50050	45500	45500		13300	36750
RATINGS									
13. TOTAL HEAT REJECTION	q <sub>tr</sub>	BTUH	56100	50900	46300	46300		13050	35600
14. CONDENSING HEAT REJECTION	q <sub>cr</sub>	BTUH	54350	49950	45400	45400		13000	35900
15. SUBCOOLING HEAT REJECTION	q <sub>sr</sub>	BTUH	1750	950	900	900		50	600
16. AIR FLOW RATE	Q <sub>r</sub>	CFM	3750	3320	2700	2700		3320	3170
17. CONDENSER COIL EXTERNAL RESISTANCE	P <sub>ss</sub>	"H <sub>2</sub> O	0.24	0.20	0.13	0.13		0.20	0.20
18. FAN MOTOR POWER	P <sub>fm</sub>	WATTS	450	520	600	600		520	520
19. FAN BRAKE HORSEPOWER	P	BHP	-	-	-	-		-	-
20. HEAT REJECTION PER UNIT PRIMARY SURFACE AREA	BTUH/SF		2418	2194	1996	1996		563	1573
21. HEAT REJECTION PER UNIT SECONDARY SURFACE AREA	BTUH/SF		235.4	213.6	194.3	194.3		54.8	153.2
22. HEAT REJECTION PER UNIT TOTAL SURFACE AREA	BTUH/SF		214.5	194.6	177.1	177.1		49.9	139.6
23. HEAT REJECTION PER CFM	BTUH		15.0	15.3	17.1	17.1		3.9	11.5

Table 2

