

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

NBS REPORT

1003-20-4891

February 19, 1960

6670

**CAPACITY TESTS OF TWO REMOTE AIR-COOLED
SIZE B REFRIGERANT CONDENSERS**

Manufactured by
Kramer Trenton Company
Trenton, New Jersey

by

F. J. J. Drapeau and C. W. Phillips
Air Conditioning, Heating, and Refrigeration Section
Building Technology Division

to
Mechanical Engineering Division
Headquarters,
Quartermaster Research and Engineering Command
Natick, Massachusetts

IMPORTANT NOTICE

NATIONAL BUREAU OF ST/ intended for use within the (to additional evaluation and re listing of this Report, either in the Office of the Director, Nat however, by the Government : to reproduce additional copie

Approved for public release by the Director of the National Institute of Standards and Technology (NIST) on October 9, 2015.

gress accounting documents nally published It is subjected reproduction, or open-literature ion is obtained in writing from Such permission is not needed, prepared if that agency wishes



**U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS**

FOR OFFICIAL USE ONLY

CAPACITY TESTS OF TWO REMOTE AIR-COOLED SIZE B REFRIGERANT CONDENSERS

Manufactured by
Kramer Trenton Company
Trenton, New Jersey

by

F. J. J. Drapeau and C. W. Phillips

1. INTRODUCTION

Capacity tests were made of two specimens of Size B remote air-cooled refrigerant condensers manufactured by the Kramer Trenton Company of Trenton, New Jersey. These specimens were of identical dimensions and were identified for testing purposes as NBS 147-58 and NBS 146-58. Specimen NBS 147-58 was a Class 1 condenser and consisted of a copper coil with aluminum fins. Specimen NBS 146-58 was a Class 2 condenser and consisted of a copper coil with copper fins.

The tests were made with an apparatus conforming in most details to that described in the proposed ASRE Standard for remote air-cooled condensers, PS2.4. This apparatus provided a means for measuring the heat transfer capacity of the specimens by the psychrometric method and by the refrigerant flow method.

2. TEST PROCEDURE

The capacity tests were made at an ambient temperature of 110°F, established as a standard for QMR&E application.

These tests were a part of a series of tests planned under the Condenser Standardization Project, QMREL-M P.O. 57-26, to determine the possibility of standardizing air-cooled condenser performance on the basis of maximum overall dimensions and minimum air flow rate.

These condensers were tested with a Torrington propeller fan with air delivery capacity meeting the minimum requirement of the QMR&E Purchase Description dated March 22, 1957.

3. TEST RESULTS

The results obtained and the dimensional data describing these condensers are attached. Figure 1 indicates the shape and tube arrangement of both specimens, and uses letter symbols to identify the dimensions of the specimens as summarized in Tables 1 and 2. Table 1 describes the materials and construction of the Class 1 condenser with aluminum fins and lists significant dimensions of coil, fins, and complete unit. Table 2 summarizes the corresponding information on the Class 2 condenser with copper fins.

Tables 3 and 4 summarize the test data, and the heat rejection capacity ratings and heat transfer coefficients computed therefrom. Figure 2 is a pressure-enthalpy diagram labeled with the symbols used in the proposed ASRE Standard, PS2.4. This diagram indicates the changes occurring in state conditions of the refrigerant between the condenser inlet and outlet.

Two Size B, Class 1 condensers, NBS 135-57 and NBS 147-58, both manufactured by the Kramer Trenton Company, were received under this standardization project. As indicated by letter symbol K of item 1, in the section on Coil Dimensions of Table 1, specimen NBS 147-58 consisted of a 2-section coil. The upper section had 215 fins and the lower section had 218 fins. Specimen NBS 135-57, examined for comparison purposes, consisted of a 3-section coil with fins 16 in. high on the top section, 8 in. high on the middle section, and 10 in. high on the bottom section. The top section had 219 fins, the middle section had 216 fins, and the bottom section had 214 fins.

In order to provide a further means for comparing the performance of the various types of fins, tube arrangements, etc., of the several condensers in this test program, two additional coefficients were evaluated, which can be considered as Items 24 and 25 of Tables 3 and 4 as follows:

Item 24 Heat Rejection per Unit of Total Surface Area per Degree F Log Mean Temperature Difference, $\text{Btu/hr(ft}^2\text{)}(^{\circ}\text{F})$

Item 25 Heat Rejection per Unit of Total Surface Area per Degree F Log Mean Temperature Difference per cfm of Standard Air, $\text{Btu/hr(ft}^2\text{)}(^{\circ}\text{F})(\text{cfm})$

Addition to Table 2

<u>Item</u>	<u>QMR&E High Ambient Temperature</u>	
	<u>Free Discharge</u>	
Specimen No.	NBS 147-58	NBS 146-58
Fin Material	Aluminum	Copper
24.	5.32	5.55
25.	0.00166	0.00174

In comparing the results on the two condensers, it will be noted that the Class 1 specimen with aluminum fins had about 2% more total surface area than the Class 2 specimen with copper fins, but the heat transfer coefficients shown as items 24 and 25 above were about 4% higher on the specimen having the copper fins. The rating of the specimen with aluminum fins was about 92% and that of the specimen with copper fins about 93% of the required value of 35,600 Btu/hr.


CONDENSER SPÉCIMEN

MFR. Kramer Trenton Co.


NBS No. 147-58 146-58 SIZE - B

CLASS - 1 and 2


TOP VIEW



REAR VIEW
FACING AIR DISCHARGE



LEFT SIDE VIEW



RIGHT SIDE VIEW





Figure 1

PRESSURE - ENTHALPY
DIAGRAM
NO SCALE



NOTE 1
LABELED IN ACCORDANCE
WITH ASRE PS 2.4

CONDENSER SPECIMEN
DIAGRAM




Figure 2

CONDENSER SPECIMEN

MFR. Kramer Trenton Company		SIZE - B	
NBS NO. 147-58		CLASS - 1	
ITEM	PROPERTY	REMARKS	
COIL TUBE CHARACTERISTICS			
1 MATERIAL	Copper	Type L	
2 NUMBER OF ROWS DEEP	3		
3 NUMBER OF TUBES HIGH	34		
4 NUMBER OF CIRCUITS IN PARALLEL	3		
5 NUMBER OF TUBES PER CIRCUIT	34		
6 TUBE DIAMETER, O.D., IN.	3/8		
7 TUBE WALL THICKNESS, IN.	0.030		
8 TUBE RETURN BEND DIAMETER, O.D., IN.	3/8		
9 GAS INLET CONNECTION DIAM., O.D., IN.	7/8		
10 LIQUID OUTLET CONN. DIAMETER, O.D., IN.	5/8		
11 VERTICAL TUBE SPACING, IN.	S 1.0		
12 PRIMARY SURFACE AREA, SQ. FT.	22.6		
COIL FIN CHARACTERISTICS			
1 MATERIAL	Aluminum		
2 TYPE OF FIN	Embossed	Rolled collar	
3 FIN SPACING, PER INCH	8	215 fins on upper sec.	
4 FIN THICKNESS, IN.	0.009	218 fins on lower sec.	
5 SECONDARY SURFACE AREA, SQ. FT.	283.2		
COIL DIMENSIONS			
1 FINNED HEIGHT, IN.	K 34.0	fins in 2 sec. vertically	
2 FINNED WIDTH, IN.	F 27.1	upper sec. 22 in. high	
3 FINNED DEPTH, IN.	V 3.0	lower sec. 12 in. high	
4 COIL HEIGHT, IN.	H 33.0		
5 COIL WIDTH, IN.	W 29.5		
6 COIL DEPTH, IN.	D 2.0		
7 COIL DEPTH, OVERALL, IN.	N 10.6		
8 FACE AREA, SQ. FT.	6.4		
9 TOTAL SURFACE AREA, SQ. FT.	305.8		
10 DISTANCE BETWEEN CONNECTIONS	T 31.0		
OVERALL CONDENSER DIMENSIONS			
1 WIDTH, OVERALL, IN.	A 32.5		
2 WIDTH, SHROUD, IN.	B 27.4		
3 HEIGHT, IN.	C 34.1		
4 DEPTH, IN.	E 11.0		
5 BELLMOUTH ORIFICE DIAMETER, IN.	X 24 5/8		
6 BELLMOUTH RADIUS, IN.	R 5/8		

Table 1

CONDENSER SPECIMEN

MFR. Kramer Trenton Company		SIZE - B	
NBS NO. 146-58		CLASS - 2	
ITEM		PROPERTY	REMARKS
COIL TUBE CHARACTERISTICS			
1 MATERIAL		Copper	Type L
2 NUMBER OF ROWS DEEP		3	
3 NUMBER OF TUBES HIGH		34	
4 NUMBER OF CIRCUITS IN PARALLEL		3	
5 NUMBER OF TUBES PER CIRCUIT		34	
6 TUBE DIAMETER, O.D., IN.		3/8	
7 TUBE WALL THICKNESS, IN.		0.030	
8 TUBE RETURN BEND DIAMETER, O.D., IN.		3/8	
9 GAS INLET CONNECTION DIAM., O.D., IN.		7/8	
10 LIQUID OUTLET CONN. DIAMETER, O.D., IN.		5/8	
11 VERTICAL TUBE SPACING, IN.	S	1.0	
12 PRIMARY SURFACE AREA, SQ. FT.		22.6	
COIL FIN CHARACTERISTICS			
1 MATERIAL		Copper	
2 TYPE OF FIN		Embossed	Rolled collar
3 FIN SPACING, PER INCH		8	211 fins on upper sec.
4 FIN THICKNESS, IN.		0.009	212 fins on lower sec.
5 SECONDARY SURFACE AREA, SQ. FT.		277.0	
COIL DIMENSIONS			
1 FINNED HEIGHT, IN.	K	34.0	fins in 2 sec. vertically
2 FINNED WIDTH, IN.	F	27.1	upper sec. 22 in. high
3 FINNED DEPTH, IN.	V	3.0	lower sec. 12 in. high
4 COIL HEIGHT, IN.	H	33.0	
5 COIL WIDTH, IN.	W	29.5	
6 COIL DEPTH, IN.	D	2.0	
7 COIL DEPTH, OVERALL, IN.	N	10.6	
8 FACE AREA, SQ. FT.		6.4	
9 TOTAL SURFACE AREA, SQ. FT.		299.7	
10 DISTANCE BETWEEN CONNECTIONS	T	31.0	
OVERALL CONDENSER DIMENSIONS			
1 WIDTH, OVERALL, IN.	A	32.5	
2 WIDTH, SHROUD, IN.	B	27.4	
3 HEIGHT, IN.	C	34.1	
4 DEPTH, IN.	E	11.0	
5 BELLMOUTH ORIFICE DIAMETER, IN.	X	24.6	
6 BELLMOUTH RADIUS, IN.	R	5/8	

Table 2

CONDENSER SPECIMEN

MFR. Kramer Trenton Co. · NBS NO. 146-58

SIZE - B

CLASS - 12

AIR CIRCULATING EQUIPMENT AND REFRIGERANT USED	ASRE HIGH SATURATION TEMPERATURE				ASRE LOW SATURATION TEMPERATURE		QMR & E HIGH AMBIENT TEMPERATURE		
	STANDARD CONDITION	OBSERVED CONDITION		STANDARD CONDITION	OBSERVED CONDITION		STANDARD CONDITION	OBSERVED CONDITION	
		HIGH	FREE DISCH.		LOW	AIR FLOW RATE CFM		FREE DISCHARGE	AIR FLOW RATE CFM
FAN MFR. — Torrington FAN SERIAL NO. — E-2420-4 FAN SPEED — 1140 rpm MOTOR HP RATING — 0.500 REFRIGERANT — Freon-12									
ITEM									
1. BAROMETRIC PRESSURE	P_{ab}	"Hg	29.921			29.921		29.921	29.42
2. DRY BULB TEMPERATURE OF AIR ENTERING COIL	t_{ae}	°F	95			95		110	110.0
3. WET BULB TEMPERATURE OF AIR ENTERING COIL	t_{we}	°F	75±5			75±5		110	75.0
4. DRY BULB TEMPERATURE OF AMBIENT AIR	t_{ae}	°F	95			95		135	110.0
5. SATURATION TEMPERATURE OF ENTERING REFRIGERANT VAPOR	t_{sc}	°F	130			105			135.1
6. SUPERHEAT TEMPERATURE OF ENTERING REFRIGERANT VAPOR	t_{sc}	°F	195±10			170±10			197.4
AIR FLOW METHOD									
7. NOZZLE AIR AND WATER VAPOR MIXTURE FLOW RATE	Q_{ad}	CFM							3580
8. TOTAL HEAT REJECTION CAPACITY	q_{tc}	BTUH							33250
REFRIGERANT FLOW METHOD									
9. REFRIGERANT FLOW RATE	W_r	lb/min							8.62
10. CONDENSER COIL INTERNAL PRESSURE DROP	ΔP_c	PSI							8.25
11. SUBCOOLING OF LEAVING REFRIGERANT LIQUID	ΔT_s	°F	10° MAX.					5° MAX.	7.9
12. TOTAL HEAT REJECTION CAPACITY	q_{tr}	BTUH							33550
RATINGS									
13. TOTAL HEAT REJECTION	q_{tr}	BTUH							33200
14. CONDENSING HEAT REJECTION	q_{cr}	BTUH							31750
15. SUBCOOLING HEAT REJECTION	q_{sr}	BTUH							1450
16. AIR FLOW RATE	Q_r	CFM							3190
17. CONDENSER COIL EXTERNAL RESISTANCE	P_{es}	"H ₂ O							0.16
18. FAN MOTOR POWER	P_{fm}	WATTS							503
19. FAN BRAKE HORSEPOWER	P	BHP							
20. HEAT REJECTION PER UNIT PRIMARY SURFACE AREA		BTUH/SF							1467
21. HEAT REJECTION PER UNIT SECONDARY SURFACE AREA		BTUH/SF							119.9
22. HEAT REJECTION PER UNIT TOTAL SURFACE AREA		BTUH/SF							110.8
23. HEAT REJECTION PER CFM		BTUH							10.4

Table 3

CONDENSER SPECIMEN

MFR. Kramer Trenton Co.		NBS NO. 147-58		SIZE - B		CLASS - 1	
AIR CIRCULATING EQUIPMENT AND REFRIGERANT USED		ASRE HIGH SATURATION TEMPERATURE		ASRE LOW SATURATION TEMPERATURE		QMR & E HIGH AMBIENT TEMPERATURE	
FAN MFR. Torrington		OBSERVED CONDITION		STANDARD CONDITION		STANDARD CONDITION	
FAN SERIAL NO. E-2420-4		AIR FLOW RATE CFM		AIR FLOW RATE CFM		AIR FLOW RATE CFM	
FAN SPEED 1140 rpm		HIGH		LOW		FREE DISCHARGE	
MOTOR HP RATING 0.500		FREE DISCH.		FREE DISCH.		FREE DISCHARGE	
REFRIGERANT Freon-12		STANDARD CONDITION		STANDARD CONDITION		STANDARD CONDITION	
ITEM		HIGH TEMPERATURE		LOW TEMPERATURE		HIGH TEMPERATURE	
1. BAROMETRIC PRESSURE	P _{ab} "Hg	29.921		29.921		29.921	29.60
2. DRY BULB TEMPERATURE OF AIR ENTERING COIL	t _{ae} °F	95		95		110	110.1
3. WET BULB TEMPERATURE OF AIR ENTERING COIL	t _{we} °F	75 ± 5		75 ± 5			76.2
4. DRY BULB TEMPERATURE OF AMBIENT AIR	t _{ae} °F	95		95		110	110.1
5. SATURATION TEMPERATURE OF ENTERING REFRIGERANT VAPOR	t _{sc} °F	130		105		135	135.3
6. ENTERING REFRIGERANT VAPOR	t _{sc} °F	195 ± 10		170 ± 10			195.4
AIR FLOW METHOD							
7. NOZZLE AIR AND WATER VAPOR MIXTURE FLOW RATE	Q _{ad} CFM						3570
8. TOTAL HEAT REJECTION CAPACITY	q _{tc} BTUH						32650
REFRIGERANT FLOW METHOD							
9. REFRIGERANT FLOW RATE	W _r lb/min						8.57
10. CONDENSER COIL INTERNAL PRESSURE DROP	ΔP _c PSI						6.45
11. SUBCOOLING OF LEAVING REFRIGERANT LIQUID	ΔT _s °F	10° MAX.					9.7
12. TOTAL HEAT REJECTION CAPACITY	q _{tr} BTUH						33300
RATINGS							
13. TOTAL HEAT REJECTION	q _{tr} BTUH						32750
14. CONDENSING HEAT REJECTION	q _{cr} BTUH						31150
15. SUBCOOLING HEAT REJECTION	q _{sr} BTUH						1650
16. AIR FLOW RATE	Q _r CFM						3200
17. CONDENSER COIL EXTERNAL RESISTANCE	P _{es} "H ₂ O						0.17
18. FAN MOTOR POWER	P _{fm} WATTS						503
19. FAN BRAKE HORSEPOWER	P BHP						-
20. HEAT REJECTION PER UNIT PRIMARY SURFACE AREA	BTUH/SF						1446
21. HEAT REJECTION PER UNIT SECONDARY SURFACE AREA	BTUH/SF						115.6
22. HEAT REJECTION PER UNIT TOTAL SURFACE AREA	BTUH/SF						107.0
23. HEAT REJECTION PER CFM	BTUH						10.2

Table 4



R152 1/3 Series
File Folders



www.pendaflex.com 10% PA
MADE IN USA

