

687-

NATIONAL BUREAU OF STANDARDS REPORT

6922

PERFORMANCE TESTS OF AN AUTOMATIC
RENEWABLE MEDIA AIR FILTER
ROLL-KLEEN, MODEL 3-70

manufactured by
Farr Company, Los Angeles, California

by

Carl W. Coblenz and Paul R. Achenbach

Report to
Public Buildings Service
General Services Administration
Washington 25, D. C.



**U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS**

FOR OFFICIAL USE ONLY

THE NATIONAL BUREAU OF STANDARDS

Functions and Activities

The functions of the National Bureau of Standards are set forth in the Act of Congress, March 3, 1901, as amended by Congress in Public Law 619, 1950. These include the development and maintenance of the national standards of measurement and the provision of means and methods for making measurements consistent with these standards; the determination of physical constants and properties of materials; the development of methods and instruments for testing materials, devices, and structures; advisory services to Government Agencies on scientific and technical problems; invention and development of devices to serve special needs of the Government; and the development of standard practices, codes, and specifications. The work includes basic and applied research, development, engineering, instrumentation, testing, evaluation, calibration services, and various consultation and information services. A major portion of the Bureau's work is performed for other Government Agencies, particularly the Department of Defense and the Atomic Energy Commission. The scope of activities is suggested by the listing of divisions and sections on the inside of the back cover.

Reports and Publications

The results of the Bureau's work take the form of either actual equipment and devices or published papers and reports. Reports are issued to the sponsoring agency of a particular project or program. Published papers appear either in the Bureau's own series of publications or in the journals of professional and scientific societies. The Bureau itself publishes three monthly periodicals, available from the Government Printing Office: The Journal of Research, which presents complete papers reporting technical investigations; the Technical News Bulletin, which presents summary and preliminary reports on work in progress; and Basic Radio Propagation Predictions, which provides data for determining the best frequencies to use for radio communications throughout the world. There are also five series of nonperiodical publications: The Applied Mathematics Series, Circulars, Handbooks, Building Materials and Structures Reports, and Miscellaneous Publications.

Information on the Bureau's publications can be found in NBS Circular 460, Publications of the National Bureau of Standards (\$1.25) and its Supplement (\$0.75), available from the Superintendent of Documents, Government Printing Office, Washington 25, D. C.

Inquiries regarding the Bureau's reports should be addressed to the Office of Technical Information, National Bureau of Standards, Washington 25, D. C.

NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

NBS REPORT

1003-30-10630

August 4, 1960

6922

PERFORMANCE TESTS OF AN AUTOMATIC
RENEWABLE MEDIA AIR FILTER
ROLL-KLEEN, MODEL 3-70

manufactured by
Farr Company, Los Angeles, California

by

Carl W. Coblentz and Paul R. Achenbach
Air Conditioning, Heating, and Refrigeration Section
Building Technology Division

to

Public Buildings Service
General Services Administration
Washington 25, D. C.

IMPORTANT NOTICE

NATIONAL BUREAU OF
Intended for use within the
to additional evaluation and
listing of this Report, either
the Office of the Director,
however, by the Government
to reproduce additional copies

Approved for public release by the
Director of the National Institute of
Standards and Technology (NIST)
on October 9, 2015.

For progress accounting documents
formally published it is subjected
to reproduction, or open-literature
permission is obtained in writing from
NIST. Such permission is not needed,
however, for documents prepared
by the agency if that agency wishes



U. S. DEPARTMENT OF COMMERCE
NATIONAL BUREAU OF STANDARDS

FOR OFFICIAL USE ONLY

PERFORMANCE TESTS OF AN AUTOMATIC
RENEWABLE MEDIA AIR FILTER
ROLL-KLEEN, MODEL 3-70

manufactured by
Farr Company, Los Angeles, California

by

C. W. Coblentz and P. R. Achenbach

1. Introduction

At the request of the Public Buildings Service, General Services Administration, the performance characteristics of an automatic renewable media air filter were determined. The scope of this examination included the determination of the arrestances of the particulate matter in the laboratory air and Cottrell precipitate, at the rated air flow rate of the device, and at air flow rates 20 percent above and below this rate; it included, further, the observation of the pressure drop, the automatic advancement of the filter medium, and the determination of the dust-holding capacity of the filter medium.

2. Description of Test Specimen

The test specimen was manufactured and supplied for test purposes by the Farr Company of Los Angeles, California. It was identified as their Roll-Kleen Model 3-70. The filter medium reported on was the fourth such roll supplied by the manufacturer since the performance of the earlier mats did not meet applicable Government applications with regard to either arrestance or dust-holding capacity.

The filter medium was a glass fiber mat about 1 1/2" thick and reinforced on the downstream side by a rigid webbing. The glass fibers appeared to be bonded by an organic fibrous material and were covered with an adhesive. The mat was supplied in a 3-ft wide roll, compressed to approximately 1/2 in. thickness. The clean roll was suspended in the upper part of the housing and, after passing the 24 in. square air flow opening, was rolled up on another spool at the bottom of the housing by an electric motor. While passing from the clean roll at the top of the housing to the bottom roll, the medium was backed up by a stationary grid that prevented excessive deflection of the filter mat as it passed across the air flow opening. The electric motor was controlled by a

pressure switch, General Controls Type L-48A. This pressure switch started the motor, i.e., the advance mechanism, when a certain pressure drop across the filter medium was reached. This pressure drop could be selected in a wide range, whereas, the differential of about 0.07 in. W.G. was fixed.

3. Test Method and Procedure

The arrestance measurements were made in accordance with the NBS "Dust Spot Method" described in a paper by R. S. Dill and entitled, "A Test Method for Air Filters" (ASHVE Transactions, Vol. 44, p. 379, 1938).

For test purposes, the housing with the filter media in place was installed in the test apparatus and carefully sealed to prevent inward leakage of air except through the measuring orifice. The desired rate of air flow through the filter was established and samples of air were drawn from the center points of the test duct two feet upstream and eight feet downstream of the test specimen at equal rates and passed through known areas of Whatman No. 41 filter paper. The change of the opacity of these areas was determined with a sensitive photometer which measured the light transmission of the same spot on each sampling paper before and after the test. The two sampling papers used for each test were selected to have the same light transmission readings when clean.

For determining the arrestance of the filter, with Cottrell precipitate as the test dust, different size areas of sampling papers were used upstream and downstream of the filter in order to obtain a similar increase of opacity on both sampling papers. The arrestance A (in percent), was then calculated by the formula:

$$A = \left(1 - \frac{S_D}{S_U} \times \frac{\Delta D}{\Delta U} \right) \times 100$$

where S_U and S_D were the upstream and downstream sampling areas and ΔU and ΔD the observed changes in the opacity of the upstream and downstream sampling papers, respectively.

For determining the arrestance of the particulate matter in the laboratory air, equal sampling areas were used for the upstream and downstream samplers. A similar increase of the opacity of the upstream and downstream filter papers was

obtained by passing the sampling air through the upstream paper only part of the time while operating the downstream sampler continuously. This was accomplished by installing one solenoid valve in the upstream sampling line and another one in a bypass line. The valves were operated by an electric timer and a relay so that one was open while the other one was closed during any desired percentage of the 5-minute timer cycle, reversing the position of the two valves during the remainder of the cycle. The arrestance, A (in percent), was then determined with the following formula:

$$A = 100 - T \times \frac{\Delta D}{\Delta U}$$

where T is the percentage of time during which air was drawn through the upstream sampler, ΔU and ΔD being the changes of opacity of the sampling papers, as previously indicated.

The pressure drop of an automatic self-cleaning air filter of this type increases during operation due to the accumulating dust load until it reaches the value at which the pressure switch is set to operate the advance mechanism. When the clean media is moved into the air stream, the pressure drop decreases until the pressure switch stops the advance mechanism. The filter then operates repetitively in the on-off range of the pressure switch, the pressure differential controlling the length of the clean blanket that is moved into the air stream and the rate of dust accumulation determining the frequency of the cycles. The operation of this type of filter at a higher average pressure drop will increase the dust load per unit area of the filter medium. This saving on filter material, however, tends to be offset by the increase of the required blower power. The maximum pressure drop of slightly below 0.5 in. W.G. selected for this test corresponds to common operating practice for this type of filter.

The following procedure was used for determining the performance of the test specimen. After the filter assembly, with the new mat in place, had been installed in the test apparatus, the pressure drop of the clean blanket was determined at the rated face velocity of 500 ft/min, i.e., at an air flow rate of 2000 cfm, and also at velocities of 20 percent above and below this value. To determine the uniformity of the filter mat, the blanket was then advanced approximately 4 feet and the above pressure drop measurements were repeated. Thereafter, several determinations of the arrestance were made

with the particulate matter in the laboratory air as the aerosol, followed by arrestance determinations with Cottrell precipitate.

At the request of the manufacturer's representative, who attended the test, some of these arrestance measurements were made with Diglass filters instead of Whatman paper. No significant difference in the arrestance value could be established, using these two papers for collecting the sample. It had been assumed that the differences in performance of previous filter mats observed at this Bureau and at the manufacturer's plant were the result of using different sampling paper.

After these arrestance determinations were made, the loading of the filter with a mixture of 96 parts by weight of Cottrell precipitate and 4 parts of lint was started. The Cottrell precipitate had been sifted previously through a 100-mesh screen and was dispersed into the test apparatus in a ratio of 1 gram per 1000 cu ft of air. The lint was introduced into the air stream separately and had been prepared by grinding No. 7 cotton linters through a Wiley mill with a 4 millimeter screen.

After the blanket had advanced several steps, the arrestance determinations with both aerosols were repeated. The distance of each advance of the filter media was observed by means of small markers fastened to the mat. These markers moved alongside a yardstick mounted in the filter housing and could be observed through a glass window in the test duct. A pilot light was installed parallel with the advance motor and enabled the operator to record the pressure drop of the filter mat. Altogether, a total of 20 advance cycles was observed during which the blanket moved 49 inches. At the termination of the test, a group of arrestance determinations with Cottrell precipitate were conducted at face velocities 20 percent above and below the rated air flow of the specimen. A total of 21 arrestance determinations were made during the test.

4. Test Results

The test results are summarized in Tables 1 and 2. Table 1 shows the observed values for dust load and the average arrestance values at certain positions of the filter mat using the particulate matter in the laboratory air or Cottrell precipitate, at the rated air flow and at values 20 percent above and below the rated flow.

Table 1

Summary of Arrestance Determinations
Roll-Kleen Model 3-70

Dust Load g/ft width	Air Flow Rate cfm	Advance of Mat in.	Arrestance %	Aerosol *
0	2000	0	16	A
15	2000	0	70	C
312	2000	16	79	C
570	2000	32	81	C
730	2000	46 1/2	82	C
736	2000	46 1/2	20	A
748	1600	46 1/2	85	C
760	2400	46 1/2	80	C

* Aerosol A - Particulate matter in the laboratory air.
Aerosol C - Cottrell precipitate in the laboratory air.

NOTE: Each arrestance value presents the average of two or more individual arrestance determinations.

The dust load is reported in grams per foot width, referring to the 2-ft square air flow opening. At the end of the test, a total of 1532 grams of dust and lint had been introduced into the test apparatus, and no fallout was determined in the upstream portion of the duct so that the full amount had reached the filter.

The arrestance of the particulate matter in the laboratory air with a clean filter medium was observed to average 16 percent based on 3 tests. The arrestance of Cottrell precipitate for the clean filter was 70 percent, which is the average of 4 individual arrestance determinations which ranged from 69.2 to 71.9%.

It will be noted that the arrestance of Cottrell precipitate was 79% when the filter mat had moved 16 in. but varied between 81 and 82% after a 32-in. movement of the filter medium at rated face velocity. Steady state arrestance of Cottrell precipitate was approximately 81%, and of the particulate matter in the laboratory air, about 20%, at the rated flow. The arrestance of Cottrell precipitate increased to 85% when the air flow rate was reduced by 20%, and decreased to 80% when the air flow rate was increased by 20%.

The dust load, and pressure drop before and after each advance of the filter medium, together with the incremental and total mat travel are shown in Table 2 for the entire test period.

Table 2

Mat Travel, Dust Load and Pressure Drop
Roll-Kleen Model 3-70
at Rated Face Velocity of 500 ft/min

Dust Load g/ft width	Travel of Mat, in.		Pressure Drop, In. W.G.	
	<u>Advance</u>	<u>Total</u>	<u>Before Advance</u>	<u>After Advance</u>
0	-	-	0.170	-
213	5	5	0.495	0.420
240	3	8	0.460	0.400
271	2	10	0.460	0.400
302	3	13	0.495	0.420
334	3	16	0.495	0.415
365	2	18	0.485	0.410
386	2	20	0.500	0.440
417	2 1/2	22 1/2	0.500	0.420
448	2	24 1/2	0.495	0.420
469	2 1/2	27	0.495	0.420
490	2 1/2	29 1/2	0.490	0.415
521	2 1/2	32	0.495	0.420
531	2	34	0.495	0.420
562	2	36	0.495	0.430
593	2	38	0.500	0.430
614	2	40	0.495	0.425
645	2 1/2	42 1/2	0.495	0.420
674	2	44 1/2	0.485	0.425
696	2	46 1/2	0.490	0.425
729	2 1/2	49	0.495	0.420

The pressure drop of two sections of the clean filter mat, 4 feet apart on the roll is shown in Table 3. It indicates a variation of about 5% in the pressure drop for two sections of the blanket 4 feet apart.

Table 3

Uniformity of Filter Medium
Roll-Kleen Model 3-70

Air Flow Rate cfm	Face Velocity ft/min	Pressure Drop, In. W.G.	
		1. Section	4 ft Further
2400	600	0.218	0.230
2000	500	0.160	0.170
1600	400	0.115	0.120

The dust load values shown in Tables 1 and 3 are the cumulative weights of Cottrell precipitate and lint that had been introduced into the test apparatus at the beginning of each advance of the filter medium. With the exception of the first advance cycle, the blanket advanced between 2 and 3 in. for each step. The individual advance could not be observed much closer than $\pm 1/2$ in. and it can be assumed, therefore, that the advance distance was practically the same for each step after the first 16 inches of mat travel. The average pressure drop before the advance was 0.491 in. W.G., with a maximum value of 0.500 and a minimum of 0.460 in. W.G., whereas, the pressure drop at the termination of the advance cycle averaged 0.420 in. W.G., with a maximum value of 0.440 and a minimum of 0.400 in. W.G.

The amount of Cottrell precipitate collected on a unit area of filter medium during the steady state operation of the test specimen provides a measure of the consumption of mat length during actual use. Disregarding the insignificant mass of particulate matter collected on the filter during the arrestance determinations with laboratory air, the dust-holding capacity per unit area at rated air flow is expressed by the slope of the straight line in Fig. 1. This line was drawn to approximate the least mean square distances of the points of observation. According to this line, there were $750 - 250 = 500$ grams per foot width of dust received by the filter mat while the filter mat traveled from the 8.7- to the 51.5-inch position, a distance of 42.8 inches, or 3.57 ft.

Therefore, the dust-holding capacity was $\frac{500}{3.57} = 140$ grams

per square foot. Table 4 below presents a summary of the performance data for this filter.

Table 4

Summary of Test Results

Pressure Drop, clean

- at 600 ft/min Face Velocity - 0.230 in. W.G.
- at 500 ft/min Face Velocity - 0.170 in. W.G.
- at 400 ft/min Face Velocity - 0.120 in. W.G.

Average Operating Pressure* - 0.491 in. W.G. to 0.420 in. W.G.

Average Arrestance*

- Clean Mat, Laboratory Air - 16%
- Cottrell Precipitate - 70%
- Steady State, Laboratory Air - 20%
- Cottrell Precipitate - 81%

Arrestance at Steady State with Cottrell Precipitate

- at 600 ft/min Face Velocity - 80%
- at 400 ft/min Face Velocity - 85%

Dust-Holding Capacity* - 140 g/ft width

* At rated face velocity of 500 ft/min.

MAT TRAVEL v/s DUST LOAD

FARR COMPANY
ROLL-KLEEN MODEL 3-70




Figure 1



THE NATIONAL BUREAU OF STANDARDS

The scope of activities of the National Bureau of Standards at its major laboratories in Washington, D.C., and Boulder, Colorado, is suggested in the following listing of the divisions and sections engaged in technical work. In general, each section carries out specialized research, development, and engineering in the field indicated by its title. A brief description of the activities, and of the resultant publications, appears on the inside of the front cover.

WASHINGTON, D.C.

Electricity and Electronics. Resistance and Reactance. Electron Devices. Electrical Instruments. Magnetic Measurements. Dielectrics. Engineering Electronics. Electronic Instrumentation. Electrochemistry.

Optics and Metrology. Photometry and Colorimetry. Photographic Technology. Length. Engineering Metrology.

Heat. Temperature Physics. Thermodynamics. Cryogenic Physics. Rheology. Molecular Kinetics. Free Radicals Research.

Atomic and Radiation Physics. Spectroscopy. Radiometry. Mass Spectrometry. Solid State Physics. Electron Physics. Atomic Physics. Neutron Physics. Radiation Theory. Radioactivity. X-rays. High Energy Radiation. Nuclonic Instrumentation. Radiological Equipment.

Chemistry. Organic Coatings. Surface Chemistry. Organic Chemistry. Analytical Chemistry. Inorganic Chemistry. Electrodeposition. Molecular Structure and Properties of Gases. Physical Chemistry. Thermochemistry. Spectrochemistry. Pure Substances.

Mechanics. Sound. Mechanical Instruments. Fluid Mechanics. Engineering Mechanics. Mass and Scale. Capacity, Density, and Fluid Meters. Combustion Controls.

Organic and Fibrous Materials. Rubber. Textiles. Paper. Leather. Testing and Specifications. Polymer Structure. Plastics. Dental Research.

Metallurgy. Thermal Metallurgy. Chemical Metallurgy. Mechanical Metallurgy. Corrosion. Metal Physics.

Mineral Products. Engineering Ceramics. Glass. Refractories. Enamelled Metals. Constitution and Microstructure.

Building Technology. Structural Engineering. Fire Protection. Air Conditioning, Heating, and Refrigeration. Floor, Roof, and Wall Coverings. Codes and Safety Standards. Heat Transfer. Concrete Materials.

Applied Mathematics. Numerical Analysis. Computation. Statistical Engineering. Mathematical Physics.

Data Processing Systems. SEAC Engineering Group. Components and Techniques. Digital Circuitry. Digital Systems. Analog Systems. Application Engineering.

• Office of Basic Instrumentation.

• Office of Weights and Measures.

BOULDER, COLORADO

Cryogenic Engineering. Cryogenic Equipment. Cryogenic Processes. Properties of Materials. Gas Liquefaction.

Radio Propagation Physics. Upper Atmosphere Research. Ionospheric Research. Regular Propagation Services. Sun-Earth Relationships. VHF Research. Radio Warning Services. Airglow and Aurora. Radio Astronomy and Arctic Propagation.

Radio Propagation Engineering. Data Reduction Instrumentation. Modulation Research. Radio Noise. Tropospheric Measurements. Tropospheric Analysis. Propagation Obstacles Engineering. Radio-Meteorology. Lower Atmosphere Physics.

Radio Standards. High Frequency Electrical Standards. Radio Broadcast Service. High Frequency Impedance Standards. Electronic Calibration Center. Microwave Physics. Microwave Circuit Standards.

Radio Communication and Systems. Low Frequency and Very Low Frequency Research. High Frequency and Very High Frequency Research. Ultra High Frequency and Super High Frequency Research. Modulation Research. Antenna Research. Navigation Systems. Systems Analysis. Field Operations.

