

REFERENCE

UNITED STATES
DEPARTMENT OF
COMMERCE
PUBLICATION



NBS TECHNICAL NOTE 708

Interlaboratory Evaluation of Smoke Density Chamber

U.S.
DEPARTMENT
OF
COMMERCE
National

-QC-
100
U5753
no. 708
1971

NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards¹ was established by an act of Congress March 3, 1901. The Bureau's overall goal is to strengthen and advance the Nation's science and technology and facilitate their effective application for public benefit. To this end, the Bureau conducts research and provides: (1) a basis for the Nation's physical measurement system, (2) scientific and technological services for industry and government, (3) a technical basis for equity in trade, and (4) technical services to promote public safety. The Bureau consists of the Institute for Basic Standards, the Institute for Materials Research, the Institute for Applied Technology, the Center for Computer Sciences and Technology, and the Office for Information Programs.

THE INSTITUTE FOR BASIC STANDARDS provides the central basis within the United States of a complete and consistent system of physical measurement; coordinates that system with measurement systems of other nations; and furnishes essential services leading to accurate and uniform physical measurements throughout the Nation's scientific community, industry, and commerce. The Institute consists of a Center for Radiation Research, an Office of Measurement Services and the following divisions:

Applied Mathematics—Electricity—Heat—Mechanics—Optical Physics—Linac Radiation²—Nuclear Radiation²—Applied Radiation²—Quantum Electronics³—Electromagnetics³—Time and Frequency³—Laboratory Astrophysics³—Cryogenics³.

THE INSTITUTE FOR MATERIALS RESEARCH conducts materials research leading to improved methods of measurement, standards, and data on the properties of well-characterized materials needed by industry, commerce, educational institutions, and Government; provides advisory and research services to other Government agencies; and develops, produces, and distributes standard reference materials. The Institute consists of the Office of Standard Reference Materials and the following divisions:

Analytical Chemistry—Polymers—Metallurgy—Inorganic Materials—Reactor Radiation—Physical Chemistry.

THE INSTITUTE FOR APPLIED TECHNOLOGY provides technical services to promote the use of available technology and to facilitate technological innovation in industry and Government; cooperates with public and private organizations leading to the development of technological standards (including mandatory safety standards), codes and methods of test; and provides technical advice and services to Government agencies upon request. The Institute also monitors NBS engineering standards activities and provides liaison between NBS and national and international engineering standards bodies. The Institute consists of the following divisions and offices:

Engineering Standards Services—Weights and Measures—Invention and Innovation—Product Evaluation Technology—Building Research—Electronic Technology—Technical Analysis—Measurement Engineering—Office of Fire Programs.

THE CENTER FOR COMPUTER SCIENCES AND TECHNOLOGY conducts research and provides technical services designed to aid Government agencies in improving cost effectiveness in the conduct of their programs through the selection, acquisition, and effective utilization of automatic data processing equipment; and serves as the principal focus within the executive branch for the development of Federal standards for automatic data processing equipment, techniques, and computer languages. The Center consists of the following offices and divisions:

Information Processing Standards—Computer Information—Computer Services—Systems Development—Information Processing Technology.

THE OFFICE FOR INFORMATION PROGRAMS promotes optimum dissemination and accessibility of scientific information generated within NBS and other agencies of the Federal Government; promotes the development of the National Standard Reference Data System and a system of information analysis centers dealing with the broader aspects of the National Measurement System; provides appropriate services to ensure that the NBS staff has optimum accessibility to the scientific information of the world, and directs the public information activities of the Bureau. The Office consists of the following organizational units:

Office of Standard Reference Data—Office of Technical Information and Publications—Library—Office of International Relations.

¹ Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

² Part of the Center for Radiation Research.

³ Located at Boulder, Colorado 80302.

8 1974

acc. - Ref.

100

5753

5, 708

71

UNITED STATES DEPARTMENT OF COMMERCE
Maurice H. Stans, Secretary
NATIONAL BUREAU OF STANDARDS • Lewis M. Branscomb, Director



t.

TECHNICAL NOTE 708

ISSUED DECEMBER 1971

Nat. Bur. Stand. (U.S.), Tech. Note 708, 80 pages (Dec. 1971)

CODEN: NBTNA

Interlaboratory Evaluation of Smoke Density Chamber

T. G. Lee

Building Research Division

Institute for Applied Technology

U.S. National Bureau of Standards

Washington, D.C. 20234



NBS Technical Notes are designed to supplement the Bureau's regular publications program. They provide a means for making available scientific data that are of transient or limited interest. Technical Notes may be listed or referred to in the open literature.

TABLE OF CONTENTS

	<u>Page</u>
Abstract	1
1. Introduction	2
2. Participants	5
3. Test Procedures	5
4. Test Materila	8
5. Results	10
Summary of Values	16
6. Statistical Analysis	17
6.1 Means and Standard Deviation	17
6.2 Variability	18
6.3 Ranking of Materials	27
7. Discussion	27
7.1 Variation between Laboratories	29
7.2 Materials	29
7.3 Results	31
7.4 Possible Sources of error	34
8. Conclusion and Recommendations	34
9. Acknowledgment	36
10. References.....	36
APPENDIX I Original Data	37
APPENCIX II Test Method for Measuring the Smoke Generation of Solid Materials	42
1. Scope	42
2. Significance	42
3. Summary of Method	43
4. Apparatus	44
4.1.1 Test Chamber	44
4.1.2 Radiant Heat Furnace	45
4.1.3 Specimen Holder	46
4.1.4 Framework	46
4.1.5 Photometric System	46
4.1.6 Radiometer	47
4.1.7 Thermocouples for Determining Chamber Wall Temperature	47
4.1.8 Portable Recorder or Read Out Meter	47
4.1.9 Manometer for Chamber Pressure Measurements	47
4.1.10 Multiple Flamelet Burner	48
5. Test Specimens	48
5.1 Size	48
5.2 Specimen Orientation	48
5.3 Specimen Assembly	49
6. Specimen Conditioning	51
7. Number of Test Specimens	51
8. Test Procedure	51
9. Calculations	55
10. Report	56

	Page
Appendix II A Calibration of Test Equipment	59
A.1.1 Photometric System	59
A.1.2 Radiometer	59
A.1.3 Chamber Pressure Manometer	60
A.1.4 Standard Smoke Generating Materials.....	60
Appendix II B Presentation and Use of Test Results	61
Appendix II C Construction Details	64
C.4.1.2 Radiant Heat Furnace	64
C.4.1.3 Specimen Holder	65
C.4.1.4 Support of Furnace & Specimen Holder	65
C.4.1.5 Photometric System	66
C.4.1.6 Radiometer	67
C.4.1.7 Chamber Wall Thermocouple	67
C.4.1.10 Burner	67
C.4.1.11 Pressure Regulator	68
Appendix II D Analysis of Products of Combustion	69
Appendix II E Suggested Report Form	70
Appendix II Fig. 1 Smoke Density Chamber	71
Fig. 2 Chamber Assembly	72
Fig. 3 Furnace Section	73
Fig. 4 Details of Speciment Holders and Burner	74
Fig. 5 Furnace Support	75
Fig. 6A Photometer Details	76
Fig. 6B Photometer Location	77
Fig. 7 Radiometer Details	78

Interlaboratory Evaluation of Smoke Density Chamber

T. G. Lee

Results are reported of a interlaboratory (round-robin) evaluation of the smoke density chamber method for measuring the smoke generated by solid materials in fire. A statistical analysis of the results from 10 material-condition combinations and 18 laboratories is presented. For the materials tested, the median coefficient of variation of reproducibility was 7.2% under non-flaming exposure conditions and 13% under flaming exposure conditions. A discussion of errors and recommendations for improved procedures based on user experience is given. A tentative test method description is included as an appendix.

Key Words: Building materials; fire tests; interlaboratory tests; round-robin; optical density; smoke; smoke density chamber; statistical analysis.

Interlaboratory Evaluation of Smoke Density Chamber

1. Introduction

In January 1970, an interlaboratory comparison study on the measurement of the smoke generation characteristics of materials was initiated by the Fire Research Section, Building Research Division of the National Bureau of Standards (NBS). ASTM Committee E-5 on Fire Tests of Materials and Constructions acted as an advisor to the study. The goal of the study was to evaluate the suitability of the test method for measuring and classifying specimens of materials according to their smoke generation potential.

A test method had been developed at NBS and reported in 1967 by Gross, Loftus and Robertson [1]^{1/}. It was later used to evaluate the smoke properties of over 140 aircraft interior materials [2]. The laboratory method measures the smoke generation characteristic of solid specimens of given thickness under both flaming and non-flaming exposure conditions, which represents two parameters of fire hazard. All specimens are exposed to an irradiance level of 2.5 W/cm^2 (2.2 Btu/sec ft^2) and, in the flaming exposure, also to the flames from a small propane-air pilot burner. In the test, smoke from a burning specimen in an enclosed chamber is monitored continuously by a photometer which measures the attenuation of light caused by the smoke.

Because of the general interest in the problem of smoke and the need for standardization of equipment, the American

^{1/} Figures in brackets indicate the literature references at the end of this paper.

Instrument Company (AMINCO)^{2/} decided to build a commercial model of the smoke chamber. These production models became available in the latter part of 1969; while some home-built units were made earlier.

In late 1969, NBS circulated a proposed test method to all known users of the Smoke Density Chamber for comments. Many constructive suggestions were received and were incorporated in a revised draft of the test method. All laboratories having a Smoke Density Chamber were then invited to participate in a interlaboratory evaluation of the method. Two samples each of two materials (pure alpha-cellulose paper and a PVC-PVA copolymer) were distributed for a preliminary screening and general familiarization with the test procedure. The reported results and comments indicated the need to provide better alignment of the burner in the flaming exposure; and to correct for smoke deposits on the windows of the photometer. The results of these initial studies were considered reasonable for tests of this type.

A meeting, attended by representatives from some of the participating laboratories in the round-robin was held to discuss the preliminary test results and test procedures. A more comprehensive interlaboratory evaluation of the test method followed.

The test results from the 22 participating laboratories are summarized in this report. A statistical analysis of the

^{2/} Certain commercial equipment, instruments, or materials are identified in this paper in order to adequately specify the experimental procedure. In no case does such identification imply recommendation or endorsement by the National Bureau of Standards, nor does it imply that the material or equipment identified is necessarily the best available for the purpose.

Table 1

Participants of Interlaboratory Evaluation of Smoke Density Chamber.

<u>Laboratory</u>	<u>Location</u>	<u>Representative</u>
Allied Chemical (Plastics Div.)	Morristown, N.J.	K. G. Smack
Armstrong Cork (R & D Center)	Lancaster, Pa.	Z. Zabawsky
DuPont (Engineering Test Center)	Newark, Del.	F. Thompson
DuPont (Plastics Dept.)	Wilmington, Del.	J. Blair
Federal Aviation Adm. (NAFEC)	Atlantic City, N.J.	J. F. Marcy E. Nicholas
Forest Products Lab.	Madison, Wisc.	H. W. Eickner J. Brenden
General Electric Co. (Plastics Dept.)	Mt. Vernon, Ind.	C. Bialous
General Tire & Rubber Co. (Chemical Plastic Dept.)	Akron, Ohio	G. Wear
Johns-Manville Research Center	Manville, N.J.	E. Davis
Koppers Co., Inc.	Monroeville, Pa.	C. Dzik
Lawrence Radiation Laboratory	Livermore, Calif.	J. Gaskill
Mobay Chemical Co.	Pittsburgh, Pa.	R. Hagins
National Bureau of Standards	Gaithersburg, Md.	T. Lee
National Research Council (Canada)	Ottawa, Canada	J. McGuire
Olin (Research Center)	New Haven, Conn.	A. Cianciola
Owens Corning Fiberglas Corp.	Granville, Ohio	P. Hays
Union Carbide (Plastics Dept.)	S. Charlestown, W. Va.	C. Hilado
Uniroyal Inc. (Research Center)	Wayne, N.J.	M. Jacobs
Uniroyal Inc.	Mishawaka, Ind.	G. Jablonski
Rohm & Haas Co. (Redstone Res. Lab.)	Huntsville, Ala.	T. Pratt
Underwriters Laboratory, Inc.	Northbrook, Ill.	J. Thiel
Weyerhaeuser Co.	Longview, Wash.	D. Crawford

data and comments on possible sources of errors are also included.

2. Participants

A total of 22 laboratories, three with home-built and 19 with commercial chambers participated in the study. The list is given in Table 1. The laboratories are identified in the report by code letters only. The cooperation, comments and suggestions from the participating laboratories, are gratefully acknowledged.

3. Test Procedures

Detail test procedures were supplied to the participants in a tentative test method standard. Slight modification in procedures were subsequently (after the test) made, but these are not expected to appreciably change the precision estimate based on the reported results. The latest version of the test method standard is given in Appendix II.

Supplementary notes, instructions, data sheets, and a total of 26 specimens were distributed to the participants after they reported their preliminary test results.

There were a total of 8 materials and 10 test conditions. Two materials were tested under both flaming and non-flaming conditions. The instructions requested that duplicate tests be performed for each of the test conditions, and an additional six replicates for one designated test condition. This arrangement was selected to permit good statistical estimates to be made of (within-laboratory) repeatability and (between-laboratory) reproducibility with a reasonably small number of tests.

Table 2 Type and Number of Tests Performed by Each Laboratory

LABORATORIES

Specimen	a/ conditions	LABORATORIES																		
		A	B	C	D	E EE	F	G	H	I	J	K	L	M	N	O	P	Q	R	
B. Linoleum	N	8	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	
Polypropylene Rug	N	2	8	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	
Red Oak, 1/4"	N	2	2	8	2	2	2	2	2	2	2	2	8	2	2	2	2	2	2	
ABS, 0.022"	N	2	2	2	8	2	2	2	2	2	2	2	2	8	2	2	2	2	2	
Polystyrene Foam, 1"	F	2	2	2	2	8	3	3	3	3	3	3	3	8	2	2	2	2	2	
α- Cellulose Paper	N	2	2	2	2	2	2	2	2	2	2	2	2	2	8	2	2	2	2	
PVC - Veneer	F	2	2	2	2	2	8	2	2	2	2	2	2	2	2	8	2	2	2	
Gypsum Board	N	2	2	2	2	2	2	2	8	2	2	2	2	2	2	2	2	8	2	
Acoustic Tile, Mineral Type	F	2	2	2	2	2	2	2	2	8	2	2	2	2	2	2	2	2	8	

a/ F = Flaming; N = Non-flaming

Table 3 Test Materials ^{a/}

Material	Thickness inch	Density		Color	Description
		lb/ft ³	g/cm ³		
Linoleum	0.125	87	1.4	Green	"battleship" linoleum with burlap backing
Polypropylene Rug	0.22	17	0.28	Light Brown	Twist, loop weave, burlap backing
Red Oak	0.25	43	0.69	Natural	Uniform grain, wood, smooth finish
ABS	0.022	66	1.05	Créam	Rigid plastic opaque
α -cellulose	0.030	41	0.66	White	Pure cotton linter matting, (blotter paper)
PVC-Gypsum PVC veneer Paper (S) Gypsum	0.010 0.015 0.5	51	0.82	Dark Brown	PVC Veneer, simulating wood grain over gypsum board
Acoustic ceiling tile	0.75	20	0.32	Painted White	Mineral type, random and irregular shaped holes
Polystyrene Foam	1.03	1.8	0.03	Blue	Rigid low density insulating foam, fire retardant treated
PVA/PVC	0.047	75	1.2	Brown	Flexible
ABS	0.032	66	1.05	Cream	Rigid Plastic

^{a/} All specimens were 3 x 3 inches

The experimental design is shown in Table 2. It was suggested that tests be made in random order, but some laboratories tested duplicates in sequence. A few did not condition the specimens to moisture equilibrium prior to tests because of the lack of facility or time.

Some laboratories used the previously suggested flowmeter settings based on an air to fuel ratio of 3 to 1, for their pilot burners; whereas the procedure had been modified to require a ratio of 10 to 1 (500 cm³/min air and 50 cm³/min propane). This discrepancy introduced a relatively large systematic error in the flaming results in those laboratories.

4. Test Material

The materials selected (Table 3) represent common interior finish and construction materials, including simple and composite plastic, cellulosic and inorganic-base materials with thickness ranging from 0.022 to 1.03 in (0.5 to 26 mm). These materials exhibit different forms of physical response to fire exposure: such as slow melting, fast shrinking, rapid decomposition and nearly non-reactive. The smoke levels from the materials span the full range of the test instrument as well as a very narrow region to show the degree of resolution. Most materials were obtained from commercial sources without special controls on uniformity. All the specimens were cut and randomized before distribution. Because of an unanticipated addition of laboratories to the study, a second batch of some materials were prepared.

Since small quantities of fillers, pigments and additives, and other chemical and physical properties affect the smoke potential of materials, it should not be assumed that all materials of the same generic type, density, and thickness will produce the same quantity of smoke under the same conditions.

TABLE 4 SUMMARY OF SELECTED TEST PARAMETERS

Lab	Completion Date (1970)	Conditioning Predry	50%RH	Test Sequence Random	Duplicate Pr.	Chamber Wall Temp. °C	Air mm \bar{c} /	Flowmeter Reading Propane mm \bar{d} /	Photometer Lamp, Volt	Burner Distance, e/ Vert. Horiz.
B	3-31	Y	Y	Y		33-36	150	75	2.5	-
D	6-10	Y	Y		Y	36	131	75	2.4	-
EE	5-08	Y	Y	Y		33-37	140	60*	2.7	-
F	5-14	Y	Y	Y	Y	34-37	(150)	68 (s)		3/8
G	3-19	Y	Y	Y		33	150	75		-
H	5-14	Y	Y	Y		33-36	150	75 (s)*		-6H
I	5-08	N	Y	Y	Y	34-35	150	70 *	4.2	-6H
J	6-25	Y	Y	Y		31-34	150	75	2.4	-6H
K	4-16	Y	Y	Y	Y	35-37	140	52	3.5	-
L	3-06	Y	Y	Y		34-36	135	45 (s)	3.5	-6H
LL	5-06	Y	Y	Y		38-39	140	30 (s)*		5/16
M	3-06				Y	36			2.7	-6H
N	4-17	Y	Y	Y	Y	35-36	150	75	3.1	-
O	6-15	Y	Y	Y		34	150	75	2.7	-6H
OO	6-02	Y	Y	Y		34-36	142	75	2.4	-
P	4-29	Y	Y	Y		33-37	150	75	4.7	-
Q	6-22	Y	Y	Y	Y	35	132	70 (s) *		-6H
R	4-16	N	Y	Y		34-36	120	80 (s)	4.2	-6H
S	3-17	Y	Y	Y		34-35	150	75		-
A	3-26	Y	Y	Y	Y	33-36	not applicable	not applicable	>90	-6H
C	3-10	Y	Y	Y		33-37	not applicable	not applicable	>90	-6H
E	3-23	N	Y	Y		33-35	methane		>90	15/64 -6H

a/ y=yes, n=no, blank=no data.

b/ duplicate pair means 2 specimens of a material measured sequentially.

c/ steel ball.

d/ all use plastic ball except (s), steel ball; * denotes propane of commercial grade.

e/ - denotes 1/4", otherwise given; 6H denotes 6-holes burner in contrast to 6-tubes burner.

5. Results

Table 4 lists the relevant test conditions under which each laboratory performed the tests.

The data on lamp voltage were based on the mid-range sensitivity setting of 25 and were recorded by AMINCO during the check-out tests. A voltage of 4 ± 0.2 volts ac or dc has since been adopted in the revised test method following completion of this study.

Flowmeter settings and burner-to-specimen distances were that reported by the individual laboratory. Laboratories with flowmeter settings much above 30 mm (steel ball) or 75 mm (plastic ball) inadvertently used propane at a higher than required rate.

Because of its shorter service life, the 6-hole tee burner was replaced with a heavier 6-tube burner of similar flaming characteristics on chambers originally shipped in the spring of 1970. As a result, both types of burners were used in the flaming tests. In addition to this, a modified specimen holder with trough and burner with flamelets pointing in three directions were distributed to test participants for use only in the flaming test on the polystyrene sample. This holder and burner combination retains the melted portion of the specimen under test and exposes it directly to the burner flamelets. The modified burner and holder were subsequently used by 12 laboratories to evaluate the 0.032 in. ABS (acrylonitrile butadiene styrene) specimens. It has since been adopted in the revised test method for all flaming tests.

TABLE 5 Mean Dm (corr.) For Each Material and Laboratory

LAB.	LINOLEUM	POLY. RUG	RED OAK	ABS	POLYSTYRENE
B	748.5	739.5	548.0	201.0	21.0
D	703.0	629.5	513.0	201.0	25.5
EE	783.5	663.5	555.5	202.5	28.0
F	790.0	613.0	624.0	206.5	23.0
G	704.5	580.0	524.0	146.5	21.5
H	684.0	590.0	574.0	157.5	22.5
I	728.5	597.5	502.0	192.5	11.0
J	737.5	701.5	595.0	175.5	14.5
K	719.5	586.0	576.0	179.0	28.5
L	802.0	656.0	622.5	226.0	23.5
M	604.5	582.0	550.0	202.5	23.0
N	743.5	501.5	495.0	205.5	15.5
O	674.5	616.0	601.5	197.0	18.5
OO	690.5	629.0	514.0	170.0	15.0
P	722.0	608.5	516.0	162.0	24.0
R	718.5	617.5	544.5	177.5	30.0
S	776.0	668.5	558.5	198.0	37.0
LL	568.0	564.0	538.5	182.0	24.5
Q	480.0	449.5	381.5	197.0	10.0
A	524.0	489.5	473.0	184.5	30.0
C	495.5	522.0	383.0	86.5	11.0
E	560.5	484.5	491.0	131.0	19.5

LAB.	CELLULOSE	PVC	TILE/FL.	PVC/FL.	P. STYR./FL.
B	159.0	111.5	16.5	59.0	273.0
D	167.5	105.5	19.0	61.0	353.5
EE	159.5	110.5	19.5	75.5	326.5
F	165.0	110.0	6.5	24.5	405.5
G	165.0	107.0	19.5	57.0	322.0
H	157.5	102.5	16.5	37.5	418.0
I	164.5	105.0	33.0	87.5	428.0
J	169.5	103.0	26.5	69.0	334.5
K	153.5	102.5	27.0	83.0	377.0
L	157.5	112.0	15.0	48.5	409.0
M	153.5	118.0	27.5	79.0	406.0
N	162.5	124.5	21.0	62.0	439.0
O	163.5	114.0	27.0	92.5	425.5
OO	160.0	97.0	15.0	46.0	416.0
P	163.0	105.5	23.0	69.0	435.5
R	159.0	107.5	12.5	31.0	486.0
S	167.5	114.5	11.5	55.0	418.5
LL	179.5	115.0	27.5	83.0	376.5
Q	162.0	86.0	22.0	30.5	406.5
A	155.0	114.5	16.0	105.0	355.0
C	150.5	92.0	20.5	27.0	421.5
E	138.0	92.0	13.0	33.0	22.5

TABLE 6

Mean Dc, Clear Beam Value, For Each
Material and Laboratory

LAB.	LINOLEUM	POLY. RUG	RED OAK	ABS	POLYSTYRENE
B	3.5	22.5	.5	6.5	1.0
D	17.0	22.0	8.0	9.5	1.0
EE	3.5	20.0	5.0	16.5	3.0
F	12.5	18.5	5.5	10.5	5.5
G	14.0	68.0	14.0	7.0	2.0
H	16.5	31.0	12.0	4.0	.5
I	10.5	21.5	8.5	7.0	.0
J	22.0	34.0	10.5	7.5	1.5
K	8.5	24.0	4.5	7.0	2.5
L	13.5	22.5	5.5	10.5	.5
M	13.5	13.0	10.5	12.0	3.0
N	7.0	20.5	6.0	6.0	1.5
O	4.5	27.5	7.5	6.5	1.5
OO	.5	22.5	.0	3.5	.5
P	5.5	21.0	.5	2.0	2.5
R	6.0	15.0	6.5	5.0	2.0
S	1.5	18.0	6.0	3.5	1.0
LL	.5	54.5	4.5	1.5	4.5
Q	8.0	46.0	2.0	6.5	1.0
A	9.0	23.0	4.0	17.0	3.0
C	1.5	27.5	4.5	1.0	.0
E	3.0	68.0	6.0	8.5	1.0

LAB.	CELLULOSE	PVC	TILE/FL.	PVC/FL.	P. STYR./FL.
B	4.5	1.5	.5	.5	23.0
D	4.0	2.5	1.0	1.0	25.0
EE	20.5	5.5	1.0	.5	36.0
F	6.0	2.0	1.0	3.5	32.5
G	8.0	2.5	1.0	1.0	30.0
H	4.5	2.5	.5	1.0	29.5
I	6.5	4.0	1.0	4.5	28.5
J	4.5	1.5	.5	.5	22.0
K	3.5	.5	.0	1.0	21.0
L	3.0	1.0	1.0	.5	20.0
M	5.0	2.0	1.0	1.5	25.0
N	5.5	1.5	1.0	.0	23.0
O	4.5	.0	2.0	3.0	21.5
OO	4.0	.5	.0	.0	23.0
P	5.0	.5	.5	.0	33.0
R	6.0	1.0	1.0	1.5	33.0
S	3.5	.5	.5	1.0	25.5
LL	3.5	.0	.0	.0	35.5
Q	8.5	1.0	.0	1.0	30.0
A	6.0	2.0	1.0	1.0	24.5
C	3.5	1.0	.0	1.5	18.5
E	9.5	1.5	.0	.0	1.0

TABLE 7 Mean SON⁽⁵⁾, Smoke Obscuration Number
(5 min) For Each Material and Laboratory

LAB.	LINO	RUG	RED OAK	ABS	P STYR
B	706.0	1220.0	208.5	240.0	36.5
D	801.0	1427.0	123.5	208.0	46.5
EE	706.0	1536.5	151.0	184.5	37.0
F	687.5	1320.0	173.5	238.0	36.0
G	428.5	1065.5	65.5	106.0	33.0
H	674.0	1301.0	134.5	141.5	35.5
I	593.5	1268.5	103.0	240.0	21.5
J	741.0	1636.5	200.5	166.5	25.0
K	550.5	1212.0	105.0	187.0	43.0
L	847.5	1419.5	221.0	279.0	42.0
LL	529.0	1361.0	116.5	195.5	35.0
M	780.0	1616.0	155.0	302.5	41.0
N	947.5	1344.0	186.5	251.5	30.5
O	540.5	1107.5	259.5	194.0	39.0
OO	345.5	1343.0	109.5	208.0	31.0
P	494.5	1173.5	103.5	167.0	37.0
R	713.0	1454.0	125.5	174.0	41.0
S	687.0	1299.5	103.5	171.0	39.0
Q	650.5	997.5	70.0	230.5	35.0
A	787.5	1612.5	280.5	297.0	45.0
C	350.0	1128.0	66.0	120.0	27.0
E	377.5	1111.0	90.0	127.5	20.5

LAB.	A CELL	PVC	TILE/FL	PVC/FL.	P. STYR./FI
B	335.5	301.5	34.5	194.5	599.0
D	405.5	266.5	50.5	211.0	567.0
EE	456.5	307.0	56.0	251.5	350.5
F	415.0	287.0	8.0	114.0	1273.0
G	306.0	175.5	46.5	186.5	490.0
H	378.0	259.5	35.5	134.5	731.0
I	395.5	253.5	73.5	297.0	501.5
J	511.5	301.0	90.5	265.5	1000.0
K	329.5	213.5	61.0	270.5	324.0
L	459.5	319.0	30.0	170.0	887.0
LL	455.5	264.0	70.0	260.0	95.0
M	431.0	327.0	56.0	292.5	233.0
N	417.0	291.5	25.0	130.0	657.0
O	452.0	309.0	43.5	139.0	374.5
OO	326.0	216.5	32.0	145.5	225.5
P	306.5	270.5	59.5	226.0	166.0
R	404.5	280.0	26.0	127.0	1348.0
S	388.0	258.5	28.5	197.0	871.0
Q	315.5	216.5	86.5	112.0	948.5
A	445.0	369.0	58.0	393.0	413.5
C	234.0	188.0	26.0	116.0	1101.5
E	300.0	194.0	23.5	115.5	44.5

TABLE 8. Mean T_{9Dm} For Each Material and Laboratory

LAB.	LINOLEUM	POLY. RUB	RED OAK	ABS	POLYSTYRENE
B	9.80	6.00	9.95	12.85	14.00
D	8.15	4.30	10.65	13.80	11.65
EE	9.60	5.40	10.70	14.80	14.75
F	11.15	5.50	10.05	13.50	17.00
G	13.65	6.30	13.80	16.30	12.50
H	9.00	5.50	11.65	14.50	14.75
I	11.00	5.65	11.05	14.25	14.50
J	9.70	5.40	9.20	13.25	15.70
K	10.55	5.75	11.55	13.95	16.85
L	7.70	5.65	9.25	12.90	15.85
LL	8.80	4.95	10.75	14.00	14.25
M	6.65	4.30	10.45	11.70	16.50
N	7.50	4.50	10.75	13.50	15.35
O	9.90	6.75	9.15	14.65	12.15
OO	13.40	5.65	12.10	14.10	13.45
P	10.20	5.65	11.10	14.25	16.15
R	7.95	5.15	11.40	14.45	16.80
S	8.75	5.85	11.35	14.65	17.35
Q	7.65	4.35	13.25	13.55	5.55
A	6.60	3.40	8.75	11.70	22.50
C	12.00	5.15	15.20	11.60	11.95
E	10.00	5.10	12.00	16.00	23.00

LAB.	CELLULOSE	PVC	TILE/FL.	PVC/FL.	P. STYR./FL.
B	5.55	5.30	8.50	4.20	5.55
D	5.05	5.90	7.75	4.15	5.50
EE	4.60	5.30	7.00	3.90	6.60
F	4.80	5.35	8.75	3.50	4.25
G	5.80	7.55	9.00	4.30	6.05
H	5.15	5.25	8.75	4.55	5.25
I	5.25	6.30	8.50	4.00	5.70
J	4.35	5.00	6.45	3.90	5.65
K	5.20	5.80	9.05	4.10	6.90
L	4.35	4.90	8.20	4.15	4.85
LL	5.00	5.95	6.70	4.25	11.00
M	4.50	5.45	8.25	3.75	6.75
N	5.15	5.15	12.65	4.00	5.65
O	4.70	5.05	10.25	7.10	6.75
OO	6.65	6.10	8.85	4.50	7.30
P	5.75	5.35	9.05	4.40	6.95
R	6.10	5.65	7.35	3.55	4.50
S	4.95	5.90	7.05	3.90	4.85
Q	5.90	5.55	4.00	3.90	4.25
A	4.40	4.65	5.50	3.45	6.55
C	5.90	6.60	8.80	3.70	4.15
E	5.60	6.50	14.50	4.10	13.65

TABLE 9 Dm(corr.) Values for 6 Additional Replicates by Each Lab

Lab	Non-flaming												Flaming						
	Linoleum		Rug		Red Oak		ABS		α-cell		PVC-Gyp		P.Styrene		PVC-Gyp		Acoustic Tile		
	J	S	B	K	L	LL	D	M	F	O	OO	H	Q	EE	N	G	P	I	R
AMINCO MODEL	752	744	664	619	608	559	205	201	164	156	166	97	96	343	343	57	70	24	13
	740	789	689	599	635	534	212	213	159	162	158	102	94	325	282	56	66	20	9
	713	779	646	597	561	529	195	215	160	160	157	95	97	345	451	54	77	22	10
	745	768	628	620	591	530	210	198	171	153	161	101	94	285	478	51	63	25	9
Avg.	745	a/	628	591	590	518	211	192	157	a/	169	100	94	371	356	61	67	30	9
	739	a/	620	630	598	a/	211	176	164		166	98	101	287	461	53	77	29	12
S.D.	16	19	26	16	24	15	6.5	14	5.0	4.0	4.9	2.6	2.8	34	79	3.5	5.9	3.9	1.8
Lab	A																		
HOME BUILT	C																		
	530	E																	
	513	b/																	
	526	E																	
	528	23																	
Avg.	566	35																	
	532	32																	
S.D.	17.7	28																	
		28																	
		31																	
		28																	
		3.4																	

a/ Data not reported or withdrawn by request

b/ Specimens did not ignite; methane was used as fuel

TABLE 10 - SUMMARY OF VALUES FOR 18 LABORATORIES (AMINCO)

	Non-flaming Exposure							Flaming Exposure				
	Lino.	Rug	Red Oak	ABS	σ-cell	PVC-Gyp	P. Sty.	Modified Burner		Straight Burner		
								ABS/.032	f/ P. Sty.	PVA/PVC	e/ PVC-Gyp	Title
<u>BETWEEN-LAB</u>												
D _m (corr. Mean	725 d/	621	552	188	162d/	109	23	451.4	391	568	62	20
S. D. a/	49	52	40	20	4.7	6.6	6.3	17.3	52	39	19	6.9
Coef. Var. %	6.7	8.4	7.2	11	2.9	6.0	27	3.8	1.3	7.1	31	34
<u>WITHIN-LAB</u>												
S. D. b/	46	28	18	12	4.2	3.5	6.7	20.4	32	22	10.5	4.6
Coef. Var. % c/	6.4	4.5	3.2	6.4	2.6	3.2	29	4.5	8.0	4.0	17	23
<u>BETWEEN-LAB</u>												
T _m Mean	9.6	5.5	10.8	14.0	5.2	5.6	15.0		6.2		4.2	8.4
S. D.	1.8	.64	1.1	.98	.62	.63	1.7		1.6		.77	1.4
Coef. Var. %	19.4	11.8	10.4	7.0	11.9	11.1	11.5		26		18.2	17.0
<u>BETWEEN-LAB</u>												
Son(5) Mean	661	1337	149	203	395	272	36		623		197	45
Coef. Var. %	23.2	12.2	34.9	24.6	14.9	15.1	17.7		56.8		30.9	44.4
<u>BETWEEN-LAB</u>												
D _C Mean	8.9	26.4	6.4	7.0	5.6	1.6	1.8		27.0		1.1	.75
S. D.	6.3	13.8	3.8	3.7	3.9	1.4	1.4		5.2		1.2	.49

a/ S. D. = Calculated Standard Deviation
 b/ Between-lab, Standard deviation were based on mean of each lab. With-in lab, Standard deviation based on individual values.
 c/ Coef. Var. = Coefficient of Variation.
 d/ Excluding Lab. LL
 e/ Pre-round-robin, 17 labs.
 f/ Candidate reference material, 12 labs.

The mean values based on duplicate determinations of

D_m (corr.) - the maximum specific optical density of smoke, corrected for window deposit.

$T_{.9D_m}$ - the time to reach 90% of D_m .

D_c - the specific optical density of photometer window smoke deposit.

SON(5) - a smoke obscuration number based on the smoke buildup during the first 5 minutes. (See Appendix II-B)

are shown in Tables 5, 6, 7, and 8 respectively.^{3/}

Individual values are tabulated in Appendix I. On materials in which a laboratory performed 8 replicate tests, only the first 2 test results are included in these summary tables. The remaining 6 test results, including the mean and standard deviation are tabulated in Table 9.

6. Statistical Analysis

6.1 Means and Standard Deviation

Table 10 summarizes, for each material, the arithmetic mean, standard deviation, and coefficient of variation of data from 18 laboratories using the AMINCO-built chamber. The within-laboratory standard deviations are computed from the formula:

$$S^2 = \frac{1}{2k} \sum_{i=1}^k (X_{1i} - X_{2i})^2$$

where S is the pooled standard deviation, X_{1i} and X_{2i} are

^{3/}See Appendix II (Appendix B) for definition of terms.

the replicate test results from laboratory i , and $k = 18$ is the number of laboratories. The between-laboratory standard deviations are computed from the means of the duplicates of these 18 laboratories. The mean and between-laboratory standard deviation of $T_{.9D}$, D_c and $SON_{(5)}$ are also included. Results of one AMINCO (Q) and all three home-built (A,C,E) chambers are not included in the analysis. (There were basic differences between individual home-built chambers, and between these chambers and the AMINCO-built chambers, e.g. chamber wall construction, photometer, etc.) A comparison of the within-laboratory standard deviation in Table 10 with their counterpart in Table 9 for the various materials substantiate the assumption that laboratories using AMINCO chambers have approximately equal precision.

6.2 Variability

A simple graphical procedure, known as the Youden Plot, was used for comparing interlaboratory results [3]. A graph is prepared by plotting the value of D_m (corr.) for one material on the X-axis and that for another material of about the same value on the Y-axis. Each point represents one laboratory and there will be as many points as there are reporting laboratories. A line parallel to the X-axis is drawn through the median of these points in the Y direction; a line parallel to the Y-axis is drawn through the median of these points in the X direction. The two lines divide the graph into four quadrants.

If only random errors are present, the points can be expected to be equally distributed in all quadrants. Points tend to be concentrated in the upper right and lower left quadrants when systematic bias by individual laboratory exists.




FIG. 1 Youden Plot of Linoleum vs. Polypropylene Rug




FIG. 2 Youden Plot of PVC/Gypsum vs. Acoustic Tile, Flaming

Figure 1 is a Youden Plot based on non-flaming test data for Linoleum and Polypropylene rug, and Figure 2 for the flaming test data on PVC-gypsum board and Acoustic Tile. In both figures, Labs A, C, E and Q are identified but are not included in determining the medians. Figure 1 is representative of the other Youden plots for materials tested under the non-flaming condition, and Figure 2 for the flaming condition. There is a general tendency for points to concentrate in the upper right and lower left quadrants, which is typical for most interlaboratory data. The data, particularly in Figure 2 show that laboratories have a much greater tendency to have similar results (high or low) on both materials thus indicating a systematic deviation which requires explanation.

Figures 3 and 4 are another form of Youden plot in which the first and second (duplicate) test results for a single material are plotted. If there were no systematic biases, about 90% of the points should be within a circle whose radius is 2.15 times the standard deviation.

Analysis of Table I -1 (Appendix I) shows that for all materials with D_m (corr.) values >100 , 80% of all the individual values were within $\pm 10\%$ of the mean values for all laboratories; also over 95 percent of all the individual values were within $\pm 20\%$ of the mean values for all laboratories.

An overall distribution of results (18 AMINCO chambers) is shown in Figure 5 and 6. Deviation from the mean values of D_m (corr.) for each laboratory are plotted against the mean of all laboratories.




FIG. 3 Youden Plots of Linoleum and α -cellulose





FIG. 4 Youden Plots of Polystyrene Foam and PVC, Flaming Condition




FIG. 5 Mean $D_{m(\text{corr.})}$ of All Labs vs. Each Lab., 4 Materials




FIG. 6 Mean $D_{m(corr.)}$ of All Labs vs. Each Lab., 5 Materials

Table 11 - Material Rankings by 18 Labs. (AMINCO)
(Flaming or non-flaming exposure)

LAB.	Lino.	Rug	Red Oak	Polysty/Fl.	ABS	α -cellu.	PVC-Gyp	PVC-Gyp/Fl.	Polysty.	Tile/F
B	1	2	3	4	5	6	7	8	9	10
D	1	2	3	4	5	6	7	8	9	10
EE	1	2	3	4	5	6	7	8	9	10
F	1	3	2	4	5	6	7	8	9	10
G	1	2	3	4	6	5	7	8	9	10
R	1	2	3	4	5	6	7	8	9	10
I	1	2	3	4	5	6	7	8	10	9
J	1	2	3	4	5	6	7	8	10	9
K	1	2	3	4	5	6	7	8	9	10
L	1	2	3	4	5	6	7	8	9	10
LL	1	2	3	4	5	6	7	8	10	9
M	1	2	3	4	5	6	7	8	10	9
N	1	2	3	4	5	6	7	8	10	9
O	1	2	3	4	5	6	7	8	10	9
OO	1	2	3	4	5	6	7	8	9	10
P	1	2	3	4	6	5	7	8	9	10
R	1	2	3	4	5	6	7	8	9	10
S	1	2	3	4	5	6	7	8	9	10
Mean										
D _m (corr.)	725	621	552	391	188	162	109	62	23	20

6.3 Ranking of Materials

Of the 10 material-conditions included in the tests, all 18 laboratories with AMINCO chambers ranked 9 of the material-conditions in the same order in terms of D_m (corr.) with only 3 reversal, see Table 11. Because of the proximity of results between the 10th material, Acoustic tile, D_m (corr.)=20; and the 9th material, Polystyrene Foam, non-flaming D_m (corr.)=23, some reversal in ranking order occurred. This was not unexpected because of the closeness of the D_m values.

Table 12 shows the ranking order of the laboratories for each material and the ranking sums (score) for each laboratory. A ranking order of 10, for example, means that the particular laboratory has a D_m (corr.) value higher than nine other laboratories for that material. The score for a laboratory is based on the sum of the rankings for all materials [4]. The score rank indicate the ranking of the score.

7. Discussion

This round robin was designed to examine the level of variability of the test method for materials with a wide range of properties in terms of composition, thickness, reaction to heat and flame, and production of smoke. It also included diverse types of laboratories - research as well as testing oriented; experienced as well as new to smoke measurement work. The result should reflect therefore, a conservative estimate of the precision of the test method.

An interlaboratory test of this type indicates clearly to the participating laboratories who have reported systematic

Table 12 D_m(corr.) Ranking and Score of Labs for Each Material (18 AMINCO Labs.)

LAB.	Non-Flaming Exposure										Flame Exposure					
	Lino.	Rug	Red Oak	ABS	Cell	PVC	P.Sty	Score	Score Rank		P.Sty	PVC	Title	Score	Score Rank	
B	14	18	9	12.5	5.5	12	6	77	14		1	8	6.5	15.5	2	
D	6	13	3	12.5	15.5	6.5	14	70.5	11		5	9	8	22	8	
EE	16	15	11	14.5	7	11	15	89.5	15		3	13	9.5	25.5	10	
F	17	9	18	17	13.5	10	9.5	94	16		8	1	1	10	1	
G	7	2	16	1	13.5	8	7	44.5	3		2	7	9.5	18.5	3	
H	4	5	13	2	3.5	2.5	8	38	2		12	3	6.5	21.5	7	
I	11	6	2	9	12	5	1	46	4		15	17	18	40	17	
J	12	17	15	5	17	4	2	72	13		4	11.5	13	28.5	11	
K	9	4	14	7	1.5	2.5	16	54	5		7	15.5	14.5	37	12	
L	18	14	17	18	3.5	13	11	94.5	17		10	5	4.5	19.5	4.5	
LL	2	7	7	8	18	16	13	71	12		6	15.5	16.5	38	13.5	
M	1	3	10	14.5	1.5	17	9.5	56.5	7		9	14	16.5	39.5	15.5	
N	13	1	1	16	9	18	4	62	8		17	10	11	38	13.5	
O	3	10	16	10	11	14	5	69	10		14	18	14.5	46.5	18	
OO	5	12	4	4	8	1	3	37	1		11	4	4.5	19.5	4.5	
P	10	8	5	3	10	6.5	12	54.5	6		16	11.5	12	39.5	15.5	
R	8	11	8	6	5.5	9	17	64.5	9		18	2	3	23	9	
S	15	16	12	11	15.5	15	18	102.5	18		13	6	2	21	6	

deviations from the average, that they should examine their procedures more carefully to locate sources of such departures.

7.1 Variation Between Laboratories

The optical system and the thermal properties of the inside walls differ between the home-built (Labs. A, C, and E) and AMINCO chambers. As a group, the results of home-built chambers are lower than the AMINCO type with the difference more pronounced at the higher end of the scale.

The mean values of 5 of the 10 material-conditions supplied by Lab. Q were the lowest of all 22 laboratories. In many cases, Lab. Q deviations from the median exceeded 3 times the standard deviation, and their results have been excluded. Justifiable reruns, and withdrawal of some data by request, based on acknowledged error, were few and are listed in Table 13.

7.2 Materials

The materials selected for the tests covered a wide range of smoke levels as well as physical properties. Table 9 and 10 reflect the fact that the uncertainty of the test results (in terms of computed standard deviation and coefficient of variation) is considerably greater for materials which change in shape and position during test exposure. For example ABS melted gradually and flowed down away from the high irradiance center region. The Polystyrene foam melted and shrank into the bottom of the holder rapidly where the bottom edge shields it from further exposure.

Table 13 Adjustment of Data

Lab	Material/Condition	No. of Tests	Remarks
H	Polystrene/flaming	2	Rerun, error.
K	Ploystrene/flaming	2	Rerun requested by lab.
S	Linoleum/non-flaming	1	Replaced 2nd by 4th run.
N	PVC/flaming	2	Not reported; assumed 62.
OO	Tile/flaming	1	Excluded, error
LL	Linoleum/non-flaming	1	Withdraw Requested by
	Rug/non-flaming	1	Lab. (error). "
	Red Oak/non-flaming	1	
Q	All	All	Not used in statistical calculation (excessive variability)
A,C,E	All	All	Not used; limited only to AMINCO chamber

The results of the D_m (corr.) values show that the ratio of between-laboratory standard deviation (reproducibility), to the within-laboratory standard deviation, range between 0.9 and 2.2. This implies that variations in procedures among laboratories account for most of the error rather than specimen variations. Hence, the averaging of three replicate determinations as specified in the proposed test method standard will not improve the between-laboratory variability, unless some of the major systematic sources of error are removed. However, the required three determinations may help in getting a more representative cross-section of the material.

In terms of ranking materials based on smoke level, these tests show (a) almost total agreement among the laboratories, and (b) the ability to rank order consistently two materials whose smoke density values were within 12% of each other (Polypropylene rug = 621 versus Red oak = 552).

7.3 Results

As indicated by the D_m (corr.) values in Table 10 under the non-flaming exposure condition, the five non-melting materials have a maximum coefficient of variation of 8.4%. The other two materials which melt, ABS and Polystyrene, have coefficients of variation of 11 and 27% respectively. However, the 27% coefficient of variation represents a standard deviation of only 6.3.

Under flaming exposure, the large coefficient of variation for tile and PVC-gypsum veneer may be attributed to systematic error. In Figure 2, the high values of Lab. I and LL and the low values of F, R, and H may be the result of using

Table 14 Results of Pre-Round-Robin and Candidate Reference Specimens

Lab	α -Cellulose		PVC/PVA Flaming		ABS/32 mil Flaming ^{a/}	
	Dm	Dc	Dm	Dc	Dm(corr)	Dc
A	163	7	501	6		
	161	7	460	15		
B	171	2	561	5	433	10
	153	8	564		440	25
C	166	5	498	26		
	163	7	513	18		
D	161	5	597	7		
			607	11		
E	160	10	505	15	(EE) 452	22
	161	16	513	14	437	18
F	174	5	553	12	487	24
	175	5	516	17	491	24
G	166	3	505	13		
	176	3	517	13		
H	160	3	560	11		
	165	5	592	12		
I	161	4	581	5	(J)435	23
	157	3	597	9	475	27
K	150		550		488	26
	162		543		453	19
L	163	2	549	8	462	20
	156	3	608	12	457	18
LL	164	9	513	14		
	169	8	523	11		
M	157	6	620	18		
	166	7	629	13		
OO					439	26
					440	17
O	156	4			420	18
	162	5			471	16
P	162	6	545	7	469	25
	176	2	568	6	474	27
Q	175	2	549	14	426	54(32) ^{b/}
	160	2	541	14	455	58(36)
R	162	9	531	20		
	163	10	606	19		
S	166	5	495	7	439	26
	162	4	535	9	417	27
U					415	20
					462	22
Between Lab						
Mean	163.6		548.4		451.4	
S.D.	4.8		38.9		17.3	
Coef.Var%	2.9		7.1		3.8	
Within Lab						
S.D.	6.1		22.0		20.4	
Coef.Var%	3.7		4.0		4.5	

^{a/} Modified Burner and Trough Holder

^{b/} Values in parenthesis were used to calculate Dm(corr)

improper fuel flow rate and burner distance, (See Table 4). If these data were excluded, the coefficient of variation for the two materials would be reduced by about one-third. However, for the tile and the PVC-gypsum materials, the actual values of the standard deviation are 6.9 and 19 respectively, representing low absolute variations for low smoke producing materials. The result for Polystyrene under flaming exposure is less affected by variations in burner location and fuel, since once ignited, it becomes strongly exothermic and burns without requiring external energy. This is also true with the thicker PVC-PVA sheet under flaming exposure used in the preliminary tests and the 0.032" ABS sheet used in the post-round-robin tests. There, the coefficient of variation was only 7.1% (mean D_m (corr.) = 548) and 4.5% (mean D_m (corr.) = 458) for the two materials respectively.

In order to detect possible gross errors in procedure or equipment, a short series of tests was conducted prior to the round-robin on two materials. The data are shown in Table 14. Also included are results of tests performed after the round-robin on a candidate reference material (ABS). The unusually high D_c values on ABS for Lab. Q were attributed to the additional smoke deposited on the window during an excessive exposure time after a maximum smoke level has been reached. A D_c correction of 22 was arbitrarily subtracted from the reported values. The statistical results from these tests are summarized in Table 10.

Of all the parameters listed in Table 10, the D_c values, photometer window deposit, has a relatively higher between-laboratory variance; which appears to be systematic. This may have been caused by the differences in window temperature among chambers and/or improper procedure (e.g. failure to remove the specimen from the front of the furnaces within one minute after teaching the minimum transmittance).

7.4 Possible Sources of Error

For the materials tested in this study, there was greater variability in the flaming exposure test results compared to the non-flaming tests. There are several possible sources for systematic errors in the flaming test, these include:

1. Type of pilot burner.
2. Position of the pilot burner relative to the specimen surface (horizontal and vertical spacings).
3. Flow rates of propane and air to the pilot burner.

8. Conclusions and Recommendations

This interlaboratory study of the smoke density chamber test method showed that reproducible test results were attainable for a wide variety of materials tested under flaming and non-flaming exposure conditions.

To improve reproducibility and repeatability even further, and to reduce systematic errors, certain features of the test method description, apparatus and/or experimental procedures may be noted:

1. For flaming exposure conditions, a reference standard material with a maximum specific optical density in the range of 400 to 500 appears useful.
2. Care should be taken in the proper location and use of the standard pilot burner to ensure its identical re-positioning from test to test.
3. Propane and air flowmeters of the proper range

- and calibration should be used and maintained.
4. The modified six-tube burner and holder (used on melting specimens) should be adopted for all flaming specimens. This would simplify procedures and avoid the need of selecting from two burners.
 5. A properly calibrated radiometer should be used and carefully maintained.
 6. Checks should be made of the proper furnace voltage prior to each test. In case where line voltage fluctuation causes excessive variation of irradiance, a constant voltage transformer may be necessary.
 7. The specified temperature limits of the wall surface should be observed.
 8. Proper conditioning of all specimens is necessary.
 9. Improved specification and/or design of the photometer window heater should minimize temperature and smoke deposit variability among the chamber windows.
 10. Remove the specimen and commence smoke exhaust one minute after reading maximum smoke value in order to reduce photometer window deposit.
 11. Care should be exercised when changing optical filters, to avoid measurement errors. A system where filter changes can be made without removal of the optical drawer is recommended.

Recommendations 1 and 4 have since been included in the revised test method. An effective method for changing filters, as per Recommendation 11, is now available from AMINCO.

9. Acknowledgment

I would like to thank all participating laboratories and their representatives for their helpful comments, and cooperation in making this joint study possible; the participants for attending the pre-test conference; Mr. John Brendan of the U. S. Forest Products Laboratory for providing the red oak specimens; and Dr. H. H. Ku (NBS) for advice on the statistical design and analysis.

10. References

- [1] D. Gross, J. J. Loftus and A. F. Robertson, "Method for Measuring Smoke from Burning Materials", ASTM Special Technical Publication No. 422 (1967).
- [2] D. Gross, et al, Smoke and Gas Produced by Burning Aircraft Interior Materials, Nat. Bur. Stand. (U.S.), Bldg. Sci. Ser. 18, 27 pages (Feb 1969).
- [3] Youden, W. J., "Precision Measurement and Calibration, Statistical Concept and Procedures" edited by H. H. Ku, NBS Special Publication 300, Vol. 1, February 1969, U. S. Government Printing Office, Washington, D. C., 20402 or Youden, W. J., Industrial Quality Control, Vol. XV, No. 11, 1959.
- [4] Youden, W. J., Ranking Laboratories by Round-Robin Test. Materials Research and Standards 3, No. 1, 9-13 (1963).

APPENDIX I--ORIGINAL DATA

Table I-1 lists the duplicate values of D_m (corr.) for all materials and all laboratories.

Table I-2 lists the corresponding values of $T_{.9D_m}$

Table I-3 lists the corresponding values of $SON(5)$

Table I-4 lists the corresponding values of D_c .

TABLE I-1 Duplicate Values of Dm (corr),
Maximum Specific Optical Density, Corrected

LAB.	LINGULEUM		POLY. RUG		RED OAK		ARS		POLYSTYRENE	
B	764.	733.	741.	738.	562.	534.	197.	205.	17.	25.
D	707.	699.	633.	626.	525.	501.	197.	205.	22.	29.
EE	795.	772.	675.	652.	555.	556.	195.	210.	24.	32.
F	788.	792.	603.	623.	616.	632.	204.	209.	26.	20.
G	687.	722.	580.	580.	524.	524.	147.	146.	24.	19.
H	632.	736.	592.	588.	583.	565.	153.	162.	20.	25.
I	762.	695.	594.	601.	505.	499.	193.	192.	11.	11.
J	744.	731.	739.	664.	597.	593.	192.	159.	18.	11.
K	704.	735.	579.	593.	556.	596.	166.	192.	30.	27.
L	831.	773.	656.	656.	645.	600.	230.	222.	24.	23.
M	608.	601.	583.	581.	555.	545.	199.	206.	29.	17.
N	744.	743.	498.	505.	491.	499.	200.	211.	18.	13.
O	738.	611.	656.	576.	586.	617.	183.	211.	11.	26.
OO	699.	682.	659.	599.	539.	489.	169.	171.	15.	15.
P	742.	702.	628.	589.	508.	524.	165.	159.	23.	25.
R	657.	730.	596.	639.	534.	555.	193.	162.	33.	27.
S	806.	746.	682.	655.	550.	567.	194.	202.	24.	50.
LL	568.	.	564.	.	520.	557.	166.	198.	18.	31.
Q	450.	510.	446.	453.	385.	378.	184.	210.	10.	10.
A	528.	520.	486.	493.	473.	473.	174.	195.	29.	31.
C	483.	508.	513.	531.	352.	414.	63.	110.	9.	13.
E	564.	557.	481.	488.	490.	492.	130.	132.	18.	21.

LAB.	A CELLULOSE		PVC		TILE/FL.		PVC/FL.		P. STYR./FL.	
B	164.	154.	114.	109.	15.	18.	57.	61.	292.	254.
D	168.	167.	102.	109.	20.	18.	59.	63.	341.	366.
EE	158.	161.	113.	108.	19.	20.	78.	73.	326.	327.
F	160.	170.	107.	113.	6.	7.	26.	23.	397.	414.
G	162.	168.	113.	101.	21.	18.	51.	63.	327.	317.
H	157.	158.	104.	101.	15.	18.	44.	31.	408.	428.
I	162.	167.	108.	102.	32.	34.	106.	69.	459.	397.
J	167.	172.	100.	106.	29.	24.	77.	61.	283.	386.
K	153.	154.	102.	103.	27.	27.	85.	81.	372.	382.
L	161.	154.	111.	113.	16.	14.	47.	50.	414.	404.
M	152.	155.	120.	116.	29.	26.	78.	80.	416.	396.
N	158.	167.	124.	125.	25.	17.	62.	62.	465.	411.
O	167.	160.	115.	113.	16.	38.	78.	107.	421.	430.
OO	162.	158.	95.	99.	15.	15.	50.	42.	419.	413.
P	159.	167.	106.	105.	21.	25.	73.	65.	398.	473.
R	156.	162.	109.	106.	11.	14.	32.	30.	519.	453.
S	169.	166.	117.	112.	6.	17.	41.	69.	422.	415.
LL	184.	175.	117.	113.	27.	28.	89.	77.	340.	413.
Q	160.	164.	91.	81.	22.	22.	28.	33.	390.	423.
A	158.	152.	109.	120.	19.	13.	108.	102.	336.	374.
C	142.	159.	93.	91.	15.	26.	24.	30.	391.	452.
E	132.	144.	88.	96.	15.	11.	31.	35.	21.	24.

TABLE I-2 Duplicate Values of T_{.9Dm}
Time (min.) at 90% of Maximum Smoke

LAB.	LINOLEUM		POLY. RUG		RED OAK		ABS		POLYSTYRENE	
B	8.5	11.1	5.9	6.1	10.0	9.9	12.7	13.0	10.0	16.0
D	7.8	8.5	4.3	4.3	9.8	11.5	13.3	14.3	9.3	14.0
EE	8.2	11.0	5.4	5.4	9.8	11.6	15.6	14.0	14.0	15.5
F	11.5	10.8	5.5	5.5	10.3	9.8	13.0	14.0	17.0	17.0
G	15.3	12.0	6.3	6.3	14.3	13.3	16.3	16.3	14.0	11.0
H	8.0	10.0	5.5	5.5	11.8	11.5	15.5	13.5	13.0	16.5
I	10.7	11.3	5.3	6.0	10.0	12.1	15.5	13.0	16.0	13.0
J	9.4	10.0	5.5	5.3	9.0	9.4	12.5	14.0	17.6	13.8
K	9.5	11.6	5.9	5.6	11.6	11.5	14.0	13.9	16.7	17.0
L	6.8	8.6	5.6	5.7	9.1	9.4	12.5	13.3	15.7	16.0
LL	7.6	10.0	4.4	5.5	11.5	10.0	14.5	13.5	11.0	17.5
M	6.6	6.7	4.3	4.3	9.7	11.2	12.0	11.4	16.2	16.8
N	7.5	7.5	4.5	4.5	11.0	10.5	14.0	13.0	16.0	14.7
O	10.8	9.0	6.5	7.0	9.5	8.8	16.5	12.8	4.3	20.0
OO	14.0	12.0	5.8	5.5	12.0	12.2	14.2	14.0	10.7	16.2
P	10.4	10.0	6.0	5.3	11.6	10.6	13.8	14.7	15.5	17.0
R	8.5	7.8	5.3	5.0	11.8	11.0	13.9	15.0	17.0	16.6
S	8.5	9.0	6.6	5.1	11.5	11.2	15.2	14.1	16.5	18.2
Q	6.8	8.5	4.0	4.7	14.0	12.5	13.3	13.8	5.3	5.8
A	7.5	5.9	3.8	3.0	7.8	9.7	11.0	12.4	22.6	23.0
C	12.0	12.0	5.4	4.9	14.5	15.9	7.2	16.0	3.1	20.8
E	9.0	11.0	5.0	5.2	12.0	12.0	17.0	15.0	20.0	26.0
LAB. A	CELLULOSE		PVC		TILE/FL.		PVC/FL.		P. STYR. /FL.	
B	5.7	5.4	5.4	5.2	9.0	8.0	4.0	4.4	5.5	5.6
D	4.8	5.3	5.8	6.0	8.5	7.0	4.3	4.0	5.5	5.5
EE	4.8	4.4	5.2	5.4	6.8	7.2	3.8	4.0	7.6	5.6
F	5.0	4.6	5.4	5.3	8.5	9.0	3.5	3.5	4.0	4.5
G	5.8	5.8	8.3	6.8	9.0	9.0	4.3	4.3	6.3	5.8
H	5.5	4.3	5.0	5.5	8.5	9.0	4.0	4.5	6.0	4.5
I	6.0	4.5	6.1	6.5	8.0	9.0	4.3	3.7	6.2	5.2
J	4.6	4.1	4.9	5.1	6.5	6.4	2.8	5.0	5.9	5.4
K	5.0	5.4	5.8	5.8	9.8	8.3	3.9	4.3	7.0	6.8
L	4.5	4.2	4.8	5.0	7.0	9.4	4.0	4.3	4.8	4.9
LL	5.5	4.5	5.7	6.2	6.7	6.7	4.5	4.2	9.0	13.0
M	4.6	4.4	5.7	5.2	8.0	8.5	3.6	3.7	7.0	6.5
N	4.8	5.5	6.0	4.3	10.3	15.0	4.0	4.0	4.8	6.5
O	4.6	4.8	4.3	5.8	10.0	10.5	4.9	9.3	8.3	5.2
OO	7.0	6.3	6.0	6.2	9.2	8.5	4.5	4.5	7.8	6.8
P	6.0	5.5	5.1	5.6	8.1	10.0	4.5	4.3	10.0	7.9
R	7.8	4.4	5.6	5.7	6.9	7.8	3.9	3.2	3.7	5.3
S	5.0	4.9	5.8	6.0	7.9	6.2	3.6	4.0	4.9	4.8
Q	5.5	6.3	5.8	5.3	2.5	5.5	3.0	4.8	4.5	4.0
A	4.7	4.1	4.6	4.7	6.0	5.0	3.5	3.4	7.4	5.7
C	6.3	5.5	6.4	6.8	8.0	9.6	3.5	3.9	4.6	3.7
E	6.0	5.2	6.0	7.0	17.0	12.0	4.5	3.7	15.3	12.0

TABLE I-3 Duplicate Values of SON (5)
Smoke Obscuration Number (5 min)

LAB.	LINOLEUM		POLY. RUG		RED OAK		ABS		POLYSTYRENE	
B	960.	452.	1338.	1102.	259.	158.	214.	266.	40.	33.
D	725.	877.	1437.	1417.	135.	112.	242.	174.	41.	52.
EE	854.	358.	1579.	1494.	167.	135.	112.	257.	38.	36.
F	636.	739.	1309.	1331.	170.	177.	242.	234.	49.	23.
G	325.	532.	1020.	1111.	61.	70.	112.	100.	35.	31.
H	717.	631.	1323.	1279.	137.	132.	123.	160.	38.	33.
I	726.	461.	1276.	1261.	119.	87.	207.	273.	21.	22.
J	819.	663.	1743.	1530.	200.	201.	207.	126.	24.	26.
K	628.	473.	1156.	1268.	100.	110.	173.	201.	45.	41.
L	999.	696.	1389.	1450.	234.	208.	291.	267.	51.	33.
LL	529.	529.	1361.	1361.	89.	144.	184.	207.	45.	25.
M	748.	812.	1603.	1629.	163.	147.	294.	311.	51.	31.
N	958.	937.	1383.	1305.	196.	177.	281.	222.	29.	32.
O	589.	492.	1246.	969.	260.	259.	134.	254.	42.	36.
OO	327.	364.	1260.	1426.	124.	95.	206.	210.	37.	25.
P	527.	462.	1101.	1246.	82.	125.	200.	134.	40.	34.
R	613.	813.	1353.	1555.	123.	128.	209.	139.	49.	33.
S	734.	640.	1182.	1417.	111.	96.	141.	201.	44.	34.
Q	751.	550.	887.	1108.	78.	62.	257.	204.	35.	35.
A	665.	910.	1492.	1733.	341.	220.	327.	267.	49.	41.
C	283.	417.	1053.	1203.	82.	58.	112.	128.	35.	19.
E	413.	342.	1120.	1102.	94.	86.	122.	133.	19.	22.
LAB.	CELLULOSE		PVC		TILE/FL.		PVC/FL.		P. STYR./FL.	
B	326.	345.	308.	295.	31.	38.	197.	192.	563.	635.
D	445.	366.	253.	280.	54.	47.	201.	221.	490.	644.
EE	431.	482.	318.	296.	59.	53.	257.	246.	108.	593.
F	388.	442.	283.	291.	8.	8.	110.	118.	1112.	1434.
G	315.	297.	152.	199.	46.	47.	172.	201.	501.	479.
H	341.	415.	261.	258.	32.	39.	154.	115.	498.	964.
I	346.	445.	268.	239.	82.	65.	355.	239.	378.	625.
J	469.	554.	285.	317.	122.	59.	296.	235.	852.	1148.
K	339.	320.	233.	194.	56.	66.	285.	256.	325.	323.
L	450.	469.	326.	312.	35.	25.	168.	172.	943.	831.
LL	428.	483.	271.	257.	69.	71.	275.	245.	58.	132.
M	421.	441.	337.	317.	66.	46.	282.	303.	345.	121.
N	435.	399.	287.	296.	23.	27.	130.	130.	762.	552.
O	472.	432.	316.	302.	29.	58.	230.	48.	148.	601.
OO	312.	340.	218.	215.	32.	32.	154.	139.	157.	294.
P	253.	360.	284.	257.	61.	58.	240.	212.	80.	252.
R	357.	452.	281.	279.	26.	26.	131.	123.	1862.	834.
S	386.	390.	263.	254.	12.	45.	160.	234.	662.	880.
Q	329.	302.	220.	213.	91.	82.	110.	114.	1026.	871.
A	436.	494.	355.	383.	66.	50.	401.	385.	382.	445.
C	185.	283.	192.	184.	21.	31.	105.	127.	841.	1362.
E	249.	351.	217.	171.	27.	20.	108.	123.	31.	58.

TABLE I-4 Duplicate Values of Dc
Photometer Window Deposit

LAB.	LINOLEUM		POLY. RUG		RED OAK		ABS		POLYSTYRENE	
B	1.	6.	21.	24.	1.	0.	2.	11.	0.	2.
D	13.	21.	21.	23.	9.	7.	12.	7.	1.	1.
EE	0.	1.	20.	20.	8.	2.	13.	20.	3.	3.
F	17.	8.	21.	16.	6.	5.	9.	12.	6.	5.
G	14.	14.	70.	66.	15.	13.	6.	8.	2.	2.
H	19.	14.	35.	27.	11.	13.	3.	5.	1.	0.
I	8.	13.	21.	22.	8.	9.	3.	11.	0.	0.
J	23.	21.	29.	39.	11.	10.	8.	7.	2.	1.
K	5.	12.	26.	22.	4.	5.	4.	10.	2.	3.
L	14.	13.	20.	25.	5.	6.	11.	10.	1.	0.
M	12.	15.	13.	13.	12.	9.	12.	12.	3.	3.
N	5.	9.	18.	23.	10.	2.	7.	5.	1.	2.
O	6.	3.	25.	30.	9.	6.	5.	8.	0.	3.
OO	1.	0.	20.	25.	0.	0.	2.	5.	0.	1.
P	9.	2.	15.	27.	0.	1.	1.	3.	3.	2.
R	7.	5.	16.	14.	6.	7.	6.	4.	3.	1.
S	2.	1.	20.	16.	10.	2.	5.	2.	2.	0.
LL	1.	0.	50.	59.	8.	1.	2.	1.	9.	0.
Q	9.	7.	48.	44.	1.	3.	7.	6.	1.	1.
A	13.	5.	22.	24.	1.	7.	14.	20.	3.	3.
C	2.	1.	36.	19.	8.	1.	1.	1.	0.	0.
E	2.	4.	87.	89.	11.	5.	8.	9.	0.	2.
LAB.	A CELLULOSE		PVC		TILE/FL.		PVC/FL.		P. STYR./FL.	
B	4.	5.	1.	2.	1.	0.	1.	0.	26.	20.
D	5.	3.	3.	2.	1.	1.	1.	1.	25.	25.
EE	20.	21.	6.	5.	2.	0.	0.	1.	26.	46.
F	6.	6.	2.	2.	1.	1.	2.	5.	32.	33.
G	8.	8.	2.	3.	1.	1.	1.	1.	30.	30.
H	3.	6.	3.	2.	0.	1.	1.	1.	33.	26.
I	7.	6.	5.	3.	1.	1.	7.	2.	32.	25.
J	4.	5.	2.	1.	1.	0.	1.	0.	20.	24.
K	3.	4.	0.	1.	0.	0.	1.	1.	21.	21.
L	3.	3.	0.	2.	1.	1.	1.	0.	17.	23.
M	5.	5.	2.	2.	1.	1.	1.	2.	25.	25.
N	4.	7.	2.	1.	1.	1.	0.	0.	22.	24.
O	5.	4.	0.	0.	2.	2.	0.	6.	17.	26.
OO	5.	3.	0.	1.	0.	0.	0.	0.	23.	23.
P	5.	5.	1.	0.	1.	0.	0.	0.	34.	32.
R	5.	7.	1.	1.	1.	1.	2.	1.	33.	33.
S	3.	4.	0.	1.	1.	0.	2.	0.	26.	25.
LL	7.	0.	0.	0.	0.	0.	0.	0.	37.	34.
Q	9.	8.	1.	1.	0.	0.	1.	1.	58.	62.
A	7.	5.	2.	2.	1.	1.	1.	1.	26.	23.
C	6.	1.	1.	1.	0.	0.	2.	1.	15.	22.
E	5.	14.	1.	2.	0.	0.	0.	0.	0.	2.

September 1971

TEST METHOD FOR MEASURING THE SMOKE
GENERATION CHARACTERISTICS OF SOLID MATERIALS

1. Scope

1.1 This method of test covers a procedure for measuring the smoke generation characteristics of solid materials and assemblies in thicknesses up to and including 1 in. (25.4 mm). Measurement is made of the attenuation of a light beam by smoke (suspended solid or liquid particles) accumulating within a closed chamber due to nonflaming pyrolytic decomposition and flaming combustion. Results are expressed in terms of specific optical density, which is derived from a geometrical factor and the measured optical density (absorbance), the single measurement most characteristic of the "concentration of smoke." The photometric scale used to measure smoke by this test method is similar to the optical density scale for human vision.

2. Significance

2.1 This method provides a means for comparing the smoke generated by materials and assemblies of given thickness and properties under the specified exposure conditions. The values determined by this test are specific to the material as tested and are not to be considered inherent, fundamental

NOTE 1 - The values stated in U.S. customary units are to be regarded as the standard. The metric equivalents of U.S. customary units given in the standard may be approximate.

properties. Correlation with other fire conditions or with measurements by other test methods has not been established.*

3. Summary of Method^{1/}

3.1 This method for measuring the smoke generation characteristics of materials employs an electrically-heated radiant energy source mounted within an insulated ceramic tube and positioned so as to produce an irradiance level of 2.2 Btu/sec ft² (2.5 W/cm²) averaged over the central 1.5 in. (38.1 mm) diameter area of a vertically mounted specimen facing the radiant heater. The nominal 3 by 3 in. (76.2 by 76.2 mm) specimen is mounted within a holder which exposes an area measuring 2 9/16 by 2 9/16 in. (65.1 by 65.1 mm). The holder can accommodate specimens up to 1 in. (25.4 mm) thick. This exposure provides the nonflaming condition of the test.

3.2 For the flaming condition, a six-tube burner is used to apply a row of equidistant premixed (air-propane) flamelets across the lower edge of the exposed specimen area. This application of flame in addition to the specified irradiance level from the heating element constitutes the flaming combustion exposure.

* Other test methods for measuring smoke have been reviewed and summarized in "The Control of Smoke in Building Fires - A State-of-the-Art Review," Materials Research and Standards, pp. 16-23, 42, April 1971.

^{1/}D. Gross, J. J. Loftus and A. F. Robertson, "Method for Measuring Smoke from Burning Materials," ASTM Special Technical Publication No. 422 (1967), describes factors in the development of this method and provides comparative test data on the measurement of the smoke generating characteristics of materials.

3.3 The test specimens are exposed to the flaming and non-flaming conditions within a closed 18 ft³ (0.51 m³) chamber. A photometric system with a 36 in. (914 mm) vertical light path measures the continuous decrease in light transmission as smoke accumulates.

3.4 Calibration procedures for the test equipment as described in Appendix A shall be followed. The light transmittance measurements are used to express the smoke generation characteristics of the test materials in terms of the specific optical density during the time period to reach the maximum value.²

4. Apparatus

4.1 The apparatus shall be essentially as shown in Figs. 1 and 2. A more detailed description of suggested details (using the same paragraph numbers) is given in Appendix C. The apparatus shall include the following:

4.1.1 Test Chamber - As shown in Fig. 2, the test chamber shall be fabricated from laminated panels³ to provide inside dimensions of 36 by 24 by 36 in. \pm 1/8 in. (914 by 610 by 914 \pm 3 mm) for width, depth and height, respectively. The

^{2/} Additional parameters, such as the maximum rate of smoke accumulation, time to a fixed optical density level, or a smoke obscuration index may be more appropriate in particular situations. See Appendix B.

^{3/} Commercially available panels of porcelain-enameled steel (interior surface) permanently laminated to asbestos-cement board and backed with galvanized steel (exterior surface), total thickness 3/16 in., has been found suitable.

interior surfaces shall consist of porcelain-enameled metal, or equivalent coated metal resistant to chemical attack and corrosion, and suitable for periodic cleaning. Sealed openings shall be provided to accommodate a vertical photometer, power and signal connectors, air and gas supply tubes, an exhaust blower, inlet and exhaust vents, pressure and gas sampling taps, a pressure relief valve, a rod for remote positioning of the specimen holder, an aluminum foil (0.0010 in. approx. 0.025 mm or less) safety blowout panel, at least 125 in.² (806 cm²) in area, and a hinged front mounted door with an observation port or window. All openings except the gas sampling taps, the positioning rod, and an inlet vent shall be located on the floor of the chamber. When all openings are closed the chamber shall be capable of developing and maintaining positive pressure during test periods, in accordance with paragraph 8.10.

4.1.2 Radiant Heat Furnace - As shown in Fig. 3 an electric furnace with a 3 in (76.2 mm) diameter opening shall be used to provide a constant irradiance on the specimen surface. The furnace is to be located centrally along the long axis of the chamber with the opening facing toward and about 12 in. (305 mm) from the right wall. The centerline of the furnace shall be about 7 3/4 in. (195 mm) above the chamber floor.

The furnace control system shall maintain the required irradiance level under steady-state conditions with the chamber door closed to within $\pm .04$ Btu/sec ft² ($\pm .05$ W/cm²) for 20 minutes. The control system shall consist of an autotransformer or alternate control device, and a voltmeter or other means for monitoring the electrical output. Where line voltage fluctuations are present, a constant-voltage transformer may be required to maintain the prescribed irradiance level.

4.1.3 Specimen Holder - Specimen holders shall conform in shape and dimension to that shown in Fig. 4, and be fabricated to expose a 2 9/16 in. (65.1 by 65.1 mm) specimen area. For flaming exposure tests, and where melting occurs in nonflaming tests, a modified holder with trough shall be used. Also shown in Fig. 4 are the spring and rods for retaining the specimen within the holders.

4.1.4 Framework for Support of the Furnace and Specimen Holder - The furnace and specimen supporting framework shall be constructed essentially in accordance with Fig. 5.

4.1.5 Photometric System - The photometric system shall consist of a light source and photodetector, oriented vertically to reduce variations in measurement brought about by stratification of the smoke generated by materials under test. The system shall be shown in Fig. 6, and includes the following:

4.1.5.1 The light source shall be an incandescent lamp operated at a fixed voltage in a circuit powered by a voltage regulating transformer. The light source shall be mounted in a sealed and light-tight box located below the chamber. This box shall contain the necessary optics to provide a collimated light beam passing vertically through the chamber.

4.1.5.2 The photodetector shall be a photomultiplier tube, with an S-4 spectral sensitivity response and a dark current less than 10^{-9} A. A sealed box located directly opposite the light source shall be provided to house the photodetector and the focusing optics. A glass window shall be used to isolate the photodetector and its optics from the interior of the chamber.

4.1.6 Radiometer - The radiometer for standardizing the output of the radiant heat furnace shall be of the circular foil type, the operation of which was described by Gardon⁴. The construction of the radiometer shall be as shown in Fig. 7. It shall have a stainless steel reflective heat shield with a 1 1/2 in. (38.1 mm) aperture on the front and a finned cooler supplied with compressed air mounted on the rear to maintain a constant body temperature of 200 ± 5 °F (93 ± 3 °C).

4.1.7 Thermocouples for Determining Chamber Wall Temperature - A thermocouple shall be provided for determining the chamber wall temperature prior to testing.

4.1.8 Portable Recorder or Read-Out Meter. The outputs of the radiometer and the thermocouples shall be monitored by a suitable recorder or read-out meter. The photodetector output shall be recorded or monitored with a potentiometer or other suitable instrument capable of measurement over a range of 5 decades, or more. See Appendix C, paragraph C.4.1.5.

4.1.9 Manometer for Chamber Pressure Measurements - A simple water manometer with a range up to 6 in. (152 mm) of water shall be provided to monitor chamber pressure and leakage (see Appendix A). The pressure measurement point shall be through a gas sampling hole at the top of the chamber. A simple water column or relief valve shall be provided to permit control of chamber pressure. (See C4.1.11)

^{4/}R. Gardon, "An Instrument for the Direct Measurement of Intense Thermal Radiation," Review of Scientific Instruments, Vol. 24, pp. 366-370, (1953).

4.1.10 Multiple Flamelet Burner with Premixed Air-Propane Fuel - For a flaming exposure test, a six-tube burner, with construction details as shown in Fig. 4, shall be used.

The burner shall be centered in front of and parallel to the specimen holder. The tips of the two horizontal tubes shall be centered 1/4 in. (6.4 mm) above the holder edge and 1/4 in. (6.4 mm) away from the specimen surface. Provision shall be made to rotate or move the burner out of position during non-flaming exposures. A premixed air and propane (95% purity or better) test gas shall be used. The air and propane shall be metered by calibrated rotameters and needle valves at 500 cm³/min. for air and 50 cm³/min. for the propane.

5. Test Specimens

5.1 Size - The test specimens shall be 3 by 3 ± .03 in. (76.2 by 76.2 ± 0.7 mm) by the intended installation thickness up to and including 1 in. (25.4 mm) thick. Specimens provided in thicknesses in excess of 1 in. (25.4 mm), shall be sliced to 1 in. (25.4 mm) thickness and the original (uncut) surface tested. Multi-layer materials greater than 1 in. (25.4 mm) thick, consisting of a core material with surface facings of different materials shall be sliced to 1 in. (25.4 mm) thickness, and each original (uncut) surface tested separately if required under 5.3.1.

5.2 Specimen Orientation - If visual inspection of the specimen indicates a pronounced grain pattern, process-induced surface orientation, or other nonisotropic property, the specimen shall be tested in two or more orientations. The highest smoke density value and the test orientation shall be stated.

5.3 Specimen Assembly

5.3.1 The specimen shall be representative of the materials or composite and shall be prepared in accordance with recommended application procedures. However, flat sections of the same thickness and composition may be supplied and tested in place of curved, molded or specialty parts. Substrate or core materials for the test specimens should be the same as those for the intended application. Where a material or assembly may be exposed to a potential fire on either side, both sides should be tested.

5.3.1.1 Finish materials, including sheet laminates, tiles, fabrics and others secured to a substrate material with adhesive, and composite materials not attached to a substrate, may be subject to delamination, cracking, peeling, or other separations affecting its smoke, generating characteristics. To evaluate these effects, supplementary tests performed on a scored (slit) exposed surface, or on interior layers or surfaces, may be necessary. When supplementary tests are conducted for this purpose, the manner of performing such supplementary tests, and the test results, shall be included in the report with the conventional test.

5.3.2 For comparative tests of finish materials without a normal substrate or core, and for screening purposes only, the following procedures shall be employed:

5.3.2.1 All sheet or film materials shall be tested by the standard procedure regardless of thickness.

5.3.2.2 Liquid film (paints, adhesives, etc.) intended for application to combustible base materials, shall be applied to the smooth face of 1/4 in. (6.4 mm) thick tempered hardboard,

nominal density 50 to 60 lb/ft³ (0.8 to 0.97 g/cm³), using recommended (or practical) application techniques and coverage rates. Tests shall also be conducted on the hardboard substrate alone and these values shall be recorded as supplemental to the measured values for the composite specimen.

5.3.2.3 Liquid films, (paints, adhesives, etc.) intended for application to noncombustible substrate materials, shall be applied to the smooth face of 1/4 in. (6.4 mm) thick asbestos-cement board, nominally 120 lb/ft³ (1.9 g/cm³) in density, using recommended (or practical) application techniques and coverage rates.

5.3.3 It is the intent of this test method to maintain the prescribed exposure conditions on the specimen for the test duration. If, during a nonflaming exposure test, the specimen tends to melt or drip and fall away from the specimen holder, it shall be tested using the modified specimen holder (with trough) designed for the flaming test.

5.3.4 Specimen Mounting

5.3.4.1 All specimens, shall be covered across the back, along the edges, and over the front surface periphery with a single sheet of aluminum foil (0.0015 ± 0.0005 in. or approximately 0.04 mm). Care shall be taken not to puncture the foil or to introduce unnecessary wrinkles during the wrapping operation. Fold in such a way so as to minimize losses of melted material at the bottom of the holder. Excess foil along the front edges should be trimmed off, after mounting. In using the modified holder with the trough, a flap of foil should be cut and bent forward at the spout to permit flow from melting specimens.

5.3.4.2 All specimens shall be backed with a sheet of asbestos millboard (see paragraph 4.1.3.). The specimen and its backing shall be secured with the spring and retaining rod. A modified "C" shape retaining rod shall be used with specimens from 5/8 to 1 in. (1.6 to 2.5 cm) thick. Do not compress flexible specimens below their normal thickness.

6. Specimen Conditioning

6.1 Specimens shall be predried for 24 hr. at 140 ± 5 °F (60 ± 3 °C) and then conditioned to equilibrium (constant weight) with an ambient temperature of 73 ± 5 °F (23 ± 3 °C) and a relative humidity of 50 ± 5 percent.

7. Number of Test Specimens

7.1 At least three tests under flaming exposure and three tests under nonflaming exposure shall be conducted on each material (total of six specimens) in accordance with the conditions described herein.

8. Test Procedure

8.1 All tests shall be conducted in a room or enclosed space having a ambient temperature of 73 ± 5 °F (23 ± 3 °C) and relative humidity of 50 ± 20 percent at the time of test.

8.2 Clean the chamber walls whenever periodic visual inspection indicates the need⁵. Clean the exposed surfaces of the glass windows separating the photodetector and light source housings from the interior of the chamber, before each test (ethyl alcohol is generally effective). Charred residues on the specimen holder and horizontal rods should be removed to avoid contamination.

⁵/An ammoniated spray detergent, and soft scouring pads have been found effective.

8.3 During the warm-up period all electric systems (furnace, light source, photometer readout etc.) should be on; the exhaust vent and chamber door closed; and the inlet vent open. When the temperature on the center surface of the back wall reaches 95 ± 4 °F (35 ± 2 °C), the chamber is considered to be at steady-state condition and ready for furnace calibration or testing. To increase chamber wall surface temperature to the stated level under adverse conditions, an auxiliary heater may be used; conversely, to decrease this temperature, the exhaust blower may be used to introduce cooler air from the laboratory. Calibrate the furnace output irradiance at periodic intervals according to test experience (normally twice per test day).

A "blank" specimen holder, with the asbestos millboard backing exposed should always be directly in front of the furnace except when displaced to the side by (1) the specimen holder during a test or (2) the radiometer during calibration. It should be returned immediately to this position when testing or calibration is completed.

8.4 During calibration, the radiometer is placed on the horizontal rods of the furnace support framework and accurately positioned in front of the furnace opening, by sliding and displacing the "blank" specimen holder against the pre-positioned stop. With the chamber door closed and inlet vent opened, the compressed air supply to the radiometer cooler is adjusted to maintain its body temperature at 200 ± 5 °C (93 °C). The autotransformer setting is adjusted so as to obtain the calibrated millivolt output of the radiometer corresponding to a steady-state irradiance of $2.2 \pm .04$ Btu/sec ft² ($2.5 \pm .05$ W/cm²) averaged over the central 1.5 in. (38.1 mm) diameter area.

The recorder or meter described in paragraph 4.1.8 is used to monitor the radiometer output. After the prescribed irradiance level has reached steady-state, the radiometer is removed from the chamber and replaced with the "blank" specimen holder.

8.5 After the system has reached steady-state conditions, adjust meter and/or recorder zero. Adjust the amplifier sensitivity to obtain a full-scale reading of the photo-detector (100 percent transmittance) on the recorder or read-out meter. Determine the "dark current" (zero percent transmittance) on the maximum sensitivity range of the read-out meter by blocking the light, and adjust the "dark current" reading to zero.

8.6 For nonflaming exposures, the multiple flamelet burner is removed. For flaming exposures, the burner is positioned across the lower edge of the specimen as described in paragraph 4.1.10. Check the burner distances relative to the "blank" specimen before fuel adjustment and ignition.

8.7 Before positioning the test specimen, flush the chamber with the door and exhaust and inlet vents open for about 2 minutes, and verify the starting temperature of the chamber, using the procedure described in paragraph 8.3.

8.8 Close the exhaust vent and blower. Place the loaded specimen holder on the bar support and push it into position in front of the furnace (with burner in position for flaming exposure) by displacing the "blank" holder. Quickly close the chamber door and simultaneously start the timer, and/or recorder chart drive. Close the inlet vent completely only when the photometer indicates smoke.

8.9 Record light transmittance and the corresponding time either as a continuous plot with a multi-range recorder or at sufficient time intervals with a multi-range meter read-out. Make and note the necessary full-scale range changes in decade steps.

8.10 Observe the increase in chamber pressure with the manometer described in paragraph 4.1.9. A regulator (see C4.1.11) shall be used to maintain the pressure in the range of 4 ± 2 in. (100 ± 50 mm) of water during most of the test. If negative pressure develops after very intense specimen flaming, open the inlet vent slightly to equalize the pressure. As a result of pressure rise, the fuel and air valves must be adjusted during the flaming test to maintain constant flow rate.

8.11 Record any observations pertinent to the burning and smoke generating properties of the material under test, in accordance with paragraphs 10.1.6 and 10.1.7.

8.12 Continue the test until a minimum light transmittance value is reached or after an exposure of 20 minutes; whichever occurs first. If desired, the test may be conducted for periods in excess of 20 minutes, when minimum transmittance levels have not been reached during the 20 minute exposure. The term "Extended Exposure" is to be used to identify data developed in tests longer than 20 minutes in duration.

8.13 If transmittance falls below 0.01%, the chamber window should be covered with an opaque screen to avoid possible light scattering effects from room light. Also any supplementary optical filter in the photometer system should be removed or displaced in order to extend the measuring range. If extraneous

light can reflect into the photometer during removal of the filter, turn the high voltage off or adjust the scale to minimize sensitivity. Replace the filter before exhausting smoke from the chamber.

8.14 Extinguish the burner on flaming exposures and start exhausting the chamber within one minute after reaching minimum transmittance. Displace the specimen from the front of the furnace by pushing the "blank" specimen holder with the positioning rod. Continue to exhaust with the inlet vent open until maximum transmittance is reached. Record this transmittance value as the T_c , "clear beam" reading which is to be used to correct for deposits on the photometer windows.

9. Calculations

9.1 Calculate specific optical density, D_s , from the reduction in light transmittance, T , caused by the smoke generated from an exposed specimen area, A , in the closed chamber of volume, V , and over a light path, L , as follows:

$$D_s = \frac{V}{LA} \left[\log_{10} \left(\frac{100}{T} \right) \right] = G \left[\log_{10} \left(\frac{100}{T} \right) \right]$$

where G represents the geometrical factor associated with the dimensions of the chamber and specimen.

9.2 Calculate the maximum specific optical density, D_m , using the formula in paragraph 9.1 with a light transmittance corresponding to the minimum level reached during the test. Correct all maximum specific optical density values by subtracting the specific optical density equivalent for soot and other deposits on the photometer windows. As described in paragraph 8.14, the "clear beam" transmittance reading T_c is used to

calculate a specific optical density equivalent D_c , using the same formula but with different subscript. A corrected maximum specific optical density calculation is expressed as follows:

$$D_m \text{ (corr.)} = D_m - D_c$$

9.3 For systems without "dark current" cancellation, a correction must be made for any light transmittance reading T , approaching the dark current value T_d . The corrected light transmittance T' , is obtained from:

$$T' = 1 - \frac{1-T}{1-T_d}$$

and is used for the specific optical density calculations described in paragraphs 9.1 and 9.2.

9.4 Determine $t_{.9D_m}$, the time for the smoke to accumulate to 90 percent of the uncorrected maximum specific optical density value from a plot of specific optical density versus time or from the tabulated data.

9.5 When the test is continued beyond the standard 20 minute exposure, all calculations are to be made in accordance with paragraphs 9.1 through 9.4 and the results identified as "Extended Exposure."

10. Report

10.1 The report (see Appendix E) shall include the following:

10.1.1 Complete description of the material tested including: type, manufacturer, shape, thickness and/or other appropriate dimensions, weight or density, coloring, etc.

10.1.2 Complete description of the test specimens, including: substrate or core, special preparation, mounting, etc.

10.1.3 Test specimen conditioning procedure.

10.1.4 Number of specimens tested.

10.1.5 Test conditions: type of exposures, type of holder used, exposure period.

10.1.6 Observations of the burning or smoldering characteristics of the specimens during test exposure, such as delamination, sagging, shrinkage, melting, collapse, etc.

10.1.7 Observations of the smoke generating properties of the specimens during exposure, such as, color of the smoke, nature of the settled particulate matter, etc.

10.1.8 A record of the geometrical factor, G , as calculated from measured values of chamber volume, V , photometer light path length, L , and exposed specimen area, A (see Section 9 on calculations).

10.1.9 Test results calculated as described in Section 9, including the average and range on each set of specimens for D_m (corr.), $t_{.9D_m}$, D_c and others (see Appendix B.) if required.

11. Precision and Accuracy

11.1 For D_m values above 100, the coefficient of variation of measurements on a uniform sample by an individual laboratory may range from 2 to 8 percent. For D_m values below 100, the

estimated standard deviation by an individual laboratory is about 10 or less. For measurements among laboratories, the coefficient of variation and standard deviation estimates may be greater by a factor of about 1.5.

APPENDIX II-A

Calibration of Test Equipment

A1.1 Photometric System

A1.1.1 Calibration of the photometer is checked by interrupting the light beam with calibrated neutral density filters. The filters should cover the full range of the instrument. Optical density values measured by the photometer shall be within $\pm 3\%$ of the calibrated values.

A1.1.2 Effective light beam cross-section measurements are made at the top and bottom of the chamber, by inserting an opaque sheet of material into the beam path from opposite sides of the beam at several points, and noting the point at which the light transmittance reading decreases. Using these measurements, the average diameter of the sensing area to the phototube may be determined. See C4.1.5.

A1.1.3 Shifts in dark current levels between tests, excessive zero shifts during test or lack of calibration indicates the need for inspection of the photometer system.

A1.2 Radiometer

Calibration of the radiometer is accomplished by placing it at suitable distances from a radiant energy source, while maintaining its body temperature at 200 ± 5 °F (93 ± 3 °C) with controlled air flow through the rear-mounted cooler, and measuring its electrical output as a function of the irradiance level. The irradiance level is determined calorimetrically by measuring the rate of temperature rise of a blackened thin copper disk of known weight, area (1 1/2 in., 38.1 mm dia), specific heat and absorptivity in place of the radiometer.

The measured millivolt output of the radiometer, at a body temperature of 200 °F (93 °C), corresponding to an irradiance level of $2.2 \pm .04$ Btu/sec. ft² ($2.5 \pm .05$ W/cm²) is used to establish the furnace control settings discussed in paragraphs 4.1.2 and 8.3.

A1.3 Chamber Pressure Manometer - Leakage Rate Test

For purposes of standardization, periodically conduct a leakage rate test using the manometer and tubing described in paragraph 4.1.9. Pressurize the chamber to 3 in. (approximately 76 mm) of water by introducing compressed air through a gas sampling hole in the top. Time the decrease in pressure from 3 to 2 in. (approximately 76 to 50 mm) of water with a stop watch. This time should not be less than 5.0 minutes.

A1.4 Standard Smoke Generating Materials

For checking operational and procedural details of the equipment and method described herein, two standard materials may be used. Under nonflaming conditions, a single layer of nominal 0.030 in. (approximately 0.76 mm) thick alpha-cellulose (cotton linters) paper should provide repeatable maximum specific optical density values of 170 ± 10 ; under flaming conditions, a 0.032 in. (0.81 mm) thick plastic sheet should provide repeatable maximum specific optical density values of 455 ± 15 . These reference samples may be purchased from the Office of Standard Reference Materials, National Bureau of Standards, Washington, D.C. 20234. Use of these standard materials does not obviate the need for following the calibration and standardization procedure outlined in this Standard.

APPENDIX II-B

Presentation and Use of Test Results

B1. The smoke chamber test results in a curve of specific optical density versus time. The maximum specific optical density, D_m , represents total smoke accumulation. Since the time to reach this point is often indistinct, the time to reach 90% of D_m , $t_{.9D_m}$, generally represents a more easily defined and repeatable point. Additional parameters which may be of particular value include:

R_m : Maximum rate of increase in specific optical density per minute, measured over a 2-min. period.

$t_{D_s = 16}$: Time to reach $D_s = 16$ ($T = 75\%$), or other smoke level.

This is a simple measure of smoke generation rate, particularly where time is important.

$$SOI = \frac{D_m^2}{2000 t_{D_s = 16}} \left(\frac{1}{t_{.3} - t_{.1}} + \frac{1}{t_{.5} - t_{.3}} + \frac{1}{t_{.7} - t_{.5}} + \frac{1}{t_{.9} - t_{.7}} \right)$$

where $t_{.1}$, $t_{.3}$, etc., indicate the time in minutes at which the smoke accumulation reaches 10, 30, etc., percent of the maximum density D_m . The smoke obscuration index incorporates the effects of total smoke, generation rate and time to reach $D_s = 16$. (See footnote 1 of main text)

$$SON_4 = D_1 + D_2 + D_3 + D_4$$

Smoke obscuration number based on the simple addition of the 1, 2, 3 and 4 minute values of specific optical density. This index represents a weighted rate of smoke generation over a 4 minute interval only.

B2. The preceding parameters are obtained for the flaming and nonflaming exposures separately, and the highest value could presumably be used. There may be some merit in combining values from the flaming and nonflaming tests to yield a single composite index, e.g.⁶

$$SOI_c = [(SOI)_f \cdot (SOI)_n]^{1/6}$$

B3. A more comprehensive approach to smoke hazard evaluation of a material might include the effects of smoke obscuration under a bracketing set of fire conditions⁷, e.g.

$$MSCU = \sum_{i=1}^8 (SOI)_i$$

- for i = 1, nonflaming test (std)
- i = 2, flaming test (std)
- i = 3, nonflaming test with forced ventilation
- i = 4, flaming test with forced ventilation
- i = 5, nonflaming test at high irradiance level
- i = 6, flaming test at high irradiance level
- i = 7, nonflaming test at high irradiance level and forced ventilation
- i = 8, flaming test at high irradiance level and forced ventilation.

⁶/G. Williams-Leir, Private Communications.

⁷/J. R. Gaskill, Fire Technology, August 1968.

B4. A principal advantage of using specific optical density is that the results can be related to (a) areas of materials which potentially could be involved in fire, (b) distances of light paths from observer to exitways, and (c) the volume of enclosing space. This may be accomplished by multiplying D or D_m by the involved areas (flaming and nonflaming) and the length of light path and dividing by the volume of the enclosed space, $\frac{AL}{V}$. See reference (1) for a more detailed discussion.

APPENDIX II-C
Construction Details

(Paragraph numbers correspond to applicable paragraphs in Section 4. Apparatus of main text).

C4.1.2 Radiant Heat Furnace

The furnace shall consist of a coiled wire or other suitable electrical heating element (525 W or greater) mounted vertically in a horizontal ceramic tube 3 in. (76.2 mm) i.d. by 3 3/8 in. (85.7 mm) o.d. by 1 5/8 in. (41.3 mm) long. The tube is bored out at one end to 3 1/32 in. (77.0 mm) i.d. and to a depth of 5/8 in. (15.9 mm) to accommodate the heating element. A 1/16 in. (1.6 mm) asbestos paper gasket, three stainless steel reflectors are mounted behind the heating element. A 3/8 in. (9.5 mm) asbestos millboard disc, provided with ventilation and lead wire holes, shall be positioned behind the heating element and used to center the assembly with respect to the front 3/8 in. (9.5 mm) asbestos millboard ring by means of a 6-32 stainless steel screw. The adjustment nuts on the end of the centering screw shall provide proper spacing of the furnace components. The cavities adjacent to the heating element assembly shall be packed with glass wool. The furnace assembly shall be housed in a 4 in. (102 mm) o.d. by 0.083 in. (2.1 mm) wall by 4 1/8 in. (10.5 cm) long stainless steel tube. Two additional 3/8 in. (9.5 mm) asbestos board spacing rings and a rear cover of 3/8 in. (9.5 mm) asbestos board shall complete the furnace. The furnace is to be located centrally along the long axis of the chamber with the opening facing toward and about 12 in. (305 mm) from the right wall. The centerline of the furnace shall be about 7 3/4 in. (195 mm) above the chamber floor.

C4.1.3 Specimen Holder

The specimen holder shall conform in shape and dimension to Fig. 4 and be fabricated by bending and brazing (or spot welding) 0.025 in. (0.6 mm) thick stainless steel to provide a 1 1/2 in. (38.1 mm) depth, and to expose a 2 9/16 by 2 9/16 in. (65.1 by 65.1 mm) specimen area. As described in paragraph 4.1.4, the holder shall have top and bottom guides to permit accurate centering of the exposed specimen area in relation to the furnace opening. A 3 by 3 in. (76.2 by 76.2 mm) sheet of 1/2 in. (12.7 mm) asbestos millboard, having a nominal density of $50 \pm 10 \text{ lb/ft}^3$ ($0.85 \pm 0.17 \text{ g/cm}^3$), shall be used to back the specimen. A spring bent from 0.010 in. (approximately 0.25 mm) thick phosphor bronze sheet shall be used with a steel retaining rod to securely hold the specimen and millboard backing in position during testing.

C4.1.4 Support of Furnace and Specimen Holder

The framework as shown in Fig. 5 shall have welded to it a 5 in. (12.7 cm) o.d., 1/4 in. (6.4 mm) wall, 2 in. (50.8 mm) long horizontally oriented steel tube to support the radiant heat furnace described in paragraph 4.1.2. This support tube shall have provision to accurately align the furnace opening so that it is: (1) 1 1/2 in. (38.1 mm) away from, (2) parallel to and (3) centered with respect to the exposed specimen area. Three tapped holes with screws equidistantly positioned around the furnace support tube, or one screw at the top of the support in conjunction with two adjustable (vertically along the support tube) metal guide strips mounted horizontally inside to the tube, shall provide adequate alignment.

The framework shall have two 3/8 in. (9.5 mm) diameter transverse rods of stainless steel to accept the guides of

the specimen holder described in paragraph C4.1.3. The rods shall support the holder so that the exposed specimen area is parallel to the furnace opening. Spacing stops shall be mounted at both ends of each rod to permit quick and accurate lateral positioning of the specimen holder.

C4.1.5 Photometric System

The photometric system shall consist of a tungsten-filament light source, (Type 1630 6.5 volt lamp, maintained at $4 \pm 0.2V$) and photodetector (Type 931V-A), oriented vertically to reduce variations in measurement brought about by stratification of the smoke generated by the specimens under test. The system shall be as shown in Fig. 6. The window in the chamber floor through which the light beam passes shall be provided with an electric heater to maintain a temperature of at least $125^{\circ}F$ ($52^{\circ}C$) to minimize smoke condensation. The collimated beam inside the chamber shall have a path length of $36 \pm 1/8$ in. (914 ± 3 mm) and a sensing cross-section of $1 \frac{1}{2} \pm 1/8$ in. (38.1 ± 3.2 mm) diameter (see Appendix A, paragraph A1.1.2). The approximately circular light "spot" shall be centered entirely within the sensing area of the detector. A typical photomultiplier photometer system will require a high-voltage D.C. power supply and a neutral density filter of sufficient optical density to produce a convenient signal level for the indicator or recorder. The photometer system used shall be capable of permitting the recording of reliable optical densities up to 5.0, corresponding to transmittance values of 0.001 percent of the incident light. (See Appendix A A1.1.1).

The two optical platforms and their housings shall be kept in alignment with three metal rods, $1/2$ in. (12.7 mm) in diameter, fastened securely into $5/16$ in. (7.9 mm) thick externally

mounted top and bottom plates and symmetrically arranged about the collimated light beam.

C4.1.6 Radiometer

The body temperature of the radiometer shall be monitored with a 100-220 °F (38-100 °C) thermometer in a 1/2 by 1/2 by 1 1/2 in. long (12.7 by 12.7 by 38.1 mm) brass well drilled to accept the thermometer with a close fit. Silicone grease may be used to provide good thermal contact.

The circular receiving surface of the radiometer shall be spray-coated with an infrared-absorbing black paint containing a silicone vehicle. The radiometer shall be calibrated calorimetrically in accordance with the procedure summarized in paragraph A1.2 of Appendix A.

C4.1.7 Chamber Wall Thermocouple

A thermocouple shall be mounted with its junction secured to the geometric center of the inner rear wall panel of the chamber using a 1/4 in. (6.4 mm) thick polystyrene foam disk cover and epoxy cement.

C4.1.10 Burner

The Multiple flamelet burner shall be a six-tube burner, with construction details as shown in Fig. 4. The vertical tubes of the six-tube burner shall be made from 1/8 in. (3.2 mm) o.d. by 0.031 in. (0.8 mm) thick-wall stainless steel tubing. All tubes should be crimped at the tip to reduce the opening diameter to 0.055 in (1.4 mm). The horizontal manifold section of the burner shall consist of 1/4 in. (6.4 mm) o.d. by 0.035 in. (0.9 mm) wall stainless steel tubing. The other end is attached to a fitting in the chamber floor.

C4.1.11 Chamber Pressure Regulator

A simple pressure regulator consists of an open, water-filled bottle and a length of flexible tubing, one end of which is connected to a sampling port on the top of the chamber. The other end of the tubing is inserted 4 in. (10 mm) below the water surface. The bottle is located at the same level as the floor of the chamber.

APPENDIX II-D

Analysis of Products of Combustion

Although not specifically required as a part of the method, products of combustion may be drawn from the chamber at various times during the progress of the test for analysis. The physical properties of the smoke may be investigated by electrostatic or impact collection and various methods of particle analysis. The presence and concentrations of various toxic and irritating gaseous products may be determined using colorimetric gas detector tubes, gas chromatography methods, ion-selective electrodes, or other techniques.




Fig. 1 SMOKE DENSITY CHAMBER





Figure 2. Smoke Density Chamber Assembly






- | | | |
|----------------------------------|----------------------------------|------------------------|
| A - Phototube Enclosure | J - Voltmeter (furnace) | S - Support Frame |
| B - Chamber | K - Fuse Holders | T - Indicating Lamps |
| C - Blowout Panel | L - Furnace Heater Switch | U - Photometer Readout |
| D - Hinged Door with Window | M - Gas & Air Flowmeters | V - Rods |
| E - Exhaust Vent Control | N - Gas & Air Shutoff Valves | W - Glass Window |
| F - Radiometer Output Jack | O - Light Intensity Controls | X - Exhaust Vent |
| G - Temperature (Wall) Indicator | P - Light Voltage Measuring Jack | Y - Inlet Vent |
| H - Temperature Indicator Switch | Q - Light Source Switch | Z - Access Ports |
| I - Autotransformers | R - Line Switch | |




- | | | |
|----------------------------|---|------------------------|
| A - STAINLESS STEEL TUBE | F - ASBESTOS PAPER GASKET | J - ASBESTOS BOARD |
| B - ASBESTOS BOARD | G - STAINLESS STEEL SPACING WASHERS (3) | K-ASBESTOS BOARD RINGS |
| C - CERAMIC TUBE | H - STAINLESS STEEL REFLECTOR | L-ASBESTOS BOARD COVER |
| D - HEATING ELEMENT, 525 W | I - STAINLESS STEEL REFLECTOR | M-SHEET METAL SCREWS |
| E - STAINLESS STEEL SCREW | W-PYREX GLASS WOOL | |

FIG. 3 - FURNACE SECTION

Alignment of Modified Holder and Burner



Modified (trough) Sample Holder
(flaming exposure)



Specimen Retainer

Fig. 4 DETAILS OF SPECIMEN HOLDERS AND PILOT BURNER




FIG. 5 - FURNACE SUPPORT




Fig. 6A Photometer Details




Fig. 6B Photometer Location

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. NBS-TN 708	2. Gov't Accession No.	3. Recipient's Accession No.
4. TITLE AND SUBTITLE Interlaboratory Evaluation of Smoke Density Chamber		5. Publication Date December, 1971	
		6. Performing Organization Code	
7. AUTHOR(S) T. G. Lee		8. Performing Organization	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234		10. Project/Task/Work Unit No. 4212229	
		11. Contract/Grant No.	
12. Sponsoring Organization Name and Address Same		13. Type of Report & Period Covered Final	
		14. Sponsoring Agency Code	
15. SUPPLEMENTARY NOTES			
<p>16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.)</p> <p>Results are reported of an interlaboratory (round-robin) evaluation of the smoke density chamber method for measuring the smoke generated by solid materials in fire. A statistical analysis of the results from 10 material-condition combinations and 18 laboratories is presented. For the materials tested, the median coefficient of variation of reproducibility was 7.2% under non-flaming exposure conditions and 13% under flaming exposure conditions. A discussion of errors and recommendations for improved procedures based on user experience is given. A tentative test method description is included as an appendix.</p>			
<p>17. KEY WORDS (Alphabetical order, separated by semicolons)</p> <p>Building materials; fire tests; interlaboratory tests; optical density; round robin; smoke; smoke density chamber; statistical analysis.</p>			
<p>18. AVAILABILITY STATEMENT</p> <p><input checked="" type="checkbox"/> UNLIMITED.</p> <p><input type="checkbox"/> FOR OFFICIAL DISTRIBUTION. DO NOT RELEASE TO NTIS.</p>		<p>19. SECURITY CLASS (THIS REPORT)</p> <p>UNCLASSIFIED</p>	<p>21. NO. OF PAGES</p> <p>80</p>
		<p>20. SECURITY CLASS (THIS PAGE)</p> <p>UNCLASSIFIED</p>	<p>22. Price</p> <p>.75</p>

NBS TECHNICAL PUBLICATIONS

PERIODICALS

JOURNAL OF RESEARCH reports National Bureau of Standards research and development in physics, mathematics, chemistry, and engineering. Comprehensive scientific papers give complete details of the work, including laboratory data, experimental procedures, and theoretical and mathematical analyses. Illustrated with photographs, drawings, and charts.

Published in three sections, available separately:

• Physics and Chemistry

Papers of interest primarily to scientists working in these fields. This section covers a broad range of physical and chemical research, with major emphasis on standards of physical measurement, fundamental constants, and properties of matter. Issued six times a year. Annual subscription: Domestic, \$9.50; \$2.25 additional for foreign mailing.

• Mathematical Sciences

Studies and compilations designed mainly for the mathematician and theoretical physicist. Topics in mathematical statistics, theory of experiment design, numerical analysis, theoretical physics and chemistry, logical design and programming of computers and computer systems. Short numerical tables. Issued quarterly. Annual subscription: Domestic, \$5.00; \$1.25 additional for foreign mailing.

• Engineering and Instrumentation

Reporting results of interest chiefly to the engineer and the applied scientist. This section includes many of the new developments in instrumentation resulting from the Bureau's work in physical measurement, data processing, and development of test methods. It will also cover some of the work in acoustics, applied mechanics, building research, and cryogenic engineering. Issued quarterly. Annual subscription: Domestic, \$5.00; \$1.25 additional for foreign mailing.

TECHNICAL NEWS BULLETIN

The best single source of information concerning the Bureau's research, developmental, cooperative, and publication activities, this monthly publication is designed for the industry-oriented individual whose daily work involves intimate contact with science and technology—for engineers, chemists, physicists, research managers, product-development managers, and company executives. Annual subscription: Domestic, \$3.00; \$1.00 additional for foreign mailing.

NONPERIODICALS

Applied Mathematics Series. Mathematical tables, manuals, and studies.

Building Science Series. Research results, test methods, and performance criteria of building materials, components, systems, and structures.

Handbooks. Recommended codes of engineering and industrial practice (including safety codes) developed in cooperation with interested industries, professional organizations, and regulatory bodies.

Special Publications. Proceedings of NBS conferences, bibliographies, annual reports, wall charts, pamphlets, etc.

Monographs. Major contributions to the technical literature on various subjects related to the Bureau's scientific and technical activities.

National Standard Reference Data Series. NSRDS provides quantitative data on the physical and chemical properties of materials, compiled from the world's literature and critically evaluated.

Product Standards. Provide requirements for sizes, types, quality, and methods for testing various industrial products. These standards are developed cooperatively with interested Government and industry groups and provide the basis for common understanding of product characteristics for both buyers and sellers. Their use is voluntary.

Technical Notes. This series consists of communications and reports (covering both other agency and NBS-sponsored work) of limited or transitory interest.

Federal Information Processing Standards Publications. This series is the official publication within the Federal Government for information on standards adopted and promulgated under the Public Law 89-306, and Bureau of the Budget Circular A-86 entitled, Standardization of Data Elements and Codes in Data Systems.

Consumer Information Series. Practical information, based on NBS research and experience, covering areas of interest to the consumer. Easily understandable language and illustrations provide useful background knowledge for shopping in today's technological marketplace.

NBS Special Publication 305, Supplement 1, Publications of the NBS, 1968-1969. When ordering, include Catalog No. C13.10:305. Price \$4.50; \$1.25 additional for foreign mailing.

Order NBS publications from:

Superintendent of Documents
Government Printing Office
Washington, D.C. 20402

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
Washington, D.C. 20234

OFFICIAL BUSINESS

Penalty for Private Use, \$300

POSTAGE AND FEES PAID
U.S. DEPARTMENT OF COMMERCE

