



NBS TECHNICAL NOTE **836**

U.S. DEPARTMENT OF COMMERCE / National Bureau of Standards

Detector Actuated Automatic Sprinkler Systems— A Preliminary Evaluation

QC
00
5753
p. 836
974
c.2

NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards¹ was established by an act of Congress March 3, 1901. The Bureau's overall goal is to strengthen and advance the Nation's science and technology and facilitate their effective application for public benefit. To this end, the Bureau conducts research and provides: (1) a basis for the Nation's physical measurement system, (2) scientific and technological services for industry and government, (3) a technical basis for equity in trade, and (4) technical services to promote public safety. The Bureau consists of the Institute for Basic Standards, the Institute for Materials Research, the Institute for Applied Technology, the Institute for Computer Sciences and Technology, and the Office for Information Programs.

THE INSTITUTE FOR BASIC STANDARDS provides the central basis within the United States of a complete and consistent system of physical measurement; coordinates that system with measurement systems of other nations; and furnishes essential services leading to accurate and uniform physical measurements throughout the Nation's scientific community, industry, and commerce. The Institute consists of a Center for Radiation Research, an Office of Measurement Services and the following divisions:

Applied Mathematics — Electricity — Mechanics — Heat — Optical Physics — Nuclear Sciences² — Applied Radiation² — Quantum Electronics³ — Electromagnetics³ — Time and Frequency³ — Laboratory Astrophysics³ — Cryogenics³.

THE INSTITUTE FOR MATERIALS RESEARCH conducts materials research leading to improved methods of measurement, standards, and data on the properties of well-characterized materials needed by industry, commerce, educational institutions, and Government; provides advisory and research services to other Government agencies; and develops, produces, and distributes standard reference materials. The Institute consists of the Office of Standard Reference Materials and the following divisions:

Analytical Chemistry — Polymers — Metallurgy — Inorganic Materials — Reactor Radiation — Physical Chemistry.

THE INSTITUTE FOR APPLIED TECHNOLOGY provides technical services to promote the use of available technology and to facilitate technological innovation in industry and Government; cooperates with public and private organizations leading to the development of technological standards (including mandatory safety standards), codes and methods of test; and provides technical advice and services to Government agencies upon request. The Institute consists of a Center for Building Technology and the following divisions and offices:

Engineering and Product Standards — Weights and Measures — Invention and Innovation — Product Evaluation Technology — Electronic Technology — Technical Analysis — Measurement Engineering — Structures, Materials, and Life Safety⁴ — Building Environment⁴ — Technical Evaluation and Application⁴ — Fire Technology.

THE INSTITUTE FOR COMPUTER SCIENCES AND TECHNOLOGY conducts research and provides technical services designed to aid Government agencies in improving cost effectiveness in the conduct of their programs through the selection, acquisition, and effective utilization of automatic data processing equipment; and serves as the principal focus within the executive branch for the development of Federal standards for automatic data processing equipment, techniques, and computer languages. The Institute consists of the following divisions:

Computer Services — Systems and Software — Computer Systems Engineering — Information Technology.

THE OFFICE FOR INFORMATION PROGRAMS promotes optimum dissemination and accessibility of scientific information generated within NBS and other agencies of the Federal Government; promotes the development of the National Standard Reference Data System and a system of information analysis centers dealing with the broader aspects of the National Measurement System; provides appropriate services to ensure that the NBS staff has optimum accessibility to the scientific information of the world. The Office consists of the following organizational units:

Office of Standard Reference Data — Office of Information Activities — Office of Technical Publications — Library — Office of International Relations.

¹ Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

² Part of the Center for Radiation Research.

³ Located at Boulder, Colorado 80302.

⁴ Part of the Center for Building Technology.

Detector Actuated Automatic Sprinkler Systems—A Preliminary Evaluation

Richard L. P. Custer

Fire Technology Branch
Programmatic Center for Fire Research
Institute for Applied Technology
U.S. National Bureau of Standards
Washington, D.C. 20234

^t Technical note no. 836



U.S. DEPARTMENT OF COMMERCE, Frederick B. Dent, *Secretary*

NATIONAL BUREAU OF STANDARDS, Richard W. Roberts, *Director*

Issued July 1974

Library of Congress Catalog Card Number: 74-600095

National Bureau of Standards Technical Note 836

Nat. Bur. Stand. (U.S.), Tech. Note 836, 27 pages (July 1974)

CODEN: NBTNAE

U.S. GOVERNMENT PRINTING OFFICE
WASHINGTON: 1974

For sale by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402
(Order by SD Catalog No. C13.46:836). Price 65 cents.

CONTENTS

	Page
1. INTRODUCTION.....	1
2. PURPOSE.....	2
3. DESCRIPTION OF TEST SYSTEM.....	2
3.1 Detectors.....	2
3.2 Sprinkler Actuation Device.....	3
3.3 Sprinkler System.....	3
3.4 Reliability of Test System Components.....	3
4. TEST PROGRAM.....	4
4.1 Description of Test Room.....	4
4.2 Instrumentation.....	4
4.3 Test Fires.....	4
5. DISCUSSION OF RESULTS.....	5
5.1 Detector Actuated Sprinkler.....	5
5.2 Multiple Detector Test.....	6
5.3 Automatic Sprinkler Head Test.....	6
6. SUMMARY.....	6
7. TENTATIVE DESIGN CRITERIA.....	7
8. REFERENCES.....	9



Richard L. P. Custer
Fire Technology Division

An investigation was conducted to evaluate the capabilities of a detector actuated automatic sprinkler system to protect individuals who are intimately associated with the first materials ignited such as bedding materials. Tests were conducted in a simulated nursing home bedroom. System response was evaluated for both smoldering and open flaming ignition sources. It was determined that barring electrical or mechanical failure the system could be nearly 100 percent effective with smoldering fires. The effectiveness with open flaming fires was difficult to evaluate. Although these fires were extinguished with minimum damage in times as short as 36 seconds the possible effects of flammable blankets and sleepwear were not tested. It was estimated that perhaps one third of the potential victims of open flaming fires might be saved. Although these tests were limited in scope, some tentative design criteria for detector actuated sprinkler systems are presented and possible alternatives offered.

Key words: Bedding fires; design criteria; detector actuated automatic sprinklers; detectors; levels of protection; life safety; sprinklers.

1. INTRODUCTION

In the last few years the United States has experienced an increasing number of fires in nursing home occupancies involving injuries and loss of life. This has given rise to considerable interest at both the Federal and local levels in improving the fire protection for these occupancies. In order to define the extent to which fire protection systems can provide life safety, three levels of protection have been proposed [1]. Level 1 would protect the occupant of a room when intimately associated with the fire at its point of origin. This would include patients involved in bedding or clothing fires and would require rapid detection and suppression capabilities in order to save the life. Level 2 protection would safeguard other occupants of the room who might be in danger as the fire begins to spread beyond the first objects ignited. Level 3 Protection would be directed towards confining the fire to the room of origin such that other occupants in the building would not be endangered. Level 3 protection assumes that the maximum loss of life sustained from a fire would consist of the occupants of the room of origin. The analysis which follows is based on state-of-the-art fire protection engineering practice and a series of full-scale fire tests using commercially available equipment to evaluate the possibility of providing Level 1 protection in a simulated nursing home bedroom.

Although a complete automatic sprinkler system can be effective in confining a fire to its room of origin, data obtained in a 35-month period by the Oregon State Fire Marshal's office [2] showed that of

13 fatalities covered by the survey, nine took place in fully sprinklered buildings. In two instances the fires were extinguished by the sprinkler heads. In one case, however, the patient died and in the second case the patient sustained serious burns and was removed by nursing home personnel prior to the operation of the sprinkler head. There was no sprinkler operation in the other 7 cases. In evaluating the circumstances surrounding the 13 fatalities, it was determined that in 11 cases open flames from either matches or cigarette lighters were responsible for the ignition. In one case the time between ignition and discovery was estimated to be less than 5 minutes and it is possible that this fire may also have been the result of an open flame ignition. The last case was definitely of smoldering origin.

Data obtained from the Flammable Fabrics Accident Case and Testing System (FFACTS) maintained by the Office of Information and Hazard Analysis at the National Bureau of Standards indicate that approximately 55% of the bedding fires contained in the data base were initiated by open flame ignition sources. Although FFACTS is not a statistical data base, it contains over 3,000 cases and can provide an indication of trends. Thus it would appear that in order to provide Level 1 protection, a fire suppression system must be capable of responding quickly with detection and suppression capabilities to rapidly developing fires from open flame ignition sources.

2. PURPOSE

The purpose of this test series was to evaluate the effectiveness of a combination detection-suppression system in providing both early warning and suppression capabilities when exposed to fires initiated in bedding by both smoldering and flaming ignition sources. In addition to system effectiveness, the problem of false alarms presently associated with existing smoke detection hardware was also considered. Finally an attempt has been made to provide tentative design requirements, based on engineering judgement and the data available from these tests for the use of detector-actuated, automatic sprinkler systems in nursing homes and care-type facilities.

3. DESCRIPTION OF TEST SYSTEM

The system evaluated by these tests consists of a smoke detector connected to a thermal actuating device. This device is attached to an ordinary sprinkler head. Upon detection of smoke, the thermal actuating device is fired heating and releasing the operating elements of the sprinkler head. Water is then discharged on the fire. The time required from detection to operation of a standard 135°F sprinkler head ranges from 3 to 5 seconds.

3.1 Detectors

Two different types of smoke detectors were used in this test series. One operated on the ionization principle and the other on a light scattering principle. Work presently in progress at the National Bureau of

Standards indicates that the housing surrounding the operating elements of the smoke detector can have a considerable effect on the ability of that detector to respond to slowly moving smoke. Candidate detectors were evaluated by placing them in a test box and exposing them to smoke laden air at velocities of 15, 30, 50 and 100 feet per minute (7.6, 15.2, 25.4 and 50.8 cm sec⁻¹). The rate of smoke development in the box, in terms of light obscuration, was approximately 1 percent per foot per minute (0.014 ODm⁻¹min⁻¹).⁽¹⁾ Both detectors used in this test series have good response characteristics when exposed to slowly moving smoke. The velocity profiles for these units are shown in Figure 1. The detectors were tested before and after the fire tests and no changes in velocity profiles were noted.

3.2 Sprinkler Actuation Device

The commercially secured thermal actuating devices consisted of a small metal cylinder containing a solid fuel and an igniter wire. These devices are mounted directly on the sprinkler head. The flame discharge end of the actuating device is oriented such that the flame will impinge on the operating elements of the sprinkler head. The thermal actuators were fired using a smoke detector as a switch to energize the ignitor wire from an appropriate power supply. One actuator tested is currently available and the other is a prototype not yet on the market.

3.3 Sprinkler System

The automatic sprinkler system used for these tests was designed to provide a discharge density of 0.1 gallons per minute per square foot as required by the National Fire Protection Association Standard 13 [3] for Light Hazard Occupancies. Standard pendant heads of ordinary temperature classification (135°F [57°C]) were used throughout all test of the system. Figure 2 shows the arrangement of the system components.

3.4 Reliability of Test System Components

Although single samples of each detector were used, these devices have been tested and approved by recognized testing laboratories according to standard test methods [4,5]. In the testing procedures, many samples of each item are evaluated under normal and adverse conditions. The units used are stock items and are presently available commercially. In addition, each detector was checked at NBS before and after use in the tests and found to operate within the acceptable tolerances. All detectors regardless of manufacturer are subjected to the same tests prior to approval.

All automatic sprinkler heads unless indicated as prototypes have been listed by Underwriters' Laboratories [6] and their reliability is not in question.

The actuating devices have not as yet received approval but have been submitted to Underwriters' Laboratories for listing. Samples of these devices were bench tested prior to use in these tests and were

⁽¹⁾ODm⁻¹ = optical density per metre.

found to operate as designed. No design failures were observed during the full-scale tests.

4. TEST PROGRAM

4.1 Description of Test Room

The tests were conducted in a 10 foot square (3.05 m) test room with a 9 foot (2.7 m) ceiling. The test room was of noncombustible construction. A plan view of the test room showing the location of the automatic sprinkler head, the detector, and the bed is given in Figure 3.

4.2 Instrumentation

Temperatures in the room and in the bedding material and smoke levels in the room were recorded throughout each test. Temperatures were recorded using 24 gage chromel-alumel thermocouples. Room temperatures were measured with thermocouples located at the ceiling adjacent to the sprinkler head and at the 5 foot (1.5 m) level adjacent to the bed. An array of seven thermocouples was placed on the bed in the area of ignition in order to determine the area burned and the temperatures to which a patient might have been exposed had the bed been occupied at the time of the fire (see Figure 4). Smoke levels were recorded during the test using 1.5 foot (0.46 m) projected beam smoke meters. One smoke meter was located at the ceiling adjacent to the detector to measure the smoke accumulation in relation to the operation of the smoke detector. A second smoke meter was hung at the 5 foot (1.5 m) level adjacent to the bed and recorded the smoke level to which the occupant might have been exposed upon getting out of bed. Following each test, an estimate of the size of the damaged area was made. No measurements were made of the toxic gas concentrations.

4.3 Test Fires

A total of nine tests were conducted in the course of this series. Five fires were started using a smoldering ignition source and four using an open flame ignition source. The smoldering ignition source consisted of a king-sized non-filtered cigarette placed on the bottom sheet and covered with the top sheet. The open flame ignition source was a non-failsafe cigarette lighter filled with liquid fuel. In order to simulate an open flame ignition the flaming lighter was dropped from a height of 2 feet (0.61 m) onto crumpled sheets. In all test fires the point of ignition was located in the center of the thermocouple array described above. In all cases, the room door was closed during the test. Ventilation was supplied by natural convection through the view port and two 240 square inch (1548 cm²) openings in the floor.

All test fires were set in bedding materials. The mattresses were of the single bed size, with cotton ticking and padding. All of the mattresses were previously used and were obtained from the Veterans Administration Hospital in Washington, D.C. These mattresses did not meet the present flammability criteria [7] and have chosen to represent

the worst case conditions.

For each fire the beds were made up using two sheets each composed of 50% cotton and 50% polyester fiber material. This fiber blend was used to represent typical materials. Presently, only one manufacturer produces 100% cotton sheets and it is expected that this type sheet will be discontinued in the near future. Two bed configurations were used in these tests (see Figure 5). For tests using a smoldering ignition source the mattress was laid flat on the bed frame. For those tests using an open flame ignition source the mattress was bent at an angle of 45° from the horizontal with the ignition area being at the crease of the sheets.⁽¹⁾ The results of the Level 1 system tests are shown in Table 1.

In addition to the five tests conducted on the detector actuated sprinkler system, three tests were conducted to evaluate the relative response times of both detectors to smoldering and flaming fires. Both the photoelectric and ion-chamber detectors were exposed to the same fire. The time of operation and the smoke level at the ceiling and 5 feet (1.5 m) above the floor were recorded for each test. Since it was desired that both detectors operate prior to extinction, each of these fires was extinguished manually following operation of the second detector. The results of these tests are shown in Table II.

Finally, one test was run to compare the smoke level and room temperatures at the operating point of five currently available automatic sprinkler heads and one prototype. Both 135 °F (56.7 °C) and 165 °F (73.2 °C) heads were used. For this test, as in the test of the detectors alone, the suppression system was rendered inoperative in order that the relative times of sprinkler head operation might be obtained. The results of this test are shown in Table III.

5. DISCUSSION OF RESULTS

5.1 Detector Actuated Sprinkler

The results of the five tests of the detector actuated sprinkler system indicate that the system as tested can detect and respond rapidly to fires from both smoldering and flaming ignition sources. The maximum damage sustained from a smoldering ignition source was 314 square inches (2026 cm²). This test was conducted with an ion chamber detector and lasted for 1 hour 13 minutes 55 seconds. At that time the smoke level in the test room was considered marginally tenable.⁽²⁾ Smoke concentration at the 5 foot (1.5 m) level in this test was 7.8 percent per foot (0.11 ODm⁻¹) and 11.3 percent per foot (0.16 ODm⁻¹) at the ceiling. For fires initiated with an open flame ignition source the largest area damaged was 200 square inches (1290 cm²). This fire was detected and extinguished at 1 minute and 45 seconds. Photographs of typical burn damage following actuation of the system are shown in Figures 6 and 7.

(1) This orientation was chosen to simulate the effects of a person sitting in bed or a raised hospital type bed.

(2) Watanabe [8] suggests 9.2 percent per foot (0.13 ODm⁻¹) at the ceiling for those persons familiar with their surroundings.

5.2 Multiple Detector Test

The results of the multiple detector tests indicate an advantage of the photoelectric detector over the ionization detector when exposed to smoldering fire. In one test with a smoldering fire, the photoelectric detector was 16 minutes 55 seconds faster. The difference in operating times between the two types of detectors was nearly as large in the case of the flaming ignition source. In the flaming ignition test, the ion-chamber detector responded 8 seconds ahead of the photoelectric detector.

5.3 Automatic Sprinkler Head Test

A test of the operating times of the six sprinkler heads exposed to an open flaming fire with the bed in the 45° configuration showed the fastest operating time to be 2 minutes 30 seconds. This was achieved with the prototype low thermal lag 135 °F (56.7 °C) sprinkler head. The next fastest was a center strut 135°F (56.7 °C) with heat collectors. This head operated in 2 minutes 52 seconds. This was followed by an on-off sprinkler head rated at 165 °F which operated at 3 minutes 1 second. The last head to operate was a glass bulb type in 3 minutes 45 seconds. Although the smoke level both at the ceiling and 5 feet (1.5 m) above the floor were within tolerable limits at the operating point of each of the sprinkler heads, temperatures at the head of the bed were well beyond tolerable limits and it is likely that any person occupying the bed under these conditions would have been severely burned.

The time-temperature curve and smoke development at the ceiling are shown in Figures 8 and 9. It can be noted that had the Level 1 system been operational during this fire, with the smoke detector alarming at an obscuration of 2% per foot (0.085 ODm^{-1}) the fire would have been arrested in approximately 40 seconds (see Figure 9). At that point the temperature in the immediate area of ignition was approximately 900 °F (481.7 °C) while the temperature at the head of the bed was close to 100 °F (37.7 °C). It can also be seen from Figure 8 that at 150 seconds, the operating time of the fastest sprinkler head, the temperature measured at the head of the bed had exceeded 1500 °F (814.7 °C).

6. SUMMARY

As a result of this preliminary investigation, the following tentative conclusions have been reached:

1. The system as tested, although probably not capable of giving complete Level 1 protection, can provide a higher degree of protection than sprinklers alone. In those cases where the fire is initiated by a smoldering ignition source, it is likely that nearly 100% of those persons exposed to such a fire could be saved. The life saving potential of this system for fires initiated by flaming ignition sources is much more time-critical, and therefore more difficult to evaluate. Factors such as blanket, sheet, and sleep-wear flammability need to

be evaluated with instrumented mannequins before firm conclusions can be reached. Based on the extent of damaged area it is estimated that perhaps one-third of the victims of fires originating with open flaming ignition might be saved using the system as tested. It should be noted that even those persons saved may suffer severe thermal trauma. Based on the Oregon data previously cited this could result in a combined reduction of approximately 40% in single fatalities from both fire types. It must also be considered that in addition to providing some degree of Level 1 protection this system also provides Level 2 and Level 3 protection. Its use then could result in a decrease in the number of multiple deaths both within and beyond the room of origin.

2. False alarms with smoke detectors are often a problem under ordinary circumstances, but when this detector is connected to a device which automatically releases water into an area occupied by sick or elderly persons, the false alarm problem is greatly magnified. Although little data exist concerning this problem, a British study [9] indicates smoke detectors have a false alarm to real fire ratio of 14 to 1. About 25 percent of these false signals are related to ambient conditions such as smoking, cooking, or other sources of smoke not related to a hostile fire. Although much of the British data comes from non-institutional occupancies, even reduction to a false alarm ratio of 5 to 1 for burning homes would be intolerable. It is not difficult to imagine a false alarm occurring when two patients each having two visitors and all four smoking in the same room.

Although the use of a photoelectric detector might reduce the false alarm problem, it is difficult to predict the exact degree to which the problem will be alleviated. Even a two-thirds reduction to the published figures from Great Britain may not be sufficient. In the opinion of the author, a maximum false alarm ratio of 1 to 1 would be desirable for detectors used in these systems. Raising the alarm threshold, electronically instituting a pre-determined delay in operation, or manual actuation of the sprinkler head following a pre-signal from the smoke detector could reduce the number of false alarms. But any delay in the system would greatly reduce the Level 1 effectiveness for open flame ignition fires.

3. These test results suggest that a photoelectric detector may be the most appropriate triggering device for these systems to be used in nursing homes and care-type occupancies. Although the photoelectric detector was slightly slower to respond to the open flaming fire than the ionization detector, there is an advantage to the use of photoelectric

detectors. A photoelectric detector using an incandescent light source will not be nearly as sensitive as an ion chamber detector to cigarette smoke, since that detector responds best to particles greater than 0.3 micrometres. The ion chamber detector is particularly sensitive to smoke particles in the 0.01 to 0.1 micrometre range. The particle size distribution in cigarette smoke falls largely within this range, thus making the ionization detector more sensitive to this source of false alarm.

4. Automatic sprinklers alone cannot provide Level 1 protection. Sprinkler heads alone, however, can provide Level 2 protection against fires initiating from open flame ignition sources. Sprinklers cannot however, provide adequate Level 2 protection from smoldering fires. Work by Hafer and Yuill [10] indicates that it can take up to nearly 4 hours for a smoldering mattress to produce sufficient heat at the ceiling to operate a sprinkler heat. At this point smoke and toxic gas are at lethal levels.
5. The use of separate smoke detection and sprinkler systems in the same room can provide partial Level 1 protection by detection of smoke from smoldering fires, complete Level 2 and Level 3 protection.
6. Based on present price figures it is estimated that the Level 1 Protection system as tested above would cost between \$300 and \$800 per bed: depending on the system design and whether the system is installed in new construction or is being retro-fitted to an existing building. Such a system fitted to an existing facility with 50 beds could cost \$40,000. One possible approach to cost reduction would be to provide Level 1 protection in only one area of a facility and use that area to house persons who might be considered smoking risks. Reduction in patient risk from open flaming fires may also be achieved through use of bedding and sleepwear made of fabrics which are either treated to achieve fire retardant properties or made from fibers which are inherently fire resistant.

7. TENTATIVE DESIGN CRITERIA

The following tentative design criteria are based on the results of this test series and reflect the performance of the system as tested:

1. To provide the level of protection described in these tests any smoke detector chosen to actuate the sprinkler system must have good response characteristics to slowly moving smoke. It is suggested that the detector be capable of responding to minimum smoke obscuration level not exceeding 2% per foot (0.85 ODm^{-1}) at a velocity of 15 feet per minute (7.62 cm sec^{-1}). Although these

performance data are not presently being obtained for detectors in commercial listing and approval procedures, a test method and the test apparatus are being developed at the National Bureau of Standards.

2. Placement of detectors is critical in achieving maximum system effectiveness. Consideration of ambient room air flow patterns is necessary in establishing locations for detectors for minimum response time. Although alternate detector sites were not evaluated in these tests, it is suggested that the detector should be placed on the ceiling above or between beds on a line approximately 3 feet (0.9 m) from the head of the bed. This places the detector over or adjacent to the part of bed where flaming ignition is likely to provide the most serious exposure to the occupant.

Spacing of detectors should not exceed 10 feet. Increased coverage may cause delays in detection with a resulting reduction in system effectiveness with open flaming fires.

8. REFERENCES

- [1] Willenbrock, F. Karl, Testimony Before a Subcommittee of the House Committee on Government Operations--Problems of the Aging (Part 5), pp 1541-1561, April 8, 1972.
- [2] Oregon State Fire Marshal's Office, Study of 14 Casualties in Nursing and Convalescent Homes November 1969 to October 1972, Office of State Fire Marshal, Salem, Oregon, October 1972.
- [3] Installation of Automatic Sprinklers-1973, NFPA No. 13, National Fire Protection Association, Boston, Massachusetts, 1973.
- [4] Underwriters' Laboratories 167, Standard for Smoke Detectors, Combustion Products Type, Underwriters' Laboratories, Inc., Northbrook, Illinois.
- [5] Private Communication, Joseph Petkunas, Pyrotector, Incorporated, April 19, 1974.
- [6] U.L. 199, Automatic Sprinklers for Fire Protection Service, Underwriters' Laboratories, Inc., Northbrook, Illinois.
- [7] DOC FF 4-72, Flammability Standard for Mattresses.
- [8] Watanabe, A., Testing Methods of Fire Detectors in Buildings, Symposium on Automatic Fire Detection, London, March 1972.
- [9] Automatic Fire Detection: Flase Alarms, Fire Protection Association Journal, No. 88, p. 146, October 1970.

[10] Hafer, C. A. and Yuill, C. H., Characterization of Bedding and Upholstery Fires, Final Report, NBS Contract No. CST-792-5-69, Southwest Research Institute, March 31, 1970.

TABLE I

RESULTS OF LEVEL 1 SYSTEM TESTS
INVOLVING IGNITION AND AUTOMATIC SUPPRESSION OF BEDDING FIRES

Test Number	Detector Type (a)	Ignition Source (b)	Time of Operation (hr:min:sec)	Smoke Level at Operation OE % Ft ⁻¹ (ODm ⁻¹)		Temperature at Operation °F (°C)		Maximum Temperature in Bedding °F (°C)	Damage Area in ² (cm ²)
				Ceiling	5 Feet	Ceiling	5 Feet		
1	PE	S	0:33:48	1.7 (0.02)	0.99 (0.01)	61 (16)	61 (16)	347 (175) (ignition area)	20 (127)
2	IC	S	1:13:55	11.3 (0.16)	7.8 (0.11)	84 (29)	66 (19)	702 (372) (ignition area)	314 (2026)
3(d)	PE	S	0:22:46	1.4 (0.02)	0.29 (0.002)	63 (17)	57 (14)	709 (376) (ignition area)	20 (127)
4	PE	F	0:1:45	4.3 (0.06)	0 (0)	(c)	(c)	(c)	200 (1290)
5	IC	F	0:0:36	(e)	(e)	(e)	(e)	(e)	80 (516)

(a) PE = Photoelectric
IC = Ion Chamber

(b) S = Smoldering (cigarette)
F = Flaming (lighter)

(c) No temperatures due to equipment failure

(d) Prototype thermal actuator not presently on the market

(e) No temperature or smoke data due to equipment failure

TABLE II
DETECTOR OPERATION
Results of Multiple Detector Tests

Test Fire	Photoelectric			Ion Chamber		
	Obscuration at Alarm $\% \text{ Ft}^{-1} (\text{ODm}^{-1})$			Obscuration at Alarm $\% \text{ Ft}^{-1} (\text{ODm}^{-1})$		
	Time (min:sec)	Ceiling	5 Feet	Time (min:sec)	Ceiling	5 Feet
Cigarette on mattress filling (cotton padding)	12:10	2.0 (0.028)	.8 (0.011)	16:00	3.5 (0.049)	1.3 (0.018)
Cigarette folded within sheets	28:35	1.0 (0.014)	.6 (0.008)	45:30	9.0 (0.128)	4.1 (0.058)
Flaming lighter dropped	0:42	3.8 (0.054)	0 (0)	0:34	1.5 (0.021)	0 (0)

TABLE III

RESULTS OF SPRINKLER OPERATION TEST WITH AN OPEN FLAME IGNITION SOURCE

Head Number (a)	Rating °F (°C)	Operation Time (min:sec)	Temperature at Operation °F (°C)		Smoke Level at Operation OB % Ft ⁻¹ (ODm ⁻¹) Ceiling 5 Feet		Temperature at Head of Bed °F (°C)
			Ceiling	5 Feet			
1	135 (56.7)	2:30	161 (72)	79 (37)	4.8 (0.07)	3.2 (0.05)	1089 (587)
2	135 (56.7)	2:52	252 (122)	136 (58)	5.8 (0.08)	5.2 (0.07)	1206 (652)
3	165 (73.2)	3:01	259 (126)	147 (64)	6.1 (0.09)	4.5 (0.06)	1263 (684)
4	135 (56.7)	3:18	261 (127)	169 (76)	6.7 (0.10)	4.0 (0.057)	824 (440)
5	165 (73.2)	3:14	259 (126)	163 (73)	6.1 (0.09)	3.9 (0.055)	900 (482)
6	135 (56.7)	3:45	239 (115)	174 (79)	8.3 (0.12)	4.5 (0.06)	606 (319)

- (a) 1 = Prototype low thermal lag sprinkler
 2 = Center strut with heat collectors
 3 = On-off sprinkler
 4 = Center strut
 5 = Old-style 165°F (73.2°C) center strut
 6 = Glass bulb




Figure 1. Velocity profiles for test detectors.




Figure 2. Arrangement of components for experimental level system.




Figure 3. Layout of test room.





Figure 4. Location of thermocouples on test bed.

HEAD OF
BED


POINT OF FIRE ORIGIN



SMOLDERING FIRE

HEAD OF
BED

POINT OF FIRE ORIGIN



OPEN FLAMING FIRE

Figure 5. Bed configurations.



Figure 6. Smoldering fire suppressed at 22 minutes 46 seconds.



Figure 7. Flaming fire suppressed at 1 minute 45 seconds.




Figure 8. Sprinkler operation test: temperature levels.




Figure 9. Sprinkler operation test: smoke levels.

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET		1. PUBLICATION OR REPORT NO. NBS TN-836		2. Gov't Accession No.		3. Recipient's Accession No.	
4. TITLE AND SUBTITLE Detector Actuated Automatic Sprinkler System - A Preliminary Evaluation						5. Publication Date July 1974	
						6. Performing Organization Code 490-6196	
7. AUTHOR(S) Richard L. P. Custer						8. Performing Organ. Report No.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234						10. Project/Task/Work Unit No.	
						11. Contract/Grant No.	
12. Sponsoring Organization Name and Complete Address (Street, City, State, ZIP) Same as no. 9						13. Type of Report & Period Covered Final Jan.-Feb. 1974	
						14. Sponsoring Agency Code	
15. SUPPLEMENTARY NOTES Library of Congress Catalog Number: 74-600095							
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) An investigation was conducted to evaluate the capabilities of a detector actuated automatic sprinkler system to protect individuals who are intimately associated with the first materials ignited such as bedding materials. Tests were conducted in a simulated nursing home bedroom. System response was evaluated for both smoldering and open flaming ignition sources. It was determined that barring electrical or mechanical failure the system could be nearly 100 percent effective with smoldering fires. The effectiveness with open flaming fires was difficult to evaluate. Although these fires were extinguished with minimum damage in times as short as 36 seconds the possible effects of flammable blankets and sleepwear were not tested. It was estimated that perhaps one third of the potential victims of open flaming fires might be saved. Although these tests were limited in scope, some tentative design criteria for detector actuated sprinkler systems are presented and possible alternatives offered.							
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Bedding fires; design criteria; detector actuated automatic sprinklers; detectors; levels of protection; life safety; sprinklers.							
18. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input checked="" type="checkbox"/> Order From Sup. of Doc., U.S. Government Printing Office Washington, D.C. 20402, SD Cat. No. C1346-836 <input type="checkbox"/> Order From National Technical Information Service (NTIS) Springfield, Virginia 22151				19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED		21. NO. OF PAGES 27	
				20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED		22. Price 65 cents	

NBS TECHNICAL PUBLICATIONS

PERIODICALS

JOURNAL OF RESEARCH reports National Bureau of Standards research and development in physics, mathematics, and chemistry. Comprehensive scientific papers give complete details of the work, including laboratory data, experimental procedures, and theoretical and mathematical analyses. Illustrated with photographs, drawings, and charts. Includes listings of other NBS papers as issued.

Published in two sections, available separately:

• Physics and Chemistry (Section A)

Papers of interest primarily to scientists working in these fields. This section covers a broad range of physical and chemical research, with major emphasis on standards of physical measurement, fundamental constants, and properties of matter. Issued six times a year. Annual subscription: Domestic, \$17.00; Foreign, \$21.25.

• Mathematical Sciences (Section B)

Studies and compilations designed mainly for the mathematician and theoretical physicist. Topics in mathematical statistics, theory of experiment design, numerical analysis, theoretical physics and chemistry, logical design and programming of computers and computer systems. Short numerical tables. Issued quarterly. Annual subscription: Domestic, \$9.00; Foreign, \$11.25.

DIMENSIONS, NBS

The best single source of information concerning the Bureau's measurement, research, developmental, cooperative, and publication activities, this monthly publication is designed for the layman and also for the industry-oriented individual whose daily work involves intimate contact with science and technology—for engineers, chemists, physicists, research managers, product-development managers, and company executives. Annual subscription: Domestic, \$6.50; Foreign, \$8.25.

NONPERIODICALS

Applied Mathematics Series. Mathematical tables, manuals, and studies.

Building Science Series. Research results, test methods, and performance criteria of building materials, components, systems, and structures.

Handbooks. Recommended codes of engineering and industrial practice (including safety codes) developed in cooperation with interested industries, professional organizations, and regulatory bodies.

Special Publications. Proceedings of NBS conferences, bibliographies, annual reports, wall charts, pamphlets, etc.

Monographs. Major contributions to the technical literature on various subjects related to the Bureau's scientific and technical activities.

National Standard Reference Data Series. NSRDS provides quantitative data on the physical and chemical properties of materials, compiled from the world's literature and critically evaluated.

Product Standards. Provide requirements for sizes, types, quality, and methods for testing various industrial products. These standards are developed cooperatively with interested Government and industry groups and provide the basis for common understanding of product characteristics for both buyers and sellers. Their use is voluntary.

Technical Notes. This series consists of communications and reports (covering both other-agency and NBS-sponsored work) of limited or transitory interest.

Federal Information Processing Standards Publications. This series is the official publication within the Federal Government for information on standards adopted and promulgated under the Public Law 89-306, and Bureau of the Budget Circular A-86 entitled, Standardization of Data Elements and Codes in Data Systems.

Consumer Information Series. Practical information, based on NBS research and experience, covering areas of interest to the consumer. Easily understandable language and illustrations provide useful background knowledge for shopping in today's technological marketplace.

BIBLIOGRAPHIC SUBSCRIPTION SERVICES

The following current-awareness and literature-survey bibliographies are issued periodically by the Bureau:

Cryogenic Data Center Current Awareness Service (Publications and Reports of Interest in Cryogenics).

A literature survey issued weekly. Annual subscription: Domestic, \$20.00; foreign, \$25.00.

Liquefied Natural Gas. A literature survey issued quarterly. Annual subscription: \$20.00.

Superconducting Devices and Materials. A literature survey issued quarterly. Annual subscription: \$20.00.

Send subscription orders and remittances for the preceding bibliographic services to the U.S. Department of Commerce, National Technical Information Service, Springfield, Va. 22151.

Electromagnetic Metrology Current Awareness Service (Abstracts of Selected Articles on Measurement Techniques and Standards of Electromagnetic Quantities from D-C to Millimeter-Wave Frequencies). Issued monthly. Annual subscription: \$100.00 (Special rates for multi-subscriptions). Send subscription order and remittance to the Electromagnetic Metrology Information Center, Electromagnetics Division, National Bureau of Standards, Boulder, Colo. 80302.

Order NBS publications (except Bibliographic Subscription Services) from: Superintendent of Documents, Government Printing Office, Washington, D.C. 20402.

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
Washington, D.C. 20234

OFFICIAL BUSINESS

Penalty for Private Use, \$300

POSTAGE AND FEES PAID
U.S. DEPARTMENT OF COMMERCE
COM-215

