



NBS TECHNICAL NOTE **991**

U.S. DEPARTMENT OF COMMERCE/National Bureau of Standards

COMPF2--A Program for Calculating Post-Flashover Fire Temperatures

NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards¹ was established by an act of Congress March 3, 1901. The Bureau's overall goal is to strengthen and advance the Nation's science and technology and facilitate their effective application for public benefit. To this end, the Bureau conducts research and provides: (1) a basis for the Nation's physical measurement system, (2) scientific and technological services for industry and government, (3) a technical basis for equity in trade, and (4) technical services to promote public safety. The Bureau's technical work is performed by the National Measurement Laboratory, the National Engineering Laboratory, and the Institute for Computer Sciences and Technology.

THE NATIONAL MEASUREMENT LABORATORY provides the national system of physical and chemical and materials measurement; coordinates the system with measurement systems of other nations and furnishes essential services leading to accurate and uniform physical and chemical measurement throughout the Nation's scientific community, industry, and commerce; conducts materials research leading to improved methods of measurement, standards, and data on the properties of materials needed by industry, commerce, educational institutions, and Government; provides advisory and research services to other Government Agencies; develops, produces, and distributes Standard Reference Materials; and provides calibration services. The Laboratory consists of the following centers:

Absolute Physical Quantities² — Radiation Research — Thermodynamics and Molecular Science — Analytical Chemistry — Materials Science.

THE NATIONAL ENGINEERING LABORATORY provides technology and technical services to users in the public and private sectors to address national needs and to solve national problems in the public interest; conducts research in engineering and applied science in support of objectives in these efforts; builds and maintains competence in the necessary disciplines required to carry out this research and technical service; develops engineering data and measurement capabilities; provides engineering measurement traceability services; develops test methods and proposes engineering standards and code changes; develops and proposes new engineering practices; and develops and improves mechanisms to transfer results of its research to the ultimate user. The Laboratory consists of the following centers:

Applied Mathematics — Electronics and Electrical Engineering² — Mechanical Engineering and Process Technology² — Building Technology — Fire Research — Consumer Product Technology — Field Methods.

THE INSTITUTE FOR COMPUTER SCIENCES AND TECHNOLOGY conducts research and provides scientific and technical services to aid Federal Agencies in the selection, acquisition, application, and use of computer technology to improve effectiveness and economy in Government operations in accordance with Public Law 89-306 (40 U.S.C. 759), relevant Executive Orders, and other directives; carries out this mission by managing the Federal Information Processing Standards Program, developing Federal ADP standards guidelines, and managing Federal participation in ADP voluntary standardization activities; provides scientific and technological advisory services and assistance to Federal Agencies; and provides the technical foundation for computer-related policies of the Federal Government. The Institute consists of the following divisions:

Systems and Software — Computer Systems Engineering — Information Technology.

¹Headquarters and Laboratories at Gaithersburg, Maryland, unless otherwise noted; mailing address Washington, D.C. 20234.

²Some divisions within the center are located at Boulder, Colorado, 80303.

COMPF2--A Program for Calculating Post-Flashover Fire Temperatures

Vytenis Babrauskas

Center for Fire Research
National Engineering Laboratory
National Bureau of Standards
Washington, D.C. 20234



U.S. DEPARTMENT OF COMMERCE, Juanita M. Kreps, Secretary

Jordan J. Baruch, Assistant Secretary for Science and Technology

NATIONAL BUREAU OF STANDARDS, Ernest Ambler, Director

Issued June 1979

National Bureau of Standards Technical Note 991

Nat. Bur. Stand. (U.S.), Tech. Note 991, 76 pages (June 1979)
CODEN: NBTNAE

U.S. GOVERNMENT PRINTING OFFICE
WASHINGTON: 1979

For sale by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402
Stock No. 003-003-02080-0 Price \$3.50
(Add 25 percent additional for other than U.S. mailing).

TABLE OF CONTENTS

	Page
LIST OF TABLES	iv
LIST OF FIGURES	iv
NOMENCLATURE	v
ABSTRACT	1
1. INTRODUCTION	1
2. HISTORY OF DEVELOPMENT	1
3. THEORY	2
4. PYROLYSIS RATES	5
4.1 Liquid or Thermoplastic Pools	5
4.2 Solid Fuels	6
5. DETAILS OF SUBROUTINES	7
5.1 COMPF2	7
5.2 CRIB	7
5.3 DEQNS	7
5.4 ECHOID	8
5.5 ICONDS	8
5.6 INC	8
5.7 OUTPUT	8
5.8 PFLFIX	8
5.9 POOL	8
5.10 PP	9
5.11 PVTFIX	9
5.12 RPFIIX	9
5.13 STFLOW	9
5.14 TLU	9
5.15 TRIDGF	9
6. AGREEMENT WITH EXPERIMENT	9
7. INPUT INSTRUCTIONS	9
7.1 Deck Set-up	9
7.2 Namelist VARS	10
7.3 Modes of Program Operation	10
8. FILES USED	11
9. IMPLEMENTATION	12
10. LIST OF VARIABLES	12
11. ACKNOWLEDGMENTS	12
12. REFERENCES	12
APPENDIX A -- SAMPLE PROBLEMS	20
APPENDIX B -- PROGRAM LISTING	38

LIST OF TABLES

	Page
Table 1. Variables specified in the input Namelist VARS	14
Table 2. List of variables .	16

LIST OF FIGURES

	Page
Figure 1. Flow chart for main program COMPF2	19

NOMENCLATURE

A	area (m^2)	w	molecular weight (kg mol^{-1})
b_p	combustion efficiency (-)	x	thickness dimension (m)
c_d	discharge coefficient (-)	ϵ	emissivity (-)
c_p	heat capacity ($\text{J kg}^{-1} \text{ K}^{-1}$)	ρ	density (kg m^{-3})
D	smallest fuel dimension (m)	σ	Stefan-Boltzmann constant ($\text{W m}^{-2} \text{ K}^{-4}$)
g	gravitational acceleration (m s^{-1})		
h	convective coefficient ($\text{W m}^{-2} \text{ K}^{-1}$)		Subscripts
h	enthalpy (J)	air	air
h_c	combustion enthalpy (J)	b	vaporization
Δh_c	calorific value (J kg^{-1})	ep	excess pyrolysate
Δh_p	total heat of pyrolysis (J kg^{-1})	f	hot gases; pool
k	thermal conductivity ($\text{W m}^{-1} \text{ K}^{-1}$)	o	ambient
m	mass (kg)	p	pyrolysis
M_o	initial fuel mass (kg)	r	window radiation
q	heat (J)	v	ventilation, window
Q	heat flow (W)	w	walls, including ceiling
r	stoichiometric air/fuel ratio (-)		Superscripts
T	temperature (K)		time rate
v_p	regression velocity (m s^{-1})	...	per volume

COMPF2--A PROGRAM FOR CALCULATING POST-FLASHOVER FIRE TEMPERATURES

Vytenis Babrauskas

COMPF2 is a computer program for calculating the characteristics of a post-flashover fire in a single building compartment, based on fire-induced ventilation through a single door or window. It is intended both for performing design calculations and for the analysis of experimental burn data. Wood, thermoplastic, and liquid fuels can be treated. In addition to the capability of performing calculations for compartments with completely determined properties, routines are included for calculating fire behavior by an innovative variable abstraction method. A comprehensive output format is provided which gives gas temperatures, heat flow terms, and flow variables. The documentation includes input instructions, sample problems, and a listing of the program. The program is written in Fortran and constitutes an improved version of an earlier program, COMPF.

Key words: Computer programs--fire protection; fire protection; fire resistance; fire tests; fire walls; safety engineering--fires.

1. INTRODUCTION

With increasing efforts [1-4]¹ towards rational methods of providing fire endurance for structural building components, it becomes highly desirable for both the designer and the researcher to have available computer programs for calculating expected fire temperatures and heat transfer through the building components. A fire is not considered as becoming a threat to a structure and its fire barriers until it reaches the flashover stage. Flashover of a room is defined as that fire stage when the bulk of the room volume becomes involved in flames. Operationally, this roughly coincides with flames coming out the door or window, or an upper gas space temperature of around 600° C, or a radiant heat flux at floor level of about 20 kW/m². For the purpose of designing for fire endurance, then, only post-flashover fires are considered. The present report describes a computer program for calculating the expected temperatures, heat and mass flows and other variables in post-flashover building fires. Different routines are incorporated for producing design time-temperature curves and for permitting comparative theoretical curves to be generated based on experimental mass loss rates.

2. HISTORY OF DEVELOPMENT

The first computer program for calculating post-flashover fire temperatures was developed by Kawagoe [5], in conjunction with his pioneering studies leading to a theoretical room fire model. This model was an adaptation of an earlier graphical technique. The main limitations of both the computer program

¹Numbers in brackets refer to the literature references listed at the end of this paper.

and the theoretical model was the restriction to ventilation-limited fires. Fuel-limited fires could only be expressed in terms of an empirical temperature change rate. Magnusson and Thelandersson [6] studied heat release rates in more detail and produced a model. An unpublished computer program was used to implement that model. The normalized shape of the fire time-temperature curves was an input variable in this model; the shape was based on sets of typical measurements. Based on Magnusson and Thelandersson's theory, Fedock [7] published a similar computer program with emphasis on prestressed concrete structures. The first program to provide for theoretically based calculations of both ventilation-limited and fuel-limited burning was written by Tsuchiya [8]. It was restricted to fires starting in ventilation control and to fuel consisting of sparsely-packed wood sticks.

The predecessor to the present program, COMPF [9], was issued in 1975 and incorporated several new advances, including the ability to treat entirely fuel-limited fires, to allow for temperature-dependent wall properties, to permit the optional use of numerical input fuel weight loss rates, and to perform certain variable abstraction ("pessimization") calculations as an aid to design. (These techniques enable an input variable to be treated non-deterministically.) Program COMPF2 is intended to replace program COMPF and differs from it in the following main ways:

1. A subroutine has been added to allow treatment of fires where thermoplastic or liquid fuel exists in the form of a pool on the floor. The routine implements the theory discussed in reference [10] and outlined in section 4.1; examples of calculations are also given and discussed in that reference.
2. The deterministic wood fuel burning model has been extended to include the possibility of densely-packed cribs.
3. Both pool fire and densely-packed crib options have been incorporated into the pessimization routines.
4. In addition to performing transient calculations, the program can now also treat steady-state solutions, for both lossy and adiabatic walls.
5. The program is now in S.I. units throughout.
6. Certain corrections and improvements have been incorporated in the calculation routines. The method for the iterative solution of the heat balance equation has especially been improved.

3. THEORY

The post-flashover compartment fire theory has been given in some detail in reference [11], thus, only a brief summary will be given here. The main assumptions are:

- The compartment represents a well-stirred reactor, i.e., spatial temperature variations in the hot fire gases are ignored.
- The model is quasi-steady. Time variations in fuel release rate and in conduction losses are fully included. However, time rate of change terms in gas phase mass and energy balance are dropped.
- Air supply and gas outflow is through a single window in a vertical wall and is the result of fire-induced convection.
- The thermal discontinuity away from the window region is at a level below the bottom of the window. The volume below the discontinuity is occupied

by cold incoming air. In a flashed-over fire this discontinuity is close to the floor. Its exact location below the window bottom is immaterial [12].

- Burning is limited by rates of air or fuel supply rather than by gas phase chemical kinetics.
- Walls (including the ceiling) are modeled as portions of a homogeneous solid of finite thickness. Temperature-dependent material properties are allowed for.

The heat balance equation is:

$$\dot{h}_c - \dot{m}_f (h_{T_f} - h_{298}) - Q_w - Q_r - Q_{ep} = 0 \quad (1)$$

where h denotes enthalpy and the definition of symbols is given in the Nomenclature section. The subscripts on the enthalpy terms denote the temperature at which they are evaluated. The window radiation loss is, simply

$$Q_r = A_v \sigma (T_f^4 - T_o^4) \quad (2)$$

The wall loss term has a radiative and a convective component,

$$Q_w = A_w [\sigma \frac{1}{1/\epsilon_f + 1/\epsilon_w - 1} (T_f^4 - T_w^4) + h (T_f - T_w)] \quad (3)$$

The convective coefficient h above is not well known since the exact flow conditions at the wall and ceiling surfaces in a post-flashover fire are not known in detail. The convective fraction is much less than the radiative fraction, permitting a rather simplified treatment. For turbulent-free convection flow over flat plates the value for h should depend [13] on $(T_f - T_w)^{1/3}$. A value of

$$h = 5.0 (T_f - T_w)^{1/3} \quad (4)$$

was selected as being in reasonable agreement with data.

The analysis in [11] shows that for compartments greater than about 2 m on a side, a flame emissivity of $\epsilon_f \approx 0.9$ may be used.

The enthalpy evolved from combustion, \dot{h}_c , must be evaluated as the lesser of

$$\dot{m}_p \Delta h_c b_p \quad (5)$$

or

$$\dot{m}_{air} \frac{\Delta h_c}{r} b_p. \quad (6)$$

When equation (5) is limiting, the combustion is known as "fuel-limited", while if equation (6) is smaller, combustion is "ventilation-limited". Here b_p represents the maximum combustion efficiency and is a largely unknown number. Since it represents, effectively, the "unmixedness" of the combustion, there may be a scale effect, with smaller compartment spaces showing less complete mixing. Experimental data can generally be correlated within a range of about $0.7 \leq b_p \leq 0.9$.

The value of \dot{m}_{air} is obtained from the Bernoulli equation at the window and is

$$\dot{m}_{air} = \frac{2}{3} C_d \rho_o \left[2g \frac{1 - w_f T_o / w_o T_f}{[1 + (w_o T_f / w_f T_o [1 + (\dot{m}_p / \dot{m}_{air})]^2)^{1/3}]^3} \right]^{1/2} A_v \sqrt{h_v}. \quad (7)$$

The discharge coefficient has been determined by Prahl and Emmons [14] to be 0.68 for normal-shaped windows. This value does not hold in cases where the window takes up almost an entire wall. For such windows the flow patterns have not been studied, but data can be correlated by taking C_d at about one-half its normal value. The molecular weight of the products, w_f , is not exactly known since the composition of the gases, especially the unburned fuel gases (excess pyrolysates) is generally unknown. For simplicity their molecular weight has been assumed equal to that of nitrogen. The contribution of carbon monoxide and other minor combustion products is also ignored. The main dependence of \dot{m}_{air} is on the window parameter $A_v \sqrt{h_v}$. For reasonable values of temperature the whole expression becomes approximately equal to

$$\dot{m}_{air} \approx (0.45 \text{ to } 0.50) A_v \sqrt{h_v} \quad (8)$$

But this approximation has not been employed here.

Ventilation through multiple openings has not been provided for in this program. An approach for treating such problems is given in [11].

The heat of combustion, Δh_c , is taken as the net value since the hot gas outflow is above 100° C. The stoichiometric ratio, r , is a constant for a pure material; a tabulation of values is given in [15].

The rate of pyrolysis, \dot{m}_p , is one of the hardest quantities to determine. A discussion of available values is given in the next section.

The outflow mass rate, \dot{m}_f , is by mass conservation the sum of \dot{m}_{air} and \dot{m}_p . The enthalpy of the outflow products, h_{T_f} and h_{298} is evaluated on the assumption that the combusted fuel goes to CO_2 and H_2O . No account is taken of CO for two reasons: because the effect on a mass basis would be very small, and because it was considered advisable not to introduce any reaction kinetics. Also, only elements C, H, O, and N have been considered for the fuel composition.

The excess pyrolysate term Q_{ep} , is the heat required to vaporize the excess pyrolysates. Note that with the conventional definition of heat of combustion, the loss for vaporization of combusted pyrolysates is already included in Δh_c .

The second major equation to be solved is for heat conduction through the wall.

$$\rho C_p \frac{\partial T_w}{\partial t} = \frac{\partial}{\partial x} (k \frac{\partial T_w}{\partial x}) + q''' \quad (9)$$

The wall is initially at ambient temperature, T_o , and is subjected to boundary conditions at the fire side of:

$$-k \frac{\partial T_w}{\partial x} = h [T_f - T_w(o)] + \epsilon \sigma [T_f^4 - T_w^4(o)] \quad (10)$$

and on the unexposed side ($x = L$),

$$-k \frac{\partial T_w}{\partial x} = h [T_w(L) - T_o] + \epsilon \sigma [T_w^4(L) - T_o^4] \quad (11)$$

For the fire side the convective coefficient has been given above. For the unexposed side a value of

$$h = 1.87 [T_o - T_w(L)]^{1/3} \quad (12)$$

was taken.

4. PYROLYSIS RATES

4.1 Liquid or Thermoplastic Pools

There is currently only one fuel arrangement where the pyrolysis rate may adequately be predicted from theory. It consists of a pool of thermoplastic or liquid fuel on the floor. The fuel is pyrolyzed solely by radiant flux and "sees" the compartment with a view factor of 1.0 and itself with a view factor of zero. In addition, the fuel must pyrolyze at a known surface temperature, T_b , and with a known heat of pyrolysis, Δh_p . Then:

$$\dot{m}_p = A_f \frac{\epsilon \sigma (T_f^4 - T_b^4)}{\Delta h_p} \quad (13)$$

Tewarson and Pion [16] have measured heats of pyrolysis for numerous thermoplastic materials.

The above simple model is fully adequate for steady-state solutions. At the start of the fire, however, the radiation feedback is small from the hot gas volume but may be larger from the local plume above the pool itself. Thus, a plume term should be added in to model the starting transient. Very limited experimental data by Burgess [17] and by Modak [18] can be used to derive an empirical relationship for the plume pyrolysis rate as:

$$\dot{m} = A_f 0.0014 \frac{\Delta h_c}{\Delta h_p} \quad (\text{kg/s}) \quad (14)$$

This relationship does not take into account differences in flame emissivities for various materials; as a result, it only provides a crude measure. In the present application, however, the contribution of this term is minor; therefore, an approximate expression is adequate. Also, as the room radiation increases, the effect of plume radiation on pyrolyzing the

fuel decreases. For a radiatively black room, at high temperature, the plume term should properly be negligible. This interaction is crudely modeled by multiplying the plume term by a proportionality factor before adding to the far-field term. The proportionality factor, χ , has been set equal to

$$\chi = 1.0 - \frac{T_f^4 - T_b^4}{1700^4 - T_b^4} \quad (15)$$

with $\chi > 0$.

4.2 Solid Fuels

Empirical data are available for the mass loss rates of wood planks in flashed-over fires. Because of the nature of wood combustion, these rates are not especially sensitive to room radiation and can be specified [11] using a regression velocity of 7-15 $\mu\text{m}/\text{s}$. This relationship is adequate to describe the burning of large, isolated wood panels. For pieces thin in two or three dimensions, yet still widely spaced, the following expression is suitable:

$$\frac{\dot{m}_p}{M_o} = \frac{F}{C} \left(\frac{m}{M_o} \right)^{1-1/F} \quad (16)$$

Here M_o is the original mass, m is the mass at a given time, and F is a constant equal to 2 for cylinders or rectangular sticks and equal to 3 for spheres or cubes. C is given by

$$C = \frac{D}{2v_p}$$

with D being the smallest fuel dimension and v_p the regression velocity. For thin fuels v_p is approximately

$$v_p \approx 1.7 \times 10^{-6} D^{-0.6} \text{ (m/s)} \quad (17)$$

The final arrangement for wood fuel for which data are available is a crib, or a regular stacked array. From the data of Nilsson [19] and Yamashika [20], a set of simplified relationships has been evolved for the three crib burning regimes.

Fuel Surface Control

$$\dot{m}_p = \frac{4}{D} v_p \left(\frac{m}{M_o} \right)^{\frac{1}{2}} M_o \quad (\text{kg/s}) \quad (18)$$

$$v_p = 1.7 \times 10^{-6} D^{-0.6}$$

Crib Porosity Control

$$\dot{m}_p = 4.4 \times 10^{-4} \left(\frac{s}{h_c} \right) \frac{M_o}{D} \quad (19)$$

$\frac{s}{h_c}$ = ratio of stick clear spacing to crib height

Room Ventilation Control

$$\dot{m}_p = 0.12 A_v \sqrt{h_v} \quad (20)$$

In calculations, each of the three rates above are determined and the lowest rate taken as governing.

5. DETAILS OF SUBROUTINES

The program routines are written in Fortran language. A complete listing is given in appendix B. The following are brief descriptions of the operation of each subroutine.

5.1 COMPF2

COMP2 is the main program. It calls most of the calculational routines. A flow chart of COMPF2 is given in figure 1. The program starts with the initialization of certain constants and default values. The input title and namelist are then read in. If tabular data are specified, subroutine INC is called. ICONDS is then called in to set initial starting values. The input data are echoed in ECHOID. After that, the appropriate computational routine is called in. If no iteration failure has occurred the program then loops back to the start and goes to the next problem. In case of iteration failure, the program returns to the same problem, this time printing out additional intermediate calculation values. This intermediate output can also be forced to appear by specifying KTRACE=1.

5.2 CRIB

Subroutine CRIB calculates the burning of wood crib fires. A trial gas temperature value is assumed for the first time step. This value is preset, but may be overridden by specifying a value of TINPT. The flow quantities are computed, then the wall losses are determined by calling DESOLV. The heat balance is then determined. If the normalized residue is greater than 0.002, the iteration continues. The new temperature is normally determined by the Newton method. If divergence results, a scanning technique is used initially and a splitting of differences once a bounded oscillation results. After successful convergence a new wall temperature profile is established by calling RSTA. The calculation then proceeds to the next time step. Computation is terminated at the end of time MTIME, or when gas temperature drops to 353 K, or if errors or convergence failure is detected.

5.3 DEQNS

Subroutine DEQNS computes wall heat conduction using the Crank-Nicolson method [21]. DEQNS has two entry points: DESOLV and RSTA. The radiation boundary condition is linearized; updating every iteration rather than every time step ensures minimal error. An additional within-loop iteration is also used. DEQNS calls TRIDGF to solve the equation matrix.

5.4 ECHOID

Subroutine ECHOID echoes the input data. The complete data set is given for each run, rather than just the changed values. Care has been taken to give physical meaning for the variables printed.

5.5 ICONDS

Subroutine ICONDS initializes starting values and does some preliminary calculations on the input data. It also makes a few checks on the validity of the input data. The user, however, is cautioned that this checking is very rudimentary and in case of error exit or iteration failure the input data must be carefully examined.

5.6 INC

Subroutine INC is called in when tabular input data are to be read.

5.7 OUTPUT

Subroutine OUTPUT is the primary output routine. It writes at each time step a large number of variables to output files (logical units) 2 and 3. The temperatures, burning rates, and other primary variables are put on file 2, while the heat balance values and the mass fractions are written on file 3. OUTPUT also converts temperatures from Kelvin to degrees Celsius before printing them out.

5.8 PFLFIX

PFLFIX is a pessimization design routine. Fuel pyrolysis rate is calculated according to governing equations, but the ventilation is pessimized by instantaneously adjusting the window width to give the highest possible temperatures. Wood stick or wood crib fuel is assumed unless PLFUEL=T, in which case a pool fire is used. The window width is not allowed to exceed a maximum, as set by AWDOW/HWDOW. Calculations stop when the fuel, as specified by FLOAD, is exhausted, since the window width would be undefined beyond that point. Calculational procedures are similar to those in CRIB.

5.9 POOL

POOL is a pool fire burning routine. Computational details are similar to those as in CRIB. The pyrolysis rate is based on equations 13, 14, and 15. Three modes of subroutine operation are possible. If STOICH=T, the steady-state temperatures and pool area are determined for stoichiometric burning. If EISCAN=T, the steady-state solution is found for a given pool area greater than stoichiometric. The pool area is specified by use of the parameter EITA, defined as [10]

$$\eta = \frac{\frac{A_v \sqrt{h_v}}{A_f}}{\left(\frac{A_v \sqrt{h_v}}{A_f} \right)_{\text{stoich}}} \quad (21)$$

For constant window size, this becomes simply a ratio of pool areas. No solutions are possible for $\eta > 1$. Finally, a transient calculation can be made, which proceeds similarly as in the other transient calculations. The user must make sure that the pool size given is sufficiently large so that $\eta \leq 1$.

5.10 PP

Subroutine PP is a plotting routine. Details are not given since plotting routines are dependent on the hardware used.

5.11 PVTFIX

PVTFIX is a pessimization routine, and is effectively the inverse of PFLFIX. In PVTFIX a fixed ventilation opening is specified. The fuel release rate is instantaneously varied to always result in the highest possible burning temperature. Temperatures drop after the fuel load is consumed. Computational details are similar to those in PFLFIX.

5.12 RPFIX

For comparison of measured data against numerical predictions a routine is needed which can accept measured rates as an input tabular function of time. RPFIX provides for this type of checking calculation. The case of measured combustion rate input (as provided, for instance, by oxygen depletion measurements in the window outflow) can also be treated by dividing the measured rate by Δh_c (net) and setting $b_p = 1.0$.

5.13 STFLOW

Subroutine STFLOW is a wall heat conduction routine. It is similar to DEQNS, except that only the steady-state temperatures are determined.

5.14 TLU

Function TLU is a tabular data interpolating function used in several subroutines. If the independent variable entered is smaller than the smallest data point or larger than the largest data point, the output is set equal to the smallest, or largest dependent value, respectively.

5.15 TRIDGF

Subroutine TRIDGF uses a Gauss elimination procedure to solve a set of tri-diagonal matrix equations.

6. AGREEMENT WITH EXPERIMENT

A comparison of numerical predictions with experimental results has been given in [22] for the program COMPF. Similar agreement should hold for COMPF2, since COMPF2 is improved mainly in operational features, especially increased versatility, while retaining the same theoretical model as in COMPF. For pool fires useable full-scale experimental data are not available.

7. INPUT INSTRUCTIONS

7.1 Deck Set-up

The input is assigned to file 1. Each problem run consists of two or three card groups, as follows:

1. Title card (20A4). One card only. Card must be present. The identifying information from the title card is printed at the head of the output.
2. Namelist card(s). One or more cards. Details are given in the next section.

3. Tabular input (optional). This input group is contained only for the first run and for those ensuing runs where NEWPRP=T. If no tabular input is present, then blank cards must not be inserted. If tabular input is present, it is arranged as follows:

First card: NCN, NCP, NEM, NR, NQG (10I3). These are the number of points for the wall thermal conductivity, wall heat capacity, wall emissivity, mass pyrolysis rate, and wall heat generation rate, respectively. The number of points may be 0, 1, or greater than 1. If N=0, then the previous run value is unchanged. If N=1, then it is assumed the value is a constant, independent of temperature or time. If N>1, then an array is inputted.

Ensuing card(s): These are in the format (8F10.0) and arranged in pairs (independent, dependent). For wall thermal properties, temperature is the independent variable, while for mass pyrolysis rate it is time. The order is: CNDA, CPW, EMSA, RPX, QGEN. First all the points (if any) for CNDA are read in, four pairs per card. Then a new card is started even if the last card is part-full, and CPW is read in. The process is continued for EMSA, RPX, QGEN. No blank cards may be inserted. If N=1 for an array, then the constant value is entered in columns 11-20.

After cards for one run are finished, the cards for the next one are stacked, again with no blank cards.

7.2 Namelist VARS

For all non-tabular data, the namelist format was adopted. This undeservedly obscure Fortran feature is highly advantageous for the present application. Its features include:

- Semi free-format input
- Variables may be in any order
- Unneeded variable values need not be specified
- Variables needed, but not specified in current run are automatically set equal to the prior given value.

The namelist card(s) must contain the following information: the first card must start with \$VARS in columns 2-6, then a space, then the desired values, separated by commas. Input may be continued on continuation cards, each of which must have columns 1-2 blank. The stream is terminated by a \$ after the last variable.

The user is cautioned to check the input carefully, since namelist format provides for only rudimentary error messages. The namelist VARS values are written to file 5 when read in. In normal operation file 5 can be rewound or discarded. If error failures occur, however, the VARS listing on file 5 may be useful in determining input errors.

Table 1 lists all the variables inputted in namelist VARS.

7.3 Modes of Program Operation

Time

Three possibilities are available: complete time-temperature curve calculation, calculation of steady-state temperature for a given wall, or the calculation of a steady-state temperature for adiabatic walls. To select adiabatic walls, set ADIA=TRUE. To select steady-state solution for real walls,

set STEADY=TRUE. To obtain complete time-temperature curve, set ADIA and STEADY both FALSE. Note that for some fuel pyrolysis conditions below not all three possibilities are available.

Fuel Pyrolysis

The following modes of operations are available:

- 1) Pool fire
Set PLFUEL=TRUE.
 - a. Time-temperature curve for given ventilation and pool area. Specify SIZE. Set STOICH and EISCAN both FALSE.
 - b. Burning conditions at steady state for stoichiometric pool size, that is, determine values for EITA=1. Set STOICH=TRUE. Do not input SIZE. Do not set EISCAN=TRUE.
 - c. Burning conditions for any other EITA. Set EISCAN=TRUE. Specify EITA. This option must be preceded by the stoichiometric problem (option 1b, above). SIZE input is not used; if given, the value is disregarded.
- 2) Wood crib fire. This is the default option. Set FLSPEC, PLFUEL, RPSPEC, and VTSPEC all FALSE.
 - a. Simple stick burning. Must specify a value for REGRES greater than zero.
 - b. Nilsson's crib formulas for crib burning in three possible regimes. Specify REGRES=0. (default). Also specify SH.
- 3) Checking option when tabular input pyrolysis rates are given. Set RPSPEC=TRUE. Also must set NEWPRP=TRUE and give an appropriate array of RPX.
- 4) Pessimization over ventilation. Set FLSPEC=TRUE. Window width is automatically adjusted, but is no greater than determined by the inputted value of AWDOW/HWDOW. Program stops when fuel is exhausted.
 - a. Simple stick burning. Must specify a value for REGRES greater than zero and set PLFUEL=FALSE.
 - b. Nilsson's crib formulas for crib burning in three possible regimes. Set PLFUEL=FALSE and REGRES=0. Also specify SH.
 - c. Pool burning. Set PLFUEL=TRUE.
- 5) Pessimization over fuel pyrolysis rate. Set VTSPEC=TRUE. Fuel pyrolysis rate is automatically adjusted for pessimistic burning conditions.

8. FILES USED

The Fortran file logical units must be declared as follows:

File 1 -- Input
File 2 -- Output (echoed input and main calculated variables)
File 3 -- Output (heat balance and mass fractions)
File 4 -- Output (intermediate tracing output - used only if KTRACE=1)
File 5 -- Output (listing of namelist VARS contents).

File 5 can be arranged to be rewound after each problem so that it will contain data only in case of error failure.

9. IMPLEMENTATION

Program COMPF2 has been successfully implemented on a UNIVAC 1108 computer. The predecessor program, COMPF, was run on a CDC 6400 computer. The program uses, as much as possible, only standard Fortran expressions. Minor unavoidable implementation differences exist, however, in commands associated with file usage.

10. LIST OF VARIABLES

Table 2 gives a list of all the major problem variables.

11. ACKNOWLEDGMENTS

Ulf Wickstrom (Lund Institute of Technology) assisted in program development; Richard Peacock (NBS) helped implement the program.

12. REFERENCES

- [1] Pettersson, O., Magnusson, S-E., and Thor, J., Fire Engineering Design of Steel Structures (Publication 50), Stålbyggnadsinstitutet, Stockholm (1976).
- [2] [Law, M.], Design Guide for Fire Safety of Bare Exterior Structural Steel, prepared for American Iron and Steel Institute by Ove Arup and Partners, London (1977).
- [3] Centre Scientifique et Technique du Batiment, The Behavior of Concrete Structures in Fire -- A Method for Prediction by Calculation, Nat. Bur. Stand. (U.S.), Tech. Note 710-10 (1978), translation from French.
- [4] Centre Technique Industriel de la Construction Métallique, Méthode du Prévision par le Calcul du Comportement au Feu des Structures en Acier, Construction Métallique, No. 4 (1976).
- [5] Kawagoe, K., Estimation of Fire Temperature - Time Curve in Rooms (Research Paper 29), Building Research Institute, Tokyo (1967).
- [6] Magnusson, S-E., and Thelandersson, S., Time-Temperature Curves of Complete Process of Fire Development, Acta Polytechnica Scandinavica (Civil Engineering and Building Construction Series), No. 65 (1970).
- [7] Fedock, J. J., Combustion Gas Temperatures in Prestressed Concrete Apartment Fires, M.S. Thesis, University of Colorado, Department of Civil and Environmental Engineering (1973).
- [8] Tsuchiya, Y., Computer Program for the Behavior of Fire in an Enclosure (CP 32), National Research Council, Division of Building Research, Ottawa (1972).
- [9] Babrauskas, V., COMPF, A Program for Calculating Post-Flashover Fire Temperatures (Report UCB FRG 75-2), Fire Research Group, University of California, Berkeley (1975).
- [10] Babrauskas, V., and Wickstrom, U. G., Thermoplastic Pool Compartment Fires, Combustion and Flame, 34, 195-202 (1979).

- [11] Babrauskas, V., and Williamson, R. B., *Fire and Materials*, 2, 39-53 (1978).
- [12] Rockett, J. A., *Combustion Science and Technology*, 12, 165-175 (1976).
- [13] McAdams, W. M., *Heat Transmission*, McGraw-Hill Book Co., New York (1954).
- [14] Prahl, J., and Emmons, H. W., *Combustion and Flame*, 25, 369-385 (1975).
- [15] Throne, J. L., and Griskey, R. G., *Modern Plastics*, 49, 96-100 (Nov. 1972).
- [16] Tewarson, A., and Pion, R. F., *A Laboratory-Scale Test Method for the Measurement of Flammability Parameters* (Serial 22524), Factory Mutual Research Corporation, Norwood, Mass. (1977).
- [17] Burgess, D. S., Strasser, A., and Grumer, J., *Fire Research Abstracts and Reviews*, 3, 177-192 (1961).
- [18] Modak, A., and Croce, P. A., *Plastic Pool Fires* (Serial 22361-3), Factory Mutual Research Corporation, Norwood, Mass. (1976).
- [19] Nilsson, L., *The Effect of Porosity and Air Flow on the Rate of Combustion of Fire in an Enclosed Space*, Bulletin 18, Division of Structural Mechanics and Concrete Construction, Lund Institute of Technology, Lund (1971).
- [20] Yamashika, S., and Kurimoto, H., *Report of the Fire Institute of Japan*, No. 41, 8-15 (1976).
- [21] Carnahan, B., Luther, H. A., and Wilkes, J. O., *Applied Numerical Methods*, John Wiley & Sons, Inc., Somerset, N. J. (1969).
- [22] Babrauskas, V., *Fire Endurance in Buildings*, Ph.D. dissertation, University of California, Berkeley (1976).

Table 1. Variables specified in the input Namelist VARS

<u>Default Values</u>			
Variable	First run	Following run	Information
ADIA	FALSE	pv	if true, walls area adiabatic and only steady-state solution is sought
AFLLOOR	none	pv	area of floor (m^2)
AWALL	none	pv	gross area of walls and ceiling (m^2)
AWDOW	none	pv	area of window (m^2)
BPF	none	pv	maximum fraction of pyrolyzed fuel burned to be ≤ 1.0
CD	0.68	pv	discharge coefficient
CFLPC	44.4	pv	percent, by weight, of carbon in fuel
CPPYR(2)	CPN2	pv	heat capacity of pyrolysis gases (J/kg-K)
CVGROS	none	pv	upper calorific value for dry fuel (J/kg)
DENSW	none	pv	wall density (kg/m^3)
DHP	none	pv	total heat of gasification for fuel (J/kg)
DTIME	none	pv	increment of time step (s)
EF	0.9	pv	gas emissivity, assumed gray
EISCAN	FALSE	FALSE	if true, solve steady-state problem in POOL for a given EITA
EITA	none	pv	normalized air-fuel parameter for pool burning
FLOAD	none	pv	fuel load (kg/m^2 floor area)
FLSPEC	FALSE	FALSE	if true, pessimize ventilation for a specified pyrolysis rate
HFLPC	5.4	pv	percent of hydrogen, by weight, in fuel
HWDOW	none	pv	window height (m)
IRUN	1	sequential	run problem number
IX	10	pv	number of wall slices, to be ≤ 10
KTRACE	0	0	print intermediate output if =1
MTIME	360.	pv	maximum fire time (s)
MWPYR	28.97	pv	molecular weight of pyrolysis gases (g/g-mole)
NEWPLT	FALSE	FALSE	if true, start new plot frame
NEWPRP	TRUE	FALSE	if true, new data arrays will be given
NFLPC	0.	pv	percent of nitrogen, by weight, in fuel
OFLPC	0.	pv	percent of oxygen, by weight, in fuel
PLFUEL	FALSE	FALSE	if true, fuel is a pool fire
PLOT	FALSE	pv	if true, plot time-temperature curve
PNCH	FALSE	pv	if true, punch time-temperature curve
PRNT	none	pv	interval at which results are to be printed (s)
REGRES	0.	pv	rate of fuel regression (m/s)
RPSPEC	FALSE	FALSE	if true, use tabular input fuel pyrolysis
SH	0	pv	ratio of clear spacing between sticks/crib height for crib
SHAPE	2.	pv	shape factor in pyrolysis equation for wood sticks
SIZE	none	pv	for cribs: smallest dimension of stick (m) for pools: pool area (m^2)
STEADY	FALSE	FALSE	if true, only steady-state solution is to be sought
STOICH	FALSE	FALSE	if true, EITA=1 solution is sought in POOL

Table 1. (continued)

TBOILC	0.	pv	fuel vaporization temperature for pools (C)
THICKW	none	pv	wall thickness (m)
TINPT	0.	0.	optional input iteration gas temperature (K)
VTSPEC	FALSE	FALSE	if true, pessimize pyrolysis rate for a specified ventilation
WFLPC	0.	pv	percent of water, by weight, in fuel

Note:

pv = previous value

Table 2. List of variables

ADIA	true if walls are adiabatic
AFLOOR	area of floor (m^2)
AWALL	gross area of walls and ceiling (m^2)
AWALLN	AWALL minus window area
AWDOW	area of window (m^2)
BPF	maximum fraction of pyrolyzed fuel burned
BWDOW	width of window (m)
BWORST	window width (.LE.BWDOW) which maximizes gas temperatures (m)
C	moles of carbon in fuel (mole/kg fuel)
CD	discharge coefficient
CFLDC	percent of carbon, by weight, in fuel
CND	conductivity of a given wall slice (W/m-K)
CNDA	conductivity of the wall, as a function of temperature (W/m-K)
CNG	average conductivity, next to higher numbered slice
CNL	average conductivity, next to lower numbered slice
CNV	numerical factor in heat transfer coefficient
CPA	heat capacity of ambient air (J/kg-K)
CPCO	heat capacity of CO, as a function of temperature (J/kg-K)
CPCO2	heat capacity of CO ₂ , as a function of temperature (J/kg-K)
CPH2	heat capacity of H ₂ , as a function of temperature (J/kg-K)
CPH20	heat capacity of H ₂ O, as a function of temperature (J/kg-K)
CPN2	heat capacity of N ₂ , as a function of temperature (J/kg-K)
CPO2	heat capacity of O ₂ , as a function of temperature (J/kg-K)
CPPYR	heat capacity of pyrolysis gases, as a function of temperature (J/kg-K)
CPW	wall heat capacity, as a function of temperature (J/kg-K)
CVGROS	upper calorific value for dry fuel (J/kg)
CVNET	lower calorific value for moist fuel (J/kg)
DENF	Biot Number/2--fire side
DENSA	ambient air density (kg/m ³)
DENSW	wall density (kg/m ³)
DENU	Biot Number/2--unexposed side
DERIV1	current derivative of heat balance remainder (W/K)
DERIV2	previous derivative of heat balance remainder (W/K)
DIF	temperature error in iteration (K)
DTGAS	increment in gas temperature (K)
DTIME	time increment (s)
DX	wall thickness increment (m)
EF	effective flame grey body emissivity
EISCAN	true if seeking contant EITA#1 solution
EITA	dimensionless air/fuel parameter for pool burning
EMS	computed wall emissivity for parallel plane problem
EMSA	wall emissivity, as a function of temperature
FC	true if in fuel control
FLOAD	fuel load (kg/m ² of floor area)
FLREM	mass of fuel remaining at a given time (kg)
FLSPEC	true if fuel pyrolysis rate is fixed and ventilation pessimized
FUELPC	percent of original fuel supply still remaining
F1	current heat balance error (W)
F2	previous heat balance error (W)
G	acceleration of gravity (m/s ²)
H	moles of hydrogen in fuel (mole/kg fuel)
HCP	variable in solving differential equation
HF	effective heat transfer coefficient, fire side (W/m ² -K)
HFLPC	percent of hydrogen, by weight, in fuel
HU	effective heat transfer coefficient, unexposed side (W/m ² -K)
HIN	height of neutral plane (m)
HRATIO	fractional height of neutral plan above window bottom
HWDOW	height of window (m)
ILINE	line number

Table 2. (continued)

IPG	page number
IRUN	run number
IX	number of wall slices
IXC	number of middle slice
IXL	number of penultimate slice
J	number of current time step
JM	maximum number of time steps
JPRINT	output to be printed every JPRINT time steps
K	number of trial iterations at any given time step
KD	number of iterations to converge differential equation
KITER	equals 0 for normal operation, equals 1 for convergence failure
KNTRL	parameter indicating exit status
KTRACE	print intermediate tracing output if KTRACE=1
MTIME	maximum time for fire simulation (s)
MWIN	molecular weight of ambient air (g/g-mole)
MWOUT	molecular weight of exhaust gases (g/g-mole)
MWPYR	molecular weight of pyrolysis gases (g/g-mole)
N	moles of nitrogen in fuel (mole/kg fuel)
NCND	number of points in CND table
NCPW	number of points in CPW table
NEMS	number of points in EMSA table
NEWPLT	true if start new plot frame (not overlay previous one)
NEWPRP	true if read in new set of tabular data
NFLPC	percent of nitrogen, by weight, in fuel
NQGEN	number of points in QGEN table
NRP	number of points in RPX table
O	moles of oxygen in fuel (mole/kg fuel)
OFLPC	percent of oxygen by weight, in fuel
OPENF	opening factor ration ($m^{2.5}$)
PLFUEL	true if pool fire configuration
PLOT	true if plot time-temperature curve
PNCH	true if punch time-temperature curve
PRNT	number of times per second output is to be printed
QCONW	heat transferred to walls by convection (W)
QFIRE	heat generated by combustion (W)
QFLOW	net flow enthalpy (exhaust minus inflow) (W)
QFUEL	heat lost in heating up unburned fuel fraction (W)
QGEN	wall heat generation, as a function of temp (W/m ³)
QRADO	heat radiated out the window (W)
QFLOW	new flow enthalpy (exhaust minus inflow) (W)
QFUEL	heat lost in heating up unburned fuel fraction (W)
QGEN	wall heat generation, as a function of temp (W/m ³)
QRADO	heat radiated out the window (W)
QRADW	heat transferred to walls by radiation (W)
QWLSUM	total heat removed from compartment and passing into the walls (J)
R	stoichiometric air/fuel mass ratio
RO	stoichiometric oxygen/fuel mass ratio
RC	rate of burning (kg/s)
REGRES	rate of fuel surface regression (m/s)
RMA	mass inflow rate of air (kg/s)
RMF	mass outflow rate of hot gases (kg/s)
RP	rate of pyrolysis (kg/s)
RPSPEC	true if rate of pyrolysis is prescribed as input
RPX	rate of pyrolysis, as a function of time (kg/s)
SCAN	true if search for solution by scanning temperatures
SH	ratio of clear spacing between sticks to crib height
SHAPE	contant indicating shape of fuel sticks
SIGMA	Stefan-Boltzmann constant (W/m ² -K ⁴)
SIZE	thickness of crib sticks (m)
	area of pool (m ²)
SIZEL	pool area for EITA=1 condition (m ²)

Table 2. (continued)

STEADY	true if only steady-state calculation to be made
STOICH	true if pool fire and EITA=1
TAMB	ambient temperature (K)
TGAS	gas temperature (K)
TGAS1	previous value of TGAS (K)
TGAS2	previous value of TGAS1 (K)
TGASC	gas temperature (C)
TGASN	closest gas temperature, lower than true (K)
TGASP	closest gas temperature, higher than true (K)
TGOLD	value of TGAS from prior time step (K)
THICKW	wall thickness (m)
TINPT	input trial starting gas temperature (K)
TITLE	title of this run
TSF	wall surface temperature, fire side (K)
TSU	wall surface temperature, unexposed side (K)
TTIME	total time (s)
T1	old wall temperature profile (K)
T2	new wall temperature profile (K)
T2C	wall temperature profile (C)
VAVGIN	average inflow velocity (m/s)
VTSPEC	true if ventilation is fixed and pyrolysis rate pessimized
W	moles of water in fuel (mole/kg fuel)
WA	format constant
WB	format constant
WFILPC	percent of water, by weight, in fuel
WTFUEL	initial total mass of fuel (kg)
YCO2	mass fraction of CO ₂ in outflow
YH2O	mass fraction of H ₂ O in outflow
YN2	mass fraction of N ₂ in outflow
YO2	mass fraction of O ₂ in outflow
YPYR	mass fraction of pyrolysates in outflow




Figure 1. Flow chart for main program COMPF2

APPENDIX A -- SAMPLE PROBLEMS

Given below is a set of ten concatenated input problems. Each problem is intended to test out a subroutine or other feature of the program. The output for the problems is given following the input.

```

TEST PROGRAM FOR POOL FIRE, STEADY STATE, EITA=1.0
$VARS AFLLOOR=20.,AWALL=80.,AWDOW=4.,BPF=0.7,CD=0.68,CFLPC=85.7,
CVGROS=46.5E6,DENSW=790.,DHP=2.4E6,EITA=1.0,FLLOAD=20.,HFLPC=14.3,
HWDOW=1.5,OFLPC=0.0,PLFUEL=T,STOICH=T,TBOILC=390.,
THICKW=0.038,WFLPC=0.0$
001000001
    0.17
    0.5
TEST PROGRAM FOR POOL FIRE, STEADY STATE, EITA=0.01
$VARS EISCAN=T,EITA=0.01,PLFUEL=T$
TEST PROGRAM WITH DELIBERATE ERROR TO CHECK KTRACE OPERATION
$VARS EISCAN=T,PLFUEL=T,TBOILC=2000.$
TEST PROGRAM FOR POOL FIRE, TRANSIENT CASE, SIZE=7.5 M2
$VARS DTIME=60.,MTIME=3600.,NEWPRP=T, PLFUEL=T, PRNT=60.,SIZE=7.5,
TBOILC=390.$
000001
    840.
TEST PROGRAM FOR WOOD CRIB FIRE, REGRES SPECIFIED
$VARS CFLPC=44.4,CVGROS=18.8E6,FLLOAD=10.0,HFLPC=5.4,OFLPC=38.2,
REGRES=1.5E-5,SHAPE=2.0,SIZE=0.05,WFLPC=12.0$*
TEST PROGRAM 1 FOR WOOD CRIB FIRE, NILSSON'S FORMULAS
$VARS REGRESS=0.0,SH=0.10$*
TEST PROGRAM 2 FOR WOOD CRIB FIRE, NILSSON'S FORMULAS
$VARS FLLOAD=20.,SH=0.20$*
TEST PROGRAM FOR PVTFIX ROUTINE, VARIABLE WALL PROPERTIES
$VARS NEWPRP=T,VTSPEC=T$
004008
273.      0.21      372.      0.21      373.      0.16      1073.      0.26
273.      1090.     372.      1090.     373.      47300.     383.      47300.
384.      5000.     413.      5000.     414.      840.      1073.      840.
TEST PROGRAM FOR PFLFIX ROUTINE, POOL OPTION
$VARS AWDOW=10.,CFLPC=85.7,CVGROS=46.5E6,FLSPEC=T,HFLPC=14.3,NEWPRP=T,
OFLPC=0.0,PLFUEL=T,SIZE=5.0,WFLPC=0.0$*
001001
    0.17
    840.
TEST PROGRAM FOR RPFIX ROUTINE
$VARS MTIME=1903.,NEWPRP=T,RPSPEC=T$
000000000003
0.0      0.12      120.      0.12      121.      0.25

```

-----GEOMETRY AND VENTILATION-----

WALL SURFACE AREA = 80.0 M²
 FLOOR AREA = 20.00 M²
 WINDOW HEIGHT = 1.50 M
 AREA = 4.00 M²
 OPENING FACTOR = 4.899 M².5
 DISCHARGE COEFF.= .68

-----FUEL LOAD PROPERTIES-----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M²
 TOTAL ENTHALPY OF PYROLYSIS= 2.40+06 J/KG
 BOILING TEMPERATURE= 390. DEG C

FUEL COMPOSITION
 CARBON = 85.7 PERCENT BY WEIGHT
 HYDROGEN = 14.3 PERCENT
 OXYGEN = .0 PERCENT
 NITROGEN = .0 PERCENT
 WATER = .0 PERCENT
 RO = 3.43

R = 14.78
 HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG
 LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG
 MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97
 CP OF PYROLYSIS GAS = (.1127*GAS + 1010.) J/KG-K
 MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
 GREY-GAS FLAME EMISSIVITY = .900

-----WALL THERMAL PROPERTIES-----

THICKNESS = .038 M
 DENSITY = 790. KG/M³

THERMAL CONDUCTIVITY = .170 W/M-K

EMISSIVITY = .50

THERMOPLASTIC POOL FIRE

TIME S	TEMP GAS°C	WALL TEMPS C	RP KG/S	RC KG/S	EXC+PYR. KG/S	FUEL PCT	AIR IN KG/S	N.o.P.	VELOCITY M/S	MOL+WT	FUEL CNTRL
1 0.	1169.	1157. 709.	262.	*153	*107	*046	100.0	2.26	*36	1.93	29.93 F

STOICHIOMETRIC FUEL SIZE= 1.741 M²

THERMOPLASTIC POOL FIRE

TIME	GAS FLOW PCT	HEAT BALANCE WND RAD PCT	WALL CNV PCT	WALL RAD PCT	Q-FIRE W	Q-WALL SUM J	YN2 PCT MASS	YCO2 PCT MASS	YH2O PCT MASS	YPYR PCT MASS
0.	69.955	21.096	*229	6.331	4.639+06	0.000	*721	*139	*057	*019

-----GEOMETRY AND VENTILATION-----

WALL SURFACE AREA = 80.0 M²
 FLOOR AREA = 20.00 M²
 WINDOW HEIGHT = 1.50 M
 AREA = 4.00 M²
 OPENING FACTOR = 4.899 M²*5
 DISCHARGE COEFF. = .68

-----FUEL LOAD PROPERTIES-----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M²
 TOTAL ENTHALPY OF PYROLYSIS= 2.40*06 J/KG
 BOILING TEMPERATURE= 390. DEG C

FUEL COMPOSITION

CARBON = 85.7 PERCENT BY WEIGHT
 HYDROGEN = 14.3 PERCENT
 OXYGEN = .0 PERCENT
 NITROGEN = .0 PERCENT
 WATER = .0 PERCENT
 R = 14.78
 RO= 3.43

HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG
 LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG
 MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97
 CP OF PYROLYSIS GAS = (.112*TGAS + 1010.) J/KG-K
 MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
 GREY-GAS FLAME EMISSIVITY = .900
 FUEL AREA= 174.07 M²

-----WALL THERMAL PROPERTIES-----

THICKNESS = .038 M

DENSITY = 790. KG/M³

THERMAL CONDUCTIVITY = .170 W/M-K

EMISSIVITY = .50

THERMOPLASTIC POOL FIRE

TIME	GAS FLOW PCT	HEAT BALANCE WND RAD PCT	WALL TEMP C	RC KG/S	EXC-PWR. KG/S	FUEL PCT	AIR IN KG/S	N.P.	VELOCITY M/S	MOL WT	FUEL CNTRL	PAGE NO.	I	RUN NO.	PAGE NO.	I	RUN NO.	PAGE NO.	I	RUN NO.	
1	.0.	S2S.	501.	327.	153.	.785	.097	.688	100.0	2.04	.37	YN2	YCO2	YH2O	YPR	PCT	PCT	PCT	PCT	PCT	
0.	37.526	2.152	.608	2.218								Q-WALL SUM	PCT	MASS	MASS	MASS	MASS	MASS	MASS	MASS	MASS

TEST PROGRAM WITH DELIBERATE ERROR TO CHECK KTRACE OPERATION

COMPFC2 VERSION 1.1 - RUN NO. 3

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M²
FLOOR AREA = 20.00 M²
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M²
OPENING FACTOR = 4.899 M².S
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M²
TOTAL ENTHALPY OF PYROLYSIS= 2.40+06 J/KG
BOILING TEMPERATURE=2000. DEG C

FUEL COMPOSITION

CARBON = 85.7 PERCENT BY WEIGHT
HYDROGEN = 14.3 PERCENT
OXYGEN = .0 PERCENT
NITROGEN = .0 PERCENT
WATER = .0 PERCENT

R = 14.78
R0 = 3.43
HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG
MOLECULAR WEIGHT OF UNBURNED PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900
FUEL AREA= 174.07 M²

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M
DENSITY = 790. KG/M³
THERMAL CONDUCTIVITY = .170 W/M-K
EMISSIVITY = .50

THERMOPLASTIC POOL FIRE

PAGE NO. 1 RUN NO. 3

TIME S	TEMP GAS,C	WALL TEMPS C	RP KG/S	RC KG/S	EXC.PYR. KG/S	FUEL PCT	AIR IN KG/S	N.P.	VELOCITY M/S	MOL.WT	FUEL CNTRL
-----------	---------------	-----------------	------------	------------	------------------	-------------	----------------	------	-----------------	--------	---------------

---ITERATION FAILURE---
TGAS= 1890.00

TGAS.LT.TBOIL TGAS= 1890.0 GO TO NEXT CASE

RUN NO. 3

TGAS1	TGAS2	F1	F2	DERIVI	K	KD	KH	J	T2(I)	TSF	QFIRE	QFLOW	QRAOW	RP	RC
1800.00	.00	2.43+08	0.00	1.35+05	1	3	0	1	1730.86	1791.43	4.028+05	-1.009+08	4.052+05-59.938	.009	
1810.00	1800.00	2.40+08	2.43+08	-2.93+05	2	3	0	1	1740.49	1801.51	2.891+04	-1.008+08	4.083+05-59.068	.001	
1900.00	1810.00	2.10+08	2.40+08	-3.33+05	3	3	0	1	1827.13	1892.16	2.405+03	-9.183+07	4.363+05-50.558	.000	

TEST PROGRAM FOR POOL FIRE, TRANSIENT CASE, SIZE=7.5 M2

-----GEOMETRY AND VENTILATION-----

WALL SURFACE AREA = 80.0 M2
FLOOR AREA = 20.00 M2
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M2
OPENING FACTOR = 4.899 M2.5
DISCHARGE COEFF.= .68

-----FUEL LOAD PROPERTIES-----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M2
TOTAL ENTHALPY OF PYROLYSIS= 2.40+06 J/KG
BOILING TEMPERATURE= 390. DEG C

FUEL COMPOSITION

CARBON = 85.7 PERCENT BY WEIGHT
HYDROGEN = 14.3 PERCENT
OXYGEN = .0 PERCENT
NITROGEN = .0 PERCENT
WATER = .0 PERCENT
R = 14.78
R0= 3.43
HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG
MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900
FUEL AREA= 7.50 M2

-----WALL THERMAL PROPERTIES-----

THICKNESS = .038 M

DENSITY = 790. KG/M3

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K,

EMISSIVITY = .50

THERMOPLASTIC POOL FIRE

PAGE NO. 1 RUN NO. 4

TIME	TEMP	WALL TEMPS	RP	RC	EXC+PYR.	FUEL	AIR IN	N.P.	VELOCITY	MOL.WT	FUEL
S	GAS°C	C	KG/S	KG/S	KG/S	PCT	KG/S		M/S		CNTRL
1	0.	739.	513.	26.	25.	.306	.108	.198	95.4	2.29	.38
2	60.	826.	712.	34.	25.	.362	.106	.256	90.0	2.23	.37
3	120.	852.	763.	53.	25.	.381	.105	.277	84.3	2.21	.37
4	180.	870.	798.	83.	26.	.396	.104	.292	78.3	2.20	.37
5	240.	882.	820.	117.	27.	.406	.104	.302	72.2	2.19	.36
6	300.	891.	836.	151.	30.	.413	.103	.310	66.0	2.18	.36
7	360.	898.	847.	183.	34.	.419	.103	.316	59.7	2.18	.36
8	420.	903.	857.	213.	39.	.424	.103	.321	53.4	2.17	.36
9	480.	907.	864.	240.	46.	.428	.103	.325	47.0	2.17	.36
10	540.	911.	871.	265.	53.	.431	.103	.328	40.5	2.17	.36
11	600.	914.	876.	288.	61.	.434	.102	.331	34.0	2.16	.36
12	660.	917.	881.	309.	69.	.436	.102	.334	27.5	2.16	.36
13	720.	919.	885.	329.	77.	.439	.102	.336	20.9	2.16	.36
14	780.	921.	888.	347.	85.	.440	.102	.338	14.3	2.16	.36
15	840.	923.	892.	364.	93.	.442	.102	.340	7.6	2.16	.36
16	900.	925.	894.	380.	101.	.444	.102	.342	1.0	2.15	.36
17	960.	926.	897.	394.	108.	.445	.102	.343	0	2.15	.36
18	1020.	358.	534.	407.	115.	.000	.000	.000	0	2.47	.43
19	1080.	255.	409.	414.	122.	.000	.000	.000	0	2.39	.45
20	1140.	211.	350.	412.	128.	.000	.000	.000	0	2.32	.45
21	1200.	184.	310.	402.	133.	.000	.000	.000	0	2.26	.46
22	1260.	164.	280.	387.	137.	.000	.000	.000	0	2.21	.46
23	1320.	149.	257.	371.	141.	.000	.000	.000	0	2.16	.46
24	1380.	138.	238.	355.	143.	.000	.000	.000	0	2.12	.47
25	1440.	129.	222.	339.	145.	.000	.000	.000	0	2.09	.47
26	1500.	121.	209.	324.	145.	.000	.000	.000	0	2.05	.47
27	1560.	114.	198.	310.	145.	.000	.000	.000	0	2.02	.47
28	1620.	108.	188.	296.	144.	.000	.000	.000	0	1.99	.47
29	1680.	103.	179.	284.	142.	.000	.000	.000	0	1.97	.47
30	1740.	99.	171.	272.	140.	.000	.000	.000	0	1.95	.47
31	1800.	95.	164.	261.	137.	.000	.000	.000	0	1.92	.48
32	1860.	91.	157.	251.	135.	.000	.000	.000	0	1.90	.48
33	1920.	88.	151.	241.	132.	.000	.000	.000	0	1.88	.48
34	1980.	85.	146.	232.	129.	.000	.000	.000	0	1.86	.48
35	2040.	82.	141.	223.	126.	.000	.000	.000	0	1.85	.48
36	2100.	80.	136.	215.	123.	.000	.000	.000	0	1.83	.48

THERMOPLASTIC POOL FIRE

PAGE NO. 1 RUN NO. 4

TIME	HEAT BALANCE				Q-WALL				Y02			
	GAS FLOW	WND RAD	WALL CNV	WALL RAD	Q-FIRE	Q-WALL	Y02	Y02	Y02	Y02	Y02	Y02
	PCT	PCT	PCT	PCT	W	SUM	PCT	PCT	PCT	PCT	PCT	PCT
0.	44.886	5.022	11.092	28.910	4.694+06	1.127+08	.060	.679	.131	.054	.076	
60.	51.859	7.174	4.559	22.952	4.582+06	1.883+08	.058	.663	.128	.052	.099	
120.	54.089	7.950	3.297	20.091	4.543+06	2.520+08	.058	.657	.127	.052	.107	
180.	55.726	8.546	2.523	17.707	4.514+06	3.068+08	.057	.652	.126	.052	.113	
240.	56.787	8.943	2.091	16.097	4.496+06	3.559+08	.057	.650	.126	.051	.116	
300.	57.586	9.250	1.787	14.794	4.481+06	4.005+08	.057	.647	.125	.051	.119	
360.	58.196	9.486	1.574	13.785	4.470+06	4.417+08	.057	.646	.125	.051	.122	
420.	58.693	9.681	1.411	12.954	4.461+06	4.801+08	.057	.644	.125	.051	.124	
480.	59.095	9.840	1.283	12.252	4.453+06	5.163+08	.056	.643	.124	.051	.125	
540.	59.440	9.978	1.180	11.659	4.447+06	5.505+08	.056	.642	.124	.051	.126	
600.	59.737	10.097	1.094	11.144	4.442+06	5.832+08	.056	.641	.124	.051	.128	
660.	59.996	10.201	1.022	10.691	4.437+06	6.143+08	.056	.641	.124	.051	.129	
720.	60.224	10.294	.960	10.290	4.433+06	6.443+08	.056	.640	.124	.051	.130	
780.	60.427	10.376	.907	9.929	4.429+06	6.731+08	.056	.639	.124	.051	.130	
840.	60.610	10.451	.860	9.604	4.426+06	7.008+08	.056	.639	.123	.051	.131	
900.	60.776	10.518	.818	9.308	4.423+06	7.277+08	.056	.638	.123	.051	.132	
960.	60.927	10.580	.781	9.037	4.420+06	7.537+08	.056	.638	.123	.050	.132	
1020.	96.257	3.743	-4.0770	-59.079	0.000	7.537+08	.230	.770	.000	.000	.000	
1080.	97.357	2.643	-52.654	-47.486	0.000	7.537+08	.230	.770	.000	.000	.000	
1140.	97.717	2.283	-58.391	-41.795	0.000	7.537+08	.230	.770	.000	.000	.000	
1200.	97.914	2.086	-62.064	-37.859	0.000	7.537+08	.230	.770	.000	.000	.000	
1260.	98.036	1.964	-64.780	-35.129	0.000	7.537+08	.230	.770	.000	.000	.000	
1320.	98.120	1.880	-67.042	-33.129	0.000	7.537+08	.230	.770	.000	.000	.000	
1380.	98.180	1.820	-68.677	-31.505	0.000	7.537+08	.230	.770	.000	.000	.000	
1440.	98.223	1.777	-69.805	-30.128	0.000	7.537+08	.230	.770	.000	.000	.000	
1500.	98.258	1.742	-71.093	-29.103	0.000	7.537+08	.230	.770	.000	.000	.000	
1560.	98.285	1.715	-71.919	-28.159	0.000	7.537+08	.230	.770	.000	.000	.000	
1620.	98.306	1.694	-72.779	-27.407	0.000	7.537+08	.230	.770	.000	.000	.000	
1680.	98.324	1.676	-73.334	-26.712	0.000	7.537+08	.230	.770	.000	.000	.000	
1740.	98.338	1.662	-73.959	-26.146	0.000	7.537+08	.230	.770	.000	.000	.000	
1800.	98.349	1.651	-74.362	-25.603	0.000	7.537+08	.230	.770	.000	.000	.000	
1860.	98.359	1.641	-74.862	-25.162	0.000	7.537+08	.230	.770	.000	.000	.000	
1920.	98.367	1.633	-75.260	-24.756	0.000	7.537+08	.230	.770	.000	.000	.000	
1980.	98.374	1.626	-75.620	-24.394	0.000	7.537+08	.230	.770	.000	.000	.000	
2040.	98.379	1.621	-75.777	-24.028	0.000	7.537+08	.230	.770	.000	.000	.000	
2100.	98.384	1.616	-76.079	-23.735	0.000	7.537+08	.230	.770	.000	.000	.000	

TEST PROGRAM FOR WOOD CRIB FIRE, REGRES SPECIFIED

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M²
FLOOR AREA = 20.00 M²
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M²
OPENING FACTOR = 4.899 M²*5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 10.0 KG/M²

FUEL COMPOSITION

CARBON = 44.4 PERCENT BY WEIGHT
HYDROGEN = 5.4 PERCENT
OXYGEN = 38.2 PERCENT
NITROGEN = .0 PERCENT
WATER = 12.0 PERCENT

R = 5.32

R0= 1.23

HEAT OF COMBUSTION OF DRY FUEL = 18.80+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 15.07+06 J/KG
MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900
RATE OF REGRESSION = 15.00-06 M/S
FUEL DIMENSION = .050 M
SHAPE FACTOR = 2.00

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M
DENSITY = 790. KG/M³

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K

EMISSIVITY = .50

CRIB FIRE

PAGE NO. 1 RUN NO. 5

TIME	TEMP	WALL TEMPS	RP	RC	EXC+PYR.	FUEL	AIR IN	N.P.	VELOCITY	MOL.WT	FUEL
S	GAS.C	C	KG/S	KG/S	KG/S	PCT	KG/S		M/S		CNTL
1	0.	510.	296.	26.	25.	.240	.168	.072	92.8	2.35	.41
2	60.	560.	422.	30.	25.	.231	.162	.069	85.9	2.35	.40
3	120.	572.	461.	41.	25.	.222	.156	.067	79.2	2.36	.40
4	180.	574.	482.	58.	25.	.214	.150	.064	72.8	2.36	.40
5	240.	571.	490.	78.	26.	.205	.143	.061	66.6	2.37	.40
6	300.	563.	492.	98.	26.	.196	.137	.059	60.8	2.37	.40
7	360.	553.	489.	117.	30.	.187	.131	.056	55.2	2.38	.41
8	420.	540.	483.	134.	33.	.178	.125	.053	49.8	2.38	.41
9	480.	526.	474.	149.	37.	.169	.119	.051	44.7	2.39	.41
10	540.	510.	463.	162.	42.	.161	.112	.048	39.9	2.39	.41
11	600.	494.	451.	174.	46.	.152	.106	.045	35.4	2.40	.41
12	660.	476.	437.	184.	51.	.143	.100	.043	31.1	2.40	.42
13	720.	457.	423.	192.	56.	.134	.094	.040	27.1	2.40	.42
14	780.	438.	408.	199.	61.	.125	.087	.037	23.3	2.40	.42
15	840.	417.	392.	204.	66.	.116	.081	.035	19.8	2.40	.42
16	900.	396.	375.	209.	70.	.107	.075	.032	16.6	2.40	.43
17	960.	374.	358.	212.	74.	.098	.069	.029	13.7	2.39	.43
18	1020.	352.	341.	214.	78.	.089	.062	.027	11.0	2.38	.43
19	1080.	328.	324.	216.	81.	.080	.056	.024	8.6	2.37	.44
20	1140.	304.	307.	216.	84.	.071	.049	.021	6.5	2.35	.44
21	1200.	279.	289.	216.	87.	.061	.043	.018	4.7	2.33	.45
22	1260.	253.	271.	214.	89.	.052	.036	.016	3.1	2.29	.45
23	1320.	226.	252.	213.	91.	.042	.030	.013	1.9	2.25	.45
24	1380.	199.	233.	210.	93.	.033	.023	.010	.9	2.19	.46
25	1440.	169.	213.	207.	94.	.022	.016	.007	.2	2.10	.47
26	1500.	134.	190.	203.	95.	.011	.008	.003	.0	1.96	.47
27	1560.	100.	166.	198.	96.	.000	.000	.000	.0	1.74	.48
28	1620.	92.	152.	193.	96.	.000	.000	.000	.0	1.68	.48
29	1680.	87.	143.	187.	96.	.000	.000	.000	.0	1.63	.48
30	1740.	83.	135.	181.	96.	.000	.000	.000	.0	1.59	.49
31	1800.	79.	129.	175.	95.	.000	.000	.000	.0	1.55	.49
									.99		.99

CRIB FIRE

PAGE NO. 1 RUN NO. 5

TIME	HEAT BALANCE						Q-WALL	YD2	YN2	YCO2	YH2O	YPYR
	GAS FLOW	WND RAD	WALL CNV	WALL RAD	Q-FIRE	YSUM						
	PCT	PCT	PCT	PCT	W	J	MASS	MASS	MASS	MASS	MASS	MASS
0.	55.544	3.303	19.249	21.906	2.531+06	6.250+07	.129	.699	.106	.043	.028	
60.	63.693	4.410	11.122	20.800	2.438+06	1.092+08	.132	.701	.102	.041	.027	
120.	67.496	4.843	8.615	19.040	2.345+06	1.481+08	.136	.704	.098	.040	.026	
180.	70.479	5.113	7.081	17.334	2.252+06	1.811+08	.139	.706	.094	.038	.025	
240.	72.815	5.238	6.119	15.828	2.159+06	2.095+08	.143	.709	.091	.037	.024	
300.	74.815	5.278	5.434	14.473	2.066+06	2.342+08	.147	.711	.087	.035	.023	
360.	76.584	5.253	4.919	13.244	1.973+06	2.555+08	.150	.714	.083	.034	.022	
420.	78.203	5.181	4.507	12.109	1.880+06	2.745+08	.154	.716	.079	.032	.021	
480.	79.721	5.074	4.160	11.046	1.786+06	2.908+08	.158	.719	.075	.030	.020	
540.	81.173	4.941	3.852	10.036	1.693+06	3.049+08	.161	.722	.072	.029	.019	
600.	82.590	4.787	3.564	9.062	1.599+06	3.170+08	.165	.724	.068	.027	.018	
660.	83.993	4.619	3.280	8.112	1.505+06	3.273+08	.169	.727	.064	.026	.017	
720.	85.405	4.440	2.987	7.173	1.411+06	3.359+08	.172	.729	.060	.024	.016	
780.	86.848	4.254	2.673	6.232	1.317+06	3.429+08	.176	.732	.056	.023	.015	
840.	88.347	4.064	2.324	5.281	1.222+06	3.485+08	.180	.735	.052	.021	.014	
900.	89.926	3.872	1.924	4.299	1.127+06	3.527+08	.183	.737	.049	.020	.013	
960.	91.618	3.681	1.461	3.268	1.032+06	3.556+08	.187	.740	.045	.018	.012	
1020.	93.446	3.492	.919	2.150	9.368+05	3.573+08	.191	.742	.041	.017	.011	
1080.	95.478	3.308	.318	.902	8.407+05	3.580+08	.194	.745	.037	.015	.010	
1140.	96.899	3.101	-.220	-.632	7.440+05	3.580+08	.198	.748	.033	.013	.009	
1200.	97.133	2.867	-1.288	-2.188	6.465+05	3.580+08	.202	.750	.029	.012	.008	
1260.	97.353	2.647	-3.035	-3.814	5.479+05	3.580+08	.206	.753	.025	.010	.007	
1320.	97.559	2.441	-5.736	-5.614	4.476+05	3.580+08	.210	.756	.021	.009	.006	
1380.	97.750	2.250	-10.041	-7.776	3.446+05	3.580+08	.214	.759	.017	.007	.004	
1440.	97.922	2.078	-17.571	-10.734	2.366+05	3.580+08	.218	.762	.012	.005	.003	
1500.	98.072	1.928	-34.791	-16.210	1.134+05	3.580+08	.224	.766	.006	.003	.002	
1560.	98.139	1.861	-73.760	-26.340	0.000	3.580+08	.230	.770	.000	.000	.000	
1620.	98.135	1.865	-74.639	-25.412	0.000	3.580+08	.230	.770	.000	.000	.000	
1680.	98.127	1.873	-75.239	-24.810	0.000	3.580+08	.230	.770	.000	.000	.000	
1740.	98.116	1.884	-75.698	-24.354	0.000	3.580+08	.230	.770	.000	.000	.000	
1800.	98.104	1.896	-76.063	-23.994	0.000	3.580+08	.230	.770	.000	.000	.000	

TEST PROGRAM 1 FOR WOOD CRIB FIRE, NILSSON'S FORMULAS

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M²
FLOOR AREA = 20.00 M²
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M²
OPENING FACTOR = 4.899 M².5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 10.0 KG/M²

FUEL COMPOSITION

CARBON = 44.4 PERCENT BY WEIGHT

HYDROGEN = 5.4 PERCENT

OXYGEN = 38.2 PERCENT

NITROGEN = .0 PERCENT

WATER = 12.0 PERCENT

R = 5.32

R₀= 1.23

HEAT OF COMBUSTION OF DRY FUEL = 18.80+06 J/KG

LOWER ACTUAL HEAT OF COMBUSTION = 15.07+06 J/KG

MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97

CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K

MAXIMUM FRACTION OF PYROLYSATES BURNED = .70

GREY-GAS FLAME EMISSIVITY = .900

RATE OF REGRESSION = 00.00 M/S

FUEL DIMENSION = .050 M

SHAPE FACTOR = 2.00

CRIB SPACING/HEIGHT RATIO= .100

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M

DENSITY = 790. KG/M³

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K

EMISSIVITY = .50

CRIB FIRE

PAGE NO. 1 RUN NO. 6

TIME	TEMP	WALL	TEMPS	RP	RC	EXC. PYR.	FUEL	AIR IN	N.P.	VELOCITY	MOL. WT	FUEL
5	GAS+C	C		KG/S	KG/S	KG/S	PCT	KG/S		M/S		CNTRL
1	0.	408.	217.	25.	25.	.176	.123	.053	94.7	2.36	.42	1.74
2	60.	452.	315.	28.	25.	.176	.123	.053	89.4	2.38	.42	1.78
3	120.	472.	357.	36.	25.	.176	.123	.053	84.2	2.38	.41	1.79
4	180.	487.	386.	49.	25.	.176	.123	.053	78.9	2.38	.41	1.80
5	240.	498.	408.	64.	26.	.176	.123	.053	73.6	2.38	.41	1.80
6	300.	506.	424.	80.	27.	.176	.123	.053	68.3	2.38	.41	1.81
7	360.	513.	438.	96.	29.	.176	.123	.053	63.0	2.38	.41	1.81
8	420.	519.	449.	111.	31.	.176	.123	.053	57.8	2.39	.41	1.81
9	480.	524.	458.	126.	34.	.176	.123	.053	52.5	2.39	.41	1.82
10	540.	524.	463.	139.	36.	.173	.121	.052	47.3	2.39	.41	1.82
11	600.	512.	458.	152.	42.	.165	.115	.049	42.3	2.39	.41	1.81
12	660.	497.	449.	164.	46.	.156	.109	.047	37.7	2.40	.41	1.81
13	720.	481.	438.	174.	51.	.147	.103	.044	33.3	2.40	.42	1.80
14	780.	464.	425.	183.	55.	.138	.097	.041	29.1	2.40	.42	1.79
15	840.	445.	411.	191.	60.	.129	.090	.039	25.2	2.40	.42	1.78
16	900.	425.	396.	198.	64.	.120	.084	.036	21.6	2.40	.42	1.77
17	960.	405.	381.	203.	68.	.111	.078	.033	18.3	2.40	.43	1.76
18	1020.	384.	364.	207.	72.	.102	.072	.031	15.2	2.39	.43	1.74
19	1080.	362.	348.	210.	76.	.093	.065	.028	12.4	2.39	.43	1.72
20	1140.	339.	330.	212.	79.	.084	.059	.025	9.9	2.38	.44	1.70
21	1200.	315.	313.	213.	82.	.075	.053	.023	7.6	2.36	.44	1.67
22	1260.	291.	296.	213.	85.	.066	.046	.020	5.6	2.34	.44	1.64
23	1320.	266.	279.	213.	87.	.057	.040	.017	3.9	2.31	.45	1.61
24	1380.	240.	261.	211.	90.	.047	.033	.014	2.5	2.27	.45	1.57
25	1440.	213.	242.	209.	91.	.038	.027	.011	1.4	2.22	.46	1.51
26	1500.	185.	222.	206.	93.	.028	.020	.008	.5	2.15	.46	1.45
27	1560.	154.	201.	203.	94.	.017	.012	.005	0	2.04	.47	1.36
28	1620.	109.	175.	199.	94.	.002	.001	.001	0	1.80	.48	1.17
29	1680.	95.	157.	194.	95.	.000	.000	.000	0	1.70	.48	1.10
30	1740.	89.	146.	189.	95.	.000	.000	.000	0	1.65	.48	1.06
31	1800.	84.	138.	183.	95.	.000	.000	.000	0	1.60	.48	1.03
32	1860.	81.	131.	177.	95.	.000	.000	.000	0	1.56	.49	1.00
33	1920.	77.	125.	171.	94.	.000	.000	.000	0	1.53	.49	.98
												28.92

CRIB FIRE

PAGE NO. 1 RUN NO. 6

TIME	HEAT BALANCE				Q-FIRE	0-WALL	Y02	YN2	YC02	YH20	YPYR
	GAS FLOW	WND RAD	WALL CNV	WALL RAD	PCT	SUM	PCT	PCT	PCT	PCT	PCT
	PCT	PCT	PCT	PCT	W	J	MA55	MA55	MA55	MA55	MASS
0.	57.683	2.530	22.491	17.294	1.856+06	4.431+07	.154	.717	.079	.032	.021
60.	64.928	3.282	14.508	17.280	1.856+06	7.971+07	.155	.717	.079	.032	.021
120.	68.196	3.673	11.511	16.622	1.856+06	1.110+08	.155	.717	.078	.032	.021
180.	70.573	3.978	9.568	15.881	1.856+06	1.394+08	.155	.717	.078	.032	.021
240.	72.319	4.215	8.266	15.200	1.856+06	1.655+08	.155	.717	.078	.032	.021
300.	73.706	4.411	7.306	14.578	1.856+06	1.899+08	.155	.717	.078	.032	.021
360.	74.838	4.576	6.571	14.020	1.856+06	2.128+08	.155	.717	.078	.032	.021
420.	75.787	4.717	5.985	13.515	1.856+06	2.345+08	.155	.717	.078	.032	.021
480.	76.597	4.841	5.508	13.059	1.856+06	2.552+08	.155	.717	.078	.032	.021
540.	77.663	4.912	5.042	12.382	1.829+06	2.743+08	.156	.718	.077	.031	.020
600.	79.542	4.862	4.485	11.111	1.736+06	2.906+08	.160	.720	.073	.030	.019
660.	81.169	4.755	4.077	10.001	1.643+06	3.045+08	.163	.723	.070	.028	.018
720.	82.701	4.618	3.722	8.962	1.550+06	3.162+08	.167	.726	.066	.027	.017
780.	84.190	4.461	3.388	7.965	1.456+06	3.262+08	.171	.728	.062	.025	.016
840.	85.673	4.291	3.052	6.989	1.362+06	3.344+08	.174	.731	.058	.023	.015
900.	87.180	4.113	2.697	6.017	1.268+06	3.410+08	.178	.733	.054	.022	.014
960.	88.743	3.930	2.307	5.036	1.174+06	3.462+08	.181	.736	.051	.020	.013
1020.	90.393	3.745	1.864	4.022	1.080+06	3.500+08	.185	.738	.047	.019	.012
1080.	92.159	3.560	1.351	2.951	9.850+05	3.525+08	.189	.741	.043	.017	.011
1140.	94.085	3.378	.759	1.783	8.897+05	3.539+08	.193	.744	.039	.016	.010
1200.	96.227	3.200	.135	.453	7.938+05	3.542+08	.196	.746	.035	.014	.009
1260.	97.021	2.979	-.524	-1.158	6.973+05	3.542+08	.200	.749	.031	.013	.008
1320.	97.247	2.753	-1.857	-2.747	5.998+05	3.542+08	.204	.752	.027	.011	.007
1380.	97.458	2.542	-3.970	-4.448	5.009+05	3.542+08	.208	.754	.023	.009	.006
1440.	97.655	2.345	-7.264	-6.383	4.001+05	3.542+08	.212	.757	.019	.008	.005
1500.	97.836	2.164	-12.695	-8.823	2.958+05	3.542+08	.216	.760	.015	.006	.004
1560.	97.997	2.003	-23.094	-12.532	1.840+05	3.542+08	.221	.763	.010	.004	.003
1620.	98.133	1.867	-62.659	-23.888	2.191+04	3.542+08	.229	.769	.001	.001	.000
1680.	98.137	1.863	-74.329	-25.735	0.000	3.542+08	.230	.770	.000	.000	.000
1740.	98.130	1.870	-75.024	-25.025	0.000	3.542+08	.230	.770	.000	.000	.000
1800.	98.120	1.880	-75.537	-24.512	0.000	3.542+08	.230	.770	.000	.000	.000
1860.	98.108	1.892	-75.938	-24.116	0.000	3.542+08	.230	.770	.000	.000	.000
1920.	98.095	1.905	-76.262	-23.798	0.000	3.542+08	.230	.770	.000	.000	.000

TEST PROGRAM 2 FOR WOOD CRIB FIRE, NILSSON'S FORMULAS

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M²
FLOOR AREA = 20.00 M²
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M²
OPENING FACTOR = 4.899 M².5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M²

FUEL COMPOSITION

CARBON = 44.4 PERCENT BY WEIGHT
HYDROGEN = 5.4 PERCENT
OXYGEN = 38.2 PERCENT
NITROGEN = .0 PERCENT
WATER = 12.0 PERCENT

R = 5.32
R₀= 1.23

HEAT OF COMBUSTION OF DRY FUEL = 18.80+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 15.07+06 J/KG
MOLECULAR WEIGHT OF UNBURNED PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900
RATE OF REGRESSION = 00.00 M/S
FUEL DIMENSION = .050 M
SHAPE FACTOR = 2.00

CRIB SPACING/HEIGHT RATIO= .200

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M
DENSITY = 790. KG/M³

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K

EMISSIVITY = .50

CR18 FIRE

PAGE NO. 1 RUN NO. 7

TIME S	TEMP GAS°C	WALL C	TEMPS	RP KG/S	RC KG/S	EXC+PYR, KG/S	FUEL PCT	AIR IN KG/S	N.P.	VELOCITY M/S	MOL WT	FUEL CNTRL	
1	0.	739.	514.	.26.	.25.	.479	.288	.191	.92.8	2.19	.37	1.83	30.60 F
2	60.	858.	745.	.34.	.25.	.461	.286	.176	.85.9	2.17	.36	1.85	30.60 F
3	120.	902.	815.	.54.	.25.	.444	.286	.158	.79.2	2.17	.36	1.86	30.60 F
4	180.	936.	866.	.85.	.26.	.426	.286	.141	.72.8	2.17	.36	1.87	30.59 F
5	240.	960.	900.	122.	.27.	.409	.286	.123	.66.7	2.17	.36	1.87	30.59 T
6	300.	955.	905.	159.	.30.	.391	.274	.117	.60.8	2.18	.36	1.88	30.52 T
7	360.	942.	897.	194.	.34.	.374	.261	.112	.55.2	2.20	.36	1.88	30.45 T
8	420.	924.	884.	227.	.40.	.356	.249	.107	.49.9	2.21	.37	1.88	30.38 T
9	480.	903.	866.	255.	.47.	.338	.237	.101	.44.8	2.23	.37	1.88	30.31 T
10	540.	879.	846.	281.	.55.	.321	.224	.096	.40.0	2.25	.37	1.88	30.24 T
11	600.	853.	822.	302.	.63.	.303	.212	.091	.35.5	2.26	.37	1.88	30.17 T
12	660.	824.	797.	321.	.72.	.285	.200	.086	.31.2	2.28	.38	1.88	30.09 T
13	720.	794.	769.	336.	.80.	.267	.187	.080	.27.2	2.30	.38	1.88	30.02 T
14	780.	762.	740.	349.	.89.	.250	.175	.075	.23.4	2.31	.38	1.88	29.95 T
15	840.	728.	709.	360.	.97.	.232	.162	.070	.20.0	2.33	.39	1.87	29.87 T
16	900.	693.	678.	368.	104.	.214	.150	.064	.16.8	2.35	.39	1.87	29.80 T
17	960.	656.	644.	374.	111.	.196	.137	.059	.13.8	2.37	.40	1.86	29.73 T
18	1020.	617.	610.	378.	117.	.178	.125	.053	.11.1	2.38	.40	1.85	29.65 T
19	1080.	576.	575.	380.	122.	.160	.112	.048	.8.7	2.39	.40	1.84	29.58 T
20	1140.	533.	540.	380.	127.	.142	.099	.042	.6.6	2.41	.41	1.83	29.51 T
21	1200.	489.	504.	379.	131.	.123	.086	.037	.4.8	2.41	.42	1.81	29.43 T
22	1260.	442.	467.	376.	134.	.105	.073	.031	.3.2	2.42	.42	1.78	29.36 T
23	1320.	393.	429.	372.	137.	.086	.060	.026	.1.9	2.41	.43	1.75	29.28 T
24	1380.	342.	390.	366.	139.	.066	.046	.020	.9	2.39	.44	1.71	29.21 T
25	1440.	286.	350.	359.	141.	.046	.032	.014	.2	2.35	.44	1.64	29.12 T
26	1500.	223.	307.	350.	142.	.023	.016	.007	.0	2.25	.46	1.54	29.03 T
27	1560.	155.	261.	341.	143.	.000	.000	.000	.0	2.06	.47	1.37	28.92 T
28	1620.	140.	236.	330.	143.	.000	.000	.000	.0	1.99	.47	1.31	28.92 T
29	1680.	129.	219.	318.	143.	.000	.000	.000	.0	1.94	.47	1.27	28.92 T
30	1740.	121.	205.	306.	142.	.000	.000	.000	.0	1.89	.48	1.24	28.92 T
31	1800.	115.	194.	294.	141.	.000	.000	.000	.0	1.85	.48	1.21	28.92 T
32	1860.	109.	184.	282.	139.	.000	.000	.000	.0	1.81	.48	1.18	28.92 T
33	1920.	105.	175.	270.	137.	.000	.000	.000	.0	1.78	.48	1.15	28.92 T
34	1980.	101.	168.	260.	135.	.000	.000	.000	.0	1.75	.48	1.13	28.92 T
35	2040.	97.	161.	250.	133.	.000	.000	.000	.0	1.72	.48	1.11	28.92 T
36	2100.	94.	155.	240.	130.	.000	.000	.000	.0	1.69	.48	1.09	28.92 T
37	2160.	91.	149.	231.	128.	.000	.000	.000	.0	1.66	.48	1.07	28.92 T
38	2220.	88.	144.	223.	125.	.000	.000	.000	.0	1.64	.48	1.05	28.92 T
39	2280.	85.	139.	214.	122.	.000	.000	.000	.0	1.61	.48	1.04	28.92 T
40	2340.	83.	135.	207.	119.	.000	.000	.000	.0	1.59	.49	1.02	28.92 T
41	2400.	81.	131.	199.	117.	.000	.000	.000	.0	1.56	.49	1.00	28.92 T
42	2460.	79.	127.	192.	114.	.000	.000	.000	.0	1.54	.49	.99	28.92 T

CR18 FIRE

PAGE NO. 1 RUN NO. 7

TIME	GAS FLOW PCT	HEAT BALANCE	WND RAD PCT	WALL CNV PCT	WALL RAD PCT	Q-FIRE W	Q-WALL SUM J	Y02 PCT MASS	YN2 PCT MASS	YC02 PCT MASS	YH20 PCT MASS	YPR PCT MASS
0.	51.239	5.446	11.986	31.326	4.342+06	1.128+08	.055	.632	.176	.074	.071	
60.	59.890	8.578	4.838	26.713	4.305+06	1.943+08	.056	.635	.177	.074	.067	
120.	62.785	10.011	3.385	23.867	4.301+06	2.647+08	.056	.639	.178	.073	.061	
180.	64.837	11.207	2.533	21.406	4.303+06	3.265+08	.057	.644	.179	.073	.054	
240.	66.133	12.113	2.058	19.706	4.310+06	3.828+08	.057	.648	.180	.073	.047	
300.	68.439	12.473	1.715	17.383	4.125+06	4.300+08	.064	.653	.173	.070	.046	
360.	70.315	12.500	1.524	15.674	3.939+06	4.707+08	.071	.658	.166	.067	.044	
420.	72.040	12.361	1.389	14.222	3.754+06	5.058+08	.078	.663	.158	.064	.042	
480.	73.682	12.102	1.287	12.939	3.568+06	5.363+08	.086	.669	.150	.061	.040	
540.	75.291	11.754	1.203	11.759	3.381+06	5.626+08	.093	.674	.142	.058	.037	
600.	76.901	11.339	1.128	10.638	3.195+06	5.851+08	.101	.679	.135	.054	.035	
660.	78.537	10.870	1.056	9.543	3.008+06	6.043+08	.108	.684	.127	.051	.033	
720.	80.222	10.360	.978	8.444	2.821+06	6.202+08	.116	.690	.119	.048	.031	
780.	81.979	9.818	.888	7.317	2.633+06	6.332+08	.123	.695	.111	.045	.029	
840.	83.833	9.251	.778	6.136	2.445+06	6.433+08	.131	.700	.103	.042	.027	
900.	85.814	8.668	.640	4.874	2.256+06	6.508+08	.139	.706	.095	.038	.025	
960.	87.960	8.074	.464	3.496	2.067+06	6.557+08	.146	.711	.087	.035	.023	
1020.	90.318	7.476	.243	1.956	1.877+06	6.582+08	.154	.716	.079	.032	.021	
1080.	92.946	6.878	.010	.165	1.686+06	6.583+08	.162	.722	.071	.029	.019	
1140.	93.846	6.154	-.314	-.899	1.494+06	6.583+08	.169	.727	.063	.026	.017	
1200.	94.558	5.442	-1.020	-.4049	1.300+06	6.583+08	.177	.733	.055	.022	.015	
1260.	95.238	4.762	-2.239	-.6376	1.103+06	6.583+08	.185	.738	.047	.019	.012	
1320.	95.883	4.117	-4.264	-.8925	9.040+05	6.583+08	.192	.744	.039	.016	.010	
1380.	96.485	3.515	-7.700	-.111.864	6.995+05	6.583+08	.200	.749	.031	.012	.008	
1440.	97.049	2.951	-14.093	-.154.688	4.853+05	6.583+08	.209	.755	.022	.009	.006	
1500.	97.574	2.426	-28.573	-.21.936	2.439+05	6.583+08	.219	.762	.012	.005	.003	
1560.	97.982	2.018	-.66.264	-.33.909	0.000	6.583+08	.230	.770	.000	.000	.000	
1620.	98.049	1.951	-.68.413	-.31.701	0.000	6.583+08	.230	.770	.000	.000	.000	
1680.	98.085	1.915	-.69.814	-.30.274	0.000	6.583+08	.230	.770	.000	.000	.000	
1740.	98.107	1.893	-.70.898	-.29.183	0.000	6.583+08	.230	.770	.000	.000	.000	
1800.	98.122	1.878	-.71.769	-.28.312	0.000	6.583+08	.230	.770	.000	.000	.000	
1860.	98.131	1.869	-.72.495	-.27.590	0.000	6.583+08	.230	.770	.000	.000	.000	
1920.	98.136	1.864	-.73.116	-.26.981	0.000	6.583+08	.230	.770	.000	.000	.000	
1980.	98.138	1.862	-.73.665	-.26.462	0.000	6.583+08	.230	.770	.000	.000	.000	
2040.	98.138	1.862	-.73.953	-.25.954	0.000	6.583+08	.230	.770	.000	.000	.000	
2100.	98.136	1.864	-.74.573	-.25.606	0.000	6.583+08	.230	.770	.000	.000	.000	
2160.	98.133	1.867	-.74.768	-.25.201	0.000	6.583+08	.230	.770	.000	.000	.000	
2220.	98.128	1.872	-.75.114	-.24.888	0.000	6.583+08	.230	.770	.000	.000	.000	
2280.	98.123	1.877	-.75.413	-.24.604	0.000	6.583+08	.230	.770	.000	.000	.000	
2340.	98.116	1.884	-.75.679	-.24.347	0.000	6.583+08	.230	.770	.000	.000	.000	
2400.	98.109	1.891	-.75.769	-.24.079	0.000	6.583+08	.230	.770	.000	.000	.000	
2460.	98.100	1.900	-.75.979	-.23.867	0.000	6.583+08	.230	.770	.000	.000	.000	

TEST PROGRAM FOR PVT FIX ROUTINE. VARIABLE WALL PROPERTIES

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M2
FLOOR AREA = 20.00 M2
WINDOW HEIGHT = 1.50 M
AREA = 4.00 M2
OPENING FACTOR = 4.899 M2.5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M2

FUEL COMPOSITION

CARBON = 44.4 PERCENT BY WEIGHT
HYDROGEN = 5.4 PERCENT
OXYGEN = 38.2 PERCENT
NITROGEN = .0 PERCENT
WATER = 12.0 PERCENT
R = 5.32
R0= 1.23
HEAT OF COMBUSTION OF DRY FUEL = 18.80+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 15.07+06 J/KG
MOLECULAR WEIGHT OF UNBURNED PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYROLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M
DENSITY = 790. KG/M3

Thermal Conductivity Array (W/M-K)

Temperature	Conductivity
273.0	.210
372.0	.210
373.0	.160
1073.0	.260

Heat Capacity Array (J/KG-K)

Temperature	Heat Capacity
273.0	1090.
372.0	1090.
373.0	47300.
383.0	47300.
384.0	5000.
413.0	5000.
414.0	840.
1073.0	840.

EMISSIVITY = .50

VENTILATION SPECIFIED, FUEL PYROLYSIS ADJUSTED FOR WORST CONDITIONS

PAGE NO. 1 RUN NO.

TIME	TEMP 5 GAS°C	WALL TEMPS C	RP KG/5	RC KG/5	EXC.PYR. KG/5	FUEL PCT	AIR IN KG/5	N.P.	VELOCITY M/S	MOL.WT	FUEL CNTRL
1	0.	720.	453.	26.	25.	.419	.293	.126	93.7	2.23	.38
2	60.	853.	729.	32.	25.	.414	.290	.124	87.5	2.20	.37
3	120.	887.	787.	48.	25.	.412	.289	.124	81.3	2.19	.37
4	180.	913.	829.	75.	26.	.411	.288	.123	75.2	2.19	.36
5	240.	933.	860.	96.	27.	.410	.287	.123	69.0	2.18	.36
6	300.	947.	881.	131.	29.	.409	.287	.123	62.9	2.18	.36
7	360.	959.	898.	146.	32.	.409	.286	.123	56.7	2.17	.36
8	420.	969.	914.	214.	36.	.408	.286	.122	50.6	2.17	.36
9	480.	978.	927.	252.	41.	.408	.285	.122	44.5	2.17	.36
10	540.	986.	938.	278.	47.	.407	.285	.122	38.4	2.17	.36
11	600.	992.	947.	312.	53.	.407	.285	.122	32.3	2.17	.36
12	660.	998.	955.	343.	57.	.407	.285	.122	26.2	2.16	.36
13	720.	1002.	961.	363.	61.	.407	.285	.122	20.1	2.16	.36
14	780.	1007.	967.	379.	64.	.406	.284	.122	14.0	2.16	.36
15	840.	1010.	972.	392.	67.	.406	.284	.122	7.9	2.16	.36
16	900.	1013.	976.	403.	69.	.406	.284	.122	1.8	2.16	.36
17	960.	1015.	980.	416.	72.	.406	.284	.122	0	2.16	.36
18	1020.	426.	606.	428.	73.	.000	.000	.000	0	2.47	.43
19	1080.	296.	459.	433.	74.	.000	.000	.000	0	2.39	.45
20	1140.	239.	385.	419.	76.	.000	.000	.000	0	2.30	.45
21	1200.	203.	335.	392.	77.	.000	.000	.000	0	2.22	.46
22	1260.	178.	298.	364.	78.	.000	.000	.000	0	2.15	.47
23	1320.	160.	269.	337.	79.	.000	.000	.000	0	2.08	.47
24	1380.	145.	245.	312.	80.	.000	.000	.000	0	2.02	.47
25	1440.	134.	226.	290.	81.	.000	.000	.000	0	1.96	.47
26	1500.	124.	209.	271.	81.	.000	.000	.000	0	1.91	.48
27	1560.	115.	194.	255.	82.	.000	.000	.000	0	1.85	.48
28	1620.	108.	181.	240.	82.	.000	.000	.000	0	1.80	.48
29	1680.	102.	170.	227.	82.	.000	.000	.000	0	1.76	.48
30	1740.	96.	160.	216.	82.	.000	.000	.000	0	1.71	.48
31	1800.	92.	152.	205.	83.	.000	.000	.000	0	1.67	.48
32	1860.	87.	144.	196.	83.	.000	.000	.000	0	1.63	.48
33	1920.	84.	137.	187.	83.	.000	.000	.000	0	1.60	.48
34	1980.	80.	131.	179.	83.	.000	.000	.000	0	1.56	.49
35	2040.	77.	125.	172.	83.	.000	.000	.000	0	1.53	.49
									0.98	28.92	T

VENTILATION SPECIFIED, FUEL PYROLYSIS ADJUSTED FOR WORST CONDITIONS

PAGE NO. 1 RUN NO. 8

TIME	HEAT BALANCE						0-WALL SUM J	Y02 PCT MASS	YN2 PCT MASS	YC02 PCT MASS	YH20 PCT MASS	YPYR PCT MASS
	GAS FLOW PCT	WND RAD PCT	WALL CNV PCT	WALL RAD PCT	Q-FIRE W							
0.	48.339	4.946	14.745	32.022	4.419e+06	1.240e+08	.057	.648	.180	.073	.047	
60.	58.154	6.318	5.410	28.134	4.363e+06	2.118e+08	.057	.648	.180	.073	.047	
120.	60.694	9.415	4.060	25.768	4.347e+06	2.896e+08	.057	.648	.180	.073	.047	
180.	62.608	10.308	3.244	23.808	4.334e+06	3.599e+08	.057	.648	.180	.073	.047	
240.	64.103	11.047	2.695	22.137	4.324e+06	4.244e+08	.057	.648	.180	.073	.047	
300.	65.155	11.590	2.344	20.860	4.317e+06	4.845e+08	.057	.648	.180	.073	.047	
360.	66.052	12.068	2.081	19.804	4.310e+06	5.411e+08	.057	.648	.180	.073	.047	
420.	66.825	12.493	1.862	18.807	4.305e+06	5.945e+08	.057	.648	.180	.073	.047	
480.	67.492	12.868	1.686	17.929	4.301e+06	6.451e+08	.057	.648	.180	.073	.047	
540.	68.080	13.204	1.545	17.190	4.296e+06	6.934e+08	.057	.648	.180	.073	.047	
600.	68.577	13.494	1.429	16.529	4.293e+06	7.396e+08	.057	.648	.180	.073	.047	
660.	68.996	13.741	1.335	15.963	4.290e+06	7.841e+08	.057	.648	.180	.073	.047	
720.	69.354	13.956	1.254	15.443	4.288e+06	8.271e+08	.057	.648	.180	.073	.047	
780.	69.673	14.149	1.187	15.000	4.285e+06	8.667e+08	.057	.648	.180	.073	.047	
840.	69.940	14.313	1.132	14.625	4.284e+06	9.092e+08	.057	.648	.180	.073	.047	
900.	70.160	14.448	1.088	14.315	4.282e+06	9.488e+08	.057	.648	.180	.073	.047	
960.	70.342	14.561	1.052	14.056	4.281e+06	9.876e+08	.057	.648	.180	.073	.047	
1020.	95.334	4.666	-34.635	-65.520	0.000	9.876e+08	.230	.770	.000	.000	.000	
1080.	96.914	3.086	-47.715	-52.475	0.000	9.876e+08	.230	.770	.000	.000	.000	
1140.	97.433	2.567	-54.773	-45.402	0.000	9.876e+08	.230	.770	.000	.000	.000	
1200.	97.701	2.299	-59.342	-40.481	0.000	9.876e+08	.230	.770	.000	.000	.000	
1260.	97.857	2.143	-62.819	-37.109	0.000	9.876e+08	.230	.770	.000	.000	.000	
1320.	97.958	2.042	-65.406	-34.512	0.000	9.876e+08	.230	.770	.000	.000	.000	
1380.	98.025	1.975	-67.489	-32.461	0.000	9.876e+08	.230	.770	.000	.000	.000	
1440.	98.071	1.929	-69.232	-30.849	0.000	9.876e+08	.230	.770	.000	.000	.000	
1500.	98.101	1.899	-70.589	-29.483	0.000	9.876e+08	.230	.770	.000	.000	.000	
1560.	98.121	1.879	-71.719	-28.347	0.000	9.876e+08	.230	.770	.000	.000	.000	
1620.	98.133	1.867	-72.665	-27.396	0.000	9.876e+08	.230	.770	.000	.000	.000	
1680.	98.138	1.862	-73.461	-26.598	0.000	9.876e+08	.230	.770	.000	.000	.000	
1740.	98.138	1.862	-74.133	-25.925	0.000	9.876e+08	.230	.770	.000	.000	.000	
1800.	98.135	1.865	-74.703	-25.355	0.000	9.876e+08	.230	.770	.000	.000	.000	
1860.	98.128	1.872	-75.188	-24.871	0.000	9.876e+08	.230	.770	.000	.000	.000	
1920.	98.119	1.881	-75.603	-24.459	0.000	9.876e+08	.230	.770	.000	.000	.000	
1980.	98.108	1.892	-75.960	-24.108	0.000	9.876e+08	.230	.770	.000	.000	.000	
2040.	98.095	1.905	-76.269	-23.809	0.000	9.876e+08	.230	.770	.000	.000	.000	

TEST PROGRAM FOR PFLFIX ROUTINE. POOL OPTION

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M2
FLOOR AREA = 20.00 M2
WINDOW HEIGHT = 1.50 M
AREA = 10.00 M2
OPENING FACTOR = 12.247 M2•5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M2
TOTAL ENTHALPY OF PYROLYSIS= 2.40+06 J/KG
BOILING TEMPERATURE= 390. DEG C

FUEL COMPOSITION

CARBON = 85.7 PERCENT BY WEIGHT

HYDROGEN = 14.3 PERCENT

OXYGEN = .0 PERCENT

NITROGEN = .0 PERCENT

WATER = .0 PERCENT

R = 14.78

R0= 3.43

HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG

LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG

MOLECULAR WEIGHT OF UNBURNT PYROLYSATES = 28.97

CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K

MAXIMUM FRACTION OF PYROLYSATES BURNED = .70

GREY-GAS FLAME EMISSIVITY = .900

FUEL AREA= 5.00 M2

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M

DENSITY = 790. KG/M3

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K

EMISSIVITY = .50

FUEL PYROLYSIS (POOL) SPECIFIED. VENTILATION ADJUSTED FOR WORST CONDITIONS

PAGE NO. 1 RUN NO. 9

TIME S	TEMP GAS °C	WALL TENPS C	RP KG/S	RC KG/S	EXC. PYR. KG/S	FUEL PCT	AIR IN KG/S	N.P.	VELOCITY M/S	MOL. WT	FUEL CNTRL	WINDOW WIDTH
1 0.	1051.	666.	.27.	.25.	.388	.271	.116	.94.2	.37	1.93	29.93	4.67
2 60.	1126.	1052.	.39.	.25.	.457	.267	.190	.87.3	.36	1.93	29.92	6.67
3 120.	1140.	1079.	.70.	.25.	.471	.266	.205	.80.3	.36	1.93	29.92	6.67
4 180.	1154.	1104.	.26.	.26.	.485	.265	.220	.73.0	.559	1.93	29.91	6.67
5 240.	1161.	1118.	.28.	.28.	.493	.264	.228	.65.6	.558	.36	1.93	29.91
6 300.	1166.	1128.	.32.	.32.	.499	.264	.234	.56.1	.558	.36	1.93	29.91
7 360.	1170.	1135.	.38.	.38.	.503	.264	.239	.50.6	.557	.36	1.93	29.91
8 420.	1174.	1141.	.293.	.46.	.507	.264	.243	.43.0	.557	.36	1.93	29.91
9 480.	1176.	1146.	.329.	.55.	.510	.263	.246	.35.3	.556	.36	1.93	29.91
10 540.	1178.	1150.	.361.	.65.	.512	.263	.249	.27.7	.556	.36	1.93	29.91
11 600.	1180.	1154.	.390.	.76.	.514	.263	.251	.19.9	.556	.36	1.92	29.91
12 660.	1182.	1156.	.417.	.87.	.516	.263	.253	.12.2	.555	.36	1.92	29.91
13 720.	1183.	1159.	.442.	.97.	.518	.263	.255	.4.4	.555	.36	1.92	29.91
14 780.	1185.	1161.	.464.	.107.	.519	.263	.256	.0	.555	.36	1.92	29.91

FUEL PYROLYSIS (POOL) SPECIFIED. VENTILATION ADJUSTED FOR WORST CONDITIONS

PAGE NO. 1 RUN NO. 9

TIME	GAS FLOW PCT	HEAT BALANCE WIND RAD PCT	WALL CNV PCT	WALL RAD PCT	Q-FIRE W	Q-WALL SUM J	YQ2 PCT MASS	YN2 PCT MASS	YCO2 PCT MASS	YH2O PCT MASS	YPYR PCT MASS
0.	6.2.235	1.0.3228	3.130	22.170	1.177407	1.787-08	.063	.721	.139	.057	.019
60.	68.003	1.8.755	.948	12.241	1.157407	2.702-08	.063	.712	.138	.056	.031
120.	69.104	1.9.586	.734	10.576	1.153407	3.484-08	.062	.710	.137	.056	.034
180.	70.153	20.397	.551	8.900	1.149407	4.136-08	.062	.709	.137	.056	.036
240.	70.729	20.849	.461	7.962	1.147407	4.715-08	.062	.708	.137	.056	.037
300.	71.176	21.204	.396	7.225	1.145407	5.239-08	.062	.707	.137	.056	.039
360.	71.507	21.469	.351	6.674	1.144407	5.721-08	.062	.706	.136	.056	.040
420.	71.773	21.683	.316	6.229	1.143407	6.170-08	.062	.706	.136	.056	.040
480.	71.990	21.859	.286	5.864	1.142407	6.591-08	.062	.705	.136	.056	.040
540.	72.172	22.007	.266	5.556	1.142407	6.990-08	.062	.705	.136	.056	.041
600.	72.327	22.134	.247	5.292	1.141407	7.369-08	.062	.705	.136	.056	.041
660.	72.462	22.244	.231	5.062	1.140407	7.731-08	.062	.705	.136	.056	.042
720.	72.581	22.342	.218	4.859	1.140407	8.079-08	.062	.704	.136	.056	.042
780.	72.686	22.428	.206	4.679	1.140407	8.413-08	.062	.704	.136	.056	.042

TEST PROGRAM FOR RPFIIX ROUTINE

----GEOMETRY AND VENTILATION----

WALL SURFACE AREA = 80.0 M2
FLOOR AREA = 20.00 M2
WINDOW HEIGHT = 1.50 M
AREA = 10.00 M2
OPENING FACTOR = 12.247 M2•5
DISCHARGE COEFF.= .68

----FUEL LOAD PROPERTIES----

FIRE LOAD PER FLOOR AREA = 20.0 KG/M2

FUEL COMPOSITION

CARBON = 85.7 PERCENT BY WEIGHT
HYDROGEN = 14.3 PERCENT
OXYGEN = .0 PERCENT
NITROGEN = .0 PERCENT
WATER = .0 PERCENT

R = 14.78

R0= 3.43

HEAT OF COMBUSTION OF DRY FUEL = 46.50+06 J/KG
LOWER ACTUAL HEAT OF COMBUSTION = 43.36+06 J/KG
MOLECULAR WEIGHT OF UNBURNED PYROLYSATES = 28.97
CP OF PYROLYSIS GAS = (.1127*TGAS + 1010.) J/KG-K
MAXIMUM FRACTION OF PYRCLYSATES BURNED = .70
GREY-GAS FLAME EMISSIVITY = .900

RATE OF PYROLYSIS (KG/S)

TIME	RP
0.	.120
120.	.120
121.	.250

----WALL THERMAL PROPERTIES----

THICKNESS = .038 M
DENSITY = 790. KG/M3

THERMAL CONDUCTIVITY = .170 W/M-K

HEAT CAPACITY = 840. J/KG-K

EMISSIVITY = .50

INPUTTED VALUES OF RP ARE USED

PAGE NO. 1 RUN NO. 10

TIME	TEMP	WALL TEMPS	RP	RC	EXC.PYR.	FUEL	AIR IN	N.P.	VELD CITY	MOL.WT	FUEL
S	GAS.C	C	KG/5	KG/5	KG/5	PCT	KG/5		M/S		CNTRL
1	0.	432.	234.	26.	25.	.120	.084	.036	98.2	6.11	.43
2	60.	457.	323.	29.	25.	.120	.084	.036	96.4	6.13	.42
3	120.	467.	355.	37.	25.	.120	.084	.036	94.6	6.13	.42
4	180.	805.	666.	51.	25.	.250	.175	.075	90.9	5.98	.39
5	240.	843.	756.	71.	26.	.250	.175	.075	87.1	5.95	.39
6	300.	856.	784.	97.	27.	.250	.175	.075	83.4	5.94	.39
7	360.	866.	804.	128.	29.	.250	.175	.075	79.6	5.94	.39
8	420.	872.	817.	160.	32.	.250	.175	.075	75.9	5.93	.38
9	480.	877.	827.	190.	37.	.250	.175	.075	72.1	5.93	.38
10	540.	881.	835.	218.	42.	.250	.175	.075	68.4	5.93	.38
11	600.	884.	841.	244.	49.	.250	.175	.075	64.6	5.92	.38
12	660.	887.	846.	267.	56.	.250	.175	.075	60.9	5.92	.38
13	720.	889.	851.	289.	64.	.250	.175	.075	57.1	5.92	.38
14	780.	891.	855.	309.	72.	.250	.175	.075	53.4	5.92	.38
15	840.	893.	858.	327.	80.	.250	.175	.075	49.6	5.92	.38
16	900.	894.	861.	344.	88.	.250	.175	.075	45.9	5.92	.38
17	960.	896.	864.	360.	95.	.250	.175	.075	42.1	5.92	.38
18	1020.	897.	866.	375.	102.	.250	.175	.075	38.4	5.91	.38
19	1080.	898.	868.	389.	109.	.250	.175	.075	34.6	5.91	.38
20	1140.	899.	870.	401.	116.	.250	.175	.075	30.9	5.91	.38
21	1200.	900.	872.	413.	122.	.250	.175	.075	27.1	5.91	.38
22	1260.	901.	874.	425.	127.	.250	.175	.075	23.4	5.91	.38
23	1320.	902.	876.	435.	133.	.250	.175	.075	19.6	5.91	.38
24	1380.	903.	877.	445.	138.	.250	.175	.075	15.9	5.91	.38
25	1440.	904.	878.	454.	142.	.250	.175	.075	12.1	5.91	.38
26	1500.	904.	880.	463.	147.	.250	.175	.075	8.4	5.91	.38
27	1560.	905.	881.	471.	151.	.250	.175	.075	4.6	5.91	.38
28	1620.	905.	882.	478.	154.	.250	.175	.075	.9	5.91	.38
29	1680.	906.	883.	485.	158.	.250	.175	.075	.0	5.91	.38
30	1740.	206.	476.	491.	161.	.000	.000	.000	.0	5.58	.46
31	1800.	148.	357.	491.	164.	.000	.000	.000	.0	5.08	.47
32	1860.	126.	307.	481.	167.	.000	.000	.000	.0	4.80	.48
33	1920.	112.	272.	464.	169.	.000	.000	.000	.0	4.58	.48

INPUTTED VALUES OF RP ARE USED

PAGE NO. 1 RUN NO. 10

TIME	HEAT BALANCE				Q-WALL		Y02	YN2	YC02	YH20	YPYR
	GAS FLOW	WNO RAD	WALL CNV	WALL RAD	Q-FIRE	Q-WALL	Y02	YN2	YC02	YH20	YPYR
	PCT	PCT	PCT	PCT	W	SUM	PCT	PCT	PCT	PCT	PCT
0.	75.919	3.719	11.044	9.317	3.642+06	4.450+07	.179	.755	.042	.017	.006
60.	80.960	4.296	6.596	8.147	3.642+06	7.672+07	.179	.755	.042	.017	.006
120.	82.877	4.533	5.171	7.419	3.642+06	1.042+08	.180	.755	.042	.017	.006
180.	72.523	10.016	3.312	14.154	7.588+06	1.837+08	.124	.739	.088	.036	.012
240.	76.015	11.532	1.779	10.659	7.588+06	2.404+08	.124	.739	.089	.036	.012
300.	77.201	12.086	1.379	9.318	7.588+06	2.891+08	.124	.739	.089	.036	.012
360.	78.063	12.502	1.122	8.308	7.588+06	3.320+08	.124	.739	.089	.036	.012
420.	78.650	12.792	.963	7.606	7.588+06	3.710+08	.124	.739	.089	.036	.012
480.	79.090	13.013	.848	7.049	7.588+06	4.070+08	.124	.739	.089	.036	.012
540.	79.441	13.191	.762	6.606	7.588+06	4.405+08	.124	.739	.089	.036	.012
600.	79.729	13.339	.694	6.239	7.588+06	4.721+08	.123	.739	.089	.036	.012
660.	79.970	13.464	.639	5.927	7.588+06	5.020+08	.123	.739	.089	.036	.012
720.	80.176	13.571	.594	5.659	7.588+06	5.305+08	.123	.739	.089	.037	.012
780.	80.355	13.665	.556	5.424	7.588+06	5.577+08	.123	.739	.089	.037	.012
840.	80.513	13.748	.523	5.217	7.588+06	5.838+08	.123	.739	.089	.037	.012
900.	80.653	13.822	.494	5.031	7.588+06	6.090+08	.123	.739	.089	.037	.012
960.	80.778	13.889	.469	4.864	7.588+06	6.332+08	.123	.739	.089	.037	.012
1020.	80.892	13.949	.447	4.712	7.588+06	6.567+08	.123	.739	.089	.037	.012
1080.	80.996	14.005	.427	4.573	7.588+06	6.795+08	.123	.739	.089	.037	.012
1140.	81.090	14.055	.409	4.445	7.588+06	7.016+08	.123	.739	.089	.037	.012
1200.	81.178	14.102	.393	4.328	7.588+06	7.231+08	.123	.739	.089	.037	.012
1260.	81.258	14.146	.378	4.219	7.588+06	7.440+08	.123	.739	.089	.037	.012
1320.	81.333	14.186	.364	4.117	7.588+06	7.644+08	.123	.739	.089	.037	.012
1380.	81.402	14.224	.352	4.023	7.588+06	7.843+08	.123	.739	.089	.037	.012
1440.	81.466	14.258	.340	3.935	7.588+06	8.038+08	.123	.739	.089	.037	.012
1500.	81.526	14.291	.330	3.853	7.588+06	8.228+08	.123	.739	.089	.037	.012
1560.	81.582	14.322	.320	3.776	7.588+06	8.415+08	.123	.739	.089	.037	.012
1620.	81.635	14.350	.311	3.704	7.588+06	8.598+08	.123	.739	.089	.037	.012
1680.	81.683	14.377	.303	3.637	7.588+06	8.777+08	.123	.739	.089	.037	.012
1740.	97.678	2.322	-.55.416	-44.732	0.000	8.777+08	.230	.770	.000	.000	.000
1800.	98.014	1.986	-64.641	-35.282	0.000	8.777+08	.230	.770	.000	.000	.000
1860.	98.094	1.906	-68.298	-31.506	0.000	8.777+08	.230	.770	.000	.000	.000
1920.	98.127	1.873	-70.817	-29.066	0.000	8.777+08	.230	.770	.000	.000	.000

APPENDIX B -- PROGRAM LISTING

```

C
C      COMPF2--MAIN PROGRAM
C      CONSTITUTES REVISION OF PROGRAM COMPF
C      COMPF2 VERSION 1.0 PROGRAMMED 1 MARCH 1978 BY V. BABRAUSKAS
C      VERSION 1.1 MINOR REVISIONS 18 AUG 1978
C
COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH20(2),CPN2(2),
1    CP02(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1    OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1    J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1    RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1    PRNT,STEADY,THICKW
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1    NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /TITLE/   TITLE(14)
COMMON /CPLOT/   BUFX(500),BUFY(500),SCALX,SCALY,SPECS(30)
INTEGER TITLE
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,
1    PLOT,PNCH,RPSPEC,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
C
DATA ADIA,CD,CFLPC,CNV,CPA,DENSA,EF,G
1    /.FALSE.,0.68,44.4,5.0,1005.,1.18,0.9,9.8/,
2    HFLPC,IRUN,IX,MTIME,MWPYR,NEWPRP
3    /5.4,0,10,360.,28.97,.TRUE./,
4    NFLPC,OFLPC,PLOT,PNCH,REGRES,SH,SHAPE
5    /0.0,38.2,.FALSE.,.FALSE.,0.0,0.0,2.0/,
6    SIGMA,SIZE1,STEADY,TINPT,WFLPC
7    /5.6697E-8,-10...FALSE.,0.0,12.0/
C      HEAT CAPACITIES ARE GIVEN IN THE FORM CP(1)*TEMP+CP(2)
DATA CPCO /0.1185, 1018./,
1    CPCO2 /0.2114, 931./,
2    CPH20 /0.3549, 1814./,
3    CPH2 /0.6862, 13966./,
4    CP02 /0.3704, 931./,
5    CPN2 /0.1127, 1010./,
6    CPPYR /0.1127, 1010./
C      PROPERTIES OF PYROLYSIS GASES ARE ASSUMED SAME AS FOR NITROGEN
C
NAMELIST /VARS/ ADIA,AFLLOOR,AWALL,AWDOW,BPF,CD,CFLPC,CPPYR,CVGROS,
1    DENSW,DHP,DTIME,EF,EISCAN,EITA,FLOAD,FLSPEC,HFLPC,HWDOW,
2    IRUN,IX,KTRACE,MTIME,MWPYR,NEWPLT,NEWPRP,NFLPC,OFLPC,PLFUEL,
3    PLOT,PNCH,PRNT,REGRES,RPSPEC,SH,SHAPE,SIZE,STEADY,STOICH,
4    TINPT,THICKW,TBOILC,VTSPEC,WFLPC,SCALX,SCALY
10 READ (1,900,END=150) TITLE
900 FORMAT (13A6,A2)
      WRITE(2,910) TITLE
910 FORMAT(1H1,13A6,A2)
      EISCAN=.FALSE.
      STOICH=.FALSE.

```

```

STEADY=.FALSE.
KITER= 0
TINPT= 0.
KNTRL= 1
KTRACE= 0
NEWPLT= .FALSE.
RPSPEC= .FALSE.
FLSPEC= .FALSE.
VTSPEC= .FALSE.
PLFUEL= .FALSE.
IRUN= IRUN+1
20 READ (1,VARS)
WRITE (5,VARS)
IF(ADIA.OR.EISCAN.OR.STOICH) STEADY=.TRUE.
IF (PNCH) PUNCH 900, TITLE
IF (NEWPLT.AND.PLOT) CALL PLTRST
IF (NEWPRP) CALL INC
NEWPRP= .FALSE.
30 CALL ICONDS
IF (KNTRL.EQ.2) GOTO 10
IF (KTRACE.NE.1)GOTO 50
40 WRITE (4,901) IRUN
901 FORMAT ('1 RUN NO.',I4//
1   ' TGAS1    TGAS2    F1      F2      DERIV1    K KD '
2   'KH      J     T2(1)    TSF      QFIRE    QFLOW    QRADW   '
3   ' RP      RC  ')
50 IF (KITER.EQ.1) GO TO 60
CALL ECHOID
60 IF (RPSPEC) GOTO 70
IF (FLSPEC) GOTO 80
IF (VTSPEC) GOTO 90
IF (PLFUEL.AND..NOT.FLSPEC) GOTO 100
CALL CRIB
GOTO 110
70 CALL RPFIX
GOTO 110
80 CALL PFLFIX
GOTO 110
90 CALL PVTFIX
GOTO 110
100 CALL POOL
110 GO TO (120,10,130,120),KNTRL
C       KNTRL= 1 INITIAL VALUE
C       KNTRL= 2 INPUT ERROR DETECTED, PROCEED TO NEW RUN
C       KNTRL= 3 ITERATION FAILURE--PRINT OUT STEPS EVEN IF KTRACE= 0.
C       KNTRL= 4 SIMULATION TIME LIMIT EXCEEDED
120 CONTINUE
C       INSERT HERE ANY REWIND COMMAND TO BE DONE IF NO ERROR
IF (PLOT.OR.PNCH) CALL DOUT
GO TO 10
130 IF (KTRACE.EQ.1) GOTO 10
140 KTRACE= 1
KITER= 1
WRITE (2,903) TGAS
903 FORMAT ('0---ITERATION FAILURE---'/' TGAS=' ,F16.2)
GO TO 30
150 CONTINUE
C       ENDFILE 5
STOP
END

```

SUBROUTINE CRIB

C
C CRIB FIRE ROUTINE
C EQUATIONS FOLLOW NILSSON'S DATA FOR WOOD CRIBS.
C OTHER FUEL CRIBS CAN BE TREATED IF PYROLYSIS CONSTANTS
C ARE KNOWN.
C
COMMON /CNSTS/ AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/ CPA,CPCO(2),CPCO2(2),CPH2(2),CPH2O(2),CPN2(2),
1 CPO2(2),CPPYR(2)
COMMON /FUEL/ C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1 OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/ AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1 J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/ FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1 RPSPEC,VTSPEC
COMMON /PLAST/ TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/ ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1 PRNT,STEADY,THICKW
COMMON /QS/ QCONW,QFIRE,QFLOW,QRADO,QRADW,QWLSum
COMMON /TEMP/ DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/ CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1 NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/ BWORST,FLREM,HRATIO,RMA,RMF,TTIME,VAVGIN,
1 WA,WB,YCO2,YH2O,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1 PLOT,PNCH,RPSPEC,SCAN,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
IF (STEADY) GOTO 190
FC=.FALSE.
SCAN=.FALSE.
QRADW=0.
QCONW=0.
F2=0.
F1=0.
DTGAS=10.
CALL HEADING
C START TIME LOOP
DO 170 J=1,JM
KH=0
DERIV1=1.
TGAS2=0.
TGAS1=0.
TGASP=2000.
TGASN=TAMB
20 CONTINUE
K=0
30 CONTINUE
IF (FLREM.GT.0.) GOTO 40
RC=0.
RP=0.
GO TO 50
40 IF (REGRES.LE.0.0) GOTO 45
C USE THIS FORMULA IF INPUT REGRES IS SPECIFIED
RP= REGRES*2.*SHAPE/SIZE*FLREM**((1.-1./SHAPE)*WTFUEL**((1./SHAPE))
GO TO 50
45 CONTINUE

```

C      FUEL SURFACE CONTROL
C      ASSUME CRIB STICK DENSITY RHOZR= 500 KG/M**3
RHOZR= 500.
REGREN= 1.24E-3/RHOZR*SIZE**-0.6
RP1= REGREN*2.*SHAPE/SIZE*FLREM**((1.-1./SHAPE)*WTFUEL**((1./SHAPE))
C      CRIB POROSITY CONTROL
RP2= 0.22*WTFUEL/(RHOZR*SIZE)*SH
C      ROOM VENTILATION CONTROL
RP3= 0.120*AWDOW*SQRT(HWDOW)
RP= AMIN1 (RP1,RP2,RP3)
50 RMF= RMA+RP
YCO2= 3.66667*CFLPC*RC/100./RMF
YH20= (WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2= (0.23*RMA-R0*RC)/RMF
YN2= 0.77*RMA/RMF +NFLPC*RP/100./RMF
YPYR= (RP-RC)/RMF
IF (YPYR.LT..0) YPYR= 0.
MWOUT= 44.*YC02+18.*YH20+28.*YN2+32.*YO2+MWPYR*YPYR
HRATIO= 1./(1.+((TGAS/TAMB)*(MWIN/MWOUT)*(1.+RP/RMA)**2))
1   **0.3333333333)
C      NOTE HIN IS TAKEN AS POSITIVE
HIN= HWDOW* HRATIO
ZW=1.-MWOUT*TAMB/MWIN/TGAS
IF (ZW)195,55,55
55 VAVGIN= 0.666667*SQRT(2.*G*HIN*ZW)
RMA= CD*VAVGIN*HIN*BWDOW*Densa
RMF= RMA+RP
IF (RMA/R-RP) 60,60,65
60 RC= BPF*RMA/R
GO TO 70
65 RC= BPF*RP
FC= .TRUE.
70 CONTINUE
QFLOW= RMF*((YC02*(TGAS*(0.5*CPC02(1)*TGAS+CPC02(2))-TAMB*(0.5*
1   CPC02(1)*TAMB+CPC02(2)))+YH20*(TGAS*(0.5*CPH20(1)*TGAS+
2   CPH20(2))-TAMB*(0.5*CPH20(1)*TAMB+CPH20(2)))+YO2*(TGAS*(
3   0.5*CP02(1)*TGAS+CP02(2))-TAMB*(0.5*CP02(1)*TAMB+CP02(2))*
4   +YN2*(TGAS*(0.5*CPN2(1)*TGAS+CPN2(2))-TAMB*(0.5*CPN2(1)*
5   TAMB+CPN2(2)))+YPYR*(TGAS*(0.5*CPPYR(1)*TGAS+CPPYR(2))-
6   -TAMB*(0.5*CPPYR(1)*TAMB+CPPYR(2))))*
QFIRE= RC*CVNET
IF (ADIA) GOTO 90
CALL DESOLV
QRADW= AWALLN*EMS(1)*SIGMA*(TGAS**4.-TSF**4.)
QCONW= AWALLN*(TGAS-TSF)*CNV*((TGAS-TSF)*(TGAS-TSF))**0.16666667
90 CONTINUE
QRADO= AWDOW*SIGMA*(TGAS**4.-TAMB**4.)
K= K+1
F3=F2
F2=F1
F1= QFIRE-QFLOW-QRADO-QRADW-QCONW
TGAS3=TGAS2
TGAS2=TGAS1
TGAS1=TGAS
IF (F1.LT.0..AND.TGAS.LT.TGASP) TGASP=TGAS
IF (F1.GT.0..AND.TGAS.GT.TGASN) TGASN=TGAS
DERIV2= DERIV1
IF (TGAS1.EQ.TGAS2) GOTO 130

```

```

DERIV1=(F1-F2)/(TGAS1-TGAS2)
IF (KTRACE.GT.0) WRITE (4,99) TGAS1,TGAS2,F1,F2,DERIV1,K,KD,
1   KH,J,T2(1),TSF,QFIRE,QFLOW,QRADW,RP,RC
99 FORMAT(2F9.2,3(1PE9.2),3I3,I5,2(0PF9.2),3(1PE10.3),2(0PF7.3))
IF (.NOT.SCAN) GOTO 95
IF (F1/F2.GE.0.0) GOTO 93
SCAN= .FALSE.
GOTO 100
93 TGAS= TGAS-DTGAS
IF (TGAS.LT.TAMB) GOTO 200
GOTO 120
95 IF (DERIV1.LT..0.AND.ABS(F2).GT..0001) GOTO 100
IF(DERIV2.LT..0.AND.J.GT.2) GOTO 100
TGAS= TGAS1+DTGAS/5.
GOTO 120
100 DIF= ABS(F1/QFLOW)
IF (DIF.LT.0.002.AND.ABS(TGAS2-TGAS1).LT.2.) GOTO 130
TGAS=(F1*TGAS2-F2*TGAS1)/(F1-F2)
IF (K.GT.10.AND.F1.LT.0..AND.TGAS.GT.TGASP) GOTO 105
IF (K.GT.10.AND.F1.GT.0..AND.TGAS.LT.TGASN) GOTO 105
IF (K.EQ.1.AND.KH.EQ.0) TGAS= TGAS1 +10.
IF (TGAS.GT.2000.) GOTO 110
IF (TGAS.LT.(TAMB+30.)) GOTO 110
GOTO 120
105 TGAS= (TGASN+TGASP)/2.
GOTO 120
110 SCAN= .TRUE.
TGAS= 1900.
120 CONTINUE
IF (K=200) 30,30,200
130 CONTINUE
CALL RSTA
FLREM= FLREM-RP*DTIME
IF(FLREM.LT.0.) FLREM=0.
IF (QCONW.GT.0.) QWLSUM= QWLSUM+(QRADW+QCONW)*DTIME
IF (TTIME .GE. MTIME) GO TO 210
IF (TGAS.LE.353..AND.J.GE.10) GO TO 210
IF (J.EQ.1) GO TO 150
IF (JP.LT.JPRINT) GO TO 160
JP= 0
150 CALL OUTPUT
160 JP= JP+1
TTIME= TTIME+DTIME
170 CONTINUE
C      END TIME STEP DO-LOOP
180 CONTINUE
185 CALL OUTPUT
RETURN
C      ERROR IN INPUT
190 CONTINUE
KNTRL= 2
WRITE (2,910)
910 FORMAT ('//'' CRIB ROUTINE DOES NOT ACCEPT STEADY-STATE CASE'')
RETURN
C      SQUARE ROOT ERROR
195 CONTINUE
IF(KTRACE.EQ.1) WRITE(2,930) TGAS,RC,RP,YPYR,ZW,RMA,MWOUT
930 FORMAT ('' TGAS='',F5.0,'' RC='',E10.4,'' RP='',E10.4,

```

```
I  * YPYR=*,E10.4,* ZW=*,F6.4,* RMA=*,E10.4,* MWOUT=*,F6.1)
C      FAIL TO CONVERGE, ERROR EXIT
200 CONTINUE
KNTRL=3
RETURN
C      FIRE IS OVER (TRANSIENT CASE)
210 CONTINUE
CALL OUTPUT
RETURN
END
```

```

SUBROUTINE DEQNS
C
C           DIFFERENTIAL EQUATION SOLVER BASED ON CRANK-NICOLSON METHOD.
C
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /PRBLM/   ADIA,AFLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
DIMENSION A(20),B(20),C(20),CND(20),D(20),HCP(20)
C
C           ENTRY RSTA
C
C           ENTER HERE WHEN READY FOR NEW TIME STEP (FINISHED ITERATING)
C
DO 10 I=1,IX
T1(I)= T2(I)
10 CONTINUE
TGOLD= TGAS
IF (J.EQ.0) TGOLD=TAMB
RETURN
C
C           ENTRY DESOLV
C
C           SOLVE DIFFERENTIAL EQUATION
C
KD= 1
DX1= DX
DO 20 I=1,IX
CND(I)= TLU(CNDA,NCND,T1(I))
20 HCP(I)= DENSW*DX/DTIME*TLU(CPW,NCPW,T1(I))
EMS(1)= 1./(1./TLU(EMSA,NEMS,TSF) +1./EF -1.)
EMS(2)= TLU(EMSA,NEMS,TSU)
DO 50 I=2,IXL
CNL= 1./(DX/CND(I-1)+DX/CND(I))
IF (I.EQ.2) CNL= 1./(DX1/CND(1)+DX/CND(2))
CNG= 1./(DX/CND(I)+DX/CND(I+1))
A(I)= -CNL
B(I)= HCP(I)+CNL+CNG
C(I)= -CNG
D(I)= (HCP(I)-CNL-CNG)*T1(I)+CNL*T1(I-1)+CNG*T1(I+1)
50 IF (NQGEN.GT.0) D(I)= D(I)+DX*TLU(QGEN,NQGEN,T1(I))
CNG= 1./(DX1/CND(1)+DX/CND(2))
C(I)= -CNG
CNL= 1./(DX/CND(IXL)+DX/CND(IX))
A(IX)= -CNL
C
C           ENTER HERE WHEN KD.GT.1 SINCE PRIOR EXPRESSIONS DO NOT CHANGE
C
30 TSFOLD= TSF
ZRF= TGAS*(TGAS*(TGAS+TSF)+TSF*TSF)+TSF*TSF*TSF
ZCF= CNV*((TGAS-TSF)*(TGAS-TSF))**0.166666667
HF= ZCF+SIGMA*EMS(1)*ZRF
DENF= HF*DX1/2./CND(1)
ZF= HF/2./DENF+1.

```

```

B(1)= HCP(1)+ZF+CNG
D(1)= (HCP(1)-ZF-CNG)*T1(1)+ZF*(TGAS+TGOLD)+CNG*T1(2)
IF (NQGEN.GT.0) D(1)= D(1)+DX*TLU(QGEN,NQGEN,T1(1))
ZRU= TAMB*(TAMB*(TAMB+TSU)+TSU*TSU)+TSU*TSU*TSU
ZCU= 1.87*((TAMB-TSU)*(TAMB-TSU))**0.166666667
HU= ZCU+SIGMA*EMS(2)*ZRU
DENU= HU*DX/2./CND(IX)
ZU= HU/2./(DENU+1.)
B(IX)= HCP(IX)+ZU+CNL
D(IX)= (HCP(IX)-ZU-CNL)*T1(IX)+ZU*2.*TAMB+CNL*T1(IX)
IF (NQGEN.GT.0) D(IX)= D(IX)+DX*TLU(QGEN,NQGEN,T1(IX))
CALL TRIDGF (A,B,C,D,T2,IX)
TSF= (DENF*TGAS+T2(1))/(DENF+1.)
TSU= (DENU*TAMB+T2(IX))/(DENU+1.)
KD= KD+1
IF (ABS(TSF-TSFOLD).LT.4) RETURN
IF (KD.LE.6) GO TO 30
WRITE (2,100) TSF,TSFOLD
100 FORMAT ('0    FAIL TO CONVERGE D.E.  TSF=',F7.2,'  TSFOLD=' F7.2)
IF (KD.LE.30) GO TO 30
RETURN
END

```

```

C SUBROUTINE ECHOID
C
C SUBROUTINE TO ECHO INPUT DATA
C
COMMON /CP/      CPA,CPC0(2),CPC02(2),CPH2(2),CPH20(2),CPN2(2),
1   CP02(2),CPPYR(2)
COMMON /FUEL/     C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1   OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/       AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/    FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1   RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1   PLOT,PNCH,RPSPEC,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,N,NFLPC
WRITE (2,90) IRUN
WRITE (2,91) AWALL, AFLOOR, HWDOW, AWDOW, OPENF, CD
WRITE (2,92) FLOAD
IF (PLFUEL) WRITE (2,93) DHP,TBOILC
WRITE (2,94) CFLPC,HFLPC,OFLPC,NFLPC,WFLPC,R,R0
WRITE (2,95) CVGROS,CVNET,MWPYR,CPPYR,BPF,EF
IF (.NOT.(PLFUEL.OR.VTSPEC.OR.RPSPEC)) WRITE (2,96) REGRES,SIZE,
1   SHAPE
IF (PLFUEL.AND..NOT.STOICH) WRITE (2,97) SIZE
IF (.NOT.(PLFUEL.OR.VTSPEC.OR.RPSPEC).AND.SH.GT.0.0) WRITE (2,908)
1   SH
IF (RPSPEC.AND.NRP.EQ.1) WRITE (2,913) RPX(2,1)
IF (RPSPEC.AND.NRP.NE.1) WRITE (2,914) ((RPX(I,J),I=1,2),J=1,NRP)
IF (ADIA) GOTO 200
WRITE (2,98) THICKW,DENSW
IF (NCND.EQ.1) WRITE (2,900) CNDA(2,1)
IF (NCND.GT.1) WRITE (2,901)((CNDA(I,J),I=1,2),J=1,NCND)
IF (NCPW.EQ.1) WRITE (2,904) CPW(2,1)
IF (NCPW.GT.1) WRITE (2,905)((CPW(I,J),I=1,2),J=1,NCPW)
IF (NEMS.EQ.1) WRITE (2,902) EMSA(2,1)
IF (NEMS.NE.1) WRITE (2,903)((EMSA(I,J),I=1,2),J=1,NEMS)
IF (NQGEN.EQ.1) WRITE (2,906) QGEN(2,1)
IF (NQGEN.GT.1) WRITE (2,907)((QGEN(I,J),I=1,2),J=1,NQGEN)
200 IF (ADIA) WRITE(2,909)
RETURN
90 FORMAT (1H+, T86,'COMPF2 VERSION 1.1 - RUN NO.',I4)
91 FORMAT ('0----GEOMETRY AND VENTILATION---'//)
1   ' WALL SURFACE AREA = ',F8.1,' M2'/
2   ' FLOOR AREA = ',F8.2,' M2'/
3   ' WINDOW HEIGHT = ',F8.2,' M'/
4   '          AREA = ',F8.2,' M2'/
5   ' OPENING FACTOR = ',F7.3,' M2.5'/
6   ' DISCHARGE COEFF.= ',F4.2/)
92 FORMAT ('0----FUEL LOAD PROPERTIES---'//)
1   ' FIRE LOAD PER FLOOR AREA = ',F6.1,' KG/M2')
913 FORMAT ('0RATE OF PYROLYSIS =',F7.2,' KG/S')
914 FORMAT ('0RATE OF PYROLYSIS (KG/S)'//      TIME      RP'

```

```

1   50(/3X,F5.0,F9.3))
93 FORMAT (' TOTAL ENTHALPY OF PYROLYSIS= '
1   ' 1PE10.2,' J/KG'/' BOILING TEMPERATURE= ',0PF5.0,' DEG C')
94 FORMAT ('OFUEL COMPOSITION'
1   ' CARBON = ',F4.1,' PERCENT BY WEIGHT'
2   ' HYDROGEN = ',F4.1,' PERCENT'
3   ' OXYGEN = ',F4.1,' PERCENT'
4   ' NITROGEN = ',F4.1,' PERCENT'
5   ' WATER = ',F4.1,' PERCENT'
6   ' R = ',F5.2/
7   ' R0= ',F5.2)
95 FORMAT (' HEAT OF COMBUSTION OF DRY FUEL = ',2PE10.2,' J/KG'
1   ' LOWER ACTUAL HEAT OF COMBUSTION = ',E10.2,' J/KG'
2   ' MOLECULAR WEIGHT OF UNBURNED PYROLYSATES = ',0PF6.2/
3   ' CP OF PYROLYSIS GAS = (',F6.4,'*TGAS + ',F6.0,
4   ') J/KG-K'
5   ' MAXIMUM FRACTION OF PYROLYSATES BURNED = ',F5.2/
6   ' GREY-GAS FLAME EMISSIVITY = ',F5.3)
96 FORMAT (' RATE OF REGRESSION = ',2PE9.2,' M/S'
1   ' FUEL DIMENSION = ',0PF5.3,' M'
2   ' SHAPE FACTOR = ',F4.2 '/')
97 FORMAT (' FUEL AREA=',F10.2,' M2')
908 FORMAT (' CRIB SPACING/HEIGHT RATIO=',F6.3)
98 FORMAT ('0----WALL THERMAL PROPERTIES----'//'
1   ' THICKNESS = ',F5.3,' M'
2   ' DENSITY = ',F6.0,' KG/M3')
909 FORMAT ('0----WALL THERMAL PROPERTIES----'//'
1   ' ADIABATIC WALL'//')
900 FORMAT ('OTHERMAL CONDUCTIVITY = ',F7.3,' W/M-K')
901 FORMAT ('OTHERMAL CONDUCTIVITY ARRAY (W/M-K)'/
1   ' TEMPERATURE CONDUCTIVITY', 10(/3X,F7.1,4X,F10.3))
902 FORMAT ('OEMISSIVITY = ',F4.2)
903 FORMAT ('OEMISSIVITY ARRAY'/' TEMPERATURE EMISSIVITY'
1   10(/3X,F7.1,4X,F10.3))
904 FORMAT ('OHEAT CAPACITY = ',F7.0,' J/KG-K')
905 FORMAT ('OHEAT CAPACITY ARRAY (J/KG-K)'/
1   ' TEMPERATURE HEAT CAPACITY', 10(/3X,F7.1,4X,F10.0))
906 FORMAT ('OWALL HEAT GENERATED = ',F9.3,' W/M3')
907 FORMAT ('OWALL HEAT GENERATED ARRAY (W/M3)'/
1   ' TEMPERATURE QGEN', 10(/3X,F7.1,4X,F10.3))
END

```

SUBROUTINE ICONDS

```

C
C          SET INITIAL CONDITIONS AND CONSTANTS
C

COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH20(2),CPN2(2),
1   CP02(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1   OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPRP,PLFUEL,PLOT,PNCH,
1   RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /QS/      QCONW,QFIRE,QFLOW,QRADO,QRADW,QWLSUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/   BWORST,FLREM,HRATIO,RMA,RFMF,TTIME,VAVGIN,
1   WA,WB,YC02,YH20,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1   PLOT,PNCH,RPSPEC,STEADY,STOICH
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
FC=.FALSE.
KNTRL=1
AWALLN= AWALL-AWDOW
BWDOW= AWDOW/HWDOW
WTFUEL= FLOAD*AFLLOOR
OPENF= AWDOW*SQRT(HWDOW)
MWIN= 28.97
MWOUT= MWIN
TAMB= 298.
TGAS= 1800.
IF (TINPT.GT.0.) TGAS= TINPT
IXL= IX-1
IXC= IX/2
TSF= TAMB
TSU= TAMB
DENF= 0.
DENU= 0.
WA= 6H
WB= 5H
IF (.NOT.FLSPEC) GO TO 10
WA= 6HWINDOW
WB= 5HWIDTH
10 JP= 0
IF (.NOT.STEADY) JPRINT= PRNT/DTIME + (1.0-1.E-6)
IF (STEADY) GOTO 20
IF (DTIME.GT.0.00001) GOTO 15
WRITE (2,95)
KNTRL= 2
RETURN
95 FORMAT (///' FOR NON-STEADY PROBLEMS MUST SPECIFY DTIME ',
1   'GREATER THAN ZERO')
15 IF (MTIME.GT.DTIME) GOTO 20

```

```

      WRITE (2,92)
92 FORMAT ('//'* FOR NON-STEADY PROBLEMS MUST SPECIFY MTIME *,
1   "GREATER THAN DTIME")
  KNTRL= 2
  RETURN
20 CONTINUE
  IF (.NOT. STEADY) JM= MTIME/DTIME +2
  IF (STEADY) JM= 2
  DX= THICKW/IX
  FLREM= WTFUEL
  TTIME= 0.
  EMS(1)= 1./(1./TLU(EMSA,NEMS,TAMB) +1./EF -1.)
  QWLSUM= 0.
  DO 60 I=1,IX
60  T2(I)= TAMB
  J= 0
  CALL RSTA
  TOTAL= CFLPC+HFLPC+OFLPC+NFLPC+WFLPC
  IF (TOTAL.LT.101.1.AND.TOTAL.GT.98.9) GOTO 70
C     CHECK FOR ERRORS IN FUEL COMPOSITION
  KNTRL= 2
  WRITE (2,90)
90 FORMAT ('//'* SUM OF FUEL COMPOSITION INPUT IS INCORRECT')
  RETURN
70 C= CFLPC*(10./12.)
  H= HFLPC*10.
  O= OFLPC*(10./16.)
  W= WFLPC*(10./18.)
  N= NFLPC*(10./14.)
  R0= (C+H+O+W+N)*32./1000.
  R= R0/0.232
  CVNET= CVGROS*(1.-WFLPC/100.)-(WFLPC+9.0*HFLPC)/100.*2440.E+3
C     LATENT HEAT OF H2O EVAPORATION= 2440E+3 J/KG AT 25 C
  RMA= 0.16*AWDOW*Densa*SQRT(G*HWDDOW)
  RMF= RMA
  RC= BPF*RMA/R
  Y02= 0.10
  IF (STOICH) EITA= 1.
  IF (EISCAN) SIZE= SIZE1/EITA
  RETURN
END

```

SUBROUTINE INC

C
C
C
ROUTINE TO INPUT ALL CONSTANTS NOT GIVEN IN NAMELIST -VARS-

COMMON /THERML/ CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1 NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
NQGEN= 0
READ (1,91) NCN,NCP,NEM,NR,NQG
IF (NCN.EQ.0) GO TO 10
NCND= NCN
READ (1,90) (CNDA(1,I),CNDA(2,I),I=1,NCND)
10 IF (NCP.EQ.0) GO TO 20
NCPW= NCP
READ (1,90) (CPW(1,I),CPW(2,I),I=1,NCPW)
20 IF (NEM.EQ.0) GO TO 30
NEMS= NEM
READ (1,90) (EMSA(1,I),EMSA(2,I),I=1,NEMS)
30 IF (NR.EQ.0) GO TO 40
NRP= NR
READ (1,90) (RPX(1,I),RPX(2,I),I=1,NRP)
NQGEN= NQG
40 IF (NQG.EQ.0) GO TO 50
READ (1,90) (QGEN(1,I),QGEN(2,I),I=1,NQGEN)
50 RETURN
90 FORMAT (8F10.0)
91 FORMAT (10I3)
END

```

SUBROUTINE OUTPUT
C
C      PRINTS OUTPUT DATA
C
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1  OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/       AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1  J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1  RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1  PRNT,STEADY,THICKW
COMMON /QS/       QCONW,QFIRE,QFLOW,QRADO,QRADW,QWL SUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /WOUT/    BWORST,FLREM,HRATIO,RMA,RFMF,TTIME,VAVGIN,
1  WA,WB,YCO2,YH20,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1  PLOT,PNCH,RPSPEC,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,N,NFLPC
LOGICAL DATPRT
DIMENSION T2C(3)
DATA DATPRT /.FALSE./
IF (KITER.EQ.1) RETURN
IF (PLOT.OR.PNCH) CALL DSTO      (TTIME,TGAS)
IF (ILINE.LE.47) GO TO 50
DATPRT=.TRUE.
GO TO 300
50 TGASC= TGAS-273.
T2C(1)= TSF-273.
T2C(2)= T2(IXC)-273.
T2C(3)= TSU-273.
FUELPC= FLREM/WTFUEL*100.
QNORM= QFIRE/100.
IF (QCONW.LT.0) QNORM= (QFLOW+QRADO)/100.
ZFLOW= QFLOW/QNORM
ZRADO= QRADO/QNORM
ZCONW= QCONW/QNORM
ZRADW= QRADW/QNORM
EXCESS= RP-RC
ILINE = ILINE+1
WRITE (2,90) J,TTIME,TGASC,T2C,RP,RC,EXCESS,FUELPC,RMA,HRATIO,
1  VAVGIN,MWOUT,FC
IF (FLSPEC) WRITE (2,91) BWORST
WRITE (3,92) TTIME,ZFLOW,ZRADO,ZCONW,ZRADW,QFIRE,QWL SUM,
1  YO2,YN2,YCO2,YH20,YPYR
IF (STOICH) WRITE (2,901) SIZE1
RETURN
C
C      ENTRY HEADNG
C      START NEW PAGE
IF (KITER.EQ.1) RETURN
IPG = 1
300 CONTINUE
ILINE = 0
IF (.NOT.RPSPEC) GOTO 315
WRITE (2,94) IPG,IRUN

```

```

      WRITE (3,94) IPG,IRUN
      GO TO 400
315 IF (.NOT.FLSPEC) GOTO 325
      IF (.NOT.PLFUEL) WRITE (2,95) IPG,IRUN
      IF (.NOT.PLFUEL) WRITE (3,95) IPG,IRUN
      IF (PLFUEL) WRITE (2,905) IPG,IRUN
      IF (PLFUEL) WRITE (3,905) IPG,IRUN
      GO TO 400
325 IF (.NOT.VTSPEC) GOTO 335
      WRITE (2,96) IPG,IRUN
      WRITE (3,96) IPG,IRUN
      GO TO 400
335 IF (.NOT.PLFUEL) GO TO 345
      WRITE (2,97) IPG,IRUN
      WRITE (3,97) IPG,IRUN
      GO TO 400
345 WRITE (2,98) IPG,IRUN
      WRITE (3,98) IPG,IRUN
400 IPG = IPG+1
      WRITE (2,99) WA,WB
      WRITE (3,900)
      IF (.NOT.DATPRT) RETURN
      DATPRT=.FALSE.
      GO TO 50
90 FORMAT (1H ,I4,T6,F8.0,T15,F7.0,T25,3F6.0,T44,F6.3,T51,F6.3,
1   T60,F6.3,T69,F5.1,T79,F4.2,T87,F7.2,T96,F9.2,T109,F6.2,5X,L1)
91 FORMAT (1H+, T124, F6.2)
92 FORMAT (1H ,F7.0,4F11.3,1PE15.3,E15.3,1X,0P(5F8.3))
94 FORMAT (1H1,T14,' INPUTTED VALUES OF RP ARE USED'
1   T100,'PAGE NO.',I3,T115,'RUN NO.',I4//)
95 FORMAT (1H1,T14, ' FUEL PYROLYSIS (CRIB) SPECIFIED, VENTILATION '
1   ' ADJUSTED FOR WORST CONDITIONS', T100,'PAGE NO.',I3,T115,
2   'RUN NO.',I4//)
96 FORMAT (1H1,T14,' VENTILATION SPECIFIED, FUEL PYROLYSIS ADJUSTED'
1   ' FOR WORST CONDITIONS',T100,'PAGE NO.',I3,T115,'RUN NO.',I4/
2   /)
97 FORMAT (1H1,T14,' THERMOPLASTIC POOL FIRE',T100,'PAGE NO.'
1   I3,T115,'RUN NO.', I4//)
98 FORMAT (1H1,T14,'CRIB FIRE',T100,'PAGE NO.',I3,
1   T115,'RUN NO.',I4/)
99 FORMAT (1H0,T10,'TIME',T17,'TEMP',T30,'WALL TEMPS',T47,'RP',
1   T54,'RC',T59,'EXC.PYR.',T70,'FUEL',T78,'AIR IN',T90,'N.P.',
2   T98,'VELOCITY',T109,'MOL.WT',T118,'FUEL',T124,A6/
3   T11,'$',T17,'GAS,C',T34,'C',T46,'KG/S',T53,'KG/S',T61,
4   'KG/S',T71,'PCT',T79,'KG/S',T101,'M/S',T108,
5   T118,'CNTRL',T124,A5/)
900 FORMAT (T5,'TIME',T24,'HEAT BALANCE',T75,'Q=WALL',T88,'Y02',T96,
2   'YN2',T104,'YCO2',T112,'YH2O',T120,'YPYR'/
2   T13,'GAS FLOW',T25,'WND RAD',T36,'WALL CNV',T47,'WALL RAD',
3   T60,'Q=FIREF',T76,'SUM',T88,'PCT',T96,'PCT',T104,'PCT',T112,
4   'PCT',T120,'PCT'/
5   T16,'PCT',T27,'PCT',T39,'PCT',T49,'PCT',T62,'W',T77,
6   'J',T88,'MASS',T96,'MASS',T104,'MASS',T112,'MASS',
7   T120,'MASS'//)
901 FORMAT (//' STOICHIOMETRIC FUEL SIZE= ',F8.3,' M2')
905 FORMAT (1H1,T14, ' FUEL PYROLYSIS (POOL) SPECIFIED, VENTILATION'
1   ' ADJUSTED FOR WORST CONDITIONS', T100,'PAGE NO.',I3,T115,
2   'RUN NO.',I4//)
END

```

SUBROUTINE PFLFIX

```

C
C
C      PESSIMIZATION ROUTINE
C      FIXED FUEL PYROLYSIS, WINDOW WIDTH VARIED FOR WORST
C      BURNING CONDITIONS.
C      EITHER CRIB OR POOL FUELS ACCEPTED
C      FOR POOL FUELS, MUST ALSO SET PLFUEL=.TRUE.
C

COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH2O(2),CPN2(2),
1   CP02(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1   OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1   RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /QS/      QCONW,QFIRE,QFLOW,QRADO,QRADW,QWLSUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/    BWORST,FLREM,HRATIO,RMA,RMF,TTIME,VAVGIN,
1   WA,WB,YC02,YH20,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1   PLOT,PNCH,RPSPEC,SCAN,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
IF (STEADY) GOTO 190
FC=.FALSE.
SCAN=.FALSE.
QRADW=0.
QCONW=0.
F2=0.
F1=0.
DTGAS=10.
TBOIL=TBOILC+273.
CALL HEADING
C          START TIME LOOP
DO 170 J=1,JM
KH=0
DERIV1=1.
TGAS2=0.
TGAS1=0.
TGASP=2000.
TGASN=TAMB
20 CONTINUE
K=0
30 CONTINUE
KR=0
RMA=0.666667*CD*0.5*AWDOW*DENSA*SQRT(G*HWDOW*(1.-TAMB/TGAS))
IF (FLREM) 220,220,35
C          AS SOON AS FUEL IS EXHAUSTED PROGRAM MUST STOP,
C          SINCE WINDOW SIZE WOULD NOT BE WELL DEFINED.
35 IF (.NOT.PLFUEL) GOTO 40

```

```

RP= SIZE*EF*SIGMA*(TGAS**4.-TBOIL**4.)/DHP
PLUME= SIZE*0.0014*CVNET/DHP
PROP= 1.-(TGAS**4.-TBOIL**4.)/(1700.***4.-TBOIL**4.)
IF (PROP.LT.0.) PROP= 0.
RP= RP+PROP*PLUME
GO TO 50
40 IF (REGRES.LE.0.0) GOTO 45
C      USE THIS FORMULA IF INPUT REGRES IS SPECIFIED
RP= REGRES*2.*SHAPE/SIZE*FLREM**(.1.-1./SHAPE)*WTFUEL**(.1./SHAPE)
GO TO 50
45 CONTINUE
C      FUEL SURFACE CONTROL
C      ASSUME CRIB STICK DENSITY RHOCR= 500 KG/M**3
RHOCR= 500.
REGREN= 1.24E-3/RHOCR*SIZE**=-0.6
RP1= REGREN*2.*SHAPE/SIZE*FLREM**(.1.-1./SHAPE)*WTFUEL**(.1./SHAPE)
C      CRIB POROSITY CONTROL
RP2= 0.22*WTFUEL/(RHOCR*SIZE)*SH
RP= AMIN1 (RP1,RP2)
50 RMF= RMA+ RP
YCO2= 3.66667*CFLPC*RC/100./RMF
YH2O= (WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2= (0.23*RMA-R0*RC)/RMF
YN2= 0.77*RMA/RMF +NFLPC*RP/100./RMF
YPYR= (RP-RC)/RMF
IF (YPYR.LT..0) YPYR= 0.
MWOUT= 44.*YCO2+18.*YH2O+28.*YN2+32.*YO2+MWPYR*YPYR
HRATIO= 1./(1.+((TGAS/TAMB)*(MWIN/MWOUT)*(1.+RP/RMA)**2))
1   **0.3333333333
C      NOTE HIN IS TAKEN AS POSITIVE
HIN= HWDDOW* HRATIO
ZW=1.-MWOUT*TAMB/MWIN/TGAS
IF (ZW)195,55,55
55 VAVGIN= 0.666667*SQRT(2.*G*HIN*ZW)
RMA= CD*VAVGIN*HIN*BWDDOW*Densa
IF (RP=RMA/R) 60,60,65
60 RC= RP*BPF
BWORST= BWDDOW*RC*R/RMA
RMA= RC*R/BPF
GO TO 70
65 RC= BPF*RMA/R
BWORST= BWDDOW
C      RECALCULATE Y- VALUES SINCE RP,RC HAVE BEEN CHANGED
70 KR= KR+1
IF (KR-3) 50,75,75
75 CONTINUE
QFLOW= RMF*(YCO2*(TGAS*(0.5*CPCO2(1)*TGAS+CPCO2(2))-TAMB*(0.5*
1 CPCO2(1)*TAMB+CPCO2(2)))+YH2O*(TGAS*(0.5*CPH20(1)*TGAS+
2 CPH20(2))-TAMB*(0.5*CPH20(1)*TAMB+CPH20(2)))+YO2*(TGAS*(
3 0.5*CPO2(1)*TGAS+CPO2(2))-TAMB*(0.5*CPO2(1)*TAMB+CPO2(2)))
4 +YN2*(TGAS*(0.5*CPN2(1)*TGAS+CPN2(2))-TAMB*(0.5*CPN2(1)*
5 TAMB+CPN2(2)))+YPYR*(TGAS*(0.5*CPPYR(1)*TGAS+CPPYR(2))
6 -TAMB*(0.5*CPPYR(1)*TAMB+CPPYR(2))))
QFIRE= RC*CVNET
IF (ADIA) GOTO 90
CALL DESOLV
QRADW= AWALLN*EMS(1)*SIGMA*(TGAS**4.-TSF**4.)
QCONW= AWALLN*(TGAS-TSF)*CNV*((TGAS-TSF)*(TGAS-TSF))**0.1666667

```

```

90 CONTINUE
QRADO= HWDOW*BWORST*SIGMA*(TGAS**4.-TAMB**4.)
K= K+1
F3=F2
F2=F1
F1= QFIRE-QFLOW-QRADO-QRADW-QCONW
TGAS3=TGAS2
TGAS2=TGAS1
TGAS1=TGAS
IF (F1.LT.0..AND.TGAS.LT.TGASP) TGASP=TGAS
IF (F1.GT.0..AND.TGAS.GT.TGASN) TGASN=TGAS
DERIV2= DERIV1
IF (TGAS1.EQ.TGAS2) GOTO 130
DERIV1=(F1-F2)/(TGAS1-TGAS2)
IF (KTRACE.GT.0) WRITE (4,99) TGAS1,TGAS2,F1,F2,DERIV1,K,KD,
1 KH,J,T2(1),TSF,QFIRE,QFLOW,QRADW,RP,RC
99 FORMAT(2F9.2,3(1PE9.2),3I3,I5,2(0PF9.2),3(1PE10.3),2(0PF7.3))
IF (.NOT.SCAN) GOTO 95
IF (F1/F2.GE.0.0) GOTO 93
SCAN= .FALSE.
GOTO 100
93 TGAS= TGAS-DTGAS
IF ((PLFUEL.AND.(TGAS.LT.TBOIL)).OR.(TGAS.LT.TAMB)) GOTO 200
GOTO 120
95 IF (DERIV2.LT..0.AND.ABS(F2).GT..0001) GOTO 100
IF(DERIV2.LT..0.AND.J.GT.2) GOTO 100
TGAS= TGAS1+DTGAS
GOTO 120
100 DIF= ABS(F1/QFLOW)
IF (DIF.LT.0.002.AND.ABS(TGAS2-TGAS1).LT.2.) GOTO 130
TGAS=(F1*TGAS2-F2*TGAS1)/(F1-F2)
IF (K.GT.10.AND.F1.LT.0..AND.TGAS.GT.TGASP) GOTO 105
IF (K.GT.10.AND.F1.GT.0..AND.TGAS.LT.TGASN) GOTO 105
IF (TGAS.GT.TGASP.OR.TGAS.LT.TGASN) TGAS=(TGASP+TGASN)/2.
IF (K.EQ.1.AND.KH.EQ.0) TGAS= TGAS1+10.
IF (TGAS.GT.2000.) GOTO 110
IF (TGAS.LT.(TAMB+30.)) GOTO 110
IF (PLFUEL.AND.TGAS.LT.TBOIL) GOTO 110
GOTO 120
105 TGAS= (TGASN+TGASP)/2.
GOTO 120
110 SCAN= .TRUE.
TGAS= 1900.
120 CONTINUE
IF (K=200) 30,30,200
130 CONTINUE
CALL RSTA
FLREM= FLREM-RP*DTIME
IF(FLREM.LT.0) FLREM=0.
IF (QCONW.GT.0.) QWLSUM= QWLSUM+(QRADW+QCONW)*DTIME
IF (TTIME .GE. MTIME) GO TO 210
IF (TGAS.LE.353..AND.J.GE.10) GO TO 210
IF (J.EQ.1) GO TO 150
IF (JP.LT.JPRINT) GO TO 160
JP= 0
150 CALL OUTPUT
160 JP= JP+1
TTIME= TTIME+DTIME

```

```
170 CONTINUE
C           END TIME STEP DO-LOOP
      RETURN
C           ERROR IN INPUT
190 CONTINUE
      KTRL= 2
      WRITE (2,910)
910 FORMAT (///' PFLFIX ROUTINE DOES NOT ACCEPT STEADY-STATE CASE')
195 CONTINUE
      IF(KTRACE.EQ.1) WRITE(2,930) TGAS,RC,RP,YPYR,ZW,RMA,MWOUT
930 FORMAT (/'
      TGAS=',F5.0,' RC=',E10.4,' RP=',E10.4,
      1  ' YPYR=',E10.4,' ZW=',F6.4,' RMA=',E10.4,' MWOUT=',F6.1)
C           FAIL TO CONVERGE, ERROR EXIT
200 CONTINUE
      KTRL=3
      RETURN
C           FIRE IS OVER (TRANSIENT CASE)
210 CONTINUE
      CALL OUTPUT
220 CONTINUE
      RETURN
      END
```

SUBROUTINE POOL

```

C
C          PLASTIC FUEL (POOL FIRE) ROUTINE
C          FUEL 'SEES' ONLY COMPARTMENT AND NOT ITSELF
C
COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH2O(2),CPN2(2),
1   CPO2(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1   OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1   RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /QS/       QCONW,QFIRE,QFLOW,QRADO,QRADW,QWLSUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CND(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/    BWORST,FLREM,HRATIO,RMA,RMF,TTIME,VAVGIN,
1   WA,WB,YCO2,YH2O,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1   PLOT,PNCH,RPSPEC,SCAN,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
C           Y= DENOTE MASS FRACTIONS OF OUTFLOW
C           RMA= MASS INFLOW RATE
C           RMF= MASS OUTFLOW RATE
C           R= STOICHIOMETRIC AIR/FUEL MASS RATIO
C           R0= STOICHIOMETRIC OXYGEN/FUEL RATIO
SCAN=.FALSE.
C           INITIALIZES STOICHIOMETRIC CASE
IF (STOICH) EITA =1.
QRADW=0.
QCONW= 0.
F2=0.
F1=0.
DTGAS=10.
TBOIL=TBOILC+273.
FC=.FALSE.
CALL HEADNG
TF2= TGAS
C           START TIME STEP
DO 170 J=1,JM
KH= 0
DERIV1= 1.
TGAS2= 0.
TGAS1= 0.
TGASP= 2000.
TGASN= TAMB
20 CONTINUE
K= 0
30 CONTINUE
IF (STOICH) GOTO 34
32 RP= SIZE*EF*SIGMA*(TGAS**4.-TBOIL**4.)/DHP
IF (STEADY) GOTO 33

```

```

PLUME= SIZE*0.0014*CVNET/DHP
PROP= 1.-(TGAS**4.-TBOIL**4.)/(1700.***4.-TBOIL**4.)
IF (PROP.LT.0.) PROP= 0.
RP= RP+PROP*PLUME
33 CONTINUE
RMF= RMA+RP
IF (FLREM.LE.0) RP=0.
34 YC02= 3.66667*CFLPC*RC/100./RMF
YH20= (WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2= (0.23*RMA-R0*RC)/RMF
YN2= 0.77*RMA/RMF +NFLPC*RP/100./RMF
YPYR= (RP-RC)/RMF
IF (YPYR.LT..0) YPYR= 0.
QFUEL= (RP-RC)*DHP
MWOUT= 44.*YC02+18.*YH20+28.*YN2+32.*YO2+MWPYR*YPYR
HRATIO= 1./(1.+((TGAS/TAMB)*(MWIN/MWOUT)*(1.+RP/RMA)**2))
1   **0.3333333333
C     NOTE HIN IS TAKEN AS POSITIVE
HIN= HWDDOW* HRATIO
ZW=1. - MWOUT*TAMB/MWIN/TGAS
IF (ZW)195,35,35
35 VAVGIN= 0.66667*SQRT(2.*G*HIN*ZW)
RMA= CD*VAVGIN*HIN*BWDOW*Densa
RMF= RMA+RP
RC= BPF*RMA/R
IF (STOICH) RP= RC/BPF
IF ((EISCAN.AND.EITA.LT.1.).OR.STOICH) GOTO 37
36 IF (RC.GT.RP*BPF) GOTO 40
37 FC= .FALSE.
GO TO 45
40 FC= .TRUE.
RC= RP*BPF
C     RECALCULATE VALUES IF IN FUEL CONTROL REGIME.
YC02= 3.66667*CFLPC*RC/100./RMF
YH20= (WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2= (0.23*RMA-R0*RC)/RMF
YN2= 0.77*RMA/RMF +NFLPC*RP/100./RMF
YPYR= (RP-RC)/RMF
45 CONTINUE
QFLOW= RMF*(YC02*(TGAS*(0.5*CPC02(1)*TGAS+CPC02(2))-TAMB*(0.5*
1   CPC02(1)*TAMB+CPC02(2)))+YH20*(TGAS*(0.5*CPH20(1)*TGAS+
2   CPH20(2))-TAMB*(0.5*CPH20(1)*TAMB+CPH20(2)))+YO2*(TGAS*(
3   0.5*CPO2(1)*TGAS+CPO2(2))-TAMB*(0.5*CPO2(1)*TAMB+CPO2(2)))
4   +YN2*(TGAS*(0.5*CPN2(1)*TGAS+CPN2(2))-TAMB*(0.5*CPN2(1)*
5   TAMB+CPN2(2)))+YPYR*(TGAS*(0.5*CPPYR(1)*TGAS+CPPYR(2))
6   -TAMB*(0.5*CPPYR(1)*TAMB+CPPYR(2)))))
QFIRE= RC*CVNET
IF (ADIA) GOTO 90
IF (.NOT.STEADY) CALL DESOLV
IF (STEADY) CALL STFLOW
QRADW= AWALLN*EMS(1)*SIGMA*(TGAS**4.-TSF**4.)
QCONW= AWALLN*(TGAS-TSF)*CNV*((TGAS-TSF)*(TGAS-TSF))**0.1666667
90 CONTINUE
QRADO= AWDOW*SIGMA*(TGAS**4.-TAMB**4.)
K= K+1
F3=F2
F2=F1
F1= QFIRE-QFLOW-QFUEL-QRADO-QRADW-QCONW

```

```

TGAS3=TGAS2
TGAS2=TGAS1
TGAS1=TGAS
IF (F1.LT.0..AND.TGAS.LT.TGASP) TGASP=TGAS
IF (F1.GT.0..AND.TGAS.GT.TGASN) TGASN=TGAS
DERIV2= DERIV1
IF (TGAS1.EQ.TGAS2) GOTO 130
DERIV1=(F1-F2)/(TGAS1-TGAS2)
IF (KTRACE.GT.0) WRITE (4,99) TGAS1,TGAS2,F1,F2,DERIV1,K,KD,
1   KH,J,T2(1),TSF,QFIRE,QFLOW,QRADW,RP,RC
99 FORMAT(2F9.2,3(1PE9.2),3I3,I5,2(0PF9.2),3(1PE10.3),2(0PF7.3))
IF (.NOT.SCAN) GOTO 95
IF (F1/F2.GE.0.0) GOTO 93
SCAN= .FALSE.
GOTO 100
93 TGAS= TGAS-DTGAS
IF (TGAS.LT.TAMB) GOTO 200
IF (TGAS.LT.TBOIL.AND.(FLREM.GT.0.0)) GOTO 190
GOTO 120
95 IF (DERIV1.LT..0.AND.ABS(F2).GT..0001)GOTO 100
IF(DERIV2.LT..0.AND.J.GT.2) GOTO 100
TGAS= TGAS1+DTGAS
GOTO 120
100 DIF= ABS(F1/QFLOW)
IF (DIF.LT.0.002.AND.ABS(TGAS2-TGAS1).LT.2.) GOTO 130
TGAS=(F1*TGAS2-F2*TGAS1)/(F1-F2)
IF (K.GT.10.AND.F1.LT.0..AND.TGAS.GT.TGASP) GOTO 105
IF (K.GT.10.AND.F1.GT.0..AND.TGAS.LT.TGASN) GOTO 105
IF (K.EQ.1.AND.KH.EQ.0) TGAS= TGAS1+10.
IF (TGAS.GT.2000.) GOTO 110
IF (TGAS.LT.(TAMB+30.)) GOTO 110
IF (TGAS.LT.TBOIL.AND.(FLREM.GT.0.0)) GOTO 110
GOTO 120
105 TGAS= (TGASN+TGASP)/2.
GOTO 120
110 SCAN= .TRUE.
TGAS= 1900.
120 CONTINUE
IF (STEADY.AND..NOT.ADIA) CALL STFLOW
IF (K=200) 30,30,200
130 IF (STEADY) GOTO 180
CALL RSTA
FLREM= FLREM-RP*DTIME
IF(FLREM.LT.0) FLREM=0.
IF (QCONW.GT.0.) QWLSUM= QWLSUM+(QRADW+QCONW)*DTIME
IF (TTIME .GE. MTIME) GO TO 210
IF (TGAS.LE.353..AND.J.GE.10) GO TO 210
IF (J.EQ.1) GO TO 150
IF (JP.LT.JPRINT) GO TO 160
JP= 0
150 CALL OUTPUT
160 JP= JP+1
TTIME= TTIME+DTIME
170 CONTINUE
C      END TIME STEP DO-LOOP
180 CONTINUE
IF(.NOT.STOICH) GOTO 185
C      FIND STOICHIOMETRIC FUEL SIZE

```

```

      SIZE1= RP/(EF*SIGMA*(TGAS**4.-TBOIL**4.)/DHP)
185 CALL OUTPUT
C      NORMAL EXIT WHEN STEADY.EQ.T
      RETURN
C      ERROR EXIT
190 CONTINUE
      IF (KTRACE.EQ.1) WRITE (2,910) TGAS.
910 FORMAT(///' TGAS.LT.TBOIL   TGAS=' ,F8.1,'   GO TO NEXT CASE'///)
      GOTO 200
C      SQUARE ROOT ERROR
195 CONTINUE
      IF(KTRACE.EQ.1) WRITE(2,930) TGAS,RC,RP,YPYR,ZW,RMA,MWOUT
930 FORMAT (/'' TGAS=' ,F5.0,' RC=' ,E10.4,' RP=' ,E10.4,
1   ' YPYR=' ,E10.4,' ZW=' ,F6.4,' RMA=' ,E10.4,' MWOUT=' ,F6.1)
C      FAIL TO CONVERGE, ERROR EXIT
200 CONTINUE
      KNTRL=3
      RETURN
C      FIRE IS OVER (TRANSIENT CASE)
210 CONTINUE
      CALL OUTPUT
      RETURN
      END

```

```
SUBROUTINE PP
C
C      PLOTTING SUBROUTINE
C      THIS ROUTINE IS LEFT BLANK SINCE IT IS MACHINE-DEPENDENT
C
C      ENTRY PLTRST
C          THIS ENTRY SETS UP THE INITIALIZATION OF PLOTTING
C      ENTRY DSTO
C          THIS ENTRY IS CALLED EACH TIME TO STORE A DATA POINT
C      ENTRY DOUT
C          THIS IS THE LAST ENTRY FOR A GIVEN RUN
C      RETURN
C      END
```

```

SUBROUTINE PVTFIX
C
C      PESSIONIZATION ROUTINE
C      FIXED VENTILATION, WORST POSSIBLE FUEL PYROLYSIS RATE.
C
COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH2O(2),CPN2(2),
1    CP02(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1    OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1    J,JM,JP,JPRINT,K,KD,KH,KITER,KTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPRP,PLFUEL,PLOT,PNCH,
1    RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1    PRNT,STEADY,THICKW
COMMON /QS/       QCONW,QFIRE,QFLOW,QRADO,QRADW,QWLSSUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CNDA(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1    NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/    BWORST,FLREM,HRATIO,RMA,RMF,TTIME,VAVGIN,
1    WA,WB,YCO2,YH2O,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPRP,PLFUEL,
1    PLOT,PNCH,RPSPEC,SCAN,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
IF (STEADY) GOTO 190
FC=.FALSE.
SCAN=.FALSE.
QRADW=0.
QCONW=0.
F2=0.
F1=0.
DTGAS=10.
CALL HEADNG
C      START TIME LOOP
DO 170 J=1,JM
KH=0
DERIV1=1.
TGAS2=0.
TGAS1=0.
TGASP=2000.
TGASN=TAMB
20 CONTINUE
K=0
30 CONTINUE
IF (FLREM.GT.0.) GOTO 32
RC=0.
RP=0.
FC=.TRUE.
32 RMF=RMA+RP
YCO2=3.66667*CFLPC*RC/100./RMF
YH2O=(WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2=(0.23*RMA-R0*RC)/RMF
YN2=0.77*RMA/RMF+NFLPC*RP/100./RMF
YPYR=(RP-RC)/RMF
IF(YPYR.LT..0) YPYR=0.

```

```

MWOUT= 44.*YCO2+18.*YH20+28.*YN2+32.*YO2+MWPYR*YPYR
HRATIO= 1./(1.+((TGAS/TAMB)*(MWIN/MWOUT)*(1.+RP/RMA)**2)
1   **0.3333333333)
C      NOTE HIN IS TAKEN AS POSITIVE
HIN= HWDOW* HRATIO
ZW=1.-MWOUT*TAMB/MWIN/TGAS
IF(ZW)195,35,35
35 VAVGIN= 0.666667*SQRT(2.*G*HIN*ZW)
RMA= CD*VAVGIN*HIN*BWDOW*DENS A
RMF= RMA+RP
IF (.NOT.FC) RC= BPF*RMA/R
IF (.NOT.FC) RP= RC/BPF
45 CONTINUE
QFLOW= RMF*(YCO2*(TGAS*(0.5*CPCO2(1)*TGAS+CPCO2(2))-TAMB*(0.5*
1   CPCO2(1)*TAMB+CPCO2(2)))+YH20*(TGAS*(0.5*CPH20(1)*TGAS+
2   CPH20(2))-TAMB*(0.5*CPH20(1)*TAMB+CPH20(2)))+YO2*(TGAS*(
3   0.5*CP02(1)*TGAS+CP02(2))-TAMB*(0.5*CP02(1)*TAMB+CP02(2))*
4   +YN2*(TGAS*(0.5*CPN2(1)*TGAS+CPN2(2))-TAMB*(0.5*CPN2(1)*
5   TAMB+CPN2(2)))+YPYR*(TGAS*(0.5*CPPYR(1)*TGAS+CPPYR(2))-
6   -TAMB*(0.5*CPPYR(1)*TAMB+CPPYR(2))))*
QFIRE= RC*CVNET
IF (ADIA) GOTO 90
CALL DESOLV
QRADW= AWALLN*EMS(1)*SIGMA*(TGAS**4.-TSF**4.)
QCONW= AWALLN*(TGAS-TSF)*CNV*((TGAS-TSF)*(TGAS-TSF))**0.16666667
90 CONTINUE
QRADO= AWDOW*SIGMA*(TGAS**4.-TAMB**4.)
K= K+1
F3=F2
F2=F1
F1= QFIRE-QFLOW-QRADO-QRADW-QCONW
TGAS3=TGAS2
TGAS2=TGAS1
TGAS1=TGAS
IF (F1.LT.0..AND.TGAS.LT.TGASP) TGASP=TGAS
IF (F1.GT.0..AND.TGAS.GT.TGASN) TGASN=TGAS
DERIV2= DERIV1
IF (TGAS1.EQ.TGAS2) GOTO 130
DERIV1=(F1-F2)/(TGAS1-TGAS2)
IF (KTRACE.GT.0) WRITE (4,99) TGAS1,TGAS2,F1,F2,DERIV1,K,KD,
1   KH,J,T2(1),TSF,QFIRE,QFLOW,QRADW,RP,RC
99 FORMAT(2F9.2,3(1PE9.2),3I3,I5,2(0PF9.2),3(1PE10.3),2(0PF7.3))
IF (.NOT.SCAN) GOTO 95
IF (F1/F2.GE.0.0) GOTO 93
SCAN=.FALSE.
GOTO 100
93 TGAS= TGAS-DTGAS
IF (TGAS.LT.TAMB) GOTO 200
GOTO 120
95 IF (DERIV1.LT..0..AND.ABS(F2).GT..0001) GOTO 100
IF(DERIV2.LT..0..AND.J.GT.2) GOTO 100
TGAS= TGAS1+DTGAS
GOTO 120
100 DIF= ABS(F1/QFLOW)
IF (DIF.LT.0.002.AND.ABS(TGAS2-TGAS1).LT.2.) GOTO 130
TGAS=(F1*TGAS2-F2*TGAS1)/(F1-F2)
IF (K.GT.10.AND.F1.LT.0..AND.TGAS.GT.TGASP) GOTO 105
IF (K.GT.10.AND.F1.GT.0..AND.TGAS.LT.TGASN) GOTO 105

```

```

IF (K.EQ.1.AND.KH.EQ.0) TGAS= TGAS1 +10.
IF (TGAS.GT.2000.) GOTO 110
IF (TGAS.LT.(TAMB+30.)) GOTO 110
GOTO 120
105 TGAS= (TGASN+TGASP)/2.
GOTO 120
110 SCAN= .TRUE.
TGAS= 1900.
120 CONTINUE
IF (K=200) 30,30,200
130 CONTINUE
CALL RSTA
FLREM= FLREM-RP*DTIME
IF(FLREM.LT.0) FLREM=0.
IF (QCONW.GT.0.) QWLSUM= QWLSUM+(QRADW+QCENW)*DTIME
IF (TTIME .GE. MTIME) GO TO 210
IF (TGAS.LE.353..AND.J.GE.10) GO TO 210
IF (J.EQ.1) GO TO 150
IF (JP.LT.JPRINT) GO TO 160
JP= 0
150 CALL OUTPUT
160 JP= JP+1
TTIME= TTIME+DTIME
170 CONTINUE
C      END TIME STEP DO-LOOP
RETURN
C      ERROR IN INPUT
190 CONTINUE
KNTRL= 2
WRITE (2,910)
910 FORMAT (///' PVTFIX ROUTINE DOES NOT ACCEPT STEADY-STATE CASE')
RETURN
C      SQUARE ROOT ERROR
195 CONTINUE
IF(KTRACE.EQ.1) WRITE(2,930) TGAS,RC,RP,YPYR,ZW,RMA,MWOUT
930 FORMAT (/'
TGAS=',F5.0,' RC=',E10.4,' RP=',E10.4,
1   ' YPYR=',E10.4,' ZW=',F6.4,' RMA=',E10.4,' MWOUT=',F6.1)
C      FAIL TO CONVERGE, ERROR EXIT
200 CONTINUE
KNTRL=3
RETURN
C      FIRE IS OVER (TRANSIENT CASE)
210 CONTINUE
CALL OUTPUT
RETURN
END

```

```

SUBROUTINE RPFI X
C
C
C          TABULAR FUEL PYROLYSIS ROUTINE
C          FUEL PYROLYSIS RATE IS AN INPUT VARIABLE.
C
COMMON /CNSTS/  AWALLN,BWDOW,DENSA,G,GASCNT,KTRACE,MTIME
COMMON /CP/      CPA,CPCO(2),CPCO2(2),CPH2(2),CPH2O(2),CPN2(2),
1    CPO2(2),CPPYR(2)
COMMON /FUEL/    C,CFLPC,CVGROS,CVNET,H,HFLPC,MWPYR,N,NFLPC,O,
1    OFLPC,R,R0,REGRES,SH,SHAPE,SIZE,W,WFLPC,WTFUEL
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1    J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /LOGIC/   FC,FLSPEC,KRIT,NEWPLT,NEWPPR,PLFUEL,PLOT,PNCH,
1    RPSPEC,VTSPEC
COMMON /PLAST/   TBOILC,DHP,STOICH,SIZE1,EITA,EISCAN
COMMON /PRBLM/   ADIA,AFLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1    PRNT,STEADY,THICKW
COMMON /QS/      QCONW,QFIRE,QFLOW,QRADO,QRADW,QWL SUM
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  CND A(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1    NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
COMMON /WOUT/    BWORST,FLREM,HRATIO,RMA,RMF,TTIME,VAVGIN,
1    WA,WB,YCO2,YH2O,YN2,YO2,YPYR
LOGICAL ADIA,EISCAN,FC,FLSPEC,KRIT,NEWPPR,PLFUEL,
1    PLOT,PNCH,RPSPEC,SCAN,STEADY,STOICH,VTSPEC
REAL MWIN,MWOUT,MWPYR,MTIME,N,NFLPC
SCAN=.FALSE.
QRADW=0.
QCONW=0.
F2=0.
F1=0.
DTGAS=10.
CALL HEADNG
C          START TIME LOOP
DO 170 J=1,JM
KH=0
DERIV1=1.
TGAS2=0.
TGAS1=0.
TGASP=2000.
TGASN=TAMB
20 CONTINUE
K=0
30 CONTINUE
FC=.FALSE.
IF (FLREM.GT.0.) RP=TLU(RPX,NRP,TTIME)
IF (FLREM.LE.0.) RP=0.
RMF=RMA+RP
YC02=3.66667*CFLPC*RC/100./RMF
YH2O=(WFLPC*RP+9.0*HFLPC*RC)/100./RMF
YO2=(0.23*RMA-R0*RC)/RMF
YN2=0.77*RMA/RMF+NFLPC*RP/100./RMF
YPYR=(RP-RC)/RMF
IF (YPYR.LT..0) YPYR=0.
MWOUT=44.*YC02+18.*YH2O+28.*YN2+32.*YO2+MWPYR*YPYR
HRATIO=1./(1.+((TGAS/TAMB)*(MWIN/MWOUT)*(1.+RP/RMA)**2))

```

```

1    **0.333333333)
C      NOTE HIN IS TAKEN AS POSITIVE
      HIN= HWDOU* HRATIO
      ZW=1.-MWOUT*TAMB/MWIN/TGAS
      IF (ZW)195,35,35
35 VAVGIN= 0.666667*SQRT(2.*G*HIN*ZW)
      RMA= CD*VAVGIN*HIN*BWDOW*Densa
      RMF= RMA+RP
      IF (RMA/R-RP) 40,40,45
40 RC= BPF*RMA/R
      GO TO 50
45 RC= BPF*RP
      FC= .TRUE.
50 CONTINUE
      QFLOW= RMF*(YC02*(TGAS*(0.5*CPC02(1)*TGAS+CPC02(2))-TAMB*(0.5*
1 CPC02(1)*TAMB+CPC02(2)))+YH20*(TGAS*(0.5*CPH20(1)*TGAS+
2 CPH20(2))-TAMB*(0.5*CPH20(1)*TAMB+CPH20(2)))+YO2*(TGAS*(
3 0.5*CP02(1)*TGAS+CP02(2))-TAMB*(0.5*CP02(1)*TAMB+CP02(2)))+
4 +YN2*(TGAS*(0.5*CPN2(1)*TGAS+CPN2(2))-TAMB*(0.5*CPN2(1)*
5 TAMB+CPN2(2)))+YPYR*(TGAS*(0.5*CPPYR(1)*TGAS+CPPYR(2))-
6 -TAMB*(0.5*CPPYR(1)*TAMB+CPPYR(2))))
      QFIRE= RC*CVNET
      IF (ADIA) GOTO 90
      IF (.NOT.STEADY) CALL DESOLV
      IF (STEADY) CALL STFLOW
      QRADW= AWALLN*EMS(1)*SIGMA*(TGAS**4.-TSF**4.)
      QCONW= AWALLN*(TGAS-TSF)*CNV*((TGAS-TSF)*(TGAS-TSF))**0.16666667
90 CONTINUE
      QRADO= AWDOW*SIGMA*(TGAS**4.-TAMB**4.)
      K= K+1
      F3=F2
      F2=F1
      F1= QFIRE-QFLOW-QRADO-QRADW-QCONW
      TGAS3=TGAS2
      TGAS2=TGAS1
      TGAS1=TGAS
      IF (F1.LT.0..AND.TGAS.LT.TGASP) TGASP=TGAS
      IF (F1.GT.0..AND.TGAS.GT.TGASN) TGASN=TGAS
      DERIV2= DERIV1
      IF (TGAS1.EQ.TGAS2) GOTO 130
      DERIV1=(F1-F2)/(TGAS1-TGAS2)
      IF (KTRACE.GT.0) WRITE (4,99) TGAS1,TGAS2,F1,F2,DERIV1,K,KD,
1   KH,J,T2(1),TSF,QFIRE,QFLOW,QRADW,RP,RC
99 FORMAT(2F9.2,3(1PE9.2),3I3,I5,2(0PF9.2),3(1PE10.3),2(0PF7.3))
      IF (.NOT.SCAN) GOTO 95
      IF (F1/F2.GE.0.0) GOTO 93
      SCAN= .FALSE.
      GOTO 100
93 TGAS= TGAS-DTGAS
      IF (TGAS.LT.TAMB) GOTO 200
      GOTO 120
95 IF (DERIV1.LT..0.AND.ABS(F2).GT..0001)GOTO 100
      IF(DERIV2.LT..0.AND.J.GT.2) GOTO 100
      TGAS= TGAS1+DTGAS
      GOTO 120
100 DIF= ABS(F1/QFLOW)
      IF (DIF.LT.0.002.AND.ABS(TGAS2-TGAS1).LT.2.) GOTO 130
      TGAS=(F1*TGAS2-F2*TGAS1)/(F1-F2)

```

```

IF (K.GT.10.AND.F1.LT.0..AND.TGAS.GT.TGASP) GOTO 105
IF (K.GT.10.AND.F1.GT.0..AND.TGAS.LT.TGASN) GOTO 105
IF (K.EQ.1.AND.KH.EQ.0) TGAS= TGAS1+10.
IF (TGAS.GT.2000.) GOTO 110
IF (TGAS.LT.(TAMB+30.)) GOTO 110
GOTO 120
105 TGAS= (TGASN+TGASP)/2.
GOTO 120
110 SCAN= .TRUE.
TGAS= 1900.
120 CONTINUE
IF (STEADY.AND..NOT.ADIA) CALL STFLOW
IF (K=200) 30,30,200
130 CONTINUE
IF (STEADY) GOTO 180
CALL RSTA
FLREM= FLREM-RP*DTIME
IF (FLREM.LT.0.) FLREM=0.
IF (QCONW.GT.0.) QWLSUM= QWLSUM+(QRADW+QCONW)*DTIME
IF (TTIME .GE. MTIME) GO TO 210
IF (TGAS.LE.353..AND.J.GE.10) GO TO 210
IF (J.EQ.1) GO TO 150
IF (JP.LT.JPRINT) GO TO 160
JP= 0
150 CALL OUTPUT
160 JP= JP+1
TTIME= TTIME+DTIME
170 CONTINUE
C      END TIME STEP DO-LOOP
180 CONTINUE
185 CALL OUTPUT
C      NORMAL EXIT WHEN STEADY.EQ.T
RETURN
C      SQUARE ROOT ERROR
195 CONTINUE
IF(KTRACE.EQ.1) WRITE(2,930) TGAS,RC,RP,YPYR,ZW,RMA,MWOUT
930 FORMAT (' TGAS=',F5.0,' RC=',E10.4,' RP=',E10.4,
1   ' YPYR=',E10.4,' ZW=',F6.4,' RMA=',E10.4,' MWOUT=',F6.1)
C      FAIL TO CONVERGE, ERROR EXIT
200 CONTINUE
KNTRL=3
RETURN
C      FIRE IS OVER (TRANSIENT CASE)
210 CONTINUE
CALL OUTPUT
RETURN
END

```

```

SUBROUTINE STFLOW
C
C           CALCULATES WALL HEAT CONDUCTION WHEN STEADY-STATE
C           CONDITION ONLY IS NEEDED.
C
COMMON /GP/      AWDOW,BPF,CD,CNV,DTIME,EMS(2),HWDOW,IX,IXC,IXL,
1   J,JM,JP,JPRINT,K,KD,KH,KITER,KNTRL,MWIN,MWOUT,RC,RP,SIGMA
COMMON /PRBLM/   ADIA,AFLLOOR,AWALL,DENSW,FLOAD,IRUN,OPENF,
1   PRNT,STEADY,THICKW
COMMON /TEMP/    DENF,DENU,TAMB,TGAS,TINPT,T1(20),T2(20),TSF,TSU
COMMON /THERML/  Cnda(2,10),CPW(2,10),DX,EF,EMSA(2,10),
1   NCND,NCPW,NEMS,NQGEN,NRP,QGEN(2,10),RPX(2,50)
C           BIOT= BIOT NUMBER
KD= 0
TSF= TGAS -30.
TSU= TAMB +30.
10 CONTINUE
TSFOLD= TSF
TSUOLD= TSU
EMS(1)= 1./(TLU(EMSA,NEMS,TSF) +1./EF -1.)
EMS(2)= TLU(EMSA,NEMS,TSU)
TAVG= (TGAS+TAMB)/2.
CND= TLU(Cnda,NCND,TAVG)
ZRF= TGAS*(TGAS*(TGAS+TSF)+TSF*TSF)+TSF*TSF*TSF
ZCF= CNV*((TGAS-TSF)*(TGAS-TSF))**0.1666667
HF= ZCF+EMS(1)*SIGMA*ZRF
BIOTF= HF*THICKW/CND
ZRU= TAMB*(TAMB*(TAMB+TSU)+TSU*TSU)+TSU*TSU*TSU
ZCU= 1.31*((TAMB-TSU)*(TAMB-TSU))**0.1666667
HU= ZCU+EMS(2)*SIGMA*ZRU
BIOTU= HU*THICKW/CND
TSF= ((BIOTF+HF/HU)*TGAS+TAMB)/(1.+BIOTF+HF/HU)
TSU= ((BIOTU+HU/HF)*TAMB+TGAS)/(1.+BIOTU+HU/HF)
T2(1)= TSF- (TSF-TSU)*DX/THICKW/2.
T2(IXC)= (TSF+TSU)/2.
IF ((ABS(TSF-TSFOLD).LT.3.).AND.(ABS(TSU-TSUOLD).LT.3.))
1   RETURN
KD= KD+1
TSU= (TSU+TSUOLD)/2.
IF (KD.LT.20) GOTO 10
WRITE (2,90) TSF,TSFOLD
90 FORMAT ('//'*UNSUCCESSFUL ITERATION IN STFLOW'/
1   '      TSF=',F15.2,'  TSFOLD=',F15.2)
RETURN
END

```

```

FUNCTION TLU (ARRAY,NUM,VALIN)
C           TABULAR LOOK-UP INTERPOLATING ROUTINE
C
C           DIMENSION ARRAY(2,NUM)
C           ARRAY(1,I)= INDEPENDENT VARIABLE
C           ARRAY(2,I)= DEPENDENT VARIABLE
C           INTERPOLATES LINEARLY WITHIN GIVEN DOMAIN. SETS EQUAL TO
C           SMALLEST OR LARGEST VALUE IF OUTSIDE THE DOMAIN.
C
IF (NUM.NE.1) GO TO 10
TLU= ARRAY(2,1)
RETURN
10 IF (NUM.NE.2) GO TO 20
I= 2
GO TO 50
20 IF (VALIN.GT.ARRAY(1,1)) GO TO 30
TLU= ARRAY(2,1)
RETURN
30 DO 40 I=2,NUM
IF (VALIN.LE.ARRAY(1,I)) GO TO 50
40 CONTINUE
TLU= ARRAY(2,NUM)
RETURN
50 TLU= ARRAY(2,I-1) + (VALIN - ARRAY(1,I-1))*  

     ((ARRAY(2,I) - ARRAY(2,I-1)) / (ARRAY(1,I) - ARRAY(1,I-1)))
RETURN
END


```

```

SUBROUTINE TRIDGF (A,B,C,D,E,IX)
C
C           TRIDIAGONAL GAUSS ELIMINATION PROCEDURE FOR UNSYMMETRIC
C           MATRICES.
C           A=LEFT OF DIAGONAL, B=DIAGONAL, C=RIGHT OF DIAGONAL,
C           D= CONSTANT VECTOR, E= SOLUTION VECTOR, IX= SIZE OF MATRIX.
C
DIMENSION A(20),B(20),C(20),D(20),E(20),CP(20)
CP(1)= C(1)/B(1)
E(1)= D(1)/B(1)
C(IX)= 0.
IXL= IX-1
DO 10 I=2,IX
J= I-1
BX= B(I)-CP(J)*A(I)
CP(I)= C(I)/BX
E(I)= (D(I)-E(J)*A(I))/BX
10 CONTINUE
DO 20 I=1,IXL
J= IX-I
E(J)= E(J)-E(J+1)*CP(J)
20 CONTINUE
RETURN
END

```

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET		1. PUBLICATION OR REPORT NO. NBS Tech Note 991	2. Gov't. Accession No.	3. Recipient's Accession No.
4. TITLE AND SUBTITLE COMPF2--A Program for Calculating Post-Flashover Fire Temperatures		5. Publication Date June 1979		
7. AUTHOR(S) Vytenis Babrauskas		6. Performing Organization Code		
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, DC 20234		10. Project/Task/Work Unit No.		
12. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Same as 9 above		13. Type of Report & Period Covered Final		
14. Sponsoring Agency Code				
15. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.				
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) COMPF2 is a computer program for calculating the characteristics of a post-flashover fire in a single building compartment, based on fire-induced ventilation through a single door or window. It is intended both for performing design calculations and for the analysis of experimental burn data. Wood, thermoplastic, and liquid fuels can be treated. In addition to the capability of performing calculations for compartments with completely determined properties, routines are included for calculating fire behavior by an innovative variable abstraction method. A comprehensive output format is provided which gives gas temperatures, heat flow terms, and flow variables. The documentation includes input instructions, sample problems, and a listing of the program. The program is written in Fortran and constitutes an improved version of an earlier program, COMPF.				
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Computer programs--fire protection; fire protection; fire resistance; fire tests; fire walls; safety engineering--fires.				
18. AVAILABILITY <input checked="" type="checkbox"/> Unlimited		19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED	21. NO. OF PRINTED PAGES 76	
<input type="checkbox"/> For Official Distribution. Do Not Release to NTIS		20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED	22. Price \$3.50	
<input checked="" type="checkbox"/> Order From Sup. of Doc., U.S. Government Printing Office, Washington, DC 20402, SD Stock No. SN003-003-02080-0				
<input type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161				



**There's
a new
look
to...**

DIMENSIONS

NBS

. . . the monthly magazine of the National Bureau of Standards. Still featured are special articles of general interest on current topics such as consumer product safety and building technology. In addition, new sections are designed to . . . PROVIDE SCIENTISTS with illustrated discussions of recent technical developments and work in progress . . . INFORM INDUSTRIAL MANAGERS of technology transfer activities in Federal and private labs. . . DESCRIBE TO MANUFACTURERS advances in the field of voluntary and mandatory standards. The new DIMENSIONS/NBS also carries complete listings of upcoming conferences to be held at NBS and reports on all the latest NBS publications, with information on how to order. Finally, each issue carries a page of News Briefs, aimed at keeping scientist and consumer alike up to date on major developments at the Nation's physical sciences and measurement laboratory.

(please detach here)

SUBSCRIPTION ORDER FORM

Enter my Subscription To DIMENSIONS/NBS at \$11.00. Add \$2.75 for foreign mailing. No additional postage is required for mailing within the United States or its possessions. Domestic remittances should be made either by postal money order, express money order, or check. Foreign remittances should be made either by international money order, draft on an American bank, or by UNESCO coupons.

Send Subscription to:

NAME-FIRST, LAST

Remittance Enclosed
(Make checks payable to Superintendent of Documents)

Charge to my Deposit Account No.

COMPANY NAME OR ADDITIONAL ADDRESS LINE

STREET ADDRESS


CITY

STATE

ZIP CODE

PLEASE PRINT

MAIL ORDER FORM TO:
Superintendent of Documents
Government Printing Office
Washington, D.C. 20402



NBS TECHNICAL PUBLICATIONS

PERIODICALS

JOURNAL OF RESEARCH—The Journal of Research of the National Bureau of Standards reports NBS research and development in those disciplines of the physical and engineering sciences in which the Bureau is active. These include physics, chemistry, engineering, mathematics, and computer sciences. Papers cover a broad range of subjects, with major emphasis on measurement methodology, and the basic technology underlying standardization. Also included from time to time are survey articles on topics closely related to the Bureau's technical and scientific programs. As a special service to subscribers each issue contains complete citations to all recent NBS publications in NBS and non-NBS media. Issued six times a year. Annual subscription: domestic \$17.00; foreign \$21.25. Single copy, \$3.00 domestic; \$3.75 foreign.

Note: The Journal was formerly published in two sections: Section A "Physics and Chemistry" and Section B "Mathematical Sciences."

DIMENSIONS/NBS

This monthly magazine is published to inform scientists, engineers, businessmen, industry, teachers, students, and consumers of the latest advances in science and technology, with primary emphasis on the work at NBS. The magazine highlights and reviews such issues as energy research, fire protection, building technology, metric conversion, pollution abatement, health and safety, and consumer product performance. In addition, it reports the results of Bureau programs in measurement standards and techniques, properties of matter and materials, engineering standards and services, instrumentation, and automatic data processing.

Annual subscription: Domestic, \$11.00; Foreign \$13.75

NONPERIODICALS

Monographs—Major contributions to the technical literature on various subjects related to the Bureau's scientific and technical activities.

Handbooks—Recommended codes of engineering and industrial practice (including safety codes) developed in cooperation with interested industries, professional organizations, and regulatory bodies.

Special Publications—Include proceedings of conferences sponsored by NBS, NBS annual reports, and other special publications appropriate to this grouping such as wall charts, pocket cards, and bibliographies.

Applied Mathematics Series—Mathematical tables, manuals, and studies of special interest to physicists, engineers, chemists, biologists, mathematicians, computer programmers, and others engaged in scientific and technical work.

National Standard Reference Data Series—Provides quantitative data on the physical and chemical properties of materials, compiled from the world's literature and critically evaluated. Developed under a world-wide program coordinated by NBS. Program under authority of National Standard Data Act (Public Law 90-396).

NOTE: At present the principal publication outlet for these data is the Journal of Physical and Chemical Reference Data (JPCRD) published quarterly for NBS by the American Chemical Society (ACS) and the American Institute of Physics (AIP). Subscriptions, reprints, and supplements available from ACS, 1155 Sixteenth St. N.W., Wash., D.C. 20056.

Building Science Series—Disseminates technical information developed at the Bureau on building materials, components, systems, and whole structures. The series presents research results, test methods, and performance criteria related to the structural and environmental functions and the durability and safety characteristics of building elements and systems.

Technical Notes—Studies or reports which are complete in themselves but restrictive in their treatment of a subject. Analogous to monographs but not so comprehensive in scope or definitive in treatment of the subject area. Often serve as a vehicle for final reports of work performed at NBS under the sponsorship of other government agencies.

Voluntary Product Standards—Developed under procedures published by the Department of Commerce in Part 10, Title 15, of the Code of Federal Regulations. The purpose of the standards is to establish nationally recognized requirements for products, and to provide all concerned interests with a basis for common understanding of the characteristics of the products. NBS administers this program as a supplement to the activities of the private sector standardizing organizations.

Consumer Information Series—Practical information, based on NBS research and experience, covering areas of interest to the consumer. Easily understandable language and illustrations provide useful background knowledge for shopping in today's technological marketplace.

Order above NBS publications from: Superintendent of Documents, Government Printing Office, Washington, D.C. 20402.

Order following NBS publications—NBSIR's and FIPS from the National Technical Information Services, Springfield, Va. 22161.

Federal Information Processing Standards Publications (FIPS PUB)—Publications in this series collectively constitute the Federal Information Processing Standards Register. Register serves as the official source of information in the Federal Government regarding standards issued by NBS pursuant to the Federal Property and Administrative Services Act of 1949 as amended, Public Law 89-306 (79 Stat. 1127), and as implemented by Executive Order 11717 (38 FR 12315, dated May 11, 1973) and Part 6 of Title 15 CFR (Code of Federal Regulations).

NBS Interagency Reports (NBSIR)—A special series of interim or final reports on work performed by NBS for outside sponsors (both government and non-government). In general, initial distribution is handled by the sponsor; public distribution is by the National Technical Information Services (Springfield, Va. 22161) in paper copy or microfiche form.

BIBLIOGRAPHIC SUBSCRIPTION SERVICES

The following current-awareness and literature-survey bibliographies are issued periodically by the Bureau:

Cryogenic Data Center Current Awareness Service. A literature survey issued biweekly. Annual subscription: Domestic, \$25.00; Foreign, \$30.00.

Liquified Natural Gas. A literature survey issued quarterly. Annual subscription: \$20.00.

Superconducting Devices and Materials. A literature survey issued quarterly. Annual subscription: \$30.00. Send subscription orders and remittances for the preceding bibliographic services to National Bureau of Standards, Cryogenic Data Center (275.02) Boulder, Colorado 80302.

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
Washington, D.C. 20234

OFFICIAL BUSINESS

Penalty for Private Use, \$300

POSTAGE AND FEES PAID
U.S. DEPARTMENT OF COMMERCE
COM-215



SPECIAL FOURTH-CLASS RATE
BOOK
