NIST Technical Note 1895 -

Heat Pump Test Apparatus for the Evaluation of Low Global Warming Potential Refrigerants

Harrison Skye

http://dx.doi.org/10.6028/NIST.TN.1895



NIST Technical Note 1895

Heat Pump Test Apparatus for the Evaluation of Low Global Warming Potential Refrigerants

Harrison Skye Engineering Laboratory Energy and Environment Division

This publication is available free of charge from: http://dx.doi.org/10.6028/NIST.TN.1895

November 2015



U.S. Department of Commerce Penny Pritzker, Secretary

National Institute of Standards and Technology Willie E. May, Under Secretary of Commerce for Standards and Technology and Director Certain commercial entities, equipment, or materials may be identified in this document in order to describe an experimental procedure or concept adequately. Such identification is not intended to imply recommendation or endorsement by the National Institute of Standards and Technology, nor is it intended to imply that the entities, materials, or equipment are necessarily the best available for the purpose.

National Institute of Standards and Technology Technical Note 1895 Natl. Inst. Stand. Technol. Tech. Note 1895, 48 pages (November 2015) http://dx.doi.org/10.6028/NIST.TN.1895

CODEN: NTNOEF

International efforts to reduce human-induced global warming include restrictions on the use of chemicals with a high global warming potential (GWP). The heating, ventilation, air-conditioning, and refrigeration (HVAC&R) industry subsequently faces a phasedown of many commonly used hydrofluorocarbon (HFC) refrigerants that have a relatively high GWP. A new family of refrigerants known as hydrofluoroolefins (HFOs), including their mixtures with HFCs, show promise as replacements. The overall GWP impact of refrigerant use includes both the direct GWP related to inadvertent release of the fluid into the atmosphere, as well as an indirect GWP caused by emissions from the power source used to energize the associated HVAC&R equipment. In nearly all HVAC&R applications, the indirect emissions far outweigh the direct emissions, so the efficiency of candidate replacements must be carefully quantified to guide the selection of fluids that actually achieve a reduction in the overall GWP.

A 3.4 kW (1 ton) heat pump test apparatus has been constructed and instrumented for measuring the cycle performance of low-GWP refrigerants; the description of that apparatus is the focus of this report. Details are described for the system components, instrumentation, data reduction, and uncertainty analysis. Results from baseline experiments with R134a were used to test and verify the apparatus and data reduction procedure. The data will be used to provide a relative comparison between the low-GWP refrigerants as quantified by metrics including coefficient of performance and volumetric capacity.

Future tests with low-GWP refrigerants will be compared with those from baseline refrigerants R134a and R410A. Additionally, the test data will be used to verify a new NIST heat pump modeling tool, CYCLE_D-HX, which captures both thermodynamic and heat transfer processes in HVAC&R equipment. Refrigerants, refrigerant mixtures, and cycle configurations that are difficult and/or time consuming to test can be rapidly explored using the verified model.

This apparatus was constructed by John Wamsley based on the initial design by David Yashar. Dr. Yashar also helped create the outline of the report, which was valuable for keeping the presentation of information organized and complete. I would like to acknowledge Vance Payne for his help in determining the operating procedures and target operating parameters. Patrick Goenner refined the instrumentation and collected early sets of data while visiting as a guest researcher from Germany. I would also like to thank Piotr Domanski and Riccardo Brignoli for reviewing data sets and working on the CYCLE_D-HX model. Thanks to Mark Kedzierski for thoughtful insight into the calibration and uncertainty analysis for the test rig. Tara Fortin, of the NIST Applied Chemicals and Materials Division, performed differential scanning calorimeter measurements of the heat transfer fluid specific heat; these data were critical for achieving an acceptable energy balance. Finally, I would like to thank the reviewers for their helpful suggestions, including Piotr Domanski and Amanda Pertzborn at NIST, and Steve Brown at The Catholic University of America.

Table of Contents -

Abst	ract			ii -	
Ackr	nowledg	geme	nts	iii -	
Table	e of Co	ntent	s	iv -	
List o	of Figu	res		vi -	
List o	of Tabl	es		vii -	
Nom	enclatu	ıre		viii -	
1 Iı	ntroduc	tion.		1 -	
2 T	est Ap	parati	us		
2.1	l Cor	npon	ents		
2.2	2 Inst	rume	entation	11 -	
2.3	3 Ope	eratio	n	15 -	
	2.3.1	Test	t Rig Control Parameters	15 -	
	2.3.2	Test	t Rig Operating Parameters	15 -	
	2.3.2	2.1 -	Operating Parameters 1 & 2: Evaporator and Condenser Saturation		
			Temperature	15 -	
	2.3.2	2.2 -	Operating Parameters 3, 4, & 5: Capacity and Heat Flux	17 -	
	2.3.2	2.3 -	Operating Parameters 6 & 7: HTF-side Thermal Resistance Ratio		
	2.3.2	2.4 -	Operating Parameters 8 & 9: Subcool and Superheat		
	2.3.2	2.5	Operating Parameter 10: LLSL-HX included or bypassed	19 -	
3 D	Data An	alysi	S	20 -	
3.1	l The	ermod	lynamic States	20 -	
3.2	2 The	ermod	lynamic Performance	20 -	
	3.2.1	Сар	acity	20 -	
	3.2.2	Con	npressor Power	21 -	
	3.2.3	Coe	fficient of Performance	22 -	
	3.2.4	Vol	umetric Capacity	22 -	
	3.2.5	Con	npressor Efficiency	22 -	
	3.2.6	Sup	erheat and Subcooling		
	3.2.7	LLS	SL-HX Effectiveness		
4 V	/alidati	on an	d Baseline Tests with R134a		
5 (5 Conclusions and Future Work 29				
6 R	eferen	ces		29 -	
5 C 6 R	Conclus Referen	ions a	and Future Work		

Append	lix A : Uncertainty Analysis	31 -
A.1	Symbols Used in Uncertainty Analysis	31 -
A.2	General Remarks	32 -
A.3	Thermocouples with CJC Compensation	32 -
A.4	Thermocouples with Ice-Water Bath Compensation	33 -
A.5	Thermopiles in Heat Transfer Fluid	34 -
A.6	Evaporator Heat Transfer Fluid Specific Heat	36 -
A.7	Condenser Heat Transfer Fluid Specific Heat	37 -
A.8	Evaporator and Condenser Insulation Conductance	37 -
A.9	Uncertainty Analysis Software	39 -
A.10	Moving Window and Steady State Uncertainty	40 -
A.11	Uncertainty Results Summary	41 -
A.	11.1 Uncertainty Results Summary: Cooling	41 -
A.	11.2 Uncertainty Results Summary: Heating	43 -
Append	lix B : Instrumentation Schematic with DAQ Number Convention	46 -
Append	lix C : Microfin Tube Surface Area	48 -

List of Figures -

Figure 2-1:	Schematic of MBBHP test apparatus	5
Figure 2-2:	Pictures of MBBHP apparatus	6
Figure 2-3:	Pictures of MBBHP compressor (a) without and (b) with safety cage	7
Figure 2-4:	Schematic showing the tube numbering convention in the (a) condenser and (b) evaporator.	5) - 8
Figure 2-5:	Schematics of annular heat exchanger including (a) refrigerant tube lengths, (b cross section of annular heat exchanger, (c) detail cross-section of microfin tub and (d) helix angle of microfins	o) - be, 9
Figure 2-6:	Capacity and heat flux for baseline R134a tests for (a) evaporator and (b) - condenser	18
Figure 3-1:	Temperature profile in (a) evaporator, showing superheat and (b) condenser, showing subcooling	23
Figure 4-1:	Energy imbalance in the evaporator and condenser	25
Figure 4-2:	Heat pump cycle pressures on the (a) high pressure side and (b) low pressure - side	26
Figure 4-3:	Performance metrics including (a) compressor power and (b) mass flow and m flux	nass - 26
Figure 4-4:	Performance metrics including (a) COP, (b) capacity, (c) volumetric capacity, (d) compressor isentropic and volumetric efficiency	and 27
Figure 4-5:	Flow regime map for microfin tube (a) evaporation and (b) condensation	28
Figure A-1:	Temperature calibration for CJC compensated thermocouples where (a) data a divided by each of the 5 calibrations and (b) all data are combined	ire - 33
Figure A-2:	Ice-water bath referenced thermocouple calibration data	34
Figure A-3:	Thermopile calibration data	35
Figure A-4:	Contours of thermopile (a) uncertainty and (b) relative contribution to uncertainty	36
Figure A-5:	Specific heat measurements for evaporator HTF	37
Figure A-6:	Specific heat of condenser HTF (water)	37
Figure A-7:	Insulation conductance for evaporator and condenser	39
Figure A-8:	Uncertainty in temperature due to fluctuations at steady state for (a) evaporato outlet and (b) evaporator inlet	or - 41

List of Tables -

Table 2-1:	Components for MBBHP rig	. 10
Table 2-2:	Refrigerant microfin tube specifications	. 11
Table 2-3:	List of MBBHP instruments (SI units)	. 13
Table 2-4:	List of MBBHP instruments (I-P units)	. 14
Table 2-5:	List of the Control Parameters and Operating Parameters	. 15
Table 2-6:	Evaporator and condenser fluid temperatures for standard rating tests	. 17
Table 3-1:	Measurements and equations used to define the thermodynamic states	. 20
Table A-1:	Condenser & evaporator thermopile polynomial coefficients	. 35
Table A-2:	Evaporator HTF specific heat polynomial coefficients	. 37
Table A-3:	Uncertainty of refrigerant-side evaporator cooling capacity	. 42
Table A-4:	Uncertainty of HTF-side evaporator cooling capacity	. 42
Table A-5:	Uncertainty of cooling COP	. 43
Table A-6:	Uncertainty of refrigerant-side condenser heating capacity	. 44
Table A-7:	Uncertainty of HTF-side condenser heating capacity	. 44
Table A-8:	Uncertainty of heating COP	. 45

<u>Symbol</u>	<u>Units</u>	Definition
A	m^2	Area
A_{total}	m^2	Total combined heat transfer area from evaporator and condenser
COPheat		Coefficient of Performance - Heating
COP _{cool}		Coefficient of Performance - Cooling
C_p	kJ kg ⁻¹ K ⁻¹	Specific heat
d_o	mm	Microfin tube outer diameter
d_i	mm	Microfin tube inner diameter
D_{comp}	m ³	Compressor displacement
h	kJ kg ⁻¹	Specific enthalpy
L	m	Tube length
'n	kg s ⁻¹	Mass flow rate
N	Hz	Compressor frequency
Nf		Number of microfins on inner circumference of refrigerant tube
NT		Number of heat exchanger tubes
Р	kPa	Pressure
ΔP	kPa	Pressure difference
R	K kW ⁻¹	Thermal resistance
R _{total}	K kW ⁻¹	Total resistance in heat exchanger including both fluids and tube wall
Ż	kW	Energy transfer
$\dot{Q}_{{\scriptscriptstyle LLSL},v}$	kW	Energy transfer in LLSL-HX, on the vapor side
$\dot{Q}_{{\scriptscriptstyle LLSL,max}}$	kW	Maximum possible energy transfer in LLSL-HX
Т	°C	Temperature
ΔT	Κ	Temperature difference
t _b	mm	Microfin tube bottom wall thickness
S_f	mm	Spacing between microfins
S	kJ kg ⁻¹ K ⁻¹	Specific entropy
SC	Κ	Condenser subcooling
SH	Κ	Evaporator superheat
UA	W K ⁻¹	Thermal conductance
v	m ³ kg ⁻¹	Specific volume
VCC	kJ m ⁻³	Volumetric Cooling Capacity
VHC	kJ m ⁻³	Volumetric Heating Capacity
\dot{W}_{comp}	k W	Compressor power, computed using enthalpy change of refrigerant
$\dot{W_{shaft}}$	k W	Compressor power, computed using torque and speed of driveshaft
x		Vapor quality (mass of vapor divided by total mass of fluid)

Nomenclature -

Greek		
<u>Symbol</u>	<u>Units</u>	Definition
α	0	Microfin helix angle about tube axis
β	0	Microfin angle
\mathcal{E}_{LLSL}		Effectiveness of the liquid-line suction-line heat exchanger
η_s		Compressor isentropic efficiency
η_{v}		Compressor volumetric efficiency
$ ho_{air}$	kg m ⁻³	Density of air
τ	Nm	Compressor shaft torque

Definition
Active refrigerant heat exchanger tubes -
Air -
Ambient air surrounding test apparatus -
Average -
Condenser
Evaporator
Heat Transfer Fluid
Inlet
Insulation
Inactive refrigerant heat exchanger tubes
Outlet
Refrigerant
Refrigerant thermodynamic states as defined in Figure 2-1

Abbreviation	Definition
AHRI	Air-Conditioning, Heating, and Refrigeration Institute
ANSI	American National Standards Institute
CFC	Chlorofluorocarbon
СОР	Coefficient of Performance (W of capacity per W of electric input)
CYCLE_D-HX	A NIST heat pump cycle simulation model currently under development. The simulation captures both thermodynamic and transport processes in the cycle.
DAQ	Data Acquisition
DOE	Department of Energy (United States)
EER	Energy Efficiency Ratio (Btu of capacity per W of electric input)
EOS	Equation of State
GWP	Global Warming Potential
HFC	Hydrofluorocarbon
HFO	Hydrofluoroolefin
HTF	Heat Transfer Fluid
HVAC&R	Heating, Ventilation, Air-Conditioning, and Refrigeration
LLSL-HX	Liquid-Line Suction-Line Heat Exchanger
MBBHP	Mini Breadboard Heat Pump
NIST	National Institute of Standards and Technology (United States)
PID	Proportional Integral Derivative controller
RPM	Revolutions per Minute (compressor shaft)

1 Introduction -

Concerns about the environmental impacts of global warming (i.e., global climate change) are driving an effort to limit anthropogenic sources of atmospheric pollutants that trap longwave radiation emitted from the earth's surface. The chlorinated- and fluorinated-hydrocarbon working fluids (i.e., refrigerants) employed by the heating, ventilation, air-conditioning, and refrigeration (HVAC&R) industry exhibit a particularly large global warming potential (GWP) with 100-year GWP values hundreds to thousands of times larger than an equivalent mass of carbon dioxide (Solomon, et al., 2007, p. 212). In the European Union, the F-gas regulation (EU, 2014) mandates a phase-down of hydrofluorocarbons (HFCs) with high GWP to 21 % of the average levels from years 2009 through 2012 by 2030. The current North American proposal would amend the Montreal Protocol to limit HFC consumption to have a weighted GWP of 15 % of average levels from years 2011 through 2013 by 2036 (EPA, 2015).

Major efforts are underway to identify alternative refrigerants with a lower GWP. Chemical manufacturers are proposing halogenated olefins (e.g., hydrofluoroolefins, or HFOs), which offer substantially lower GWP due to short atmospheric lifetimes. For some HFOs, the lower GWP comes at the cost of an increase in flammability. The Air-Conditioning, Heating, and Refrigeration Institute (AHRI) is leading a collaborative effort to evaluate the drop-in and soft-optimized performance of low-GWP alternatives largely consisting of HFOs and HFO/HFC blends (AHRI, 2015). The National Institute of Standards and Technology (NIST) investigated the maximum thermodynamic potential expected for working fluids by optimizing the parameters governing the Equations of State (EOS) (Domanski et al., 2014). In a companion NIST study, a coarse filter criteria was developed (based on the atomic elements, GWP, toxicity, flammability, critical temperature, and stability) to sift through the 100 million chemicals currently listed in the public-domain PubChem database for possible low-GWP refrigerant candidates, 1234 of which were identified (Kazakov et al., 2012). The candidate list was further refined to 62 by limiting the critical temperature to the range 300 K to 400 K, which is typical for fluids in HVAC&R equipment (McLinden et al., 2014).

The remaining 62 candidates, and their mixtures, must be evaluated using more stringent criteria that consider detailed performance in HVAC&R equipment. In particular, the criteria must include the cycle efficiency of the fluid since the carbon dioxide emissions from the power source (i.e., "indirect emissions") far outweighs the direct GWP impact (i.e., the GWP from the release of the fluid into the atmosphere) of the working fluid in nearly all HVAC&R equipment. A cycle modeling tool, CYCLE D-HX, is being developed at NIST to evaluate the efficiency of low-GWP refrigerants and refrigerant mixtures. The model expands upon the thermodynamic considerations from CYCLE D (Brown et al., 2011) by including transport phenomena. In this way, appropriate penalties can be applied to refrigerants whose thermodynamic properties are favorable but exhibit poor performance in HVAC&R systems because of large pressure drops or poor heat transfer. The consideration of transport processes represents a lesson learned from the previous effort to find replacements for chlorofluorocarbon (CFC) fluids that were found to cause stratospheric ozone destruction. R410A, the dominant replacement for the CFC R22, was initially considered to be a significantly inferior replacement based on thermodynamic properties alone. However, later practice showed that the lower pressure drop (due to high operating pressure) and superior heat transfer of R410A could be exploited with optimized heat exchangers to yield performance competitive with R22. Including transport processes also allows for the

optimization of mass flux; the number of parallel heat exchanger tube circuits are adjusted to balance performance enhancement/degradation of increased heat transfer/pressure drop with higher mass flux. The more sophisticated capabilities of the new model will allow for more accurate identification of optimal low-GWP fluids using computational methods.

A heat pump test apparatus has been constructed for the purpose of generating cycle performance data to compare low-GWP refrigerants and to tune and verify the new NIST model; that test apparatus is the focus of this report. The apparatus is highly configurable, which allows the system to operate with a wide variety of working fluids as if tailored to each one. Specifically, the apparatus features a variable-speed compressor, variable-area heat exchangers, and a manually adjusted throttle valve. These adjustable components allow for operation at constant capacity per total combined evaporator and condenser conductance (\dot{Q}/UA_{total}) across all test fluids, a condition required for equitable comparison of refrigerants (as well as fixed heat transfer fluid inlet/outlet temperatures) (McLinden et al., 1987). In practice, it is difficult to hold Q/UA_{total} constant because the conductance depends on the refrigerant side heat transfer coefficient, which changes for each fluid and operating condition. Rather, a fixed capacity per total heat exchanger area (\dot{Q}/A_{total}) is used as a close approximation. For example, with a fixed heat exchanger area, \dot{Q}/A_{total} is held constant from R134a (low volumetric capacity) to R410A (high volumetric capacity) by decreasing the compressor speed. If adjustment of compressor speed is insufficient to maintain constant \dot{Q}/A_{total} between refrigerants, the heat exchanger area can be adjusted as well. The adjustability and relatively small capacity of 1.7 kW to 3.5 kW (0.5 ton to 1 ton) provide the etymology for the apparatus name, the Mini Breadboard Heat Pump (MBBHP). Measurements of cycle performance with legacy high-GWP HFCs and novel low-GWP fluids in the MBBHP will provide a rich data set to test the predictive capability of the new NIST model.

This report describes the construction and operation of the test apparatus, the data analysis used to quantify performance, an uncertainty analysis of the performance metrics, and baseline and validation results using refrigerant R134a.

2 Test Apparatus -

2.1 Components

The test apparatus, shown in Figure 2-1 through Figure 2-3, was designed to emulate refrigerant-side operating conditions of typical HVAC&R equipment. (Figure B-1 and Figure B-2 in Appendix B show the instrument numbering convention used in the raw data files). The rig design is partially based on one used in a previous NIST effort to investigate alternatives to CFCs (Pannock et al., 1991). The refrigerant circuit includes a variable-speed compressor powered by an electric motor and inverter, where the speed controls cooling/heating capacity. The evaporator and condenser, shown in detail in Figure 2-4 and Figure 2-5 (a) and (b), are single-circuit (i.e., there are no parallel tube branches) annular heat exchangers where the refrigerant is on the inner tube and the liquid heat transfer fluid (HTF) is in the annular space. As shown in Figure 2-5(c), the refrigerant tube is smooth on the outside and enhanced with rifled microfins on the inside. The size of the heat exchangers can be adjusted by changing the number of active refrigerant tubes; the valves on the side of the heat exchanger allow for up to 10 (in increments of 2) of the 20 refrigerant tubes to be bypassed (this section of the rig is referred to as the "bypass valve header"). When operating these bypass valves, care is taken to avoid trapping subcooled liquid in a closed section; a section completely filled with subcooled liquid will experience a catastrophic increase in pressure if the temperature rises enough to vaporize the refrigerant. A liquid-line suction-line heat exchanger (LLSL-HX) can be included or bypassed as needed. Each of three heat exchangers (evaporator, condenser and LLSL-HX) are arranged in counterflow configuration. Two sizes of manually controlled Vernier-handled needle valves are used to throttle the refrigerant and can be used individually or in tandem; the needle valve sizes were selected using a correlation for short tubes (Kim et al., 2005). A filter-dryer is used to control contaminants, and an oil separator is used to ensure proper oil return to the compressor and to minimize oil circulation in the heat exchangers. The system refrigerant charge is adjusted using two Shrader access valves, where refrigerant is removed from or added to the liquid/suction line valves, respectively. Two 40 W heaters preheat the compressor before startup to avoid foam in the oil (the heaters are turned off after the discharge temperature has warmed to about 60 °C). A safety cage was constructed around the compressor because during cooling tests with high pressure fluids such as R410A, the compressor will be operated slightly above the manufacturer's specified maximum pressure of 2600 kPa (363 psig). Finally, a series of sight glasses provide visual confirmation of fully subcooled liquid exiting the condenser, vapor only (i.e., no liquid) entering the compressor suction port, proper oil level in the compressor, and proper oil return from the oil separator. Detailed component specifications are listed in Table 2-1. The microfin tube parameters are shown in Figure 2-5 and Table 2-2, and Appendix C shows how the microfin surface area was calculated.

The HTF circuits include a water heater/chiller to respectively control the evaporator and condenser HTF inlet temperatures, where the heater/chiller contains a pump for circulating the fluid. The evaporator HTF is a potassium formate and water solution with freeze protection to -40 °C (-40 °F), whereas water is used for the HTF in the condenser. Flow control provided by three valves in each HTF circuit allows for a wide range of flowrates: two in-line valves are used where the larger/smaller (gate/needle) valve provides gross/fine flow adjustment and the third valve bypasses the heater (or chiller) for flow and pressure control. Air bubbles in the condenser HTF circuit are controlled by drawing from the bottom of the vented chiller reservoir

tank. The evaporator HTF circuit is pressurized with an expansion tank, so air bubbles can be removed by venting trapped air from local high spots using Shrader valves. Experience operating the test apparatus has shown that the vented reservoir tank (in the chiller) is a superior solution for minimizing air bubbles. The temperature of the fluid delivered to the heat exchangers is regulated using proportional-integral-derivative (PID) controllers.



Figure 2-1: Schematic of MBBHP test apparatus







Figure 2-2: Pictures of MBBHP apparatus



Figure 2-3: Pictures of MBBHP compressor (a) without and (b) with safety cage. -



Figure 2-4: - Schematic showing the tube numbering convention in the (a) condenser and (b) evaporator.



Figure 2-5: - Schematics of annular heat exchanger including (a) refrigerant tube lengths, (b) cross section of annular heat exchanger, (c) detail cross-section of microfin tube, and (d) helix angle of microfins.

Component	Characteristics			
Chiller	Cooling capacity:	2500 W (0.7 ton)		
Compressor	Туре:	Reciprocating		
-	Cylinders:	2		
	Speed:	8.3 Hz to 66.7 Hz		
		(500 RPM to 4000 RPM)		
	Displacement rate:	$1.31 \text{ m}^3\text{h}^{-1}$ to $10.81 \text{ m}^3\text{h}^{-1}$		
	Displacement:	7.165 cm^3		
	Max pressure:	2604 kPa (363 psia)		
Electric motor	Maximum power:	3.73 kW (5 hp)		
Expansion tank (HTF)	Size:	19 liter (5 gallon)		
Filter (HTF)	Filter size:	50 µm		
Filter-dryer (refrig.)	Line size:	9.5 mm (0.375 in)		
Inverter	Voltage:	230 VAC, 3-phase		
	Maximum power:	3.73 kW (5 hp)		
Heater	Heating capacity:	10 kW (2.8 ton)		
Heat exchanger	Number of tubes:	10 to 20, increments of 2		
(evaporator/condenser)	Tube active length:	560 mm (22 in)		
	Return bend length:	83 mm (3.25 in)		
	Outer tube ID:	25.4 mm (1 in)		
	Outer tube OD:	26.8 mm (1.125 in)		
	Outer tube material:	Copper		
	Inner tube:	See Table 2-2		
Liquid-line suction-line heat	Nominal capacity:	370 W (0.5 hp)		
exchanger (LLSL-HX)	Shell O.D.:	51 mm (2 in)		
	Type:	Corrugated (liquid side)		
Needle valves (refrig.)	Valve 1	Valve 1		
	Orifice:	1.42 mm (0.056 in)*		
	Flow coeff. (C_v) :	0.03*		
	Valve 2	Valve 2		
	Orifice:	3.25 mm (0.128 in)*		
	Flow coeff. (C_v) :	0.16*		
Needle valves (HTF)	Orifice:	6.4 mm (0.25 in)*		
	Flow coeff. (C_v) :	0.73*		
Oil separator	Diameter:	102 mm (4 in)		
	Height:	356 mm (14 in)		
	Capacity:	10 to 17 kW (3 to 5 ton)		
Pressure relief valve	Cracking pressure:	800 psig		

Table 2-1: Components for MBBHP rig

*Note: valve orifice sizes and flow coefficients (C_v) can vary between 0 and the listed maximum values

Parameter	Symbol	Value	Uncertainty
Inside diameter	d_i	8.46 mm (0.333 in)	Unknown
Outside diameter	d_o	9.52 mm (0.375 in)	±0.050 mm (±0.002 in)
Bottom wall thickness	t_b	0.33 mm (0.013 in)	±0.025 mm (±0.001 in)
Fin height	е	0.20 mm (0.008 in)	±0.025 mm (±0.001 in)
Spacing between fins	S_f	0.22 mm (0.009 in)	Unknown
Number of fins	N_f	60	
Fin angle	β	60°	Unknown
Helix angle	α	18°	2°
Internal surface area per unit tube length	A_i/L	0.0424 m (1.67 in)	
Material		Copper	

Table 2-2: Refrigerant microfin tube specifications

2.2 Instrumentation

Refrigerant-side instrumentation is selected to capture the key thermodynamic state points in the cycle. Specifications for the instruments (including instrument uncertainty) in both the refrigerant and HTF circuits are listed in Table 2-3 (Table 2-4 shows I-P units). The pressure transducers and in-stream thermocouple probes are numbered in Figure 2-1 according to the eleven states computed in Section 3.1; the thermodynamic state number convention is also consistent with that used in the new CYCLE_D-HX model. The thermocouple probes are referenced to a cold junction in an ice-water bath. Differential pressure transducers quantify the pressure drop in the condenser, evaporator, and suction line. The location of the heat exchanger pressure taps has been selected at the bottom of the bypass valve header, where the pressure is equal to that of the refrigerant leaving the heat exchanger regardless of how many tubes are bypassed. A coriolis flowmeter measures the refrigerant mass flow and density, and provides confirmation of fully subcooled liquid in the liquid line (a two-phase mixture will exhibit large oscillations in measured flowrate). The compressor shaft power is captured by the in-line torque meter and tachometer.

On the HTF fluid side, energy transfers are measured in the evaporator and condenser to provide verification of the refrigerant-side calculations. The mass flow and temperature difference in the heat exchangers are measured with coriolis meters and thermopiles (in thermowells), which are combined with the fluid heat capacity to compute energy transfer. Thermocouples inserted into the thermowells with the thermopiles provide the measure of absolute temperature required for applying the thermopile calibration. Additionally, the thermocouples provide verification of the thermopile temperature difference measurement.

Figure 2-1 and Figure 2-4 also show the tube-surface-mounted thermocouples used to measure both refrigerant and HTF temperature profiles in the evaporator and condenser. As shown in Section 3.2.6, these temperature profiles are useful for determining refrigerant tube

number where the phase transitions (superheat, subcooling, two-phase) occur. The refrigerantand HTF-side sensors are mounted on the return bends of each inner/outer tube, respectively.

The instruments are scanned once per minute by the data acquisition (DAQ) system, and when steady state is achieved, the measurements are calculated as the average of a moving window of 30 readings (i.e., the average over the last 30 minutes). The measurements inevitably fluctuate during steady state, which contributes to the uncertainty of the measurement. This "steady state" uncertainty has been quantified for a nominal test condition and is listed in Table 2-3. The total measurement uncertainty (last column of Table 2-3) is found by adding the instrument error and the steady state error in quadrature. A detailed discussion of the selection of the steady state moving window size and computation of steady state uncertainty is shown in Appendix A.10.

Instrument	Range	Instrument Uncertainty ¹	Steady State Uncertainty ¹	Total Uncertainty ^{1,2}
Coriolis meter (HTF)	Mass flow: (0 to 756) gs ⁻¹	Mass flow ³ : $\pm 0.1\%$ rdg.	Mass flow: ± 0.23 gs ⁻¹	Mass flow: ±0.26 gs ⁻¹
	Density: $(0 \text{ to } 3) \text{ g cm}^{-3}$	Density: ±0.001 gcm ⁻³	Density: ±0.0001 gcm ⁻³	Density: ±0.001 gcm ⁻³
Coriolis meter (refrigerant)	Mass flow: (0 to 60)5 gs ⁻¹	Mass flow ⁴ : $\pm 0.1\%$ rdg.	Mass flow: $\pm 0.01 \text{ gs}^{-1}$	Mass flow: ± 0.016 gs ⁻¹
	Density: $(0 \text{ to } 3) \text{ g cm}^{-3}$	Density: ±0.0005 gcm ⁻³	Density: ±0.0001 gcm ⁻³	Density: ±0.0005 gcm ⁻³
Data acquisition system	(-10 to 10) V	$\pm 1 \ \mu V$		$\pm 1 \ \mu V$
Press. transducer (diff.) – condenser	(0 to 172) kPa	±0.7 kPa	±0.8 kPa	±1.3 kPa
Press. transducer (diff.) – evaporator	(0 to 345) kPa	±0.1 kPa	±0.8 kPa	±0.8 kPa
Press. transducer (diff.) – suction	(0 to 69) kPa	±0.01 kPa	±0.3 kPa	±0.3 kPa
Press. transducer (high press.)	(0 to 3447) kPa	±3.4 kPa	±0.7 kPa	±3.5 kPa
Press. transducer (low press.)	(0 to 1724) kPa	±3.4 kPa	±0.7 kPa	±3.5 kPa
Tachometer	(0.17 to 1667) Hz (10 to 99 999) RPM	±0.0167 Hz ±1 RPM	±0.005 Hz ±0.3 RPM	±0.0173 Hz ±1.04 RPM
Thermocouple (in-stream probe, ice ref.)	(-10 to 100) °C	±0.08 °C	±0.06 °C	±0.09 °C
Thermocouple (surface-mount, CJC)	(-10 to 60) °C	±0.6 °C	±0.04 °C	±0.6 °C
Thermopile ⁵	(1 to 10) K	±0.015 K	±0.013 K	±0.0153 K
Thermopile voltage	(-10 to 10) V	$\pm 1 \ \mu V$	$\pm 6.5 \ \mu V$	$\pm 7 \ \mu V$
Torque meter	(0 to 40) N m	±0.33 Nm	±0.005 Nm	0.33 Nm

Table 2-3: List of MBBHP instruments (SI units)

¹ 95% confidence interval (k = 2) -

 2 % rdg values have been applied to nominal values -

³ Maximum of 0.1% and (z.s./flowrate)*100 %, where z.s. is zero stability = 0.0491 gs^{-1} .

⁴ Maximum of 0.1% and (z.s./flowrate)*100 %, where z.s. is zero stability = 0.0075 g s⁻¹. -

⁵ For temperature differences in 1 K to 10 K range. Outside range, uncertainty is higher. See Appendix A.5 for more - detail.

Instrument	Range	Instrument Uncertainty ¹	Steady State Uncertainty ¹	Total Uncertainty ^{1,2}
Coriolis meter (HTF)	Mass flow: (0 to 100) lb min ⁻¹	Mass flow ³ : $\pm 0.1\%$ rdg.	Mass flow: ± 0.03 lb min ⁻¹	Mass flow: ±0.035 lb min ⁻¹
	Density: (0 to 187) lb ft ⁻³	Density: ±0.062 lb ft ⁻³	Density: ± 0.006 lb ft ⁻³	Density: ±0.062 lb ft ⁻³
Coriolis meter (refrigerant)	Mass flow: (0 to 79.9) lb min ⁻¹	Mass flow ⁴ : ±0.1% rdg.	Mass flow: ± 0.0015 lb min ⁻¹	Mass flow: ± 0.002 lb min ⁻¹
	Density: (0 to 187) lb ft ⁻³	Density: ±0.062 lb ft ⁻³	Density: ±0.006 lb ft ⁻³	Density: ± 0.062 lb ft ⁻³
Data acquisition system	(-10 to 10) V	$\pm 1 \ \mu V$		$\pm 1 \ \mu V$
Press. transducer (diff.) – condenser	(0 to 25) psi	±0.1 psi	±0.1 psi	±0.18 psi
Press. transducer (diff.) – evaporator	(0 to 50) psi	±0.015 psi	±0.1 psi	±0.1 psi
Press. transducer (diff.) – suction	(0 to 10) psi	±0.0015 psi	±0.04 psi	±0.04 psi
Press. transducer (high press.)	(0 to 500) psia	±0.5 psi	±0.1 psi	±0.51 psi
Press. transducer (low press.)	(0 to 250) psia	±0.5 psi	±0.1 psi	±0.51 psi
Tachometer	(0.17 to 1667) Hz (10 to 99 999) RPM	±0.0167 Hz ±1 RPM	±0.005 Hz ±0.3 RPM	±0.0173 Hz ±1.04 RPM
Thermocouple (in-stream probe, ice ref.)	(14 to 212) °F	±0.15 °F	±0.11 °F	±0.18 °F
Thermocouple (surface-mount, CJC)	(14 to 140) °F	±1.1 °F	±0.08 °F	±1.1 °F
Thermopile ⁵	(1.8 to 18) °F	±0.027 °F	±0.023 °F	±0.04 °F
Torque meter	(0 to 350) in lb	±2.9 in lb	±0.045 in lb	±2.9 in lb

Table 2-4: List of MBBHP instruments (I-P units)

⁻¹ 95% confidence interval (k = 2)

² % rdg values have been applied to nominal values

³ Maximum of 0.1% and (z.s./flowrate)*100 %, where z.s. is zero stability = $0.0065 \text{ lb min}^{-1}$

⁴ Maximum of 0.1% and (z.s./flowrate)*100 %, where z.s. is zero stability = 0.001 lb min⁻¹

⁵ For temperature differences in 1.8 °F to 18 °F range. Outside range, uncertainty is higher. See Appendix A.5 for more detail.

2.3 Operation

2.3.1 Test Rig Control Parameters

There are ten Control Parameters (i.e., settings of adjustable components) listed in Table 2-5 that the MBBHP operator sets to achieve a desired set of Operating Parameters. Each Control Parameter primarily governs one or two Operating Parameters; the correspondence is shown in the table.

#	Operating Parameter	Operating Parameter Values	Control Parameter
1	Evaporator saturation temperature	See Table 2-6	Heater setpoint (HTF inlet temp.)
2	Condenser saturation temperature	See Table 2-6	Chiller setpoint (HTF inlet temp.)
3	Capacity/heat flux	1760 W to 3520 W (0.5 ton to 1 ton)	Compressor speed
4	Evaporator heat flux	$\begin{array}{c} 2000 \ W \ m^{-2} \ to \ 12 \ 000 \ W \ m^{-2} \\ (600 \ Btu \ h^{-1} \ ft^{-2} \ to \ 3800 \ Btu \ h^{-1} \ ft^{-2}) \end{array}$	Number of evaporator tubes
5	Condenser heat flux	$\begin{array}{c} 2000 \ W \ m^{-2} \ to \ 12 \ 000 \ W \ m^{-2} \\ (600 \ Btu \ h^{-1} \ ft^{-2} \ to \ 3800 \ Btu \ h^{-1} \ ft^{-2}) \end{array}$	Number of condenser tubes
6	Condenser HTF-side resistance	50 % to 70 % of overall resistance	Condenser HTF flowrate
7	Evaporator HTF-side resistance	70 % to 85 % of overall resistance	Evaporator HTF flowrate
8	Subcool/ Superheat	$\leq 2 \text{ tubes}^1 / \leq 1 \text{ tube}^2$	Refrigerant needle valve setting
9	Subcool/ Superheat	$\leq 2 \text{ tubes}^1 / \leq 1 \text{ tube}^2$	Refrigerant charge
10	LLSL-HX included/bypassed	Included/bypassed	LLSL-HX valves

 Table 2-5: List of the Control Parameters and Operating Parameters

¹achieved with subcooling of 2 K to 3 K (1.8 °F to 3.6 °F)

²achieved with superheat of 3 K to 6 K (5.4 °F to 10.8 °F)

2.3.2 Test Rig Operating Parameters

This section describes each of the target Operating Parameters, and how they are set using the Control Parameters. Note that the headings for Sections 2.3.2.1 through 2.3.2.5 include the Operating Parameters numbers (1 to 10) as listed in Table 2-5.

2.3.2.1 Operating Parameters 1 & 2: Evaporator and Condenser Saturation Temperature

The U.S. Department of Energy (DOE) requires heat pumps and air conditioners to be rated at conditions prescribed in the ANSI/AHRI 210/240-2008 (AHRI, 2008) standard. The standard specifies temperatures of the HTF (air, in the standard) entering the evaporator and condenser. A somewhat different, but derivative, method is employed here; the HTF inlet temperatures are set to achieve refrigerant saturation temperatures expected under ANSI/AHRI Cooling A, Cooling B and Heating H1 Rating Tests for the baseline refrigerant R134a.

The target saturation temperatures are computed first for the Cooling A test where the assumed Coefficient of Performance (COP_{cool}) is 4.4 (energy efficiency ratio, EER, is 15). The

ANSI/AHRI standard is not prescriptive about airflow, so typical values per unit evaporator capacity are used: for the evaporator $(\dot{V}_{air,evap}/\dot{Q}_{evap})$, 0.189 m³s⁻¹kW⁻¹ (400 ft³min⁻¹ton⁻¹), and for the condenser $(\dot{V}_{air,cond}/\dot{Q}_{evap})$, 0.378 m³s⁻¹kW⁻¹ (800 ft³min⁻¹ton⁻¹). Inlet air temperatures $(T_{air,in})$ prescribed by the ANSI/AHRI standard are listed in Table 2-6; the temperature change across the evaporator and condenser $(\Delta T_{air,evap}, \Delta T_{air,cond})$ is 12.6 K and 9.7 K (22.8 °F and 17.5 °F), respectively, as computed using an energy balance on the airstream, where the condenser energy is larger by an amount that reflects the compressor power (in the COP term):

$$\Delta T_{air,evap} = \left(\dot{V}_{air,evap} / \dot{Q}_{evap}\right)^{-1} \frac{1}{\rho_{air} C_{p,air}}$$
(2.1)

$$\Delta T_{air,cond} = \left(\dot{V}_{air,cond} / \dot{Q}_{evap}\right)^{-1} \left(1 + \frac{1}{\text{COP}_{cool}}\right) \frac{1}{\rho_{air} C_{p,air}}$$
(2.2)

where the variables represent:

$$C_{p,air}$$
 = specific heat of air at constant pressure
 $\dot{V}_{air,cond}/\dot{Q}_{evap}$ = condenser airflow per unit evaporator capacity
 $\dot{V}_{air,evap}/\dot{Q}_{evap}$ = evaporator airflow per unit evaporator capacity
 ρ_{air} = density of air

The air outlet temperatures ($T_{air,out}$) are then computed by respectively subtracting or adding the $\Delta T_{air,evap}$, $\Delta T_{air,cond}$, from the $T_{air,in}$ values.

The average temperature difference between the refrigerant and the air ($\Delta T_{air,ref}$) for Cooling A is specified as 10 K and 3.3 K (18 °F and 6 °F) in the evaporator and condenser, respectively, based on experience and measurements at NIST for air-source heat pumps with comparable COPs. Table 2-6 shows the average air ($T_{air,avg}$) and average refrigerant saturation temperatures ($T_{ref,avg}$) computed using this method. The Cooling B refrigerant saturation temperatures are computed using the same ΔT_{air} and $\Delta T_{air,ref}$. In heating, the heat exchangers operating as the evaporator/condenser swap, so the values of ΔT_{air} and $\Delta T_{air,ref}$ for the evaporator (in cooling) are used for the condenser, and vice versa. The resulting refrigerant saturation temperatures are nominally aligned with values observed in heat pump measurements at NIST. The HTF inlet temperatures ($T_{HTF,in}$) are adjusted to achieve the target refrigeration saturation temperature at a compressor speed of 30 Hz (1800 RPM) with R134a, and then held constant for all other speeds. The corresponding HTF outlet temperatures ($T_{HTF,out}$) are defined as:

$$T_{HTF,e,out} = T_{HTF,e,in} + \Delta T_e \tag{2.1}$$

$$T_{HTF,c,out} = T_{HTF,c,in} + \Delta T_c \tag{2.2}$$

where ΔT_e and ΔT_c are the HTF temperature differences across the evaporator/condenser measured by the thermopiles. The $T_{HTF,out}$ values differ for each speed; Table 2-6 shows the values at 30 Hz (1800 RPM) as a nominal example. As discussed in Section 1, a completely fair comparison of refrigerants requires the same HTF inlet *and* outlet temperatures (McLinden et al., 1987). However, it is only possible to match either the evaporator or condenser (but not both) $T_{HTF,out}$ by adjusting the heat pump capacity (via compressor speed); the other $T_{HTF,out}$ will be an uncontrolled value, which will vary somewhat from the R134a value, depending on the COP of each fluid (note the HTF mass flow rate is fixed as described in Section 2.3.2.3, so it cannot be adjusted to control the other $T_{HTF,out}$). Tests with future refrigerants will be carried out with an evaporator or condenser $T_{HTF,out}$ equal to the measurements for R134a in cooling or heating, respectively, and the other $T_{HTF,out}$ will vary for each fluid.

	Rating Test	<i>Tair,in</i> °C (°F)	Δ <i>T_{air}</i> K (°F)	Tair,out °C (°F)	<i>T_{air,avg}</i> °C (°F)	Δ <i>T_{air,ref}</i> K (°F)	<i>T_{ref,avg}</i> °C (°F)	<i>T_{HTF,in}</i> °C (°F)	<i>T_{HTF,out}¹</i> °C (°F)	\dot{m}_{HTF} kg s ⁻¹ lb min ⁻¹
	Cooling A	35.0 (95.0)	9.7 (17.5)	44.7 (112.5)	39.9 (103.8)	3.3 (6.0)	43.2 (109.8)	33.9 (93.0)	39.1 (102.4)	0.098 (13)
Condenser	Cooling B	27.8 (82.0)	9.7 (17.5)	37.5 (99.5)	32.6 (90.8)	3.3 (6.0)	36.0 (96.8)	24.9 (76.7)	30.9 (87.6)	0.098 (13)
	Heating H1	21.1 (70.0)	12.6 (22.8)	33.8 (92.8)	27.4 (81.4)	10.0 (18.0)	37.4 (99.4)	32.0 (89.5)	36.3 (97.3)	0.098 (13)
	Cooling A	26.7 (80.0)	12.6 (22.8)	14.0 (57.3)	20.3 (68.6)	10.0 (18.0)	10.3 (50.6)	20.2 (68.5)	15.4 (59.7)	0.131 (17.3)
Evaporator	Cooling B	26.7 (80.0)	12.6 (22.8)	14.0 (57.3)	20.3 (68.6)	10.0 (18.0)	10.3 (50.6)	19.9 (67.8)	14.2 (57.6)	0.131 (17.3)
	Heating H1	8.3 (47.0)	9.7 (17.5)	-1.4 (29.5)	3.5 (38.3)	3.3 (6.0)	0.1 (32.3)	10.3 (50.5)	6.5 (43.7)	0.131 (17.3)

Table 2-6:	Evaporator and	condenser fluid	temperatures f	for standard	rating tests
	1		1		

¹ Values for R134a at a compressor speed of 30 Hz (1800 RPM)

2.3.2.2 Operating Parameters 3, 4, & 5: Capacity and Heat Flux

Baseline capacities were established for R134a at speeds of 23.3 Hz to 36.7 Hz (1400 RPM to 2200 RPM), in 3.3 Hz (200 RPM) increments, for each Rating Test. Tests with subsequent refrigerants will be carried out with compressor speeds that match the capacities from the baseline tests; this ensures the refrigerants are tested at the same \dot{Q}/A_{total} . The target refrigerant-side heat flux range was 2 kW m⁻² to 12 kW m⁻² (600 Btu h⁻¹ ft⁻² to 3800 Btu h⁻¹ ft⁻²) to coincide with values from typical HVAC&R equipment. The average heat flux in the evaporator and condenser was controlled by setting the number of active tubes to 10 and 12, respectively. Figure 2-6 summarizes the capacity for the baseline tests, where the evaporator capacity varies from 1.2 kW to 2.1 kW (0.34 ton to 0.60 ton) and condenser capacity ranges from 1.6 kW to 2.8 kW (0.45 ton to 0.80 ton). The heat flux in the evaporator varies from 5 kW m⁻² to 9 kW m⁻² (1600 Btu h⁻¹ ft⁻² to 3200 Btu h⁻¹ ft⁻²), meeting the target heat flux range.



Figure 2-6: - Capacity and heat flux for baseline R134a tests for (a) evaporator and (b) condenser

2.3.2.3 Operating Parameters 6 & 7: HTF-side Thermal Resistance Ratio

In typical air-to-air heat pumps the air-side convection provides the majority of the resistance to heat transfer. Evaporation heat transfer coefficients are generally larger than those for condensation, so the HTF-side resistance ratio (R_{HTF}/R_{total}) is selected in the range of 50 % to 70 % for the condenser and 70 % to 85 % in the evaporator. The CYCLE_D-HX model reports heat exchanger thermal resistances for both the evaporator and condenser when given measurements of HTF in/out temperatures, capacity, compressor efficiency, and heat exchanger geometry, pressure drop, and log-mean temperature difference. These resistances include the heat exchanger total conductance (*UA*) (the total resistance, R_{total} , is the inverse of *UA*), the heat transfer-side resistance (R_{HTF}) in the evaporator/condenser, and the refrigerant-side thermal resistance is neglected.

The MBBHP was operated under varied HTF flowrates (\dot{m}_{HTF}), and the resulting data were processed using the CYCLE_D-HX model to determine R_{HTF}/R_{total} for each flowrate. The evaporator and condenser HTF flowrates used for the tests are 0.131 kg s⁻¹ and 0.098 kg s⁻¹ (17.3 lb min⁻¹ and 13 lb min⁻¹) as shown in Table 2-6, which yield R_{HTF}/R_{total} of 80 % and 60 % for the baseline Cooling A test with R134a at 30 Hz (1800 RPM). The flowrates are kept constant for all other speeds, test conditions, and refrigerants. Maintaining a constant flowrate is important for verifying the CYCLE_D-HX model; the model evaluates the HTF-side thermal resistance for a reference data set, and then holds this resistance constant as other operating parameters, refrigerants, and tube circuit configurations are computationally explored.

2.3.2.4 Operating Parameters 8 & 9: Subcool and Superheat

The number of evaporator tubes containing superheated-vapor and condenser tubes with subcooled-liquid are controlled to one and two, respectively. It is important to limit the number of tubes in superheat and subcooling for comparison with the CYCLE_D-HX model because the

model does not consider the pressure drop or area required for heat transfer in these sections, rather, it only accounts for transport phenomena in the two-phase section. (Note that the superheat and subcooling are included as an input to the model to determine the thermodynamic states at the heat exchanger outlets.) The superheat and subcooling are also limited because of performance considerations; the single phase fluid exhibits a lower heat transfer coefficient compared to a two-phase fluid. The superheat is bound at the low end by the need to prevent liquid from entering the compressor. The lower limit for subcooling is governed by a requirement of fully subcooled liquid entering the expansion valve; vapor bubbles entering the expansion valve cause oscillations in the flow that make it difficult to achieve steady state. In general, a superheat range of 3 K to 6 K and a subcooling range of 2 K to 3 K satisfies this Operating Parameter requirement.

Closing the refrigerant needle valve increases the superheat and the subcooling, whereas adding refrigerant increases the subcooling and reduces the superheat. The combination of these two controls allows for independent regulation of superheat and subcooling.

2.3.2.5 Operating Parameter 10: LLSL-HX included or bypassed

The LLSL-HX heat exchanger is included or bypassed using the six valves shown in Figure 2-1. When the LLSL-HX is bypassed, only one (rather than both) of the valves that stops flow through the heat exchanger is closed; this prevents the possibility of trapping subcooled liquid between the valves (and presenting the same pressure hazard discussed in Section 2.1.

3 Data Analysis -

3.1 Thermodynamic States

The thermodynamic states numbered 1 through 11 in Figure 2-1 are fixed with two intensive properties defined by the measurements and equations presented in Table 3-1. Thermodynamic property data for R134a are computed using the Engineering Equation Solver (EES) software (Klein, 2015); the software uses the equation of state developed by Tilner-Roth et al. (1994) for R134a. Note that property data for mixtures and for fluids not directly available in EES will be computed using the NIST REFPROP database (Lemmon et al., 2013).

State	Description	Measurement	Equation	ns
1	Compressor inlet, LLSL-HX vapor outlet	T_{I}	$P_1 = P_{11} - \Delta P_s$	
2	Compressor cylinder before compression		$T_2 = T_1$	$P_2 = P_1$
3	Compressor outlet	T_3	$P_3 = P_4$	
4	Condenser inlet	T_4	$P_4 = P_7 + \Delta P_c$	
5	Condenser saturated vapor		$P_5 = P_4$	$x_5 = 1$
6	Condenser saturated liquid		$P_6 = P_7$	$x_6 = 0$
7	Condenser outlet, LLSL-HX liquid inlet	T_{7}, P_{7}		
8	Expansion valve inlet, LLSL-HX liquid outlet	T_8	$P_8 = P_7$	
9	Evaporator inlet, Expansion valve outlet	P_{9}	$h_9 = h_8$	
10	Evaporator saturated vapor		$P_{10} = P_{11}$	$x_{10} = 1$
11	Evaporator outlet, LLSL-HX vapor inlet	T_{11}	$P_{11} = P_9 - \Delta P_e$	

Table 3-1: Measurements and equations used to define the thermodynamic states

T = temperature, P = pressure, h = enthalpy, x = thermodynamic quality

3.2 Thermodynamic Performance

Given the fixed state points identified in Table 3-1 (and all associated intensive properties), the key thermodynamic performance metrics are calculated according to the equations in Sections 3.2.1 through 3.2.7. Nominal values and uncertainties of the metrics are shown in Section 4, and Appendix A, respectively.

3.2.1 Capacity

The evaporator and condenser capacities are computed on the refrigerant/HTF-sides according to:

$$\dot{Q}_{c,ref} = \dot{m}_{ref} \left(h_4 - h_7 \right) \tag{3.1}$$

$$\dot{Q}_{e,ref} = \dot{m}_{ref} \left(h_9 - h_{11} \right)$$
 (3.2)

$$\dot{Q}_{c,HTF} = \dot{m}_{HTF,c} C_{p,HTF,c} \Delta T_c - \dot{Q}_{ins,c}$$
(3.3)

$$Q_{e,HTF} = \dot{m}_{HTF,e} C_{p,HTF,e} \Delta T_e - Q_{ins,e}$$
(3.4)

where the variables represent:

$$\dot{m}_{ref}$$
 = mass flow of refrigerant
 $\dot{m}_{HTF,e}$ $\dot{m}_{HTF,c}$ = mass flow of HTF in evaporator/condenser
 $C_{p,HTF,e}$ $C_{p,HTF,c}$ = specific heats (average) of HTF in evaporator/condenser
 $\dot{Q}_{ins,e}$ $\dot{Q}_{ins,c}$ = insulation heat leak in evaporator/condenser
 ΔT_e ΔT_c = temperature change of HTF in evaporator/condenser

The insulation heat leak is a non-trivial 30 W to 50 W, and therefore must be accounted for in the heat exchanger capacity. The heat leak is debited from the HTF-side capacity because the HTF is the annulus, and therefore thermally interacts with the surrounding ambient air. The heat exchangers are divided into active and inactive sections (i.e., tubes where the HTF flows, but the refrigerant does and does not, respectively) to compute the heat leak according to:

$$\dot{Q}_{ins,e} = UA_{ins,e} \left(\frac{NT_{e,active}}{NT_{e,total}} \left(T_{HTF,e,active,avg} - T_{amb,e} \right) + \frac{NT_{e,inactive}}{NT_{e,total}} \left(T_{HTF,e,inactive,avg} - T_{amb,e} \right) \right)$$
(3.5)

$$\dot{Q}_{ins,c} = UA_{ins,c} \left(\frac{NT_{c,active}}{NT_{c,total}} \left(T_{HTF,c,active,avg} - T_{amb,c} \right) + \frac{NT_{c,inactive}}{NT_{c,total}} \left(T_{HTF,c,inactive,avg} - T_{amb,c} \right) \right)$$
(3.6)

where:

UA _{ins,e}	UA _{ins,c}	= insulation conductance for evaporator/condenser
NT _{e,total}	NT _{e,total}	= number of tubes in evaporator/condenser total (20)
NT _{e,active}	$NT_{c,active}$	= number of active tubes in evaporator/condenser
$NT_{e,inactive}$	$NT_{e,inactive}$	= number of inactive tubes in evaporator/condenser
$T_{HTF,e,active,avg}$	THTF,c,active,avg	= avg. HTF temp. in the active evaporator/condenser tubes
$T_{HTF,e,inactive,avg}$	$T_{HTF,c,inactive,avg}$	= avg. HTF temp. in the inactive evaporator/condenser tubes
Tamb,e	Tamb,c	= temp. of ambient air surrounding evaporator/condenser

The HTF temperatures are taken from the surface-mounted thermocouples, and the ambient air temperature is taken from a thermocouple near each of the heat exchangers. The heat exchangers are split into active/inactive sections because the slope of the HTF temperature profile is different in each section; the heat transfer is only governed by the average temperature difference if the slopes (and specific heats) are constant throughout the section. The $UA_{ins,e}$ and $UA_{ins,c}$ values for all 20 tubes are 5.48 W K⁻¹ ±0.31 W K⁻¹ and 6.52 W K⁻¹ ±0.41 W K⁻¹ (10.4 Btu h⁻¹ °F⁻¹ ±0.59 Btu h⁻¹ °F⁻¹ and 12.4 Btu h⁻¹ °F⁻¹ ±0.78 Btu h⁻¹ °F⁻¹). The method used to compute the conductance values and their uncertainties is described in Appendix A.8.

3.2.2 Compressor Power

The compressor power is computed using the change in enthalpy across the compressor:

$$W_{comp} = \dot{m}_{ref} \left(h_3 - h_1 \right) \tag{3.7}$$

The shaft power is computed for comparison with the compressor power:

$$\dot{W}_{shaft} = 2\pi \tau N \tag{3.8}$$

where the variables represent:

N =compressor shaft speed $\tau =$ compressor shaft torque

3.2.3 Coefficient of Performance

The cooling and heating COP are computed using the refrigerant-side capacity and the compressor power applied to the refrigerant:

$$\operatorname{COP}_{cool} = \dot{Q}_{e,ref} / \dot{W}_{comp}$$
(3.9)

$$\operatorname{COP}_{heat} = \dot{\mathcal{Q}}_{c,ref} / \dot{\mathcal{W}}_{comp}$$
(3.10)

3.2.4 Volumetric Capacity

The volumetric cooling and heating capacity (VCC and VHC) are:

$$VCC = \dot{Q}_{e,ref} / \left(\dot{m}_{ref} v_1 \right) \tag{3.11}$$

$$VHC = \dot{Q}_{c,ref} / (\dot{m}_{ref} v_1)$$
(3.12)

where:

 v_1 = compressor suction specific volume

3.2.5 Compressor Efficiency

The compressor isentropic efficiency is calculated as: -

$$\eta_s = \frac{h(P_3, s_1) - h_1}{h_3 - h_1} \tag{3.13}$$

where:

 $h(P_{3},s_{1})$ = compressor discharge enthalpy under isentropic compression

The volumetric efficiency is quantified by the refrigerant displacement normalized by the compressor swept volume displacement:

$$\eta_{v} = \frac{\dot{m}_{ref} v_{1}}{D_{comp} N}$$
(3.14)

where:

 D_{comp} = compressor displacement (listed in Table 2-1)

3.2.6 Superheat and Subcooling

The evaporator superheat is:

$$SH = T_{11} - T(P_{11}, x = 1)$$
(3.15)

and the condenser subcooling is:

$$SC = T(P_7, x = 0) - T_7$$
 (3.16)

where:

 $T(P_{11}, x = 1)$ = saturated vapor temperature at the evaporator exit pressure - $T(P_7, x = 0)$ = saturated liquid temperature at the condenser exit pressure -

The number of refrigerant tubes containing superheated/subcooled fluid in the evaporator/condenser is controlled to one and two, respectively, during experimental tests. Visual inspection of the temperature profile, such as the one shown in Figure 3-1, is used to determine the locations of the various phase transitions. The tube number on the x-axis reflects the convention established in Figure 2-5.



Figure 3-1: - Temperature profile in (a) evaporator, showing superheat and (b) condenser, showing subcooling

-O- 1400 RPM -D- 1600 RPM -A- 1800 RPM -X- 2000 RPM -V- 2200 RPM

*The location 21 is the exit of the 20th tube

3.2.7 LLSL-HX Effectiveness

The LLSL-HX effectiveness is computed as the ratio of the heat transferred on the vapor

side $(\dot{Q}_{LLSL,v})$ to the maximum possible heat transfer:

$$\varepsilon_{LLSL} = \frac{Q_{LLSL,v}}{\dot{Q}_{LLSL,max}} = \frac{C_{p,avg,1,11}(T_1 - T_{11})}{\text{MIN}(C_{p,avg,1,11}, C_{p,avg,7,8})(T_7 - T_{11})}$$
(3.17)

where:

 $C_{p,avg,1,11}$ = average specific heats of the refrigerant on the vapor side -

 $C_{p,avg,7,8}$ = average specific heats of the refrigerant on the liquid side -

The heat transfer on the vapor side, rather than liquid side, is chosen for the numerator because the larger temperature difference exhibited on the vapor side (due to lower specific heat) results in a smaller uncertainty in the effectiveness.

4 Validation and Baseline Tests with R134a -

An initial set of tests were carried out with R134a to provide verification of the instrumentation and show the nominal uncertainties of the measurements. One of the most important validations is to show an energy balance between the refrigerant and the HTF in the heat exchangers. The energy imbalance, defined as $\dot{Q}_{ref} / (\dot{Q}_{ref} - \dot{Q}_{HTF})$, for the initial tests is shown in Figure 4-1; the imbalance is generally around 1 % to 1.5 % or better in both the evaporator and condenser. The imbalance falls well within its uncertainty at the 95 % confidence interval, indicating that the estimation of the uncertainty in HTF capacity (3 %) is likely too conservative; note that the HTF capacity accounts for more than 90 % of the relative uncertainty in the imbalance metric.



Figure 4-1: Energy imbalance in the evaporator and condenser

The performance of R134a in the MBBHP, as described by the metrics defined in Section 3.2, are presented in Figure 4-2 through Figure 4-4. Figure 4-2 (a) and (b) show nominal pressure profiles on the low/high pressure sides of the cycle, where the error bars represent measurement uncertainty listed in Table 2-3. The compressor power measured both by the shaft power and change of enthalpy of the working fluid are shown in Figure 4-3(a), where the conversion from mechanical to fluid power is about 65 % efficient. The error bars represent the uncertainty calculated by propagating measurement uncertainty through Eqs. (3.7) and (3.8). The mass flow ranges from 8 gs⁻¹ to 13 gs⁻¹ (1.1 lbmin⁻¹ to 1.7 lbmin⁻¹). Figure 4-4 shows the COP ranges from 2.4 to 4, and the capacity ranges from 1.6 kW to 2.1 kW (0.45 ton to 0.60 ton). The figure shows the uncertainty is described further in Appendix A.10 and A.11. The volumetric capacity ranges from 2100 kJ m⁻³ to 2800 kJ m⁻³ (56 Btu ft⁻³ to 75 Btu ft⁻³), and the compressor isentropic and volumetric efficiencies are nominally 0.46 and 0.55; uncertainties in all three of these metrics are shown in the figures and are computed using a similar method as the capacity/COP, but the computation is not discussed in detail in this report.

Figure 4-3 (b) also shows the mass flux, which is used to determine the two-phase flow regimes indicated in Figure 4-5. The refrigerant generally entered the annular flow regime in the evaporator and condenser, though for some tests with low mass flux the refrigerant never left the stratified-wavy regime.



Figure 4-2: - Heat pump cycle pressures on the (a) low pressure side and (b) high - pressure side -



Figure 4-3: - Performance metrics including (a) compressor power and (b) mass flow and mass flux



Figure 4-4: Performance metrics including (a) COP, (b) capacity, (c) volumetric capacity, and (d) compressor isentropic and volumetric efficiency



Figure 4-5: - Flow regime map for microfin tube (a) evaporation and (b) condensation

¹ Flow boiling regime map from (Wojtan et al., 2005) -

² Flow condensation regime map from (Hajal et al., 2003) -

³ Boundary between Intermittent/Annular regimes from (Thome, 2007), using equation 12.6.1 with a coefficient - of 0.678, for helical microfins

5 Conclusions and Future Work

This report shows that the test apparatus is capable of measuring the performance of low-GWP refrigerants with high fidelity, including less than 0.5 % uncertainty in both capacity and COP. The energy balance closure on the evaporator and condenser was better than 1.5 % and will be continually tracked to ensure continued high quality data are collected.

Future tests will include a second baseline refrigerant R410A, followed by a series of comparative tests with low-GWP refrigerants and refrigerant mixtures. The HTF flowrates will remain fixed from the R134a baseline tests, so that the CYCLE_D-HX simulations of the test data can be carried out for all test data based on a single reference data set. After the model results are verified, the model will be used to identify additional candidate refrigerants to test in the MBBHP test apparatus.

6 References -

- AHRI. (2008). 2008 Standard for Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment. Air-Conditioning, Heating, and Refrigeration Institute, Arlington, VA, United States. Retrieved from www.ahrinet.org
- AHRI. (2015). Participants' Handbook: AHRI Low-GWP Alternative Refrigerants Evaluation Program (Low-GWP AREP). Arlington, VA, United States: Air-Conditioning, Heating, and Refrigeration Institute. Retrieved from http://www.ahrinet.org/site/514/Resources/Research/AHRI-Low-GWP-Alternative-Refrigerants-Evaluation
- Brown, J. S., Domanski, P. A., & Lemmon, E. (2011). Standard Reference Database 49, CYCLE_D: NIST Vapor Compression Cycle Design Program, Version 5.0. Retrieved from http://www.nist.gov/srd/nist49.cfm
- Domanski, P. A., Brown, S. J., Heo, J., Wojtusiak, J., & McLinden, M. O. (2014). A thermodynamic analysis of refrigerants: Performance limits of the vapor compression cycle. *International Journal of Refrigeration*, 38, 71-79. doi:10.1016/j.ijrefrig.2013.09.036
- EPA. (2015). 2015 North American Amendment Proposal to Address HFCs under the Montreal Protocol. Retrieved from http://www.epa.gov/ozone/intpol/mpagreement.html and http://www.epa.gov/ozone/intpol/HFC_Amendment_2015_Summary.pdf
- EU. (2014, April 16). Regulation (EU) No 517/2014 of the European Parliament and of the Council of 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) No 842/2006. *Journal of the European Union*. Retrieved from http://eurlex.europa.eu/legal-content/EN/TXT/?uri=uriserv:OJ.L .2014.150.01.0195.01.ENG
- Fortin, T. J. (2015). Personal communication.
- Hajal, J. E., Thome, J. R., & Cavallini, A. (2003). Condensation in horizontal tubes, part 1: twophase flow pattern map. *International Journal of Heat and Mass Transfer*, 3349-3363. doi:10.1016/S0017-9310(03)00139-X
- Harr, L., Gallagher, J. S., & Kell, G. S. (1984). *NBS/NRC Steam Tables*. Hemisphere Publishing Co.
- Kazakov, A., McLinden, M. O., & Frenkel, M. (2012). Computational Design of New Refrigerant Fluids Based on Environmental, Safety, and Thermodynamic Characteristics. *Industrial & Engineering Chemistry Research*, 51, 12537-12548. doi:10.1021/ie3016126
- Kim, Y., Payne, V., Choi, J., & Domanski, P. A. (2005). Mass flow rate of R-410A through short tubes working near the critical point. *International Journal of Refrigeration*, 28, 547-553. doi:10.1016/j.ijrefrig.2004.10.007
- Klein, S. A. (2015). Engineering Equation Solver, v 9.908. Retrieved from http://www.fchart.com/ees/
- Lemmon, E. W., Huber, M. L., & McLinden, M. O. (2013). NIST Standard Reference Database 23, Reference Fluid Thermodynamic and Transport Properties (REFPROP), Version 9.1.

National Institute of Standards and Technology. Retrieved from - http://www.nist.gov/srd/nist23.cfm -

- McLinden, M. O., & Radermacher., R. (1987). Methods for Comparing the Performance of Pure and Mixed Refrigerants in the Vapour Compression Cycle. *International Journal of Refrigeration*, 10(6), 318-325. doi:10.1016/0140-7007(87)90117-4
- McLinden, M. O., Kazakov, A., Heo, J., Brown, J. S., & Domanski, P. A. (2014). A thermodynamic analysis of refrigerants: Possibilities and tradeoffs for Low-GWP refrigerants. *International Journal of Refrigeration*, 38, 80-92. doi:10.1016/j.ijrefrig.2013.09.032
- Pannock, J., & Didion, D. A. (1991). The Performance of Chlorine-Free Binary Zeotropic Refrigerant Mixtures in a Heat Pump, NISTIR 4748. Internal Report, National Institute of Standards and Technology, U.S. Department of Commerce, Gaithersburg. Retrieved from http://fire.nist.gov/bfrlpubs/build91/art002.html
- Solomon, S., Qin, D., Manning, M., Chen, Z., Marquis, M., Averyt, K. B., . . . Miller, H. L. (2007). Contribution of Working Group I to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change. New York, NY, USA: Cambridge University Press. Retrieved July 29, 2015, from http://www.ipcc.ch/publications_and_data/publications_ipcc_fourth_assessment_report_wg1 report the physical science basis.htm
- Taylor, B. N., & Kuyatt, C. E. (1994). Guidelines for Evaluating and Expressing the Uncertainty of NIST Measurement Results, National Institute of Standards and Technology Technical Note 1297.
- Thome, J. R. (Updated in 2007). Wolverine Heat Transfer Engineering Data book III. Germany: Weiland-Werke AG. Retrieved from http://www.wlv.com/heat-transfer-databook/
- Tilner-Roth, R., & Baehr, H. D. (1994). An International Standard Formulation for the Thermodynamic Properties of 1,1,1,2-Tetrafluoroethane (HFC-134a) for Temperatures from 170 K to 455 K and Pressures up to 70 MPa. *J. Phys. Chem, Ref. Data, 23*(5).
- Wojtan, L., Ursenbacher, T., & Thome, J. R. (2005). Investigation of flow boiling in horizontal tubes: Part I—A new diabatic two-phase flow pattern map. *International Journal of Heat and Mass Transfer*, 2955-2969. doi:10.1016/j.ijheatmasstransfer.2004.12.012

Appendix A: Uncertainty Analysis -

<u>Symbol</u>	<u>Units</u>	Definition
k		Expanded uncertainty coverage factor
п		Number of data points
Ż	kW	Energy transfer
$S_{U\!A,ins,e}$	$W K^{-1}$	Standard deviation of evaporator insulation conductance
S_X		Standard deviation of measured quantity "X"
Т	°C	Temperature
T_1	°C	Temperature at cold end of thermopile
T_{cal}	°C	Temperature of RTD used for calibrations
$T_{TC,cal}$	°C	Calibrated thermocouple measurement
$T_{TC,CJC}$	°C	Thermocouple measurement with Cold Junction Compensation
ΔT_{lm}	Κ	Log-mean temperature difference
$\Delta T_{TC,cal}$	Κ	Thermocouple calibration temperature difference
ΔT_{TP}	Κ	Temperature difference of thermopile
UA	W K ⁻¹	Thermal conductance
$U_{\bar{U\!A}, {\it ins}, e}$	W K ⁻¹	Uncertainty of average of evaporator insulation conductance
U_{TC}	°C	Total instrument uncertainty of thermocouple
$U_{TC,cal}$	°C	Thermocouple instrument uncertainty from calibrating device uncertainty
$U_{TC,fit}$	°C	Instrument uncertainty of thermocouple due to fit of calibration regression
U_X		Uncertainty of measured quantity "X"
$U_{ar{X}}$		Uncertainty of average of measured quantity "X"
U_Y		Uncertainty of calculated quantity "Y"
V	V	Voltage
V_1	V	Thermopile voltage of cold end of thermopile (referenced to ice-point)
VCC	kJ m ⁻³	Volumetric Cooling Capacity
VHC	kJ m ⁻³	Volumetric Heating Capacity
V_{TC}	V	Thermocouple voltage
ΔV_{TP}	V	Thermopile voltage
X		Measured quantity
Y		Calculated quantity

A.1 Symbols Used in Uncertainty Analysis -

<u>Subscript</u>	Definition
amb	Ambient air -
С	Condenser -
е	Evaporator -
HTF	Heat Transfer Fluid -
in	Inlet -
ins	Insulation -
out	Outlet -
1 to 11	Refrigerant thermodynamic states as defined by Figure 2-1 -

Abbreviation	Definition
COP	Coefficient of Performance (W capacity per W of input power) -
CJC	Cold Junction Compensation (for thermocouples) -
DAQ	Data Acquisition -
DSC	Differential Scanning Calorimeter (used to measure fluid specific heat) -
EES	Engineering Equation Solver (software used to reduce data) -
HTF	Heat Transfer Fluid -
MBBHP	Mini Breadboard Heat Pump -
RPM	Revolutions per Minute (compressor shaft) -
RTD	Resistance Temperature Detector -

A.2 General Remarks

The uncertainty analyses for key performance metrics are presented in this section. All uncertainties are estimated based on instrument uncertainties computed at a 95 % confidence interval.

A.3 Thermocouples with CJC Compensation

The surface-mounted thermocouples, as well as the thermocouples measuring the air temperature near the evaporator/condenser, are compensated at the DAQ using a thermistor-based Cold Junction Compensation (CJC). A calibration (ΔT_{cal}) is applied to the resulting temperature reading ($T_{TC,CJC}$) to compute the calibrated temperature ($T_{TC,cal}$) according to:

$$T_{TC,cal} = T_{TC,CJC} + \Delta T_{TC,cal} \tag{A.1}$$

where the calibration is fit to a 2nd order polynomial (the order of this curve fit, and others presented in Appendix A, were selected based on t-test of polynomial coefficients):

$$\Delta T_{TC,cal} = T_{cal} - T_{TC,CJC} = a_0 + a_1 T_{TC,CJC} + a_2 T_{TC,CJC}^2$$
(A.2)

The polynomial coefficients (a_0 , a_1 , a_2) are fit using the least square error method, and T_{cal} is the temperature measured by the calibrating instrument (two calibrated RTDs read by a precision digital thermometer, expanded uncertainty of ±0.02 °C). The thermocouples were calibrated over a temperature range of -10 °C to 60 °C, and this calibration was repeated five times over the

course of two weeks; Figure A-1 (a) shows the calibration data and polynomial curve fits for a representative thermocouple. Each calibration shows a significant offset from the others; this is likely a manifestation of the repeatability error of the CJC, which has an overall uncertainty of ± 0.5 °C. Figure A-1 (b) shows the aggregation of the five data sets and the resulting curve fit and 95 % confidence interval (± 0.6 °C). The uncertainty of the calibrated RTDs is more than an order of magnitude smaller than the curve fit confidence interval, and is therefore neglected. The CJC thermocouple instrument uncertainty listed in Table 2-3 is therefore ± 0.6 °C.



Figure A-1: Temperature calibration for CJC compensated thermocouples where (a) data are divided by each of the 5 calibrations and (b) all data are combined.

A.4 Thermocouples with Ice-Water Bath Compensation

A lower level of uncertainty is achieved for the in-stream probe thermocouples, which measure the refrigerant temperatures at key thermodynamic states, by utilizing an ice-water bath reference junction. The ice-water bath consists of a vacuum insulated Dewar filled with crushed ice and water; the reference junction is submerged in the bath inside of a water-filled test tube. Using the ice-water bath removes the large uncertainty associated with the electronic CJC on the DAQ system. The thermocouples were calibrated against the RTDs (same ones used to calibrate thermocouples with CJC), where the resulting data and curve fit are shown for a representative thermocouple in Figure A-2. The data were fit to 5th order polynomials according to:

$$T_{TC,cal} = \sum_{i=0}^{5} a_i V_{TC}^i$$
(A.3)

where V_{TC} is the thermocouple voltage. The resulting instrument uncertainty (±0.08 °C) listed in Table 2-3 is the combination of the curve fit standard error ($U_{TC,fit}$, k = 2) and the calibrating RTD error ($U_{T,cal}$):

$$U_{TC} = \pm \sqrt{U_{TC,fit}^2 + U_{T,cal}^2} = \pm \sqrt{0.079^2 + 0.02^2} = \pm 0.08 \ ^\circ C \tag{A.4}$$



Figure A-2: Ice-water bath referenced thermocouple calibration data

A.5 Thermopiles in Heat Transfer Fluid

The 13-junction thermopiles were calibrated by immersing one end in an ice-water bath (inside a water-filled test tube) and the other end in a temperature controlled bath. The temperature in the controlled bath was measured using the two calibrated RTDs. A thermopile voltage-temperature dataset was generated and fit to a 4th order polynomial. Figure A-3 shows the calibration data and the curve fit, and Table A-1 shows the polynomial coefficients. The calibration data are fit to the equation:

$$T = \sum_{i=0}^{N=4} a_{TP,i} V^{i}$$
 (A.5)

The temperature difference for a thermopile is computed according to:

$$\Delta T_{TP} = T \left(V_1 + \Delta V_{TP} \right) - T_1 \tag{A.6}$$

where ΔV_{TP} is the measured thermopile voltage and T_1 is the temperature measured at the cold end of the thermopile by a CJC-corrected thermocouple. Eq. (A.5) is substituted into Eq. (A.6) to calculate the thermopile temperature difference:

$$\Delta T_{TP} = \sum_{i=0}^{N=4} a_{TP,i} \left(V_1 + \Delta V_{TP} \right) - T_1 \tag{A.7}$$

where V_1 (cold-end voltage) is computed by numerically solving Eq. (A.5) where T is set to (T_1):

$$V_1 = root \left(T_1 - \sum_{i=0}^{N=4} a_{TP,i} V_1^i = 0 \right)$$
(A.8)

The thermopile uncertainties are computed with respect to the curve fit, voltage measurement, and temperature measurement at the cold end of the thermopile (characterized respectively by the coefficient uncertainties in Table A-1, the thermopile voltage uncertainty in Table 2-3, and the CJC corrected thermocouple in Table 2-3). The EES (Klein, 2015) software

is used to numerically compute the partial derivatives and subsequent thermopile uncertainties. Figure A-4(a) shows the contours of uncertainty in the temperature difference measured by the evaporator/condenser HTF thermopiles.

Figure A-4(b) shows the contours of relative contribution to uncertainty in the thermopile measurement. Each of the uncertainty sources is dominant in different regions:

- voltage measurement: dominant at low temperature differences (less than 1 K)
- curve fit error: dominant at high cold end temperatures (greater than 50 °C)
- cold end temperature: dominant at moderate cold end temperatures -5 °C to 20 °C and temperature differences 2.5 K to 20 K

As noted in this discussion, the thermopile uncertainty is a complex function of the curve fit, voltage measurement, and cold end temperature measurement. For the temperature difference range expected for this application, 1 K to 10 K ($1.8 \,^{\circ}$ F to $18 \,^{\circ}$ F), the upper bound of uncertainty is about 0.015 K ($0.027 \,^{\circ}$ F); for simplicity, this is the value listed in Table 2-3. Note that the contribution to the uncertainty by the calibrating instrument (two calibrated RTDs) is negligible here as the error in slope (which is the error that propagates into the thermopile temperature difference) is less than 0.000248 K per K of temperature difference (e.g. 0.00248 K for a 10 K temperature difference).



Figure A-3: Thermopile calibration data

Table A-1:	Condenser & evaporator
thermopile	polynomial coefficients

		Uncertainty
Coeff.	Value	(k=2), 95%
a _{TP,e,0}	3.9243 E-02	±4.1 E-04
a _{TP,e,1}	2.0243 E+03	±1.2 E-01
a _{TP,e,2}	-5.5466 E+03	±2.2 E+01
a _{TP,e,3}	3.9023 E+04	±1.3 E+03
a _{TP,e,4}	-2.6229 E+05	±2.2 E+04
a _{TP,c,0}	3.8494 E-02	±5.3 E-04
<i>a</i> _{TP,c,1}	2.0241 E+03	±1.5 E-01
$a_{TP,c,2}$	-5.5190 E+03	±2.8 E+01
<i>a</i> _{TP,c,3}	3.8551 E+04	±1.6 E+03
a _{TP,c,4}	-2.5440 E+05	±2.9 E+04



Figure A-4: Contours of thermopile (a) uncertainty and (b) relative contribution to uncertainty

A.6 Evaporator Heat Transfer Fluid Specific Heat

The evaporator HTF is a potassium formate and water heat transfer fluid that is freeze protected to -40 °C. The manufacturer's specific heat data were found to have error of at least 10 %, so a sample of the fluid was analyzed in a Differential Scanning Calorimeter (DSC) by the NIST-Boulder Applied Chemicals and Materials Division. The temperature dependent specific heat and the 2nd order curve fit to the data are shown in Figure A-5; the curve fit coefficients and their uncertainties are listed in Table A-2. Figure A-5 also shows the manufacturer's reported specific heat data for comparison. The exact uncertainty of the DSC measurement was not available at the time of writing, but was estimated to be about 2 % to 3 % of reading based on the experience of the DSC operator (Fortin, 2015). An uncertainty of 3 % of reading is therefore assigned as a conservative estimate. Both the curve fit and DSC calibration uncertainties are included in the calculation of overall uncertainties.



Table A-2:	Evaporator HTF specific
	heat polynomial coefficients

		Uncertainty
Coeff.	Value	(k=2), 95%
<i>a</i> _{<i>Cp</i>,<i>e</i>,0}	2.5643 E+00	±1.6 E-03
$a_{Cp,e,l}$	1.1015 E-03	±2.1 E-04
$a_{Cp,e,2}$	1.7422 E-05	±9.5 E-06

Figure A-5: Specific heat measurements for evaporator HTF

A.7 Condenser Heat Transfer Fluid Specific Heat

The condenser HTF is water; the specific heat data are computed in EES using the data from (Harr et al., 1984) and are shown in Figure A-6. A conservative estimate of ± 3 % is used for the uncertainty in the specific heat.



Figure A-6: Specific heat of condenser HTF (water)

A.8 Evaporator and Condenser Insulation Conductance

The total evaporator and condenser insulation conductances ($UA_{ins,e}$ and $UA_{ins,c}$) for thermal interaction with the ambient air were measured during an initial test where the HTFs were circulated at various flow rates through the apparatus at an elevated temperature, while the refrigerant tubes were under vacuum. The temperature change of the HTF across the heat

exchanger was assumed to be entirely attributed to insulation heat leak, and therefore an effective insulation conductance could be computed. The resulting $UA_{ins,e}$ and $UA_{ins,c}$ values for all 20 tubes are shown in Figure A-7. Average values of conductances for the evaporator and condenser were calculated as 5.48 WK⁻¹ ±0.31 WK⁻¹ and 6.52 WK⁻¹ ±0.41 WK⁻¹ (10.4 Btu h⁻¹ °F⁻¹ ±0.59 Btu h⁻¹ °F⁻¹ and 12.4 Btu h⁻¹ °F⁻¹ ±0.78 Btu h⁻¹ °F⁻¹), respectively, where the uncertainty accounts for both instrumentation error and test variance. The evaporator insulation conductance for these tests is computed according to:

$$UA_{ins,e} = \frac{\dot{Q}_{ins,e}}{\Delta T_{lm,HTF,e}} = \frac{\dot{m}_{HTF,e} C_{p,HTF,e} \left(T_{HTF,in,e} - T_{HTF,out,e}\right)}{\left(T_{HTF,in,e} - T_{amb,e}\right) - \left(T_{HTF,out,e} - T_{amb,e}\right)}$$
(A.9)
$$\ln\left(\frac{\left(T_{HTF,in,e} - T_{amb,e}\right)}{\left(T_{HTF,out,e} - T_{amb,e}\right)}\right)$$

where the variables represent:

= evaporator HTF specific heat
= evaporator HTF mass flow
= evaporator insulation heat leak
= ambient air temperature surrounding evaporator
= evaporator HTF inlet temperature
= evaporator HTF outlet temperature
= evaporator log-mean temperature difference

and the uncertainty of the average value is calculated according to:

$$U_{\overline{UA},ins,e} = k S_{UA,ins,e} / \sqrt{n}$$
 (A.10)

where the variables represent:

k = expanded uncertainty coverage factor (k = 2) for 95 % confidence interval $S_{UA,ins,e}$ = standard deviation of conductances n = number of conductance data points

The condenser conductance is computed using the same method with the corresponding measurements from that heat exchanger.



Figure A-7: Insulation conductance for evaporator and condenser

A.9 Uncertainty Analysis Software

The uncertainty analyses on each of the performance metrics shown in Figure 4-1 through Figure 4-4 were calculated using the uncertainty propagation capability in EES. The software numerically computes the performance metric uncertainty by evaluating the partial derivatives with respect to each relevant measurement and applying the specified measurement uncertainty. Assuming the measurements are independent and uncorrelated, the uncertainty of a quantity is computed according to (Taylor & Kuyatt, 1994):

$$U_{Y} = \sqrt{\sum_{i} \left(\frac{\partial Y}{\partial X_{i}} U_{X_{i}}^{2}\right)^{2}}$$
(A.11)

where the variables represent:

Y = calculated quantity

 U_y = uncertainty of calculated quantity

 X_i = measurement

 U_{Xi} = uncertainty of measurement

A.10 Moving Window and Steady State Uncertainty

A moving window average was used to compute the measurements at steady state during the tests. In order to determine a proper window size, the variation of measurement steady state uncertainty with window size was examined. The steady state uncertainty is defined as the expanded standard uncertainty for the average reading within the window:

$$U_{\bar{X}} = k \frac{S_X}{\sqrt{n}} \tag{A.12}$$

where:

k = coverage factor (k = 2) for 95 % confidence interval

n = number of samples in the window

 S_x = standard deviation of measurement

 \overline{X} = average value of measurement

The data for analysis were generated by holding the MBBHP at a nominal steady operating condition and recording the measurements at 1-minute intervals (same as collection rate for all performance testing) for an extended time (3 hours). Figure A-8 shows the fluctuation of steady state uncertainty for the evaporator inlet and outlet temperatures (T_9 and T_{11}). The figure highlights two characteristic trends observed for all of the instruments, both of which suggest the need for a large moving window: (1) the steady state uncertainty decreases as the window size increases, and (2) the steady state uncertainty is highly oscillatory for small windows (the oscillations are undesirable because short-term fluctuations can have a disproportionate impact on the averaged result). A 30 sample moving window was selected to achieve low uncertainty while allowing for collection of data in a timely manner.

Figure A-8 shows that the measurement steady state uncertainty is not constant in time (it would be constant if the fluctuations at steady state were purely random), but rather exhibits drifting and periodic movements. This is possibly due to hunting by the PID controllers regulating HTF fluid temperatures, changes in air temperature in the lab space, or some other uncontrolled and/or uncharacterized phenomena. These non-random fluctuations are accounted for by using the maximum steady state uncertainty value observed during the extended steady state test. For example, Figure A-8(a) shows the maximum steady state uncertainty for the evaporator outlet (T_9) is ± 0.06 °C; this value and values for all other sensors are listed in Table 2-3. The data in the moving window are only recorded when steady state uncertainties are below these established thresholds. The total uncertainty (± 0.09 °C), also shown in Table 2-3, is subsequently computed by adding the instrument uncertainty (± 0.08 °C) and steady state uncertainty (± 0.06 °C) in quadrature.

Note that different sensors of the same type exhibit different levels of fluctuation; as a conservative estimate, the largest uncertainty of any one is applied to all of them. For example, Figure A-8(b) shows the fluctuations of steady state uncertainty for the evaporator inlet temperature (T_9) are much smaller than for the evaporator outlet (T_{11}). In fact, the evaporator outlet temperature (T_{11}) shows the most fluctuation of all the ice-water bath compensated thermocouple probes; therefore, its value (± 0.06 °C) is used in Table 2-3 to represent them all.



Figure A-8: - Uncertainty in temperature due to fluctuations at steady state for (a) evaporator outlet and (b) evaporator inlet

A.11 Uncertainty Results Summary

The detailed instrument uncertainty analysis for performance metrics including the refrigerant/HTF-side capacities and the COPs are tabulated in Appendices A.11.1 (cooling) and A.11.2 (heating). The tables show the performance metric and its total uncertainty (including both instrument and steady state contributions), as well as the measurements that contribute to the uncertainty. The measurement values, uncertainties, partial derivatives (of performance metric with respect to the measurement), and relative errors (contribution to the overall error in the performance metric) are also shown, where the measurements are listed in order of decreasing relative error. Uncertainties for other performance metrics (e.g. VCC/VHC, η_{isen}) were analyzed using similar techniques, but are not shown in detail in this report. Note that Appendices A.11.1 and A.11.2 show sample calculations for a single nominal operating condition, whereas the uncertainty values presented in the Section 4 figures are computed for each test run.

The uncertainty in cooling performance metrics are shown for a nominal operating point for R134a during a Cooling A test with a compressor speed of about 30 Hz (1800 RPM). Similarly, the uncertainty in heating performance metrics are shown for R134a during a Heating H1 test with a compressor speed of about 30 Hz (1800 RPM).

A.11.1 Uncertainty Results Summary: Cooling

Table A-3 shows that the dominant sources of instrument uncertainty for the refrigerant-side capacity are refrigerant mass flow (66 %), expansion valve inlet temperature (17 %), evaporator exit pressure (8 %), and evaporator exit temperature (7 %). Table A-4 shows the dominant source of instrument uncertainty for the HTF-side capacity is the HTF specific heat (97 %, estimate for instrument used to measure fluid properties). Table A-5 shows the dominant sources of instrument uncertainty for cooling COP are evaporator inlet pressure (39 %), compressor discharge temperature (25 %), and compressor suction temperature (18 %).

Parameter	Symbol	Value	Total Uncertainty	Partial Derivative	Relative Error
Refrigerant-side evaporator capacity	$\dot{Q}_{ ext{e}, ref}$	1.692 kW	±0.0035 kW (0.20%)		
Refrigerant mass flow	\dot{m}_{ref}	11.00 g s ⁻¹	$\pm 0.024 \text{ g s}^{-1}$	1.538 E-01	66 %
Refrigerant temp. at expansion valve inlet	T_8	38.16 C	±0.09 °C	-1.634 E-02	17 %
Refrigerant press. at evaporator inlet	P_9	412 kPa	±3.5 kPa	-2.817 E-04	8 %
Refrigerant temp. at evaporator exit	T_{11}	12.09 C	±0.09 °C	1.009 E-02	7 %
Refrigerant press. at condenser exit	P_7	1104 kPa	±3.5 kPa	2.103 E-06	0 %
Refrigerant evaporator differential press.	$\Delta P_{\rm e}$	43.92 kPa	± 0.8 kPa	2.817 E-04	0 %

Table A-3: Uncertainty of refrigerant-side evaporator cooling capacity

Table A-4: Uncertainty of HTF-side evaporator cooling capacity

Parameter	Symbol	Value	Total Uncertainty	Partial Derivative	Relative Error
HTF-side evaporator capacity	$\dot{Q}_{\mathrm{e},HTF}$	1.672 kW	±0.05 kW (3.0%)		
Evaporator HTF capacity calibration uncertainty	$cp_{_{HTF,e}}$	2.59 J g ⁻¹ K ⁻¹	± 3 % of $cp_{HTF,e}$	6.369 E-01	97 %
Temperature of ambient air surrounding evaporator	T _{amb,e}	23.0 °C	±0.6 °C	5.474 E-03	1 %
HTF mass flow	$\dot{m}_{HTF,e}$	131.2 g s ⁻¹	$\pm 0.26 \text{ g s}^{-1}$	1.257 E-02	1 %
Evaporator HTF thermopile voltage	$\Delta V_{TP,e}$	2.512 mV	±0.007 mV	6.537 E-01	1 %
Evaporator HTF thermopile polynomial coefficients	<i>a</i> _{TP,e,0}	3.9243 E-02	±4.1 E-04	4.047 E-03	0 %
	<i>a</i> _{TP,e,1}	2.0243 E+03	±1.2 E-01	8.832 E-04	0 %
	$a_{TP,e,2}$	-5.5466 E+03	±2.2 E+01	1.559 E-05	0 %
	<i>a</i> _{TP,e,3}	3.9023 E+04	±1.3 E+03	2.106 E-07	0 %
	a _{TP,e,4}	-2.6229 E+05	±2.2 E+04	2.554 E-09	0 %
Evaporator HTF capacity	a _{Cp,e,0}	2.5643 E+00	±1.6 E-03	6.369 E-01	0 %
polynomial coefficients	a _{Cp,e,1}	1.1015 E-03	±2.1 E-04	1.135 E+01	0 %
	$a_{Cp,e,2}$	1.7422 E-05	±9.5 E-06	2.024 E+02	0 %
Temperature at cold end of evaporator HTF thermopile	$T_{HTF,e,out}$	15.42 °C	±0.6 °C	-2.963 E-03	0 %
Evaporator insulation conductance	$UA_{ins,e}$	5.474 W K ⁻¹	$\pm 0.3052 \text{ W K}^{-1}$	4.175 E-03	0 %

Parameter	Symbol	Value	Total Uncertainty	Partial Derivative	Relative Error
Cooling COP	$\operatorname{COP}_{\operatorname{cool}}$	2.844	±0.01 (0.35 %)		
Refrigerant press. at evaporator inlet	P_9	412 kPa	±3.5 kPa	-1.232 E-02	39 %
Refrigerant temp. at compressor discharge	T_3	81.97 °C	±0.09 °C	5.571 E-02	25 %
Refrigerant temp. at compressor suction	T_1	12.73 °C	±0.09 °C	4.788 E-02	18 %
Refrigerant press. at condenser exit	P_7	1104 kPa	±3.5 kPa	5.144 E-03	7 %
Refrigerant temp. at expansion valve inlet	T_8	38.16 °C	±0.09 °C	-2.746 E-02	6 %
Refrigerant temp. at evaporator exit	T_{11}	12.09 °C	±0.09 °C	1.696 E-02	2 %
Refrigerant evaporator diff. press.	$\Delta P_{ m e}$	43.92 kPa	±0.8 kPa	7.432 E-04	2 %
Refrigerant condenser diff. press.	$\Delta P_{ m c}$	32.34 kPa	±1.3 kPa	4.731 E-04	1 %
Refrigerant suction line diff. press.	$\Delta P_{\rm s}$	14.22 kPa	±0.3 kPa	1.314 E-03	0 %
Refrigerant mass flow	\dot{m}_{ref}	11.00 g s ⁻¹	$\pm 0.016 \text{ g s}^{-1}$	2.209 E-04	0 %

Table A-5: Uncertainty of cooling COP

A.11.2 Uncertainty Results Summary: Heating

Table A-6 shows the dominant sources of instrument uncertainty for the refrigerant-side capacity are refrigerant mass flow (85 %), condenser exit temperature (9 %), and condenser inlet temperature (5 %). Table A-7 shows the dominant source of instrument uncertainty for the HTF-side capacity is the HTF specific heat (97 %, estimate for instrument used to measure specific heat of water in the reference). Table A-8 shows the dominant sources of instrument uncertainty for cooling COP are evaporator inlet pressure (32 %), compressor discharge temperature (31 %), and compressor suction temperature (22 %).

Parameter	Symbol	Value	Total Uncertainty	Partial Derivative	Relative Error
Refrigerant-side condenser capacity	$\dot{Q}_{c,ref}$	1.873 kW	±0.004 kW (0.2%)		
Refrigerant mass flow	\dot{m}_{ref}	9.06 g s ⁻¹	$\pm 0.016 \text{ g s}^{-1}$	2.067 E-01	85 %
Refrigerant temp. at condenser exit	T_7	37.39 °C	±0.09 °C	-1.343 E-02	9 %
Refrigerant temp. at condenser inlet	T_4	77.22 °C	±0.09 °C	9.443 E-03	5 %
Refrigerant press. at condenser exit	P_7	992.8 kPa	±3.5 kPa	-1.296 E-04	1 %
Refrigerant condenser differential press.	$\Delta P_{ m c}$	27.2 kPa	±1.3 kPa	-9.028 E-04	0 %

Table A-6: Uncertainty of refrigerant-side condenser heating capacity -

Table A-7: Uncertainty of HTF-side condenser heating capacity

Parameter	Symbol	Value	Total Uncertainty	IotalPartialertaintyDerivative	
HTF-side condenser capacity	$\dot{Q}_{ ext{c}, HTF}$	1.852 kW	±0.054 kW (2.9%)		
Condenser HTF capacity calibration uncertainty	$cp_{HTF,c}$	4.183 Jg ⁻¹ K ⁻¹	± 3 % of $cp_{HTF,c}$	4.262 E-01	97 %
Condenser insulation conductance	$UA_{ins,c}$	6.521 W K ⁻¹	$\pm 0.4071 \text{ W K}^{-1}$	1.056 E-02	1 %
HTF mass flow	$\dot{m}_{_{HTF,c}}$	98.81 g s ⁻¹	$\pm 0.23 \text{ g s}^{-1}$	1.804 E-02	1 %
Condenser HTF thermopile voltage	$\Delta V_{TP,c}$	2.318 mV	±0.007 mV	7.652 E-01	1 %
Condenser HTF thermopile	$a_{TP,c,0}$	3.8494 E-02	±5.3 E-04	4.057 E-03	0 %
polynomial coefficients	$a_{TP,c,l}$	2.0241 E+03	±1.5 E-01	1.025 E-03	0 %
	$a_{TP,c,2}$	-5.5190 E+03	±2.8 E+01	3.481 E-05	0 %
	$a_{TP,c,3}$	3.8551 E+04	±1.6 E+03	9.078 E-07	0 %
	$a_{TP,c,4}$	-2.5440 E+05	±2.9 E+04	2.309 E-08	0 %
Temperature of ambient air surrounding condenser	T _{amb,c}	24.3 °C	±0.6 °C	-6.521 E-03	0 %
Temperature at cold end of condenser HTF thermopile	$T_{HTF,c,in}$	31.96 °C	±0.6 °C	-4.093 E-03	0 %

Parameter	Symbol	Value	Total Uncertainty	Partial Derivative	Relative Error
Heating COP	COP _{heat}	3.431	±0.01 (0.28 %)		
Refrigerant press. at evaporator inlet	P_9	314.8 kPa	±3.5 kPa	-1.520 E-03	32 %
Refrigerant temp. at compressor discharge	T_3	80.73 °C	±0.09 °C	-5.933 E-02	31 %
Refrigerant temp. at compressor suction	T_1	3.54 °C	±0.09 °C	5.000 E-02	22 %
Refrigerant temp. at condenser inlet	T_7	37.39 °C	±0.09 °C	-2.461 E-02	6 %
Refrigerant press. at condenser exit	P_7	992.8 kPa	±3.5 kPa	5.532 E-04	5 %
Refrigerant temp. at condenser inlet	T_4	77.22 °C	±0.09 °C	1.731 E-02	3 %
Refrigerant condenser differential press.	$\Delta P_{\rm c}$	27.2 kPa	±1.3 kPa	5.509 E-04	1 %
Refrigerant suction line diff. press.	$\Delta P_{ m s}$	12.69 kPa	±0.3 kPa	1.520 E-03	0 %
Refrigerant evaporator diff. press.	$\Delta P_{\rm e}$	39.99 kPa	±0.8 kPa	1.520 E-03	0 %
Refrigerant mass flow	$\dot{m}_{_{ref}}$	9.06 g s ⁻¹	$\pm 0.016 \text{ g s}^{-1}$	2.187 E-04	0 %

Table A-8: Uncertainty of heating COP

Appendix B: Instrumentation with DAQ Number Convention -

The instrument numbering scheme shown in Figure 2-1 and Figure 2-5 is based on the thermodynamic states 1 to 11. However, the raw data files recorded by the DAQ system use a different numbering scheme shown in Figure B-1 and Figure B-2.



Figure B-1: - Schematic of (a) condenser and (b) evaporator, showing the instrument numbering convention used in the DAQ system.



Figure B-2: Schematic of MBBHP test apparatus including instrument numbering convention used in the DAQ system

Appendix C: Microfin Tube Surface Area -

The microfinned surface area (per tube length) is estimated according to:

$$\frac{A_i}{L} = N_f \left(\frac{s_f}{\cos \alpha} + \frac{2e}{\cos \alpha \cos(\beta/2)} \right)$$
(C.1)

where the variables represent:

e = fin height $N_f = \text{number of fins}$ $s_f = \text{fin spacing}$ $\alpha = \text{fin helix angle}$ $\beta = \text{fin angle}$

and A_i/L is computed as 0.0424 m (1.67 in). The fin parameters are shown in Figure 2-5 and Table 2-2.