

NIST Technical Note 2091

Tool for Evaluation of Vaporized Hydrogen Peroxide Disinfection of N95 Masks in Small Rooms

Dustin Poppendieck
*Indoor Air Quality and Ventilation Group
Energy and Environment Division
Engineering Laboratory*

This publication is available free of charge from:
<https://doi.org/10.6028/NIST.TN.2091>

April 2020



U.S. Department of Commerce
Wilbur L. Ross, Jr., Secretary

National Institute of Standards and Technology
Walter Copan, NIST Director and Undersecretary of Commerce for Standards and Technology

Certain commercial entities, equipment, or materials may be identified in this document in order to describe an experimental procedure or concept adequately. Such identification is not intended to imply recommendation or endorsement by the National Institute of Standards and Technology, nor is it intended to imply that the entities, materials, or equipment are necessarily the best available for the purpose.

National Institute of Standards and Technology Technical Note 2091
Natl. Inst. Stand. Technol. Tech. Note 2091, 15 pages (April 2020)
CODEN: NTNOEF

This publication is available free of charge from:
<https://doi.org/10.6028/NIST.TN.2091>

- Kenney, P., B. K. Chan, K. Kortright, M. Cintron, N. Havill, M. Russi, J. Epright, L. Lee, T. Balczak and R. Martinello (2020). "Hydrogen Peroxide Vapor sterilization of N95 respirators for reuse." [medRxiv: 2020.2003.2024.20041087](https://doi.org/10.20944/medRxiv2020.03.2024.20041087).
- Medicine, D. U. S. o. (2020). "Duke Starts Novel Decontamination of N95 Masks to Help Relieve Shortages." from <https://medschool.duke.edu/about-us/news-and-communications/med-school-blog/duke-starts-novel-decontamination-n95-masks-help-relieve-shortages>.
- Nierenberg, A. (2020). Where Are All the Masks? In the United States, there is a shortage of medical equipment. What's going on? *New York Times*. <https://www.nytimes.com/article/face-masks-coronavirus.html>
- NIOSH. (2020). "Hydrogen peroxide." from <https://www.cdc.gov/niosh/idlh/772841.html>.
- Ostriker, R. (2020). Boston hospitals getting 'game changer' machine that sterilizes 80,000 protective masks a day. *Boston Globe*. https://www.bostonglobe.com/2020/04/02/metro/boston-hospitals-getting-game-changer-machine-that-sterilizes-80000-protective-masks-day/?s_campaign=breakingnews:newsletter
- Otter, J., M. Puchowicz, D. Ryan, J. Salkeld, T. Cooper, N. Havill, K. Tuozzo and J. Boyce (2009). "Feasibility of Routinely Using Hydrogen Peroxide Vapor to Decontaminate Rooms in a Busy United States Hospital." *Infection control and hospital epidemiology* **30**: 574-577.
- Persily, A., H. Davis, S. J. Emmerich and W. S. Dols (2009). NISTIR 7546 Airtightness Evaluation of Shelter-in-Place Spaces for Protection Against Airborne Chembio Releases. U. S. D. o. Commerce. https://tsapps.nist.gov/publication/get_pdf.cfm?pub_id=901117
- Rutala, W. and D. Weber (2015). 301 - Disinfection, Sterilization, and Control of Hospital Waste. *Mandell, Douglas, and Bennett's Principles and Practice of Infectious Diseases (Eighth Edition)*. J. E. Bennett, R. Dolin and M. J. Blaser. **2**: 3294-3309.e3294.
- Rutala, W. A., D. J. Weber, Healthcare and I. C. P. A. Committee. (2008). "Guideline for Disinfection and Sterilization in Healthcare Facilities, 2008; Update May 2019." from <https://www.cdc.gov/infectioncontrol/pdf/guidelines/disinfection-guidelines-H.pdf>.